

NATIONAL ENERGY TECHNOLOGY LABORATORY



2011 Pittsburgh Coal Conference

Circulating Fluidized Bed Combustion as a Near-Term CO₂ Mitigation Strategy

Eric Grol, Office of Strategic Energy Analysis & Planning

September 14, 2011




Overview

- **Inexpensive coal power has helped fuel America's industrial growth since 1950, and needs to play a key role in the current recovery**
- **Circulating Fluidized Beds (CFB) are a coal technology that can compete in the current regulatory climate**
 - Single best performing source for Hg is CFB
- **The fuel-flexibility of a CFB allows for co-feeding biomass, which can help reduce CO₂ emissions in the near-term**
- **Building CO₂ capture-ready CFB's can help ease integration of full scale CCUS in the long-term**

Energy Consumption and U.S. GDP

U.S. Economic Prosperity Strongly Linked to Coal Generation




American Prosperity: Past, Present and Future

Coal power was the backbone of growth since 1950 and needs to play a critical role in current recovery

- ***“If we want a robust, growing economy, we need a robust, growing manufacturing sector.”*** – President Obama at a speech in Pittsburgh, June 24, 2011
- **Coal plants of America’s future need to:**
 1. Meet stringent air quality rules in the near term
 2. Be built with future installation of CCUS¹ in mind (capture ready) to deal with gradual tightening of CO₂ emissions


Pulverized Coal Power Plant

Air Quality Regulations: Compliance



Pulverized Coal Power Plant

Air Quality Regulations: Key Issues



Greenhouse Gas New Source Performance Standard

What will the GHG NSPS look like?

- **Initially, efficiency improvements/best practices likely to suffice**
 - “PSD and Title V Permitting Guidance for Greenhouse Gases,” EPA, March 2011 identifies efficiency improvements as an acceptable CO₂ mitigation strategy
 - Examples: Increased air heater, condenser surface area; improvements in turbine performance
- **Eventually, CCUS expected to become Best Available Control Technology**
- **Focus of CCUS RD&D includes facilitation of “widespread cost-effective deployment after 2020*”**
- **Solution: CO₂ capture-ready circulating fluidized beds, that can co-feed biomass**

Case Study: Recently Permitted Coal Units

Consider the emission control systems on recently permitted units...

	Nameplate Capacity (MW)	Technology	SO ₂ Control	NOx	Particulate
Prairie State Supercritical	2 x 800	Pulverized Coal	Wet FGD	SCR/Low NOx Burner	ESP, Wet ESP
Trimble County Supercritical	834	Pulverized Coal	Wet FGD	SCR/Low NOx Burner	Baghouse, Wet ESP
Longview Supercritical	808	Circulating Fluidized Bed	Wet FGD	SCR	Baghouse, Wet ESP

Case Study: Recently Permitted Coal Units


Based strictly on their air quality permits, would recent new units meet proposed air quality standards?

	EPA Limit	Prairie State Permit	<u>Prairie State in Compliance?</u>	Trimble County Permit	<u>Trimble County in Compliance?</u>	Longview Permit	<u>Longview in Compliance?</u>
NO _x	1.2 lb/MWh (NO _x +CO)	0.07 lb/MMBtu	Close (permitted level ~1.46 lb (NO _x +CO)/MWh)	0.7 lb/MMBtu	No (permitted level ~6.12 lb (NO _x +CO)/MWh)	0.065 Lb/MMBtu	Close (permitted level ~1.35 lb (NO _x +CO)/MWh)
PM	0.05 lb/MWh	0.035 lb/MMBtu	No (permitted level ~0.27 lb PM/MWh)	0.018 lb/MMBtu	No (permitted level ~0.14 lb PM/MWh)	0.018 Lb/MMBtu	No (permitted level ~0.14 lb PM/MWh)
SO ₂	1 lb/MWh or 97% removal	0.182 lb/MMBtu	No (permitted level ~1.4 lb SO ₂ /MWh)	0.84 lb/MMBtu	No (permitted level ~6.6 lb SO ₂ /MWh)	0.095 Lb/MMBtu	Yes (permitted level ~0.73 lb SO ₂ /MWh)
HCl	0.30 lb/GWh	0.0032 lb/MMBtu	No (permitted level ~24.7 lb HCl/GWh)	9 tons/year	No (permitted level ~3.8 lb HCl/GWh)	10 ⁻⁵ Lb/MMBtu	Yes (permitted level ~0.08 lb HCl/MWh)
Hg	0.0002 lb/GWh	95% removal	N/A	0.000013 lb/MWh	No (permitted level ~0.14 lb Hg/GWh)	N/A	N/A
CO	1.2 lb/MWh (NO _x +CO)	0.12 lb/MMBtu	Close (permitted level ~1.46 lb (NO _x +CO)/MWh)	0.078 lb/MMBtu	No (permitted level ~6.12 lb (NO _x +CO)/MWh)	0.11 Lb/MMBtu	Close (permitted level ~1.35 lb (NO _x +CO)/MWh)

Proposed Mercury Limits for New Units

New non-lignite units will require 99%+ Hg removal to be in compliance

- Coal with higher Hg content could become unmarketable
- CFB's could continue to make use of abundant coal supplies with higher Hg content




Why Biomass?

- **Biomass (*including wood waste, switchgrass, hybrid poplar*) is considered a carbon-neutral fuel**
 - For every pound of CO₂ resulting from biomass combustion, one pound of CO₂ scrubbed from atmosphere during plant growth
- **As of July 2011, CO₂ emissions resulting from combustion of biomass exempt (for 3 years) from EPA Title V permitting requirements**
 - Suit filed against EPA challenging this
- **Reason to believe that biomass co-firing will be an acceptable CO₂ mitigation strategy for GHG NSPS**
 - 2011 TVA Clean Air Act Settlement: New Source Review violations resulting in civil penalty, CAA compliance, obligation to address 92% of coal-fired fleet with SCR, FGD, retirement, or biomass repowering

Why Biomass?

- Assume:
 - 25% biomass / 75% coal fed (by weight)
 - Biomass 4,200 Btu/lb; Coal 11,700 Btu/lb
 - 0.26 Lb C/Lb biomass; 0.64 Lb C/Lb biomass
 - 40% efficient process
 - Biomass C-neutral, therefore is NOT included in emissions of CO₂



Why Biomass?

- Biomass (*wood waste, switchgrass, hybrid poplar*) is considered a carbon-neutral fuel
 - For every pound of CO₂ resulting from biomass combustion, one pound of CO₂ scrubbed from atmosphere during plant growth
- **As of July 2011, CO₂ emissions resulting from combustion of biomass exempt (for 3 years) from EPA Title V permitting requirements**
 - Suit filed against EPA challenging this
- **Reason to believe that biomass co-firing will be an acceptable CO₂ mitigation strategy for GHG NSPS**
 - 2011 TVA Clean Air Act Settlement: New Source Review violations resulting in civil penalty, CAA compliance, obligation to address 92% of coal-fired fleet with SCR, FGD, retirement, or biomass repowering


Why Biomass in a CFB?

- **CFB can burn low quality, opportunity fuels such as biomass**
 - Combustion of high fouling and slagging fuels due to low bed temperature
 - Rapid heating of fuel due to bed mass, long residence time allows for combustion of low Btu fuels
 - High degree of fuel flexibility with CFB
- **Ability to co-fire biomass (reducing CO₂ in the short-term), along with low NO_x, SO₂, and Hg emissions, make CFB an ideal technology for near-term builds**


Future Considerations for Carbon Mitigation

- **CO₂ emission limits will become increasingly more stringent**
 - NSPS reviewed every 5 years, every new project results in more stringent obligations for next project
- **Build CFB's with future installation of CCUS in mind**
 - Access to CO₂ storage and utilization opportunities (transportation pipeline, EOR site and saline storage)
- **Existing units built with CO₂ capture in mind can more easily integrate it in the future**
 - Available real estate for capture equipment
 - Turbine considerations (steam extraction ports at correct pressure)


Fossil Power CO₂ Emission Rates




Fossil Power CO₂ Emission Rates



Fossil Power CO₂ Emission Rates



Fossil Power CO₂ Emission Rates



Parting Shots...

- **Current regulatory climate requires ultra-low emissions, which CFB's are in a unique position to accommodate**
- **As CO₂ emission limits become more stringent, fuel-flexibility of CFB can help achieve near-to-mid term reductions by co-firing biomass**
- **Building CFB's with future installation of CCUS in mind (CO₂ capture-ready) can help ease process integration when full-scale capture is required**
- **By co-firing biomass and capturing CO₂ emissions, GHG footprint for CFB can be even lower than new NGCC with capture**