



EERC

EERC Technology... Putting Research into Practice



Long-Term Demonstration of Sorbent Enhancement Additive Technology for Mercury Control

Presented at the 2007 Mercury Control Technology Conference

Pittsburgh, Pennsylvania

**Jason Laumb, Dennis Laudal, Grant Dunham,
Chris Martin, and Kevin Galbreath**

December 11–13, 2007

Disclaimer

This presentation was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government, nor any agency thereof, nor any of their employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Presentation Outline

- Technology introduction
- Hawthorn Unit 5 (HAW5) (Kansas City Power & Light, KCP&L)
- Mill Creek Unit 4 (MC4) (Louisville Gas & Electric, LG&E)
- Conclusions
- Acknowledgments

Sorbent Enhancement Additive (SEA) Technology

- SEA1 (B&W/Niro, U.S. Patent 5,435,980)
 - Chloride added to coal feed.
 - Hg capture can be enhanced with carbon.
- SEA2 T2
 - Added upstream of the particulate control device (PCD).
 - Carbon treated in situ.
 - Tailored to desired Hg removal.

Sites

Plant	Utility Owner	Coal	Boiler Type	Boiler Size, MW	Partic. Control	SO ₂ Control	NO _x Control
HAW5	KCP&L	PRB ¹	Wall-fired	550	FF ²	SDA ³	LNB ⁴ , OFA ⁵ , SCR ⁶
MC4	LG&E	Eastern bituminous	Wall-fired	530	ESP ⁷ / SCA ⁸ = 232	Wet FGD ⁹	LNB, SCR

¹ Powder River Basin; ² fabric filter; ³ spray dryer absorber; ⁴ low-NO_x burner; ⁵ overfire air; ⁶ selective catalytic reduction; ⁷ electrostatic precipitator; ⁸ specific collection area; and ⁹ flue gas desulfurization.

Sampling Locations (both sites)

- Continuous mercury monitors (CMMs) – particulate collection device (PCD) inlet and stack for parametric tests. Stack only for long-term.
- Ontario Hydro (OH) – PCD inlet and stack for parametric tests and long-term.
- Solid samples – daily coal, ash, slurry samples during parametric. Three a week during long-term.
- U.S. Environmental Protection Agency (EPA) Method 5 – PCD inlet and stack?

Hawthorn Unit 5

Baseline Results

- Baseline Hg measurements indicate a native Hg capture average of 17.8 %* .
- Coal and OH inlet measurements are consistent
- CMM inlet and outlet measurements tend to be low for the baseline period when compared to OH and coal results, but agree well during Hg control technology testing.

Date	Test Description	Coal (Inlet) μg/Nm ³	CMM Inlet μg/Nm ³	OH Inlet μg/Nm ³	CMM Outlet μg/Nm ³	OH Outlet μg/Nm ³	Coal-to-Stack Hg Removal, %	
							OH	CMM
9/18/2006	Baseline	13.67	7.23	14.28	8.7	11.37	16.9	36.4
9/18/2006	Baseline	13.67	7.52	13.61	8.64	10.86	20.5	36.8
9/19/2006	Baseline	12.82	6.24	11.27	8.28	10.54	17.8	35.4
9/19/2006	Baseline	12.82	6.93	12.67	8.64	10.78	15.9	32.6


*Coal inlet to OH outlet basis.

SEA1 Results

- Testing of SEA1 occurred during the period of 9/20/06–9/22/06.
- Results indicate a positive effect on Hg capture when compared to baseline removals.
- Hg removal efficiencies appear to only slightly increase with increasing SEA1 rate.

Date	Test Description	Coal (Inlet) μg/Nm ³	CMM Inlet μg/Nm ³	OH Inlet μg/Nm ³	CMM Outlet μg/Nm ³	OH Outlet μg/Nm ³	Coal-to-Stack Hg Removal, %	
							OH	CMM
9/18/2006	Baseline	13.67	7.23	14.28	8.7	11.37	16.9	36.4
9/18/2006	Baseline	13.67	7.52	13.61	8.64	10.86	20.5	36.8
9/19/2006	Baseline	12.82	6.24	11.27	8.28	10.54	17.8	35.4
9/19/2006	Baseline	12.82	6.93	12.67	8.64	10.78	15.9	32.6
9/20/2006	SEA1 Only (600 ppm)	12.76	11.54	12.46	3.72	4.67	63.4	70.8
9/21/2006	SEA1 Only (800 ppm)	13.08	12.93	12.15	4.12	4.53	65.4	68.5

SEA 1 Results (cont.)



Mill Creek Unit 4

- MC4 offers challenges with the selective catalytic reduction (SCR) system in service!
 - Possibly because of reactions with SO_3 .
- SEA2 T2 and scrubber additives are the primary technologies tested at MC4.


Previous MC4 Baseline

Sample Location	SCR Inlet, $\mu\text{g}/\text{Nm}^3$	SCR Outlet, $\mu\text{g}/\text{Nm}^3$	Wet FGD Inlet, $\mu\text{g}/\text{Nm}^3$	Stack, $\mu\text{g}/\text{Nm}^3$	Reduction, %
<i>With the SCR in Service</i>					
Hg ^P	0.02	0.03	0.00	0.00	
Hg ⁰	8.32	2.83	0.33	3.97	
Hg ²⁺	0.94	5.05	7.60	0.54	
Hg _{total}	9.27	7.90	7.93	4.50	43.3
<i>With the SCR Bypassed</i>					
Hg ^P			0.07	0.05	
Hg ⁰			2.44	2.63	
Hg ²⁺			6.79	0.55	
Hg _{total}			9.30	3.23	65.3

Current MC4 Baseline


ESP Inlet (dry and 3% O ₂), µg/m ³					Wet FGD Outlet (dry and 3% O ₂), µg/m ³			
Sample	Hg(p)	Hg ²⁺	Hg ⁰	Hg (total)	Hg(p)	Hg ²⁺	Hg ⁰	Hg (total)
1	0.08	19.32	1.50	20.90	0.04	0.68	1.80	2.52
2	0.04	13.27	0.21	13.52	0.05	0.60	1.13	1.78
3	0.04	12.71	0.49	13.24	0.00	0.55	1.28	1.83
4	0.03	12.11	0.24	12.38	0.01	0.42	1.38	1.81

Baseline Removals




Baseline mercury removal was >80%.

PAC Addition




- The addition of PAC at MC4 had no measurable effect on the mercury concentration.
- Possible interference with SO_3 ?

Scrubber Additives



The addition of B&W's scrubber additive into the wet FGD increased the amount of mercury retained in the scrubber solutions.


SEA2 T2



The SEA2 T2 technology did not significantly increase the amount of mercury captured.

ACI and Scrubber Additives

The use of powdered activated carbon (PAC) with the scrubber additives had no beneficial removal.



Sorbent Trap Results


Sample	Parametric Condition	Sorbent Trap Vapor-Phase Hg Dry at 3% O ₂ , µg/m ³	Sorbent Trap Vapor-Phase Hg µg/m ³	Average CMM Vapor-Phase Hg µg/m ³
7A	SEA2 into SCR inlet at 2.5 lb/hr	2.33	1.52	1.56
7B		2.78	1.82	
Average		2.55	1.67	
8A	ACI (1.0 lb/Macf) and SEA2 (5.0 lb/hr) into ESP inlet ^a	2.65	1.68	1.76
8B		3.42	2.17	
Average		3.03	1.92	
9A	ACI (1.0 lb/Macf) and SEA2 (2.5 lb/hr) into ESP inlet ^b	2.55	1.64	1.70
9B		3.36	2.17	
Average		2.95	1.90	
1A	ACI (1.0 lb/Macf) into ESP inlet and B&W additive at 80 gph	0.87	0.56	0.63
1B		1.15	0.74	
Average		1.01	0.65	
2A	B&W additive at 80 gph	0.74	0.48	0.54
2B		0.82	0.53	
Average		0.78	0.50	

^a SEA2 stopped after approximately 30 minutes of sampling.


^b SEA2 stopped after approximately 20 minutes of sampling.

Long-Term Study at MC4


Mercury Removal Using B&W Wet FGD Reemission Additive



Mercury Concentration at the Electrostatic Precipitator Outlet at MC4



Hg Concentration at Wet FGD Outlet Using B&W Reemission Additive



Conclusions

- The amount of reemission observed at MC4 is significantly lower than previously reported.
- The addition of PAC at MC4 had no measurable effect on the mercury concentration.
- The use of the B&W scrubber additive allowed for mercury concentrations below 0.6 mg/m^3 at the scrubber outlet.
- Reasonable agreement between CMM and sorbent trap values.
- $>90\%$ mercury reduction was possible at the HAW5 with SEA1 (500 ppm) and PAC (2 lb/macf).
- Catalyst blinding observed at HAW5 led to lower oxidized Hg levels.

Acknowledgments

- U.S. Department of Energy National Energy Technology Laboratory (NETL)
- Babcock & Wilcox Company
- Kansas City Power & Light
- Louisville Gas & Electric
- Norit Americas Inc.

Contact Information

**Energy & Environmental Research Center
University of North Dakota
15 North 23rd Street
Stop 9018
Grand Forks, North Dakota 58202-9018**

**www.undeerc.org
Telephone No. (701) 777-5000
Fax No. (701) 777-5181**

**Mr. Jason D. Laumb
Research Manager
(701) 777-5114
jlaumb@undeerc.org**

