



EERC

EERC Technology... Putting Research into Practice



Long-Term Demonstration of Sorbent Enhancement Additive Technology for Mercury Control

EUEC

Tucson, Arizona

January 22-24, 2007

Jason Laumb

Brandon Pavlish

Energy & Environmental Research Center

Presentation Outline

- Introduction
- Previous work at Hawthorn
- Current Results at Hawthorn
- Introduce Phase III Project
- Schedule
- Acknowledgements

Sorbent Enhancement Additive (SEA) Technology

- SEA1 (B&W/Niro, U.S. patent 5,435,980)
 - Chloride added to coal feed.
 - Hg capture can be enhanced with carbon.
- SEA2 T2
 - Alternative method of adding SEA2.
 - Reduce effects of alkaline material.
- Questions about the technology can be addressed by B&W.


Hawthorn Unit 5

Plant	Utility Owner	Coal	Boiler Type	Boiler Size, MW	Particulate Control	SO ₂ Control	NO _x Control
HAW5	KCP&L	PRB	Wall-fired	550	FF	SDA	LNB ¹ , OFA ² , SCR


¹ Low-NO_x burners.

² Overfire air.


Previous Hawthorn Test Results



Previous Hg Speciation at SCR Outlet



Previous Hg Speciation at Stack



Conclusions

- 1000 ppm Cl addition (no PAC) at Hawthorn provided an 80%+ Hg capture for 6 hours.
- >90% Hg capture was possible (for short periods of time) using SEA2 and PAC.
- >90% REDUCTION is possible with SEA2 T2.

Phase III Project

Project Overview

- Goals & Objectives
 - To demonstrate 90% REDUCTION in mercury emissions at Hawthorn Unit 5 and Mill Creek Unit 4.

Sites

Plant	Utility Owner	Coal	Boiler Type	Boiler Size, MW	Particulate Control	SO ₂ Control	NO _x Control
HAW5	KCP&L	PRB	Wall-fired	550	FF	SDA	LNB ¹ , OFA ² , SCR
MC4	LG&E	Eastern bituminous	Wall-fired	530	ESP/SCA=232	Wet FGD	LNB, SCR

¹ Low-NO_x burners.

² Overfire air.

Task Structure/Schedule

Task Name	2006			2007				2008			
	Qtr 2	Qtr 3	Qtr 4	Qtr 1	Qtr 2	Qtr 3	Qtr 4	Qtr 1	Qtr 2	Qtr 3	Qtr 4
Task Name											
Task 1. Hawthorn Unit 5 (HAW5)											
1.1 Parametric Tests											
1.2 Longer-Term Tests											
Ontario Hydro Sampling (Three 1-week occurrences during a 2-month period)											
1.3 Management and Reporting											
Site Report - Go/No Go											
Quarterly Reports											
Project Final Report											
Task 2. Mill Creek Station Unit 4 (MC4)											
2.1 Parametric Tests											
Parametric/Baseline SCR On											
Parametric/Baseline SCR Off											
2.2 Longer-Term Tests											
Ontario Hydro Sampling (Three 1-week occurrences during a 2-month period)											
2.3 Management and Reporting											
Site Report - Go/No Go											
Quarterly Reports											
Project Final Report											
Task 3. Project Planning											
Kick-off Meeting											
Test Plan Development											
QA/QC Plan Development											
Data Reduction/Analysis											

Test Plan for Hawthorn

- Based on previous work the test plan for Hawthorn will concentrate on the following technologies:
 - SEA 1 Only
 - SEA 1 + PAC
 - SEA 2 T2

Previous Data-Mill Creek Unit 4

Sample Location	SCR Inlet, $\mu\text{g}/\text{Nm}^3$	SCR Outlet, $\mu\text{g}/\text{Nm}^3$	wet-FGD inlet, $\mu\text{g}/\text{Nm}^3$	Stack, $\mu\text{g}/\text{Nm}^3$	Removal %
<i>With the SCR in Service</i>					
Hg ^P	0.02	0.03	0.00	0.00	
Hg ⁰	8.32	2.83	0.33	3.97	
Hg ²⁺	0.94	5.05	7.60	0.54	
Hg _{total}	9.27	7.90	7.93	4.50	43.3
<i>With the SCR Bypassed</i>					
Hg ^P			0.07	0.05	
Hg ⁰			2.44	2.63	
Hg ²⁺			6.79	0.55	
Hg _{total}			9.30	3.23	65.3

Mill Creek Unit 4 Cont.

- Mill Creek offers challenges with the SCR in service!
 - Possibly due to reactions with sulfur species.
 - Lower halogen levels in scrubber?
- SEA2 T2 will be primary technology tested at Mill Creek.
- B&W Re-emission additive will also be added to scrubber, if necessary.


Mill Creek Test Plan

- Parametric study with SCR in and out of service.
- Two Month demonstration with the SCR in service.
- Plan to be developed upon completion of negotiations with plant.

Sampling Locations (Both Sites)

- Continuous Mercury Monitors – PCD inlet and stack for parametric tests. Stack only for long-term.
- Ontario Hydro – PCD inlet and stack for parametric tests and long term.
- Solid Samples – Daily coal, ash, slurry samples during parametric. Three per week during long term.
- EPA Method 5 – PCD inlet & stack?

Personnel



Hawthorn Coal Results

Parameters, Unit	9/18/2006	9/19/2006	9/20/2006	Average	Standard Deviation
Mercury, ppm (dry)	0.114	0.106	0.105	0.108	0.005
<i>Proximate</i>					
Moisture, wt%	19.1	20.6	20.9	20.20	0.964
Volatile Matter, wt%	34.86	34.22	34.14	34.41	0.395
Fixed Carbon, wt%	40.66	40	39.75	40.14	0.470
Ash, wt%	5.38	5.18	5.21	5.26	0.108
<i>Ultimate Analysis</i>					
Hydrogen, wt%	6.12	6.1	6.1	6.11	0.012
Carbon, wt%	55.17	54.06	53.6	54.28	0.807
Nitrogen, wt%	1.05	0.97	0.96	0.99	0.049
Sulfur, wt%	0.45	0.38	0.5	0.44	0.060
Oxygen, wt%	31.83	33.32	33.62	32.92	0.959
Heating Value, Btu/lb	9613	10942	9365	9973	848
<i>Calculated Parameters</i>					
F _d , dscf/10 ⁶ Btu	9636	8238	9542	9139	782
Sulfur, wt% (dry)	0.56	0.48	0.63	0.56	0.077
Heating Value, Btu/lb (dry)	11883	13781	11839	12501	1109
Hg, µg/Nm³ (flue gas basis)	13.67	12.82	12.76	13.08	0.509
Hg, lb/Tbtu (flue gas basis)	9.59	7.69	8.87	8.72	0.960

Hawthorn Baseline Results

- **Baseline Hg measurements indicate a native Hg capture average of 17.8 %***
- **Coal and OH inlet measurements are consistent.**
- **CMM inlet and outlet measurements tend to be low for the baseline period when compared to OH and Coal results, but agree well during Hg control technology testing**

Date	Test Description	Coal (Inlet) μg/Nm ³	CMM Inlet μg/Nm ³	OH Inlet μg/Nm ³	CMM Outlet μg/Nm ³	OH Outlet μg/Nm ³	Coal-to-Stack Hg Removal, %	
							OH	CMM
9/18/2006	Baseline	13.67	7.23	14.28	8.7	11.37	16.9	36.4
9/18/2006	Baseline	13.67	7.52	13.61	8.64	10.86	20.5	36.8
9/19/2006	Baseline	12.82	6.24	11.27	8.28	10.54	17.8	35.4
9/19/2006	Baseline	12.82	6.93	12.67	8.64	10.78	15.9	32.6

*Coal inlet to OH outlet basis

Hawthorn SEA1 Results

- Testing of SEA1 occurred during 9/20/06-9/22/06
- Results indicate a positive effect on Hg capture when compared to baseline removals.
- Hg removal efficiencies appear to only slightly increase with increasing SEA1 rate.

Date	Test Description	Coal (Inlet) μg/Nm ³	CMM Inlet μg/Nm ³	OH Inlet μg/Nm ³	CMM Outlet μg/Nm ³	OH Outlet μg/Nm ³	Coal-to-Stack Hg Removal, %	
							OH	CMM
9/18/2006	Baseline	13.67	7.23	14.28	8.7	11.37	16.9	36.4
9/18/2006	Baseline	13.67	7.52	13.61	8.64	10.86	20.5	36.8
9/19/2006	Baseline	12.82	6.24	11.27	8.28	10.54	17.8	35.4
9/19/2006	Baseline	12.82	6.93	12.67	8.64	10.78	15.9	32.6
9/20/2006	SEA1 Only (600 ppm)	12.76	11.54	12.46	3.72	4.67	63.4	70.8
9/21/2006	SEA1 Only (800 ppm)	13.08	12.93	12.15	4.12	4.53	65.4	68.5

Hawthorn SEA 1 + PAC Results

Additive Rate	CMM IN:OUT	CMM Coal to Stack	OH Coal to Stack
PAC 3.3 lb/Macf SEA1 800 PPM	59.5%	69.6%	
PAC 3.3 lb/Macf SEA1 1000 PPM	64.3%	73.9%	85.0
PAC 3.9 lb/Macf SEA1 1000 PPM	73.3%	80.5%	
PAC 3.6 lb/Macf SEA1 1200 PPM	80.3%	82.5%	
PAC 3.9 lb/Macf SEA1 1200 PPM	89.7%	88.3%	96.0
PAC Hg LH 3 lb/Macf SEA1 1200 PPM	90.2%	91.1%	94.0

Hawthorn SEA2 T2 Results

Additive Rate	CMM IN:OUT	CMM Coal to Stack	OH Coal to Stack
PAC 3 lb/Macf SEA2 0.07 lb/lb PAC	78.7%	79.1%	
PAC 2.8 lb/Macf SEA2 0.14 lb/lb PAC	83.6%	83.5%	85.0

Conclusions

- Baseline removals at Hawthorn are considerably more variable than previous work.
 - Different coal?
- Preliminary results with CaCl_2 are also different (lower) from previous work.
 - Catalyst age?
 - Different coal?

Future Work

- Address issues associated with different PRB coals at Hawthorn.
- Perform an additional set of parametric tests with SEA1 + PAC and SEA2 T2 while firing a consistent fuel.
- Hawthorn long-term monitoring.
- Mill Creek site assessment.

Acknowledgments

- Electric Power Research Institute, Kansas City Power & Light, Otter Tail Power Company, Dynegy, Pacificorp, Ameren UE, Southern Company, Texas Genco, The Babcock & Wilcox Company, Wisconsin Public Service, Cormetech, Norit, and the U.S. Department of Energy National Energy Technology Laboratory