


Integrated Water-Gas-Shift Pre-Combustion Carbon Capture Process



Gökhan Alptekin, PhD
TDA Research, Inc.
Wheat Ridge, CO
galptekin@tda.com

**2017 Gasification Systems
Project Review**

March 20, 2017

DE-FE0026142

October 1, 2015 – March 31, 2018

TDA Research Inc. • Wheat Ridge, CO 80033 • www.tda.com

Project Objectives

- **The project objective is to demonstrate techno-economic viability of an integrated WGS catalyst/CO₂ removal system for IGCC power plants and CTL plants**
 - A high temperature PSA adsorbent is used for CO₂ removal above the dew point of the synthesis gas
 - A commercial low temperature catalyst is used for water-gas-shift
 - An effective heat management system
- **Project Tasks**
 - Design a fully-equipped slipstream test unit with 10 SCFM raw synthesis gas treatment capacity
 - Design and fabricate CFD optimized reactors capable of managing the exothermic WGS reaction while maintaining energy efficiency
 - Demonstrate all critical design parameters including sorbent capacity, CO₂ removal efficiency, extent of WGS conversion as well as H₂ recovery for over 2,000 hr using coal synthesis gas
 - Complete a high fidelity process design and economic analysis

Project Partners



Project Duration

- Start Date = October 1, 2014
- End Date = March 31, 2018 (no-cost extension requested)

Budget


- Project Cost = \$5,632,619
- DOE Share = \$4,506,719
- TDA and its partners = \$1,125,900

Presentation Outline

- **TDA's Approach**
- **TDA's Process**
- **Bench-Scale Results**
- **Modeling Results**
- **Prototype Unit Design and Fabrication**
- **Techno-economic Analysis**
- **Future Plans**

TDA's Approach

- Conventional IGCC plants use multi-stage WGS with inter-stage cooling
 - WGS is an equilibrium-limited exothermic reaction
- Water is supplied at concentrations well above required by the reaction stoichiometry to completely shift the CO to CO₂




3-stage WGS unit as described in the DOE/NETL-2007/1281

- In the process, high temperature CO₂ adsorbent is used to shift the CO at low steam:carbon ratios
- Reduced water addition increases process efficiency

TDA's Sorbent

- **TDA's uses a mesoporous carbon modified with surface functional groups that remove CO₂ via strong physical adsorption**
 - CO₂-surface interaction is strong enough to allow operation at elevated temperatures
 - Because CO₂ is not bonded via a covalent bond, the energy input for regeneration is low
- **Heat of CO₂ adsorption is 4.9 kcal/mol for TDA sorbent**
 - Comparable to that of Selexol
- **Net energy loss in sorbent regeneration is similar to Selexol, but a much higher IGCC efficiency can be achieved due to high temperature CO₂ capture**




- **Pore size can be finely tuned in the 10 to 100 A range**
- **Mesopores eliminates diffusion limitations and rapid mass transfer, while enables high surface area**

US Patent 9,120,079, Dietz, Alptekin, Jayaraman "High Capacity Carbon Dioxide Sorbent", US 6,297,293; 6,737,445; 7,167,354
US Pat. Appl. 61790193, Alptekin, Jayaraman, Copeland "Pre-combustion Carbon Dioxide Capture System Using a Regenerable Sorbent"


Operating Conditions

- **CO₂ is recovered via combined pressure and concentration swing**
 - CO₂ recovery at ~150 psia reduces energy need for CO₂ compression
 - Small steam purge ensures high product purity
- **Isothermal operation eliminates heat/cool transitions**
 - Rapid cycles reduces cycle time and increases sorbent utilization
- **Similar PSA systems are used in commercial H₂ plants and air separation plants**



Source: Honeywell/UOP

Integrated WGS/CO₂ Capture System




- **Reducing the use of excess steam improves power cycle efficiency**
 - Lower energy consumption to raise the steam
- **Process intensification could potentially reduce the number of hardware components and cost**

Sorbent's point of view:

- **Less dilution with water increases CO₂ partial pressure and in turn improves sorbent's working capacity**

Application to CTL



Sorbent Development Work



TDA 0.1 MW pre-combustion carbon capture unit installed at the National Carbon Capture Center

- **0.1 MW_e test in a world class IGCC plant to demonstrate full benefits of the technology**
 - Field Test #1 at NCCC
 - Field Test #2 at Sinopec Yangtzi Petrochemical Plant, Nanjing, Jiangsu Province, China
- **Full operation scheme**
 - 8 reactors and all accumulators
 - Utilize product/inert gas purges
 - H₂ recovery/CO₂ purity



Yangtzi Petro-chemical Plant

Sorbent and Catalyst for Field Tests

Sulfur Sorbent and WGS Catalyst




CO₂ Sorbent for Field Tests



- 3.5 m³ of TDA's CO₂ sorbent has been produced for use in the field tests
- Warm gas Sulfur removal sorbent and High and Low Temperature WGS catalysts have been procured from Clariant

NCCC Field Test – Early Work



- **90+% capture at steam:CO ratio= 1:1.1 with average 96.4% CO conversion**
- **All objectives met (no coking etc.) but high reactor T was observed**

Technology Status/R&D Needs

- Sorbent is developed under a separate DOE project (DE-FE0000469)
- WGS catalyst is commercially available mature technology
- Early-stage concept demonstration has already been completed (DE-FE0007966)
 - Integrated sorbent/catalyst operation
 - Pointed out the need to incorporate effective heat management
- **Key R&D need is the design/development of a high fidelity prototype to fully demonstrate the concept using actual coal-derived synthesis gas**
 - A 10 kg/hr CO₂ removal is being developed
 - Testing of the high fidelity system will be carried out at the NCCC and Praxair
 - Original test site Wabash River IGCC plant is no longer available

Project Structure

Year 1

- Design a field test unit including detailed design of the sorbent reactors, using multi-component adsorption and CFD simulation models
- Have the input and full approval of test sites
- Complete sorbent manufacturing based on the current Manufacturing Plan
- Initiate a long-term sorbent life evaluation (8,000 cycles)


Year 2

- Complete evaluation of single integrated reactor with simulated syngas
- Revise our reactor design based on results from single reactor tests
- Complete fabrication of the slipstream test unit
- Continue long-term testing of the sorbent (20,000 cycles)

Year 3


- Complete long-term testing of the sorbent (30,000 cycles)
- Complete field tests at the NCCC and Praxair Plants
- Complete a high-fidelity system design/analysis and cost estimate
- Complete an Environmental, Health and Safety (EHS) assessment

T Profiles - During CO₂ Capture Only



- Heat generated during adsorption is removed during regeneration
 - Near isothermal operation

Heat Wave WGS & CO₂ Capture




- Integrated WGS & CO₂ capture results in higher ΔT
- Not ideal for CO₂ capture (the WGS heat accumulates in the beds)


Conventional Heat Management Options

10 kg/hr CO₂ Removal Pilot Test System – 6” reactors


Cooling Jacket



Immersed Tube (1)




Immersed Tubes (3)




Heat Integrated WGS & CO₂ Capture

- **Advanced heat management concept based on direct water injection has proven to achieve much better temperature control**
 - Also much better heating efficiency (i.e., kJ heat removed per kg water)
- **Objective is to achieve a more uniform cooling without having hot or cold spots**
- **The temperature rise is optimal when the catalyst is distributed into two layers with water injections before each layer**



T Contours (°C) Single Injection Layer



T Contours (°C) Multiple Injection Layers






Bench-Scale Evaluations




- 8L reactors were modified with the heat management options
- Successful proof-of-concept demonstrations have been completed
- $\Delta T < 10^{\circ}\text{C}$ was maintained over extended cycling (much lower than those observed in early field tests)

Injector Design





- We designed our own injector nozzles and the water output control system that will allow these to effectively operate inside the reactor hot zone between 200-350°C
- The water flow rate is controlled by controlling injector pulse duration and pulse delay time

Bench-scale Tests w/ Demo-size Reactor




- Effective operation of the water injectors were demonstrated in a fully instrumented test reactor
- Sorbent & catalyst volume is the same as in the demo system




NCCC Testing

- Testing during the G3 & G4 campaigns using at 1 SCFM scale validated the impact of water injection on bed temperature and CO conversion
 - System was tested for over 650 hours
 - CO conversion, overall carbon capture, temperature, water injection functionality

CO Inlet Conc.= 6-8% vol.




Reactor Design w/ Water Injectors




Water Injection System

- Water is injected in 3 locations along the bed
- A spacer will be inserted at each injector location to provide space for water vaporization and gas mixing



Integrated WGS/CO₂ Capture System




Fabrication of the Prototype



Reactor Vessel Fabrication

- Vessel fabrication is completed
- Design allows easy replacement of media without removing the injector assembly




Fabrication of the Prototype



- All plumbing work is complete

Electrical and Control Systems



- **Control box is completed (electrical, heating and insulation will be completed late April 2017)**

Process Simulation and Analysis

IGCC plant with E-Gas™ Gasifier operating on Bituminous Coal

#	CO ₂ Capture	Notes	Steam/ Water Addition	Overall Steam:CO Ratio	Net Efficiency % HHV
1	Conventional Technology	Reference IGCC case with Steam addition to 1 st WGS reactor feed	Steam	2.25	31.04
2	TDA/Advanced Technology	No steam addition to 1 st WGS reactor feed; water injection into combined WGS+PSA reactor	Water	1.50	34.30
2-3	TDA/Advanced Technology	No 1 st WGS reactor & water injection into combined WGS+PSA reactor	Water	2.21	33.73
2A	TDA/Previous Technology	Steam addition to 1 st WGS reactor feed; no water injection into 2 nd WGS reactor (not combined with PSA)	Steam	2.25	33.81

- **Reducing Steam:CO ratio to 1.50 w/ water addition to Integrated WGS/CO₂ Removal Reactor (2nd stage) provides a net plant efficiency of 34.30%**
 - **0.5% point improvement over TDA's sorbent-only technology**

IGCC plants with Shell Gasifier

Case #	Coal Type	CO ₂ Capture	Notes	Overall Steam: CO Ratio	Net Efficiency % HHV
3	Bituminous	Conventional Technology	Reference IGCC Case (H ₂ O/CO in 1 st WGS reactor feed = 1.8 mole/mole per corresponding DoE case)	1.8	31.08
4	Bituminous	TDA/Advanced Technology	No steam addition to 1 st WGS reactor feed (H ₂ O/CO in 1 st WGS reactor feed = 1.11 mole/mole); water injection into combined WGS+PSA reactor	1.38	33.71
5	Lignite	Conventional Technology	Reference IGCC Case (H ₂ O/CO in 1 st WGS reactor feed = 1.8 mole/mole)	1.8	30.89
6	Lignite	TDA/Advanced Technology	No steam addition to 1 st WGS reactor feed (H ₂ O/CO in 1 st WGS reactor feed = 1.60 mole/mole); water injection into combined WGS+PSA reactor	1.78	32.79

- **Different gasifiers and coal are being evaluated**
 - **Better plant efficiency for all coals and gasifiers**

E-Gas™ & GE Gasifiers

Gasifier Type/Make	E-Gas			GE	
	1	2	2* (WGS/CO ₂)	3	4
Case					
CO ₂ Capture Technology	Cold Gas Cleanup Selexol™	Warm Gas Cleanup TDA's CO ₂ Sorbent	Warm Gas Cleanup TDA's CO ₂ Sorbent	Cold Gas Cleanup Selexol™	Warm Gas Cleanup TDA's CO ₂ Sorbent
CO ₂ Capture, %	90	90	90	90	90
Gross Power Generated, kW	710,789	670,056	693,542	727,633	674,331
Gas Turbine Power	464,000	425,605	427,980	464,000	417,554
Steam Turbine Power	246,789	244,450	265,562	257,657	246,746
Syngas Expander Power	-	-	-	5,977	10,031
Auxiliary Load, kW	194,473	124,138	138,741	192,546	120,661
Net Power, kW	516,316	545,917	554,801	535,087	553,671
Net Plant Efficiency, % HHV	31.0	34.1	34.7	32.0	34.5
Coal Feed Rate, kg/h	220,549	212,265	212,265	221,917	213,013
Raw Water Usage, GPM/MW	10.9	10.3	10.0	10.7	10.5
Total Plant Cost, \$/kW	3,464	3,042	2,990	3,359	3,083
COE without CO ₂ TS&M, \$/MWh	136.8	120.5	118.8	133.0	121.8
COE with CO ₂ TS&M, \$/MWh	145.7	128.6	126.7	141.6	129.7
Cost of CO ₂ Captured, \$/tonne	53.2	37.4	35.8	47.3	36.1

- Efficiency is increased to 34.7% with TDA's combined WGS/CO₂ system and reduced to \$35.8/tonne

Process Economic Analysis - CTL

- Integrated WGS with CO₂ capture reduced the required selling price (RSP) for Methanol to \$438 per ST compared to \$453 per ST for a CTL plant with Rectisol

Gasifier	Shell	
Coal	Bituminous	
Case	7	8
CO ₂ Capture Technology	Cold Gas Cleanup Rectisol™	Warm Gas Cleanup TDA's CO ₂ Sorbent
CO ₂ Capture, %	90	90
Gross Power Generated, kW	320,514	292,457
Gas Turbine Power	130,684	130,114
Steam Turbine Power	189,830	162,342
Syngas Expander Power	-	-
Auxiliary Load, kW	310,729	276,851
Net Power, kW	9,785	15,606
Net Plant Efficiency, % HHV	-	0.35
Methanol Production rate, ST/D	11,094	10,934
Coal Feed Rate, kg/h	589,458	589,458
Raw Water Usage, GPM	6,529.0	5,405.0
Total Plant Cost, \$/kg/D	357.26	345.27
1st year Required Selling Price (RSP) w/o CO ₂ TS&M, \$/ST	453.0	438.0

Process Economic Analysis - CTL

Gasifier	Shell	
Coal	Bituminous	
Case	9	10A
CO ₂ Capture Technology	Cold Gas Cleanup Rectisol™	Warm Gas Cleanup TDA's CO ₂ Sorbent
CO ₂ Capture, %	90	90
Gross Power Generated, kW	462,568	458,830
Gas Turbine Power	130,283	130,519
Steam Turbine Power	332,285	328,311
Syngas Expander Power	-	-
Auxiliary Load, kW	397,803	365,956
Net Power, kW	64,764	92,875
Net Plant Efficiency, % HHV	1.08	1.55
Naphtha Production rate, ST/D	1,803	1,722
Diesel Production rate, ST/D	4,789	4,933
Coal Feed Rate, kg/h	793,864	793,864
Raw Water Usage, GPM	14,032.6	12,394.0
Total Plant Cost, \$/kg/D	949.87	864.94
NAPHTHA		
1st year Required Selling Price (RSP) w/o CO ₂ TS&M, \$/bbl	107.0	100.0
DIESEL		
1st year Required Selling Price (RSP) w/o CO ₂ TS&M, \$/bbl	153.0	143.0

- Integrated WGS with CO₂ capture reduced the required selling price for Naphtha to \$100 per bbl compared to \$107 per bbl for a CTL plant with Rectisol
- Integrated WGS with CO₂ capture reduced the required selling price for Diesel to \$143 per bbl compared to \$153 per bbl for a CTL plant with Rectisol

Future Work

- **Complete fabrication of the slipstream test unit – May 2017**
- **Testing of the unit at Praxair – June-August 2017**
- **Testing of the unit at NCCC – October-November 2017**
- **Complete long-term testing of the sorbent (30,000 cycles) – September 2017**
- **Complete a high-fidelity system design/analysis and cost estimate – March 2018**
- **Complete an Environmental, Health and Safety (EHS) assessment – March 2018**