Follow-on Turbosorp® Testing Results from the Greenidge Multi-Pollutant Control Project

Douglas J. Roll, P.E.
AES Greenidge LLC

Richard F. Abrams
Babcock Power Environmental

Daniel P. Connell
CONSOL Energy Inc. Research & Development

Greenidge Multi-Pollutant Control Project

- Part of U.S. DOE's Power Plant Improvement Initiative
- Participants
  - CONSOL Energy Inc. (administration, testing, reporting)
  - AES Greenidge LLC (host site, operations)
  - Babcock Power Environmental Inc. (EPC contractor)
- Funding
  - U.S. Department of Energy, National Energy Technology Laboratory
  - AES Greenidge LLC
- Goal: Demonstrate a multi-pollutant control system that can cost-effectively reduce emissions of NO_x, SO_2, mercury, acid gases (SO_3, HCl, HF), and particulate matter from smaller coal-fired EGUs

Existing U.S. Coal-Fired EGUs
50-300 MW_e



Existing U.S. Coal-Fired EGUs
50-300 MW_e

- ~ 440 units not equipped with FGD, SCR, or Hg control
  - Represent ~ 60 GW of installed capacity
  - Greater than 80% are located east of the Mississippi River
  - Most have not announced plans to retrofit
- Difficult to retrofit for deep emission reductions
  - Large capital costs
  - Space limitations
- Increasingly vulnerable to retirement or fuel switching because of progressively more stringent environmental regulations
  - CAIR, CAMR, CAVR, state regulations
- Need to commercialize technologies designed to meet the environmental compliance requirements of these units

AES Greenidge Unit 4 (Boiler 6)

- Dresden, NY
- Commissioned in 1953
- 107 MW_e reheat unit
- Boiler:
  - Combustion Engineering tangentially-fired, balanced draft
  - 780,000 lb/h steam flow at 1465 psig and 1005 ^oF
- Fuel:
  - Eastern U.S. bituminous coal
  - Biomass (waste wood) – up to 10% heat input
- Original emission controls:
  - Overfire air (natural gas reburn not in use)
  - ESP
  - No FGD - mid-sulfur coal to meet permit limit of 3.8 lb SO_2/MMBtu

Design Objectives

- Deep emission reductions
- Low capital costs
- Small space requirements
- Applicability to high-sulfur coals
- Low maintenance requirements
- Operational flexibility

Multi-Pollutant Control Process



Hybrid NO_x Control



- Combustion Modifications
  - Replace coal, combustion air, and overfire air nozzles
  - Reduce NO_x to 0.25 lb/MMBtu
- SNCR
  - Three zones of urea injection
  - Provide NH_3 slip for SCR
  - Reduce NO_x by ~ 42.5% (to 0.144 lb/MMBtu)
- SCR
  - Single catalyst bed (1.3 m)
  - Cross section = 45’ x 14’
  - Fed by NH_3 slip from SNCR
  - Reduce NO_x by > 30% (to ≤ 0.10 lb/MMBtu)

Turbosorp®

Internal Solids Recirculation Enhances Reactions



Very High Recirculation of Baghouse Solids Results in High Utilization of Lime

Turbosorp® System



- Completely dry
- Separate control of reagent, water, and recycled solid injection
- Applicable to high-S coal
- High solids recirculation
- 15-25% lower reagent consumption than SDA
- Carbon steel construction
- No wet stack
- Low maintenance requirements
  - Few moving parts
  - No slurries
  - No dewatering

Mercury Control

- System design favors high Hg removal without activated carbon injection
  - Hg oxidation across in-duct SCR catalyst
  - Low temperature (~170 ^{o}F) in scrubber / baghouse
  - Ample gas / solids contact in scrubber / baghouse
  - Similar to SCR / SDA / FF with bituminous coal
    - Field sampling shows 90% Hg removal often achieved with no ACI
- To ensure ≥ 90% Hg removal, demonstration at AES Greenidge includes an activated carbon injection system
  - Turbosorp® system provides high carbon residence time
  - Projected activated carbon requirement: 0.0 – 3.5 lb/mmacf

Performance Targets

Fuel: 2-4% sulfur bituminous coal, up to 10% biomass

Parameter	Goal
NO_x	≤ 0.10 lb/mmBtu (full load)
SO_2	≥ 95% removal
Hg	≥ 90% removal
SO_3, HCl, HF	≥ 95% removal

Project Schedule



Initial 2007 Data

NO_x Emission Rate

March 28, 2007



SO_2 Removal Efficiency

March 29, 2007



SO_2 Emissions

June 2007



Mercury

March 28-30, 2007



Average Removal Efficiency = >94.6% (LOD)

Acid Gases

May 2-4, 2007



October 2007 Data

Mercury Removal Efficiency



Average Removal Efficiency = 96.8%

SO_2 Removal Efficiency



Average SO_2 Removal Efficiency = 96.4%

Performance Comparison

- Mercury
  - Initial data averaged >94.6% removal (limits of detection)
  - Recent data showed average of **96.8%**
  - No noticeable change from ACI
  - Ash is high in unburned carbon (average ~18%)
  - Target removal efficiency is being met

Hg Removal Efficiency Remains High without ACI

Performance Comparison

- SO_2
  - Initial data averaged >96.0% removal
  - Recent data showed average removal of **96.4%**
  - Fuel sulfur loading increased 10% to 4.2 lb/MBtu
  - Performance guarantee continues to be met

SO_2 Removal Efficiency Remains High

Summary

- Greenidge MPC process uniquely designed to meet needs of smaller coal-fired units
  - Deep emission reductions
  - Low capital costs
  - Small space requirements
  - Applicability to high-sulfur coals
  - Low maintenance requirements
  - Operational flexibility
- Ongoing performance testing results are encouraging
  - Demonstrated ability of system to achieve emission targets for NO_x, SO_2, Hg, and acid gases
- Additional testing planned

Thank You!

Questions?

Disclaimer

This presentation was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.