



Life Cycle Analysis: Supercritical Pulverized Coal (SCPC) Power Plant

Appendix: Process Modeling Data Assumptions and GaBi Modeling Inputs

DOE/NETL-403/110609

Table of Contents

List of Tables.....	iii
Acronyms and Abbreviations	v
A.1 Life Cycle Stage Process Modeling Data Assumptions and GaBi Modeling Inputs1	
A.1.1 Life Cycle Stage #1: Raw Material Acquisition – Coal Mining and Processing.....	3
A.1.1.1 GaBi Plan.....	3
A.1.1.2 Commissioning, Installation, and Decommissioning Assumptions....	5
A.1.1.3 Construction Assumptions	6
A.1.1.4 Operation Assumptions	22
A.1.2 Life Cycle Stage #2: Raw Material Transport – Coal Transport	24
A.1.2.1 GaBi Plan.....	25
A.1.2.2 Construction Assumptions	25
A.1.2.3 Operation Assumptions	29
A.1.3 Life Cycle Stage #3: SCPC Energy Conversion Facility without CCS.....	30
A.1.3.1 GaBi Plan.....	30
A.1.3.2 Commissioning, Installation, and Decommissioning Assumptions..	32
A.1.3.3 Construction Assumptions	34
A.1.4.1 GaBi Plan.....	44
A.1.4.2 Commissioning, Installation, and Decommissioning Assumptions..	46
A.1.4.3 Construction Assumptions	47
A.1.4.4 Operation Assumptions	51
A.1.5 Life Cycle Stage #4: Product Transportation – Electrical Grid.....	55
A.1.6 Life Cycle Stage #5: End User – Electricity Consumption.....	56
References.....	57

List of Tables

Table A-1: GaBi Air Emission Outputs for Coal Mine Commissioning/Decommissioning, Diesel, and Gasoline Inputs (kg/kg coal ready for transport)	6
Table A-2: Material Inputs and GaBi Profiles used for the Construction of a Coal Mine (1 kg Coal Output).....	7
Table A-3: GaBi Air Emission Outputs for Coal Construction included Total and Profile Specific Emissions, kg/kg Coal Ready for Transport	9
Table A-4: GaBi Air Emission Outputs for Coal Construction included Total and Profile Specific Emissions, kg/kg Coal Ready for Transport	10
Table A-5: Concrete Amounts Specified in the Sugarcamp and Deer Run Mine Applications (DNR, 2008)	11
Table A-6: Data and Calculations for Concrete Needs during Mine Siting	12
Table A-7: Data and Calculations to Determine Asphalt Needs for Mine Roads and Parking Lots	13
Table A-8: GaBi Air Emissions for Coal Mine Operations, Electricity, and Diesel Use, kg/kg Coal Ready for Transport.....	24
Table A-9: GaBi Air Emission Outputs for Stage #2 Construction and Material Inputs, kg/kg Coal Delivered	26
Table A-10: Railcar and Locomotives Needed over the Lifetime of the Energy Conversion Facility	28
Table A-11: GaBi Air Emission Outputs and Profiles for Stage #2 Operations, kg/kg Coal Delivered to the Plant.....	30
Table A-12: GaBi Air Emission Outputs and Profiles for Power Plant Installation/Deinstallation, kg/MWh Plant Output.....	34
Table A-13: Air Emission Output for SCPC Power Plant Construction without CCS, kg/MWh Plant Output	38
Table A-14: Air Releases from Auxiliary Boiler.....	40
Table A-15: Air Releases from SCPC Plant without CCS	40
Table A-16: Water Withdrawal for Case 11 from the Baseline Report.....	41
Table A-17: SCPC Overall Water Balance.....	42
Table A-18: SCPC Water Loss by Function.....	42
Table A-19: Air Emissions associated with SCPC Power Plant Operations without CCS, kg/MWh Plant Output.....	43
Table A-20: Air Emissions for On-Shore Pipeline Installation/Deinstallation, kg/mile pipeline	47
Table A-21: Air Emissions from SCPC Power Plant Construction with CCS, kg/MWh Plant Output	50
Table A-22: Air Releases from SCPC Plant without CCS	51
Table A-23: Water Withdrawal for Case 12 from the Baseline Report.....	53
Table A-24: SCPC Overall Water Balance.....	53
Table A-25: SCPC Water Loss by Function.....	54
Table A-26: Air Emissions from SCPC Plant Operations with CCS, kg/MWh Plant Output	55
Table A-27: Stage #4 Transmission Loss	55

List of Figures

Figure A-1: Main GaBi Plan for the SCPC Case with CCS	2
Figure A-2: GaBi Plan for LC Stage #1: Coal Acquisition	4
Figure A-3: Fuel Inputs into the Coal Mine Commissioning/Decommissioning Third Level GaBi Plan	6
Figure A-4: GaBi Plan View for Material Inputs during Coal Mine Construction	8
Figure A-5: Flexsteel Belt Construction (Goodyear, 2008b).....	14
Figure A-6: Cross-sectional Diagram of an I-beam.....	16
Figure A-7: Coal Mine Operations Fuel Inputs	24
Figure A-8: Second Level GaBi Plan: Stage #2 Train Transport	25
Figure A-9: GaBi Plan for Train Construction	26
Figure A-10: Train Load and Locomotive Power Relationship (TIAX LLC, 2007).....	27
Figure A-11: GaBi Plan for the Operation of a Unit Train.....	30
Figure A-12: GaBi Plan for SCPC Case without CCS	31
Figure A-13: GaBi Plan for Power Plant Installation/Deinstallation.....	34
Figure A-14: GaBi Plan for SCPC Power Plant Construction without CCS.....	37
Figure A-15: GaBi Plan for SCPC Power Plant Operation without CCS.....	43
Figure A-16: GaBi Plan for Stage #3, Case 2: SCPC with CCS	45
Figure A-17: GaBi Plan for Pipeline Installation/Deinstallation.....	46
Figure A-18: GaBi Plan for SCPC Power Plant Construction with CCS	49
Figure A-19: GaBi Plan for SCPC Plant Operation with CCS.....	54

Acronyms and Abbreviations

\$/MW-hour	Dollar per Megawatt Hour
°C	Degree Celsius
°F	Degree Fahrenheit
ACSR/AW	Aluminum Conductors, Aluminum-Clad Steel Reinforced
AEO	Annual Energy Outlook
ALNG	Atlantic LNG Company of Trinidad and Tobago
As	Arsenic
ASTM	American Society for Testing and Material Standards
AWG	American Wire Gage
bcf/d	Billion Cubic Feet per Day
Btu	British thermal unit
Btu/kWh	British thermal unit per Kilowatt-Hour
CAP	Criteria Air Pollutants
CCS	Carbon Capture and Sequestration
CH ₄	Methane
cm	Centimeter
CPM	Center for Environmental Assessment of Product and Material Systems
CTG	Combustion Turbine Generator
CO	Carbon Monoxide
CO ₂	Carbon Dioxide
CO ₂ e	Carbon Dioxide Equivalent
COE	Cost of Electricity
DOE	Department of Energy
EERE	Energy Efficiency and Renewable Energy
EIA	Energy Information Administration
EIS	Environmental Impact Statements
EPA	Environmental Protection Agency
EPC	Engineer/Procure/Construct
FG	Flue Gas
FERC	Federal Energy Regulatory Commission
F _i	Consumption of Fuel per Unit of Product
ft ³ /day	Cubic Feet per Day
g	Gram
G&A	General and Administrative
Gal/day	Gallons per Day
GE	General Electric
GHG	Greenhouse Gases



GJ	Gigajoule
gpm	Gallons per Minute
GtC	Gigatonnes of Carbon
GtCO ₂	Gigatonnes of Carbon Dioxide
GWP	Global Warming Potential
H ₂ S	Hydrogen Sulfide
ha	Hectare
HC	Hydrocarbons
HDSAM	Argonne National Laboratory Hydrogen Delivery Scenario Analysis Model
Hg	Mercury
HHV	Higher Heating Value
hrs	Hours
HRSG	Heat Recovery Steam Generators
HVAC	High-Voltage Alternating Current
IKP	University of Stuttgart
IPCC	Intergovernmental Panel on Climate Change
ISO	International Organization of Standardization
kg	Kilogram
kg/GJ	Kilogram per Gigajoule
kg/h	Kilogram per Hour
kg/MWh	Kilogram per Megawatt hour
kJ	Kilojoule
km	Kilometer
kV	Kilovolt
kW	Kilowatt
kWe	Kilowatt of Electricity
kWh	Kilowatt-Hour
kWh/tonne	Kilowatt Hour per Tonne
kWt	Kilowatt-Tonnage
L	Liter
lb	Pound
lb/h	Pound per Hour
lb/MWh	Pound per Megawatt Hour
lbs/day	Pounds per Day
LC	Life Cycle
LCA	Life Cycle Analysis
LCC	Life Cycle Cost
LCI	Life Cycle Inventory
LCIA	Life Cycle Impact Assessment
LCOE	Levelized Cost of Electricity

LHV	Lower Heating Value
LNB	Low-Nitrogen Oxides Burner
LNG	Liquefied Natural Gas
m ³ /min	Cubic Meter per Minute
MACRS	Modified Accelerated Cost Recovery System
MEA	Monoethanolamine
mills/kWh	Mills per Kilowatt-Hour
MJ	Mega-Joule
mL	Milliliter
mm	Millimeter
MMBtu	Million British thermal units
MMV	Measurement, Monitoring, and Verification
MPa	Megapascals
MTPA	Metric Tonnes per Annum
MVA	Megavolt-Ampere
MW	Megawatt
MWh	Megawatt-Hour
Mwe	Megawatts (Electric)
N ₂ O	Nitrous Oxide
NETL	National Energy Technology Laboratory
NGCC	Natural Gas Combined Cycle
NH ₃	Ammonia
NO ₂	Nitrogen Dioxide
NO _x	Oxides of Nitrogen
O&M	Operations and Maintenance
oz/ft ²	Fluid Ounces per Square Foot
Pb	Lead
pH	Potential Hydrogen
PM	Particulate Matter
PM ₁₀	Particulate Matter (diameter 10 micrometer)
PM _{2.5}	Particulate Matter (diameter 2.5 micrometer)
PO ₄	Phosphate
ppm	Parts per Million
ppmv	Parts per Million Volume
psi	Pounds per Square Inch
psia	Pounds per Square Inch Absolute
psig	Pounds per Square Inch Gauge
PV	Present Value
RDS	Research and Development Solutions



scf	Standard Cubic Feet
SCR	Selective Catalytic Reduction
Se	Selenium
SF ₆	Sulfur Hexafluoride
SO ₂	Sulfur Dioxide
SO _x	Sulfur Oxide
SOW	Statement of Work
ST	Steam Turbine
TBD	To Be Determined
TOC	Total Organic Compounds
U.S.	United States
VOC	Volatile Organic Chemical
wt%	Weight Percentage

A.1 Life Cycle Stage Process Modeling Data Assumptions and GaBi Modeling Inputs

Appendix A details the process modeling data assumptions and GaBi modeling inputs for each of the life cycle (LC) stages considered in this study. For more details on the system boundary and other aspects of this study, please see the main final report. GaBi output data will be shown for air emissions. Results associated with land and all economic modeling assumptions and results are included in the main text.

All stages will be the same for both cases except for Stage #3, which has different assumptions and therefore will be described separately for each case. For each stage, the construction assumptions will be discussed separately from the operations as they often come from different reference sources. When applicable, the commissioning, installation, and decommissioning will also be discussed. For clarity, the following are general descriptions of each term as they are used in this study:

- **Construction:** materials used in the construction of a process (steel used to build a power plant)
- **Commissioning/Installation:** energy used and emissions created to prepare the land and install the processing facility. This is also when land use change occurs. Commissioning and installation are used interchangeably because commissioning is the word typically used in the literature while installation is used in GaBi.
- **Decommissioning:** energy use and emissions associated with removing the processing facility (and returning the land to grassland). Typically a fraction of the assumptions made for commissioning.
- **Operations:** energy use and subsequent emissions due to the operation of a process (electricity and diesel during coal mining, natural gas for the auxiliary boiler during power plant operations).

All assumptions and data limitations will be noted. All references are listed at the conclusion of the appendix.

Figure A-1 is the main GaBi plan for this study; this specific plan is for the SCPC case with CCS but both are similar. Plans are used in GaBi to assemble unit processes or sub-plans (nested plans) within an LC study. Essentially, plans are the process maps which visually depict a stage or sub-stage in a system. There are several levels of plans: main, second level, third level, etc. The main plan represents the highest level LC in which all other plans are embedded; from the main plan one could click onto a secondary plan (i.e., LC Stage #1 coal acquisition), and from there onto a third level plan (i.e., coal mine construction). The input and output values shown on this plan are based on the reference flow of 1 MWh (3,600 MJ = 1 MWh). Also included in **Figure A-1** are the adjustable parameters considered during the LCI sensitivity analysis for this study (see main report text for results). Specific details on why these parameters are adjustable are included within the following data assumption text.




Figure A-1: Main GaBi Plan for the SCPC Case with CCS

A.1.1 Life Cycle Stage #1: Raw Material Acquisition – Coal Mining and Processing

A.1.1.1 GaBi Plan

Figure A-2 is the second level GaBi plan for the Stage #1 coal mining process. For this stage, CH₄ emissions are the only adjustable parameter, meaning that sensitivity analysis can be performed on this parameter within the GaBi modeling framework. The reference flow of this stage is 1 kg of coal produced from the mine. Data assumptions for each input (coal mine operation, coal mine construction, and commissioning/decommissioning) are discussed in the following sections. Water withdrawals and emissions are not captured in the GaBi plans; they only show input data that is tracked within the GaBi modeling system. Emissions are considered outputs and therefore are not included. Water withdrawal, although an input, is not tracked in the model as no GaBi profiles exist for water use in the model to date. For now, water is inventoried for each stage, when applicable.




Figure A-2: GaBi Plan for LC Stage #1: Coal Acquisition

A.1.1.2 Commissioning, Installation, and Decommissioning Assumptions

No data were available for the commissioning or decommissioning of the Galatia Mine, so fuel consumption and emissions data were obtained from a draft EIS for the Red Cliff Mine in Colorado (DOI, 2009). The Red Cliff Mine is an underground mine expected to have an annual output of eight million tons, and have a productive lifetime of 20 to 30 years. The EIS provided data for the on-site machinery fuel use and tailpipe emissions (GHG and criteria air pollutants) in Appendix H, Air Quality Analysis Modeling Report (DOI, 2009). Tons of pollutants emitted per year were converted into tons per commissioning by multiplying by 1.5, the length of time expected to complete the commissioning (DOI, 2009). These values were then converted into kilograms and divided by the total expected output of the mine over 30 years, 217,724,337,600 kg, to determine the amount of emissions on a per kg of coal produced basis. Equipment fuel use data, for both gasoline and diesel, were taken from the same data source and calculated on a per-kg of coal produced basis in the same fashion.

The PM emissions were taken from a different location in the same source (DOI, 2009). It was assumed that the value given for PM_{2.5} emissions would encompass all particle matter greater than 2.5 microns, including PM₁₀ emissions; therefore the total value for PM_{2.5} was assumed for all PM ≤ 10 microns. It was also assumed that the total PM values given included consumption and fugitive dust emissions. The given values were in tons/yr, and were also converted to kg PM/kg coal produced.

The emissions for NH₃ and Hg were calculated using data from two other sources (Battye, Battye et al., 1994; Conaway, Mason et al., 2005). The emission factors for both fuels was given, NH₃ in kg/1000 L of gas (or diesel) (Conaway et al. 2005) and Hg in ng/g of gas (or diesel) (Battye et al. 1994). Each emission factor was multiplied by the amount of each fuel used during commissioning to get a final value per kg of coal produced.

The values of each fuel and emission for commissioning was then multiplied by 10 percent to account for decommissioning emissions and fuel consumption, a common assumption in the literature (Hill, O'Keefe et al., 1995; Odeh and Cockerill, 2008; Gorokhov, Manfredo et al., 2002). Reliable data for water use during coal mine commissioning and decommissioning was unable to be located and was thus considered a minor data limitation. Water would be used to suppress particulate emissions during construction and decommissioning activities.

Based on the given data assumptions, **Figure A-3** represents the fuel inputs to produce 1 kg of output coal during the commissioning/decommissioning process and **Table A-2** shows the air emissions.




Figure A-3: Fuel Inputs into the Coal Mine Commissioning/Decommissioning Third Level GaBi Plan

Table A-1: GaBi Air Emission Outputs for Coal Mine Commissioning/Decommissioning, Diesel, and Gasoline Inputs (kg/kg coal ready for transport)

Emissions (kg/kg coal ready for transport)	Total	Coal Mine Commissioning/Decommissioning	Diesel at refinery	Gasoline (regular) at refinery
Lead	4.51E-14	0.00E+00	4.51E-14	6.38E-17
Mercury	4.21E-15	3.86E-16	3.82E-15	6.79E-18
Ammonia	6.68E-12	6.35E-17	6.67E-12	1.62E-14
Carbon dioxide	1.37E-05	1.27E-05	9.97E-07	1.67E-09
Carbon monoxide	3.45E-08	3.30E-08	1.46E-09	1.88E-12
Nitrogen oxides	1.04E-07	1.01E-07	3.10E-09	3.76E-12
Nitrous oxide (laughing gas)	2.51E-10	2.34E-10	1.71E-11	2.32E-14
Sulfur dioxide	4.09E-09	8.25E-11	4.00E-09	5.38E-12
Sulfur hexafluoride	3.80E-18	0.00E+00	3.80E-18	4.74E-21
Methane	1.08E-08	3.78E-10	1.04E-08	1.12E-11
Methane (biotic)	0.00E+00	0.00E+00	0.00E+00	0.00E+00
VOC (unspecified)	4.56E-09	4.56E-09	4.32E-12	4.71E-15
Particulate Matter, unspecified	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Dust (unspecified)	3.41E-07	3.41E-07	5.90E-11	6.76E-14

A.1.1.3 Construction Assumptions

The following major equipment/components were needed to operate the modeled coal mine: site paving and concrete, conveyor belt, stacker/reclaimer, crusher, coal cleaning, silo, water treating, continuous miner, longwall miner, and shuttle car systems with replacement. Modeling

assumptions for the material use of each component is discussed in the following sections. Overall, the total material inputs needed during the construction process (on a per kg coal output basis) are summarized in **Table A-2**. Also included in **Table A-2** are the GaBi profiles used for the LC assumptions of each material. Although the level of completeness for each profile is different, most are cradle-to-gate. These material inputs are also represented as a GaBi plan view in **Figure A-4**. **Table A-3a** and **Table 3b** shows the output air emission associated with this process.

Table A-2: Material Inputs and GaBi Profiles used for the Construction of a Coal Mine (1 kg Coal Output)

Material	Amount	Unit	GaBi Assumption
Cold-Rolled Steel	1.4704807E-05	kg	Cold-rolled steel profile – PE
Hot-dip Galvanized Steel	1.5194872E-06	kg	Hot-dip Galvanized Steel profile - WOR
Rubber	4.4476729E-07	kg	Styrene butadiene rubber mix (SBR) - PE
Steel Plate	1.8025590E-04	kg	Steel plates – BF
Concrete	6.0562609E-05	kg	Concrete, ready mixed, R-5.0, (MP-CG)
Rebar	1.4088365E-06	kg	Rebar wire rod, BF – WOR
Polyvinylchloride Pipe	1.2992707E-07	kg	Polyvinylchloride pipe – PE
Steel, Stainless, 316	6.7669300E-08	kg	Steel stainless 316, 2B 80%
Stainless Steel Cold Roll 431	6.7669300E-08	kg	Stainless steel cold rolled – PE
Cast Iron	3.3834650E-07	kg	Cast iron part (Sand casting) - PE
Copper Mix	8.1127506E-09	kg	Copper mix 99.999% - PE
Asphalt	1.1053860E-03	kg	GAB II, Asphalt – DK (Data from DK but profiles from United States)




Figure A-4: GaBi Plan View for Material Inputs during Coal Mine Construction

Table A-3: GaBi Air Emission Outputs for Coal Construction included Total and Profile Specific Emissions, kg/kg Coal Ready for Transport

Emissions (kg/kg coal ready to transport)	Total	GAB II, ASPHALT (Medium water content)	SERC Power Grid Mix 2005 (USEPA, eGRID2007)	BF: Hot-dip Galvanized NETL	DE: Cast iron part (sand casting) PE [pl]	Copper mix (99,999% from electrolysis) PE	DE: Stainless steel cold roll PE	DE: Steel cold rolled PE
Lead	4.77E-10	4.20E-12	5.49E-13	5.55E-12	2.06E-14	9.29E-13	6.14E-14	4.91E-11
Mercury (Hg)	2.70E-11	3.43E-13	1.55E-13	1.96E-13	7.98E-16	2.11E-16	1.96E-14	6.28E-14
Ammonia	7.36E-10	5.60E-10	5.30E-11	0.00E+00	8.03E-13	2.24E-13	1.01E-12	8.85E-11
Carbon dioxide	2.79E-04	1.74E-05	1.10E-05	1.98E-06	4.15E-07	3.16E-08	3.26E-07	2.72E-05
Carbon monoxide	2.10E-06	3.00E-08	4.56E-09	2.30E-08	5.25E-10	2.99E-11	1.96E-10	2.58E-07
Nitrogen oxides	5.22E-07	6.55E-08	2.14E-08	4.13E-09	3.25E-10	7.17E-11	4.79E-10	5.15E-08
Nitrous oxide (laughing gas)	1.17E-08	3.19E-10	1.46E-10	9.32E-11	5.96E-12	1.38E-12	3.91E-12	1.77E-10
Sulfur dioxide	6.92E-07	9.09E-08	6.26E-08	0.00E+00	2.33E-10	1.14E-10	1.35E-09	3.77E-08
Sulfur hexafluoride	1.34E-13	1.34E-13	7.52E-17	0.00E+00	1.41E-18	1.57E-18	6.97E-18	1.98E-16
Methane	3.94E-07	1.78E-07	1.21E-08	2.80E-09	3.31E-10	4.34E-11	4.11E-10	3.19E-08
Methane (biotic)	3.82E-10	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
VOC (unspecified)	3.25E-08	3.68E-11	1.54E-12	1.99E-10	1.11E-14	3.46E-14	2.19E-12	1.55E-12
Particulate Matter, unspecified	3.19E-09	2.56E-10	0.00E+00	2.09E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Dust (unspecified)	9.52E-08	9.97E-10	1.19E-09	0.00E+00	6.79E-10	4.66E-11	1.11E-10	1.66E-08



Table A-4: GaBi Air Emission Outputs for Coal Construction included Total and Profile Specific Emissions, kg/kg Coal Ready for Transport

Emissions (kg/kg coal ready to transport)	DE: Styrene-butadiene rubber mix (SBR) PE	Polyvinylchloride pipe (PVC) PlasticsEurope	Concrete, Ready Mixed, R-5-0 (100% Portland Cement)	US: Thermal energy from heavy fuel oil PE	WOR: Rebar Wire Rod, BF Manufactures NETL	WOR: Steel Plate, BF, Manufacture NETL [MP-CG]	WOR: Steel, Stainless, 316 2B, 80% Recycled
Lead	5.45E-14	1.56E-14	0.00E+00	2.96E-15	2.76E-12	4.13E-10	0.00E+00
Mercury	4.74E-15	4.14E-14	0.00E+00	1.37E-17	1.65E-13	2.60E-11	0.00E+00
Ammonia	3.00E-11	1.57E-12	0.00E+00	1.06E-13	0.00E+00	0.00E+00	0.00E+00
Carbon dioxide	1.38E-06	3.26E-07	8.39E-06	1.82E-08	1.23E-06	2.09E-04	3.67E-07
Carbon monoxide	3.95E-10	3.97E-10	1.08E-08	6.70E-12	1.47E-08	1.76E-06	6.57E-10
Nitrogen oxides	1.51E-09	0.00E+00	2.56E-08	2.08E-11	1.32E-09	3.49E-07	8.34E-10
Nitrous oxide (laughing gas)	2.96E-11	6.20E-19	0.00E+00	1.59E-13	3.99E-11	1.08E-08	0.00E+00
Sulfur dioxide	1.61E-09	1.26E-09	1.95E-08	7.69E-11	0.00E+00	4.75E-07	1.69E-09
Sulfur hexafluoride	3.04E-18	0.00E+00	0.00E+00	7.83E-21	0.00E+00	0.00E+00	0.00E+00
Methane	5.48E-09	3.75E-09	0.00E+00	1.88E-11	8.51E-10	1.58E-07	0.00E+00
Methane (biotic)	0.00E+00	0.00E+00	3.82E-10	0.00E+00	0.00E+00	0.00E+00	0.00E+00
VOC (unspecified)	5.74E-13	8.92E-12	9.43E-10	7.56E-15	2.31E-10	3.10E-08	0.00E+00
Particulate Matter, unspecified	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.45E-10	0.00E+00	0.00E+00
Dust (unspecified)	2.58E-11	0.00E+00	2.50E-08	3.40E-13	0.00E+00	5.00E-08	4.84E-10

Site Paving and Concrete

Concrete and asphalt material inputs for mine roads and modular buildings/storage facilities were estimated from data reported in two underground mine applications: Sugarcamp Energy, LLC mine (Sugarcamp mine) in Macedonia, Illinois, and Hillsboro Energy, LLC Deer Run Mine (Deer Run Mine) in Montgomery County, Illinois (DNR, 2008). The applications were chosen due to their proximity to the studied mine site. Based on the application for the Sugarcamp mine, approximately 719 acres of the total 1,264 acres at the mine site will be developed for use, whereas the application for the Deer Run Mine estimates that 638.5 acres of the total 803.5 acres at the mine site will be developed (DNR, 2008).

Concrete was needed to build the bases and roofs for office buildings and warehouses as well as tubes for coal storage. Although many more materials would be used in building construction, concrete was listed as a main component in the applications and was therefore the only material considered here. **Table A-5** lists the total amount of concrete specified for each function and mine site. It was assumed that when the applications refer to concrete measured in a yard (yd) it is a cubic yard, based on convention.

Table A-5: Concrete Amounts Specified in the Sugarcamp and Deer Run Mine Applications (DNR, 2008)

Concrete	Sugarcamp Mine Application #382 (pg 421-422)	Deer Run Mine Application #399 (pg 406-407)
Concrete Base (yds ³)	11	11
Concrete Tank (yds ³)	2,094	2,095
Concrete Tube (yds ³)	209	209
Concrete Roof (yds ³)	260	260
Concrete Tube (yds ³)	558	837
Concrete Roof (yds ³)	622	622
Total Concrete (yds ³)	3,754	4,034

A ratio of concrete to acres of developed land was calculated by dividing the total concrete used at each mine by total developed acres. Calculations are summarized in **Table A-6**. The acres developed for the study mine was estimated at 721, and the amount of concrete used for the study mine was converted to kg by dividing the total concrete amount (yds³ converted to ft³) by the weight of concrete, 145lb/ft³ and then multiplying by the pounds to kilogram conversion factor (Portland Cement Association, 2008). Concrete used for this study mine is equal to 7,391,888.4 kg (16,296,323 lb).

Table A-6: Data and Calculations for Concrete Needs during Mine Siting

Parameter	Amount	Reference
App. #382 Concrete, yds ³	3,754	Calculated (App #382)
App. #382 Acres Developed	719	Calculated (App #382)
App. #382 Total Concrete , yds ³ /acre	5.2	Calculated (App #382)
App. #399 Concrete, yds ³	4,034	Calculated (App #399)
App. #399 Acres Developed	639	Calculated (App #399)
App. #399 Total Concrete, yds ³ /acre	6.3	Calculated (App #399)
Average Concrete, yds ³ /acre	5.77	Calculated
Study Mine Acres Developed	721	Calculated ¹
Study Mine Concrete, yds ³	4,160	Calculated
Study Mine Concrete, kg (lbs)	7,391,888 (16,296,323)	Calculated

Road asphalt was used to create parking lots and roads. According to the mine applications used, roads are to be constructed of asphalt, however no specification of the asphalt used is given. For this reason, it is assumed that study mine roads are constructed out of asphalt concrete pavement. Roads are estimated to cover approximately 16 acres at the Sugarcamp mine and 46 acres at the Deer Run Mine (DNR, 2008). The estimated amount of road using asphalt, measured in acres, was divided by the total acres developed to give a percentage of asphalt per acre. The Sugarcamp mine had a percentage of asphalt equal to 2.23, while the Deer Run Mine had a percentage equal to 7.20. These were averaged together to give an asphalt percentage for this study of 4.71. To determine the amount of asphalt used in the construction of the roads the total developed acreage of the mine site, 721.43 acres, was multiplied by the study asphalt percentage of 4.71. The total asphalt used for this study mine equals 34 acres. The study mine asphalt amount was converted to square yards and then to cubic yards using the thickness of the road, two ft., stated in the mine applications (DNR, 2008a; DNR, 2008b). The total cubic yards for the study mine is 109,753, which translates to 2,963,338 ft³. According to the U.S. DOT Federal Highway Administration, asphalt concrete pavement has a total unit weight of 148 lb/ft³ (DOT, 2002). By multiplying the total cubic feet of concrete at the study mine by the total unit weight of asphalt concrete pavement, a total weight for the study mine asphalt is calculated as 198,933,861 kg (438,574,091 lb). Data and calculations are summarized in **Table A-7**.

¹ Study mine acres developed was based on the coal output of the Galatia Mine versus that of the source data (DNR applications). As these calculations were done at different times, this number is approximately 15 percent different than the acreage used to calculate land use change (based on satellite imagery).

Table A-7: Data and Calculations to Determine Asphalt Needs for Mine Roads and Parking Lots

Parameters	Amount	Reference
App. #382 Asphalt ,acres	16	App #382
App. #382 Acres Developed	719	Calculated (App #382)
App. #382 Percent Asphalt	2.23%	Calculated (App #382)
App. #399 Asphalt ,acres	46	App #399
App. #399 Acres Developed, acres	639	Calculated (App #399)
App. #399 Percent Asphalt	7.20%	Calculated (App #399)
Average Percent Asphalt	4.71%	Calculated
Study Mine Acres Developed	721	Calculated
Study Mine Asphalt ,acres	34	Calculated
Study Mine Asphalt, ft ³	2,963,338	Calculated
Study Mine Asphalt kg (lb)	198,933,861 (438,574,091)	Calculated

Coal Conveyor

A conveyor belt is needed to carry mined coal from an underground longwall mine operation to a coal stockpile on the surface. The conveyor is modeled after the slope conveyor at the Galatia Coal Mine in Galatia, Illinois. This conveyor is 1,554.48 m long and has a 1.2192 m wide steel-cord belt (Roberts & Schaefer, 2007). The belt has a useful life of approximately 20 years (Goodyear, 2008a). Major components of the conveyor belt system include the idler system (frame and brackets on which the belt is carried and the rotating parts [rollers] on which the belt travels), the drive and tail pulleys that move the belt, the steel cord inside the belt, and the rubber compound that surrounds the cord as well as providing a surface to carry the load.

The frame, bracket, and roller specifications for the idler system were all obtained from the Sandvik Mining and Construction Company (2004). There are two individual idler systems– the main idlers that carry the belt and the coal from the mine to the surface and a return idler system that loops below the idlers and carries the belt back to the underground mine. The main idler system modeled is a three-roll inline carry and impact system. The rollers are assumed to be manufactured from cold-rolled steel and have a diameter of 152 mm and a bearing size of 6306. The total main idler system weighs a combined 58.3 kg; the rotating parts make up 24.3 kg, while the frame and brackets (manufactured from galvanized steel) make up 34.0 kg (Sandvik, 2004). The main idler system was assumed to be spaced one meter apart along the entire length of the conveyor belt. The return idler system consists of a single roller manufactured from cold-rolled steel and the frame and brackets, manufactured from galvanized steel. The rollers are the same diameter and bearing size as those used in the main idler. The return idler system weighs 33.9 kg, with the rotating parts being 20.6 kg and the frame and brackets being 13.3 kg (Sandvik, 2004). The return idler systems are assumed to be spaced every three meters, running along the same path as the main idler systems. Based on these assumptions, the rotating parts weigh 6.87 kg/m and the frame and brackets weigh 4.43 kg/m.

This conveyor belt requires both a drive pulley to power the belt and a tail pulley for the belt to return to the mine to carry more coal to the surface. Both the drive and tail pulleys are assumed

to be constructed of 100 percent cold-rolled steel. The tail pulley has a weight of 1,023 kg, and the drive pulley weighs 1,044 kg (Sandvik, 2003).

Data for the conveyor belt itself was obtained using Goodyear's Flexsteel Conveyor Belt (Goodyear, 2008a). This belt consists of galvanized steel cords with a nominal 5.2 mm diameter. The cords run the entire length of the belt, spaced every 11.4 mm on center (Goodyear, 2008a). The cord design was based on seven thin steel cables grouped together; seven of these bundles are then wound together to form a 7×7 cord. Representative steel cord (or cable) specifications were obtained from two manufacturers (Lexco, 2006; Loos, 2006); the nearest representative cable diameter was 3/16 in., or approximately 4.76 mm. Each cord has a weight of approximately 9.23 kg/100 m, which was converted to 0.0923 kg/m (Lexco, 2006; Loos, 2006). Spread evenly over the entire 1.2192 m width of the belt, there will be 106 cords running the length of the belt. In order to get the weight of the steel cord per meter of belt, the weight of a single cord (0.0923 kg/m) was multiplied by the number of cords based on the belt width for a value of 9.78 kg/m.

To calculate the total weight of the belt one has to consider the insulating rubber surrounding the steel cords, a diagram of which is shown in Figure A-5: Flexsteel Belt Construction (Goodyear, 2008b) **Figure A-5** (Goodyear, 2008b). The top rubber cover is assumed to be 4.5 mm thick and the bottom cover 1.5 mm thick. The nominal diameter of the steel cables is 5.2 mm, for a total belt thickness of 11.2 mm. The belt weight is the cover weight (7.5 kg/m²) plus the carcass weight (14.6 kg/m²), which comes out to 22.1 kg/m² (Goodyear, 2008a). The weight of the belt was multiplied by the width of the belt, 1.2192 m, to obtain a value of 26.94 kg/m of belt. The weight of steel cord was subtracted from this value for a total of 17.16 kg of rubber per meter of belt.




Figure A-5: Flexsteel Belt Construction (Goodyear, 2008b)

In addition to the rubber, the following is a summary of the other material inputs described above. The materials manufactured from hot-dip galvanized steel include the steel cord, the idler frame and brackets, and the return idler frame and brackets. The steel cord weighs 9.78 kg/m, the idler frame 34 kg/m, and the return idler frame 4.43 kg/m. Summed, this gives a total of 48.21 kg/m of hot-dip galvanized steel. Cold-rolled steel was used for the idler and return idler rotating parts, the tail pulley, and the drive pulley. Since there is only one of each type of pulley, their weights will be added to the total cold-rolled steel value at the end of the calculations.

To finalize the conveyor belt calculations, the weight of each material was multiplied by the length of the belt to obtain a total weight. The belt has a given length of 1,554.48 m, which was doubled to 3,108.96 m to account for the fact that the belt actually makes a large loop to return to the underground mine. The total weight of rubber for the belt was 17.164 kg/m times 3,108.96

m, or 53,362.52 kg. The weight for hot-dip galvanized steel was 48.214 kg/m times 3,108.96 m, a total of 149,893.99 kg. The weight of cold-rolled steel was 31.17 kg/m times 3,108.96 m added to the weights of the drive and tail pulleys, for a total weight of 98,962.92 kg.

Stacker Reclaimer

A single stacker reclaimer (referred to as a stacker) was modeled, as it is used at the mine site to stockpile the coal coming off the coal conveyor; this coal is referred to as ROM coal. A coal stacker is a piece of equipment used to retrieve and form large piles of ROM coal prior to being fed to the coal sizing and cleaning stages. A stacker uses a boom, cantilever, and conveyor system for moving coal. It is assumed that the entire machine will be constructed from steel. The conveyor belt materials will be neglected because the belt itself makes up only a small fraction of the machine's total weight. The estimated weight of the stacker is 450,000 kg, based on weight specifications of the Xstrata Rolleston Coal Stacker (Gay, 2006).

Coal Crusher

The coal crushing facility is an above ground process that reduces the size of ROM coal. The coal is conveyed from the stacker into the crushing facility, at which point the size of the coal is reduced before sending it to the coal cleaning facility for further preparation. The coal crushing facility in this study is modeled after an Australian coal crushing facility (Leed, 2006). The crushing facility in Australia was constructed to incorporate a reinforced earth wall behind the primary crusher. Other operations included in the construction were secondary and tertiary crushing equipment, product screening and stockpiling operations, an ROM pad, conveyor footings, a fine sampling area, stair footings, a pedestrian bridge, and associated earthworks for concrete works. Material requirements for the Australian facility included 250 metric tonnes (275 short tons) of steel rebar and 1,500 m³ (53,000 ft³) of concrete.

The facility located at the Illinois based underground mine is assumed to use approximately the same amount of concrete and rebar to construct its facility. The concrete pad, assumed to be Portland cement, will be constructed to have a compression rating of 4,000 psi and an average density of 1,506 kg/m³. This density was multiplied by the volume of cement assumed (1,500 m³) to get an estimate of 2,259,000 kg of concrete for construction. Additionally, the weight of rebar was also converted to kg for a total of 250,000 kg (Leed, 2006).

It was assumed that a primary and secondary coal crusher would be operational within the crushing facility (two in total), based on the input sizes and the availability of model weights compared to the coal mine output. The primary coal crusher was modeled using Pennsylvania Crusher's Bradford Breaker model 14 ft.×28 in., which weighs approximately 182,200 lb (Penncrusher, 2009). The secondary crusher will be modeled after Pennsylvania Crusher's Reversible Impactor Model CA 10-60, and weighs approximately 106,000 lb (Penncrusher, 2008). Both of these crushers are manufactured from heavy duty steel plate. Combined, these crushers weigh 288,000 lb, which was then converted to 130,635 kg.

Coal Cleaning

This process encompasses all of the materials that are required in the construction of a steel building to be used to house coal cleaning equipment; a steel building with a reinforced concrete slab as a foundation. The concrete slab will also serve as the first floor of the building. Carbon steel I-beams (high-strength, low-alloy) will form the exterior frame of the building as well as

each of the other 5 floors, plus the roof (Saginaw, 2009). The walls and roof of the facility will be constructed out of zinc-galvanized steel panels (Bay Area Rapid Transit, 2004; Buildings Direct, 2009; Steel Building, 2009; Engineers Edge, 2009).

The exterior of the building will be 100 ft. long \times 60 ft. wide. Vertical I-beams will be spaced every 20 ft. along all four walls. Horizontal I-beams will form the floors from the second level up to and including the roof (six total levels). Each level will be 14 ft. tall, for a total building height of 84 ft. The I-beams for the floor will be spaced every 20 ft., running horizontally both the length and width of the building. The weight of the steel for the I-beams will be determined by taking the average of four beams with a depth of 12 inches (in.). A cross-sectional diagram of the style of I-beam can be seen in **Figure A-6**.




Figure A-6: Cross-sectional Diagram of an I-beam

The exterior of the building, all four walls and the roof, will be clad in 26-gauge zinc-galvanized carbon steel panels (Buildings Direct, 2009; Engineers Edge, 2009; Steel Building, 2009). The zinc is a layer with a volume of approximately 1.25 ounces per square ft (oz/ft^2) of steel panel (Bay Area Rapid Transit, 2004).

The foundation of the building, which will also serve as the ground floor, will be constructed using a 4,000 psi mix of concrete. The concrete foundation will be reinforced by size #4 carbon steel rebar running horizontally over both the length and the width of the concrete. The rebar will be evenly spaced every 12 in. in both directions, and has a cross-sectional area of 0.20 in^2 (CRSI, 2008). The perimeter of the slab must be located below the frost line, which is located 21 in. below ground level at the mine location (Weather Bureau, 2008). The exterior of the concrete slab will extend an additional 6 in. below the frost line and will be 18 in. thick around the perimeter. The interior of the concrete slab will be 1 in. thick.

The flooring for each level of the building is assumed to consist of steel grating. This weight is excluded from these calculations due to the assumption they will be balanced by the sections of the interior I-beams that will be removed for stairways and to accommodate large pieces of equipment.

The weight of each material used in the coal cleaning facility was calculated separately. The materials were cold-rolled steel for the I-beams and the exterior paneling, zinc for the galvanization of the paneling, rebar for reinforcing the concrete foundation, and concrete for the building foundation.

Rebar will be spaced evenly every 12 in. along the width and length of the concrete foundation. Since the foundation will only be 12 in. thick, there will be only once grid-like layer of rebar.

There will be 58 bars running the length of the foundation and 98 running the width because in each case, the first bar will be laid 12 in. in from the perimeter of the concrete. There will be a total length of 11,680 ft. of rebar, all with a nominal area of 0.20 in² (CRSI, 2008). Multiplying these two values gives a total volume of 15.9 ft³ of rebar. Basic cold-rolled steel has a density of 0.284 lb/in³ (Metal Suppliers Online, 2009), which calculates to a total rebar mass of 7,816 lb. required for this building.

The exterior portion of the concrete foundation is 100 ft. long × 60 ft. wide by 18 in. thick, and extends 27 in. into the ground. Converting these values to feet and multiplying to account for all four sides of the building gives a total of 1,080 ft³ of concrete for the exterior foundation. The volume of concrete required for the remaining interior foundation was calculated by multiplying the length of the foundation, minus the 18 in. width of the exterior, by the width of the foundation, minus the 18 in. width of the exterior, and the thickness (12 in.) of the interior concrete slab. This value, 5,762 ft³, was added to the exterior volume for a total volume for the foundation of 6,842.25 ft³. The volume of the rebar above was subtracted from the total volume of the foundation to determine the actual volume of concrete in the foundation, which comes out to be 6,826 ft³. Multiplied by the density of 4,000 psi concrete, 145 lb/ft³, gives a total weight of 989,817 lb.

The exterior framework of the building is constructed of vertical I-beams spaced every 20 ft. along all four sides. Each beam is 84 ft. tall. The weight per foot of beam was calculated by taking the average weight of four 12 in. deep I-beams. This average weight was calculated as 39.40 lb/ft (Saginaw, 2009). Both the front and rear walls will consist of six vertical beams, for a total weight of 19,857.60 lb. for each side. Each side wall has four vertical beams, but the outer ones have already been accounted for in the calculations of the front and rear walls. Taking the average beam weight of 39.4 lb/ft. times the 84 ft. height of each beam gives a total of 6,619 lb. for each side wall. Combining the calculations for the front, back, left, and right walls gives a combined total of 52,954 lb. of cold-rolled steel for the building's I-beams.

The I-beams that will form the basis for each level within the building were calculated in a fashion similar to that of the exterior framework. Each floor consists of four 100-ft. long beams and six 60-ft. long beams. The average weight of these beams is 39.4 lb/ft (Saginaw, 2008). The four 100-ft. long beams weigh a total of 15,760 lb., while the six 60-ft. long beams weigh 14,184 lb.; combined, the I-beams for each level consist of 29,944 lb. of cold-rolled steel. The weight for each level is multiplied by six because there are six levels of horizontal I-beams in the building. The total weight for these I-beams is 179,664 lb.

The steel panels for the exterior covering of the building consists of 26-gauge galvanized steel sheets (Buildings Direct, 2009; Steel Building, 2009), which are 0.0179 in. thick (Engineers Edge, 2009). The total surface area to be covered was calculated by multiplying the area of the large sides of the building (100 ft. long by 84 ft. high) by two, multiplying the area of the smaller sides (60 ft. long by 84 ft. high) by two, and adding both to the area of the roof (100 ft. long by 60 ft. wide). The result was 32,880 ft², which when multiplied by the thickness of the steel sheets gives a volume of 49.05 ft³, the amount of steel for the paneling. The volume was converted to cubic inches and then multiplied by the density of cold-rolled steel, 0.284 lb/in³ (Metal Suppliers Online, 2009). The weight of cold-rolled steel for the panels is 24,069 lb.

The final material for the coal cleaning facility construction is the zinc for galvanization of the steel panels. This coating is 1.25 oz/ft² thick (Bay Area Rapid Transit, 2004). The coating

thickness was multiplied by the total surface area of the building, 32,880.00 ft², for a total of 41,100 oz of zinc. Adding the weight of the steel panels and the zinc results in a galvanized steel weight of 26,638 lb.

The final step was to convert the weights of each material to kilograms. Cold-rolled steel was used in the I-beams for the framework of the building, the I-beams for each floor. The I-beams weighed 105,514 kg. The galvanized steel panels weighed 1,2083 kg. The rebar for reinforcing the concrete foundation weighed 3,545 kg. Finally, the concrete for the foundation itself weighed 448,973 kg.

Coal Loading Silo

This process encompasses the total amount of steel necessary to construct a silo that stores the coal ready to be loaded into rail cars for transportation to the power generation facility. The silo is assumed to be constructed entirely of cold-rolled steel. When an empty unit train arrives to be loaded, a chute on the bottom of the silo is opened, releasing the coal to fill the rail car. The silo was modeled after an advertisement for a raw coal silo manufactured by George Third & Sons (George Third & Son, 2006). After unit conversion and scaling to match Galatia Mine's estimated average operational output, the silo was assumed to be 24.38 meters (m) high, 12.19 m in diameter, and weighed 294.84 tonnes (empty), which is the weight of cold-rolled steel for construction of the silo (George Third & Son, 2006).

Wastewater Treatment Facility Construction

The wastewater treatment facility for the study consists of a series of sedimentation ponds that receive stormwater flows from coal storage areas, refuse storage areas, and other surface operations across the mine site. The wastewater treatment facility does not receive discharge water from the coal mine or the coal cleaning process. Note that water treatment for the coal cleaning process consists of a slurry cell that is used to facilitate re-use of water within the coal cleaning cycle; no discharge from the slurry cell occurs. Characteristics of the wastewater treatment facility, including sizing of sediment ponds and details about their operation, were gathered from documentation for a proposed expansion of Deer Run Mine (Hillsboro Energy, 2007; DNR, 2008). To ensure that these assumptions were reasonable, they were cross-checked with the Galatia Mine staff and revised as needed.

The wastewater treatment facility includes approximately 15 acres of storm water retention ponds. These ponds are lined using compacted sediments, which were assumed to be present on site. Water flow into and out of ponds is facilitated by a series of earthen channels/drainages, as well as PVC piping with associated pumps and cement lined outfall/discharge structures.

Pumps and Pipes

Pumps are required to convey a portion of the flow into and out of the water treatment facility. For the purposes of this study, it was assumed that 20 percent of maximum stormwater flows would require pumps, and scaled pump installation to that amount. This resulted in a maximum pump capacity requirement of 169,927 gallons per minute (gpm). Assuming that this flow would be carried using 5,000-gpm pumps, a total of 34 pumps would be necessary to convey maximum storm flow.

Data for the weight and materials used for a pump were taken from manufacturer literature (Power Prime Pumps, 2008). The weight of a representative pump was obtained from a table listing the weights of various pumps, and a skid assembly of 7,900 lb was used from a 5,000 gpm DV-300 pump. Each pump was constructed of 316 stainless steel (impeller and wear plates), 431 stainless steel (shaft), cast iron (much of the body and framework), and hot-dip galvanized steel (skid). Based on schematics, it was estimated that each pump would include, by weight, 10 percent 316 stainless steel, 10 percent 431 stainless steel, 50 percent cast iron, and 30 percent hot-dip galvanized steel. Using the pump weight of 7,900 lb, each pump would include 790 lb of both 316 and 431 stainless steel, 3,950 lb of cast iron, and 2,370 lb of hot-dip galvanized steel. Multiplying by 34 pumps and converting to kilograms gives a total of 12,178.3 kg of 316 stainless steel, 12,178.3 kg of 431 stainless steel, 60,891.5 kg of cast iron, and 36,534.9 kg of hot-dip galvanized steel.

Pumped flows would be conveyed within either 4 in. or 8 in. PVC pipes. Based on the design of the Deer Run facility and anticipated proximity to stockpile areas, we estimate that a total of 8,500 ft of 4 in. and 3,500 ft of 8 in. schedule 80 PVC pipe would be required. Each diameter pipe was multiplied by the weight of PVC per 100 ft. (275 lb/100 ft for the 4 in., 805 lb/100 ft for the 8 in.) and then converted to kilograms. This would result in a mass of 10,603 kg of 4 in. pipe and 12,780 kg of 8 in. pipe, for a total of 23,383 kg of PVC required.

Cement Structures

Based on the design of the Deer Run facility, cement would be used for water flow dissipating structures and for a limited amount of canal lining. Based on 12,500 ft² of cement at an average thickness of 1.5 ft., it is estimated that 18,750 ft³ of cement would be required. Assuming a density of 94 lbs/ft³ for Portland cement, 799 tonnes of cement was calculated.

Wiring

Wiring will be used primarily to supply electricity to pumps, although we also assume that wiring would supply minor additional loads such as facility lighting. It was assumed that operations for the facility would be housed separately, with operations for the remainder of the mine. Wiring lengths were calculated based upon the design of the Deer Run facility and the anticipated proximity of stockpile areas to the treatment facility (Hillsboro Energy, 2007). here were calculated to be 12,000 total ft. of piping, so the length of wire necessary to power the pumps was assumed to be half of the required length of pipeline, or 6,000 ft. An additional 20 percent of total wire length was included in the assumed value to support lights and other auxiliary uses. The 20 percent was rationed 20/80 into two wiring types – 2-strand gauge 1 wire (e.g. gauge 1 / 2) and gauge 12 / 3, respectively. Herein, 6,000 ft of gauge 1 / 2 wire would be required for pumps, 240 ft for auxiliary wiring, and an additional 960 ft of gauge 12 / 3 wire for auxiliary wiring. The gauge 1 / 2 wire has a length of 3.947 ft. per pound of wire (ft/lb) per strand, while gauge 12 / 3 wire is 50.59 ft/lb (Davis, 2007). Each wire was divided by its length per pound and then multiplied by the number of strands in the wire. After conversion to kilograms, this gives 1,379 kg of gauge 1 / 2 wire for the main pump wiring, 55 kg of 1 / 2 wire for auxiliary wiring, and 26 kg of 12 / 3 wire for auxiliary wiring. Since all wiring is assumed to be copper, a total mass of approximately 1,460 kilograms was calculated.

Other Materials

Clay/sediment lining would be required for the proposed sedimentation ponds. It was assumed that these materials would be available on site, and could be recycled from the pond-digging process. It was further assumed that remaining spoils from pond construction would be used as berms around the ponds to provide flood flow protection, or for grading and fill purposes during construction of other facilities at the mine site.

Final Totals

In total, for the construction of the waste water treatment plant, there will be:

- 12,178.3 kg of 316 stainless steel.
- 12,178.3 kg of 431 stainless steel (represented in GaBi as stainless steel cold roll).
- 60,891.5 kg of cast iron.
- 36,534.9 kg of hot-dip galvanized steel.
- 23,383.0 kg of polyvinylchloride piping.
- 799,456.6 kg of Portland cement.
- 1,460.0 kg of copper.

Continuous Miner

The construction of a single continuous miner was based on specifications for the size and weight of continuous miners from the Bucyrus International company (Bucyrus, 2008). According to the Illinois DNR, the Galatia Mine coal seam thickness for ranges from 84 to 108 inches (DNR, 2006). Based on this information, the 25M-2 Bucyrus Continuous Miner was selected as the reference model because it can operate in seam heights of between 44 and 114 inches (Bucyrus, 2008).

This model has a weight of 56.7 tonnes (Bucyrus, 2008). This value was converted to 56,700 kg. According to page four of the brochure, under the heading “Weight,” the main frame of the miner is constructed from a thick steel plate. Steel is assumed to account for the majority of the weight of the continuous minor.

The hydraulic fluid and cutting head’s teeth (tungsten carbide steel) will last the entire life of the continuous miner’s operational life (will change upon more information or consideration). As delivered to the mine site, a continuous miner includes hydraulic fluid and cutting teeth. These two components are part of the entire construction weight; however, material profiles for hydraulic fluid and tungsten carbide steel are not included in this unit process. Other material components of the continuous miner are assumed to have a negligible contribution to the LC burdens of the continuous miner and are thus not included in this unit process.

Longwall Miner

The complete longwall mining system includes the shear head, roof supports, armored force conveyor, stage loader, and mobile belt tailpiece. The longwall system includes a specific number of roof supports depending on the length of the roof support shields. The roof supports

include the stage loader, armored force conveyor, and the mobile belt piece. The shear head is then connected to the roof supports to operate on the track system that is also part of the roof support system.

All components of the longwall miner system are assumed to be constructed from steel plates. The weight of each component, except for the shields, was taken from e-mail communication with Cas Bruniany of Joy Mining Machinery (Joy Mining Machinery, 2008). The weights were:

- Shearer – 50 to 75 tons.
- Armored Face Conveyor.
 - Head Drive – 60 to 70 tons.
 - Tail Drive – 40 to 50 tons.
 - Line Pans – 2.5 tons each.
 - Stage Loader – 80 to 100 tons.

Also according to Bruniany, the expected lifetime of these pieces of equipment is between ten and fifteen years.

The weights of the shields were determined to be 28.2 short tons (Bryja, Conklin et al., 2004). The weight of each component was averaged between the minimum and maximum values to get values of 62.5 tons for the shearer, 28.2 tons for the shields, 65.0 tons for the head drive, 45.0 tons for the tail drive, 2.5 tons for the line pans, and 90.0 tons for the stage loader.

There is one of each component in the longwall miner system except for the shields and line pans. It is assumed that the face of the longwall mine is 1,000 ft. long. The number of shields and line pans for the mine is 176 each (Joy Mining Machinery, 2008). This value was taken from a longwall mine installation that commenced production in 2007. The mine face at the representative mine is 1,000 ft. long, therefore, our mine face is assumed to use the same number of shields and line pans. This gives a total weight for the shields of 4,963.2 tons and 440.0 tons for the line pans.

All of the various longwall miner system components added together give a total weight of 5,665.7 short tons. This value was converted to 5,139,836.58 kg. This is the total weight of steel plate that is necessary to construct the longwall miner system.

Shuttle Car

This process encompasses the materials that are used in the construction of one shuttle car to be used to haul coal from the working mine face to the conveyor belt. Data for the shuttle car was taken from the Phillips Machine Service Manufacture for Shuttle Car models FC12, FC16, FC20, and FC25 (Phillips Machine Service, 2007). The shuttle car is assumed to consist of steel, with only negligible amounts of rubber for the four tires. These cars are powered by batteries that run motors for the pump, conveyor system, and traction systems and can handle payloads up to 19 metric tonnes. Batteries for the car were not separated from the overall weight of the car and, as a result, battery weight is included in the total weight of steel required for the shuttle car. This is a data limitation. The weights of four different sizes of shuttle cars from Phillips Machine Service were obtained and averaged. The cars ranged in capacity from 7.2 cubic meters to 16.1 cubic meters. Each car has an empty weight between 24.5 and 32.7 metric tonnes. These

minimum and maximum values were averaged to calculate an average of 28.6 metric tonnes, the empty weight of a single shuttle car.

Continuous Miner, Longwall Miner, and Shuttle Car Replacement

The number of each piece of equipment was based on information for the Galatia Mine; according to the Illinois DNR, there are nine continuous miners and three longwall miner units in the representative mine (DNR, 2006). The conveyor system was modeled after the 5,100-ft. long slope conveyor at Galatia, so there is only one of them constructed (Roberts & Schaefer Company, 2007). Finally, it was assumed that there is a two-to-one ratio of shuttle cars to continuous miners, for a total of 18 shuttle cars.

The second part of the assembly of the underground coal mine was estimating the expected lifetime of each pieces of equipment. The lifetime of the continuous miner and longwall miner unit was estimated using information obtained via personal communication with Cas Bruniany (Bruniany, 2008). The expected lifetime for both of these pieces of equipment is 15 years. In a document for their Flexsteel conveyor system, Goodyear states that their belts are expected to last for 20 years (Goodyear, 2008b). Finally, the shuttle cars have an estimated lifetime of 12 years (Australian Taxation Office, 2008).

Based on a study period of 30 years, the continuous miners and longwall miner units have a replacement rate of 2.0, the conveyor system 1.5, and the shuttle cars 2.5.

A.1.1.4 Operation Assumptions

This process covers the energy needs and emissions associated with the production of coal during operation of the coal mine, from resource extraction through the boundary for LC Stage #2; again, all data inputs for this stage were based on the reference flow of 1 kg of fully processed (output) coal over the 30-year study lifetime. Considered are the consumption of electricity, consumption of diesel, emissions of CH₄ associated with off-gassing from the coal/coal mine, PM emissions associated with fugitive coal dust, water input flows required for mining and cleaning operations, wastewater flows, and emissions of criteria air pollutants, as well as emissions of Hg and NH₃.

Operations of the coal mine were based on operation of the Galatia Mine, which is operated by the American Coal Company and located in Saline County, Illinois. Sources reviewed in support of coal mine operations include Galatia Mine production rates, electricity usage, particulate emissions, CH₄ emissions, wastewater discharge permit monitoring reports, and communications with Galatia Mine staff. When data from the Galatia Mine were not available, surrogate data were taken from other underground mines, as relevant.

Electricity is the main source of energy for coal mine operations, and use for this model was estimated based on previous estimates made by EPA for electricity use for underground mining and coal cleaning at the Galatia Mine (EPA, 2008d). The LC profile for electricity use is based on eGRID2007. The Emissions and Generation Resource Integrated Database (eGRID) is a comprehensive inventory of environmental attributes for electric power systems; the current version of eGRID was updated in January 2009 and is based on 2005 data (EPA, 2009). Although no data were found that estimated the diesel fuel used during mining operations, it was assumed that some diesel would be used to operate trucks for moving materials, workers, and

other secondary on-site operations. Therefore, diesel use was estimated for the Galatia Mine from 2002 U.S. Census data for bituminous coal underground mining operations and associated cleaning operations (U.S. Department of Commerce, 2004).

Emissions of criteria pollutants were based on emissions associated with the use of diesel. EPA Tier 4 diesel standards for non-road diesel engines were used, since these standards would go into effect within a couple years of commissioning of the mine for this study (EPA, 2004). Diesel is assumed to be ULSD (15 ppm sulfur). Emissions of Hg and NH₃ from diesel combustion were estimated from other sources and calculated in the same fashion as for diesel used during commissioning (Battye, Battye et al., 1994; Conaway, Mason et al., 2005).

In addition to combustion, other sources of PM and CH₄ existed during coal mine operations. PM emission inventory includes those due to the combustion of diesel, as well as fugitive coal dust from the mining process. Total coal dust emissions from the Galatia Mine were used based on EPA (2005) data for the mine, and were normalized to the reference flow (EPA, 2005b). Coal mining accounts for approximately 30 percent of CH₄ emissions in the United States, with underground mines contributing the largest share (EPA, 2008e). During coal acquisition, CH₄ is released during both the underground coal extraction and the post-mining coal preparation activities. From the EPA inventory of GHG emissions from 1990 through 2006, 90 percent of CH₄ emitted from underground mining was a result of coal extraction, while the remaining 10 percent was emitted during post-mining activities (EPA, 2008e). An average of CH₄ emission estimates for the Galatia Mine (EPA, 2008d) were added to CH₄ combustion emissions for this process. Due to the uncertainty in CH₄ emission estimates, the large global warming potential (GWP) of CH₄, and the ability to capture and use or sell CH₄ for on-site energy, the amount of CH₄ released is included as an adjustable parameter in this process. Sensitivity analysis results are included and discussed in the main report text.

Water use was estimated by Galatia Mine staff (Personal Communication 2009), and wastewater data were taken from available National Pollutant Discharge Elimination System permit reporting documentation for Galatia Mine from 2005-2008 (EPA, 2008c). **Figure A-5** shows the third level GaBi plan view for energy inputs during coal mine operations; water used in coal mining is assumed to be resource (ground or surface water). It is not specifically tracked in GaBi and therefore is not included in the plan. **Table A-8** shows the total GaBi emission outputs for coal mine operation and the additional life cycle emissions associated with electricity and diesel production.




Figure A-7: Coal Mine Operations Fuel Inputs

Table A-8: GaBi Air Emissions for Coal Mine Operations, Electricity, and Diesel Use, kg/kg Coal Ready for Transport

Emissions (kg/kg coal ready to transport)	Total	SERC Power Grid Mix 2005 (USEPA, eGRID2007)	Coal Mining Operation (Illinois No 6)	Diesel at refinery PE
Lead	3.29E-10	3.24E-10	0.00E+00	4.89E-12
Mercury	9.18E-11	9.14E-11	4.08E-14	4.14E-13
Ammonia	6.60E-08	3.12E-08	3.40E-08	7.23E-10
Carbon dioxide	7.45E-03	6.51E-03	8.29E-04	1.08E-04
Carbon monoxide	7.29E-06	2.69E-06	4.44E-06	1.58E-07
Nitrogen oxides	1.35E-05	1.26E-05	5.10E-07	3.36E-07
Nitrous oxide (laughing gas)	1.09E-07	8.62E-08	2.13E-08	1.85E-09
Sulfur dioxide	3.74E-05	3.69E-05	0.00E+00	4.34E-07
Sulfur hexafluoride	4.48E-14	4.44E-14	0.00E+00	4.12E-16
Methane	7.57E-03	7.14E-06	7.56E-03	1.12E-06
Methane (biotic)	0.00E+00	0.00E+00	0.00E+00	0.00E+00
VOC (unspecified)	2.39E-07	9.08E-10	2.38E-07	4.68E-10
Particulate Matter, unspecified	1.27E-06	0.00E+00	1.27E-06	0.00E+00
Dust (unspecified)	7.07E-07	7.01E-07	0.00E+00	6.39E-09

A.1.2 Life Cycle Stage #2: Raw Material Transport – Coal Transport

In Stage #2 it was assumed that the mined coal was transported by rail from the coal mine in southern Illinois to the energy conversions facility located in southeastern Illinois, an assumed distance of 205 miles. For this study, a unit train is defined as one locomotive pulling 100

railcars loaded with coal; the locomotive is powered by a 4,400 horsepower diesel engine (General Electric, 2008) and each car has a 91 tonne (100-ton) coal capacity (NETL, 2010).

A.1.2.1 GaBi Plan

Figure A-8 shows the second level plan for this stage. Commissioning /decommissioning is not included in this stage; it can be assumed that the energy used to commission the rail line, unit train, or locomotive would be included in the LC profile of the materials. The reference flow of this stage is 1 kg of transported coal (coal cargo). Several adjustable parameters are listed here for consideration during sensitivity analysis; below the plan is a screen shoot highlighted the adjustable parameters listed.




Figure A-8: Second Level GaBi Plan: Stage #2 Train Transport

A.1.2.2 Construction Assumptions

Figure A-9 shows the third level plan for train construction. For this study, a unit train consists of 100 rail cars and five locomotives. **Table A-9** shows the total GaBi air emission outputs for Stage #2 construction and the additional life cycle emission profiles of material inputs for this stage, all on a kg/kg coal delivered to the plant basis.




Figure A-9: GaBi Plan for Train Construction

Table A-9: GaBi Air Emission Outputs for Stage #2 Construction and Material Inputs, kg/kg Coal Delivered

Emissions (kg/kg coal delivered)	Total	Aluminum sheet PE [pl]	Steel Plate, BF, Manufacture	Steel, Stainless, 316 2B, 80% Recycled
Lead	1.88E-10	8.24E-11	1.06E-10	0.00E+00
Mercury	1.33E-11	6.67E-12	6.65E-12	0.00E+00
Ammonia	1.91E-09	1.91E-09	0.00E+00	0.00E+00
Carbon dioxide	5.88E-04	5.12E-04	5.34E-05	2.20E-05
Carbon monoxide	4.91E-06	4.42E-06	4.51E-07	3.94E-08
Nitrogen oxides	1.04E-06	8.99E-07	8.95E-08	5.00E-08
Nitrous oxide (laughing gas)	1.16E-08	8.87E-09	2.78E-09	0.00E+00
Sulfur dioxide	3.06E-06	2.83E-06	1.22E-07	1.01E-07
Sulfur hexafluoride	5.20E-14	5.20E-14	0.00E+00	0.00E+00
Methane	8.81E-07	8.41E-07	4.05E-08	0.00E+00
Methane (biotic)	0.00E+00	0.00E+00	0.00E+00	0.00E+00
VOC (unspecified)	2.82E-08	2.03E-08	7.95E-09	0.00E+00
Particulate Matter, unspecified	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Dust (unspecified)	9.11E-07	8.69E-07	1.28E-08	2.90E-08

The total number of railcars, 100, was defined by the Baseline Report (NETL, 2010). The weight for one empty railcar was estimated based on the average of two different railcars based on manufacturer information; the FreightCar America’s BethGon II railcar and Trinity Rail’s 4,402 cubic foot aluminum rotary Gondola railcar (FreightCar America, 2008; Trinity Rail, 2008). The

BethGon II weighed 18,915 kg (41,700lbs), while the Gondola weighs 19,051kg (42,000 lbs) (FreightCar America, 2008; Trinity Rail, 2008). This translates to an average empty railcar weight of 18,983 kg (41,850 lbs). According to the Baseline Report, one railcar has the capacity to carry 100 tons or 90,718 kg (200,000 lbs) of coal (NETL, 2010). The total weight of the one loaded railcar loaded is equal to 109,701 kg (241,850 lbs) or 110 tonnes (121 tons).

To calculate the number of locomotives needed to pull 100 loaded railcars, the total horsepower (hp) needed to move all the railcars was determined by inputting the total loaded weight of 100 cars into a correlation equation developed for the California Energy Commission (TIAX LLC, 2007). The equation is shown in **Figure A-10**. It was calculated that in order to pull 100 railcars, weighing a total 10,970 tonnes (12,093 tons), 21,310 of horsepower was needed. One locomotive has a horsepower of 4,400 (General Electric, 2008); therefore in order to match the horsepower needed it was calculated that 5 locomotives would be needed to pull 100 loaded railcars.




Figure A-10: Train Load and Locomotive Power Relationship (TIAX LLC, 2007)

A locomotive is estimated to have a useful life of approximately 20 years depending upon maintenance and operation (GE Transportation, 2009). The railcars are estimated to have a lifetime of 30 years (Department of Transport [UK], 2009); because this is the same as the study lifetime no railcar replacements will be needed. However, because locomotives have a lifetime shorter than that of the plant, a replacement set will be constructed and will replace the original five locomotives 20 years into the lifetime of the plant. It was calculated that each locomotive being used will be replaced once, making it necessary to use 10 locomotives over the life of the plant. However, because the second set of locomotives will only be used for half of their overall lifetime, it was calculated that only 7.5 equivalent locomotives will be needed over the assumed lifetime of the plant. **Table A-10** summarizes the data and calculations.

Table A-10: Railcar and Locomotives Needed over the Lifetime of the Energy Conversion Facility

Parameters	Value	Reference
Number of Railcars	100	NETL 2007
Weight of One Loaded Railcar Tonnes (Tons)	110 (121)	FreightCar America 2008 Trinity Rail 2008
Weight of 100-Cars Tonnes (Tons)	10,970 (12,093)	Calculated
Total HP Required to Pull 100 Cars	21,310	Calculated (TIAX LLC, 2007)
Locomotive Horsepower	4,400	GE Transportation 2008
Estimated Number of Locomotives ¹	5	Calculated
Locomotive Estimated Lifetime (Years)	20	GE Transportation 2009
Railcar Estimated Lifetime (Years)	30	(Department of Transport [UK], 2009)
Assumed Plant Lifetime (Years)	30	NETL 2007
Sets of Locomotives Needed Over Plant Lifetime ²	1.5	Calculated
Sets of Railcars Needed Over Plant Lifetime ²	1	Calculated
Total Number of Locomotives Needed ³	7.5	Calculated
Total Number of Railcars Needed ³	100	Calculated

¹ Rounded up to the nearest whole number.

² One set of locomotives is equal to the number of locomotives needed to pull the 100 railcars. In this case, it is 5 locomotives per set. One set of railcars is equal to 100 railcars.

³ Total number needed over the lifetime of the Energy Conversion Facility.

The round-trip mine-to-plant miles is an adjustable parameter used to determine how many unit trains are necessary; this value is adjusted during the sensitivity analysis to assess the influence transport distance has on the overall LC. Data for the amount of time it takes a coal unit train to get loaded, travel to the energy conversion facility, unload, and return to the coal mine were calculated using weekly performance statistics from six major North American rail companies (BNSF Railway Company, Canadian Pacific et al., 2009). Based on data for each company from the first quarter of 2008, it was determined that the average speed of coal unit trains was approximately 20 mph. Using dwell time data from the same source, it was determined that unit trains dwell for approximately 24 hours (BNSF Railway Company, Canadian Pacific et al., 2009); where it was assumed that the dwell time was the amount of time the train spends being loaded or unloaded. By dividing the round-trip distance by the average speed and adding that to the loading and unloading times, the total amount of time for a single trip was calculated.

In order to put the construction of the locomotives and railcars on a per kg of coal basis, the total amount of coal that can be transported by a single unit train over the lifetime of the plant had to be determined. By multiplying the number of hours in 30 years (the lifetime of the plant) by the capacity of a unit train, and dividing by the number of hours in a single trip, that amount is calculated.

The final step in this process is calculating the number of locomotives and railcars necessary to transport one kg of coal 205 miles round-trip, over the lifetime of the plant. This was done by multiplying the number of locomotives (or railcars) by the locomotive (or railcar) replacement rates to get a total number of locomotives (or railcars) over the life of the plant, and dividing that value by the amount of coal transported over 30 years by a unit train. For the SCPC cases, the

values are 3.24×10^{-10} locomotives/kg transported coal and 4.47×10^{-09} railcars/kg transported coal.

A railcar was assumed to be manufactured from steel and aluminum. Using data from Amsted Rail, it was calculated that steel accounts for approximately 35 percent of the total weight; therefore it was assumed that 65 percent was manufactured from aluminum (Amsted Rail, 2008). Lacking specific data, the locomotive was considered to be manufactured from 10 percent stainless steel and 90 percent carbon steel.

A.1.2.3 Operation Assumptions

The scope of this process covers rail transport of coal in the United States, and estimates criteria pollutant emissions, CO₂ emissions, and fugitive dust emissions on the basis of 1 kg of coal being transported along a user-defined distance (205 miles for the SCPC case). The calculation assumes that backhaul and fronthaul have the same energy intensity and emission profile. The diesel locomotive, which would operate from 2010 to 2040, is assumed to meet the emission standards EPA's Tier 4 emissions criteria for the duration of the 30 year period. Note that the Tier 4 emissions standards are set to become effective in 2015. Accordingly, diesel consumed by the train is assumed to be ULSD, with a sulfur content of 15 parts per million.

The energy requirement/diesel consumption factor used for the diesel locomotive was taken from US Bureau of Transportation statistics for 2008, which includes energy intensity data for railroad freight service (DOT, 2008). Emission factors were taken from EPA's Tier 4 standard for diesel locomotive engines, for NO_x, PM, VOCs, and CO (EPA, 2008b). Emission factors for CO₂, CH₄, and N₂O were taken from the national emissions inventory (EPA, 2005b). SO₂ emissions are calculated based on the sulfur content of ULSD, and assuming complete stoichiometric conversion from S to SO₂ during diesel combustion.

Fugitive coal dust emissions are based on a study of Australian coal mine transport in Queensland, Australia (Cornell Hatch, 2008). Therein, fugitive coal dust emissions were quantified on a per metric tonne basis over distances ranging from approximately 125 to 500 km. Fugitive coal dust emissions were then normalized to a basis of kg coal dust emissions per kg-km of coal transport, and incorporated into the DS sheet calculations.

The amount of Hg released as a result of the combustion of diesel was based on information from a study examining gasoline and diesel fuel combustion in the San Francisco Bay area of California (Conaway, Mason et al., 2005). An emission factor for NH₃ from the combustion of diesel from mobile sources was obtained from a report that developed emission factors for various sources of NH₃ (Battye, Battye et al., 1994). The GaBi plan for train transport operation is located in **Figure A-11**, with 1 kg representing 1 kg of processed coal from the mine. **Table A-11** shows the GaBi air emission outputs due to Stage #2 operations.




Figure A-11: GaBi Plan for the Operation of a Unit Train

Table A-11: GaBi Air Emission Outputs and Profiles for Stage #2 Operations, kg/kg Coal Delivered to the Plant

Emissions (kg/kg coal delivered)	Total	Diesel at refinery PE	Transport of Coal Via Train
Lead	6.39E-11	6.39E-11	0.00E+00
Mercury	5.95E-12	5.41E-12	5.33E-13
Ammonia	4.54E-07	9.45E-09	4.45E-07
Carbon dioxide	1.23E-02	1.41E-03	1.08E-02
Carbon monoxide	3.54E-05	2.06E-06	3.33E-05
Nitrogen oxides	3.33E-05	4.39E-06	2.89E-05
Nitrous oxide (laughing gas)	2.42E-08	2.42E-08	0.00E+00
Sulfur dioxide	5.77E-06	5.67E-06	1.02E-07
Sulfur hexafluoride	5.38E-15	5.38E-15	0.00E+00
Methane	1.55E-05	1.47E-05	8.55E-07
Methane (biotic)	0.00E+00	0.00E+00	0.00E+00
VOC (unspecified)	3.12E-06	6.12E-09	3.11E-06
Particulate Matter, unspecified	4.12E-05	0.00E+00	4.12E-05
Dust (unspecified)	8.36E-08	8.36E-08	0.00E+00

A.1.3 Life Cycle Stage #3: SCPC Energy Conversion Facility without CCS

Stage #3 includes the commissioning, construction, operation, and decommissioning of a 550-MWe net output SCPC plant without CCS; most data for this stage were taken from the Baseline Report (NETL, 2010).

A.1.3.1 GaBi Plan

Figure A-12 defines the second level GaBi plan for the SCPC case without CCS. This plan is based on a reference flow of 1 MW electricity output over the 30-year study lifetime.




Figure A-12: GaBi Plan for SCPC Case without CCS

A.1.3.2 Commissioning, Installation, and Decommissioning Assumptions

The energy and water used and emissions associated with the installation and deinstallation of a power plant are dominated by the use of diesel fuel to power construction equipment. Data for the installation of a power plant came from the Russell City Energy Center Application for Certification to the California Energy Commission (Calpine/Bechtel, 2001). The application was for the proposed Russell Energy Center, a 14.7 acre, 600-MW NGCC plant with equipment needs (two gas turbines with heat recovery steam generators and one steam turbine) similar to those in the Baseline Report (NETL, 2010).

The application included data on diesel fuel use, water use, and criteria air pollutants associated with a 21-month installation period. The data were calculated assuming many emission control measures were implemented, including water spray for dust suppression, low sulfur fuels, preventative maintenance on construction equipment, and limited idling time (Calpine/Bechtel, 2001). It is noted as a minor data limitation that emissions are based on a plant in California, while our model is considering a plant in Illinois. Some differences are expected due to varying landscapes and regulatory requirements.

Although it was assumed that water suppression was used to control PM emissions, no data were given on the specific amount of water used during installation. This amount was calculated using a given application rate of water, and took into account several assumptions. The application stated that most of the plant fugitive dust emissions occurred in the first month or two and thus water usage was only calculated for the first two months (Calpine/Bechtel, 2001). The application also stated that the construction process would occur from 6 a.m. to 6 p.m., Monday through Saturday, for a total of 288 hours of construction per month of activity (Calpine/Bechtel, 2001). Finally, it was assumed that the application rate of 0.25 hours per application (or four applications per hour) was incorrectly reported in the source (Calpine/Bechtel, 2001); applying that amount of water would result in approximately one inch of water per day being used over the entire installation area. RDS felt that, although dust would be suppressed, such an amount of water would cause additional problems with standing water and mud. Therefore, an adjusted application rate of 0.25 applications per hour was assumed, which correlated to one application every four hours. This application rate seemed more practical, and an inverse of units as written in the original report is a realistic error.

Diesel use during installation was obtained from the Russell City Energy Center Application for Certification (Calpine/Bechtel, 2001). In Appendix 8.1-E, table 8.1E-8 lists the total diesel use, in gallons per year, of each piece of construction equipment. These amounts were summed for a total of 122,817.7 gal/yr. This value was multiplied by the length of the construction period, 21 months (or ~1.75 years), for the volume over the entire construction period. This value was then multiplied by the density of diesel (7.1 lb/gal) and converted to kilograms (American Petroleum Institute, 2004).

The amount of CO₂ released during installation of the power plant was calculated by first determining how much carbon was present in the amount of diesel used. There are 2,778 grams of carbon in one gallon of diesel (EPA, 2005a). The amount of carbon in the diesel (568,645.9 kg) was converted to CO₂ by following EPA and IPCC guidelines, which state that 99 percent of

carbon in a fuel is oxidized and emitted as CO₂, and the mass of CO₂ was determined multiplying by the ratio of the molecular weights of CO₂ (44 moles/gram) and carbon (12 moles/gram) (EPA, 2005a). The total calculated mass of CO₂ released during construction was divided by the number of acres of construction that the study was based on (14.7, Calpine/Bechtel, 2001) to determine kg/acre of CO₂.

Table 8.1E-3 of the Russell City application lists the emissions, in tons/year, for five pollutants – NO_x, CO, VOC, SO_x, and PM (Calpine/Bechtel, 2001). The values for each, 22.95 tons/yr for NO_x, 63.82 tons/year for CO, 6.09 tons/year for VOC, 0.58 tons/year for SO_x, and 3.1 tons/year for PM, were multiplied by the number of years of construction (1.75) and then converted into kilograms. Finally, these values were divided by the total area of the construction site to get the amount of each emission per acre.

The emissions of four other pollutants were calculated using different sources – CH₄, N₂O, NH₃, and Hg. The emissions factors for CH₄ and N₂O were pulled from Appendix H of a DOE report, which references the EPA GHG inventory (EPA, 2008e). It was assumed that the diesel-powered construction equipment would be representative of the equipment used at the power plant. These emission factors were 0.58 g/gallon of diesel for CH₄ and 0.26 g/gallon for N₂O (EPA, 2008e). The NH₃ emission factor was obtained from a report published by the EPA documenting the development and selection of emission factors for NH₃. The emission factor for the combustion of diesel from mobile sources was given as 0.11 kg/1000 L of diesel (Battye, Battye et al., 1994). The emission factor of the final pollutant, Hg, was determined by dividing the average concentration of Hg in diesel from various studies by the number of samples to get 0.1564 ng/g diesel (Conaway, Mason et al., 2005).

Each of the pollutants was converted from their emission factor units into kg/acre to correspond with the other emissions. Both the CH₄ and N₂O emissions were calculated by converting first to kg/gallon of diesel, and then by multiplying by the previously-determined gallons of diesel used per acre of development. The NH₃ was also converted to kg/gallon and multiplied by the gallons of diesel used, but there was an intermediate conversion from 1000 L to gallons. Finally, the Hg was converted by changing g diesel to kg diesel, multiplying by the diesel use per acre (in kg/acre), and dividing by 10¹² (ng/kg). These calculations gave total emissions, per acre of development, of 8.48 kg CH₄, 3.80 kg N₂O, 6.09 kg NH₃, and 7.36 x 10⁻⁰⁶ kg Hg.

The total amount of water and diesel used and the emissions released includes decommissioning of the power plant site. It was assumed that the decommissioning use and emissions were 10 percent of the total commissioning use and emissions (Odeh and Cockerill, 2008). The diesel use, water use, and emissions were all multiplied by 10 percent, and this value was added onto the total values previously calculated on a per acre of installation basis.

Figure A-13 represents the GaBi plan for power plant installation/deinstallation. This is the same for all cases within this study. **Table A-12** gives the GaBi emission outputs and profiles associated with this process.




Figure A-13: GaBi Plan for Power Plant Installation/Deinstallation

Table A-12: GaBi Air Emission Outputs and Profiles for Power Plant Installation/Deinstallation, kg/MWh Plant Output

Emissions (kg/MWh plant output)	Total	Diesel at refinery PE	Power Plant Installation/Deinstallation
Lead	2.72E-10	2.72E-10	0.00E+00
Mercury	2.54E-11	2.31E-11	2.29E-12
Ammonia	1.93E-06	4.03E-08	1.89E-06
Carbon dioxide	5.18E-02	6.02E-03	4.58E-02
Carbon monoxide	2.15E-03	8.79E-06	2.14E-03
Nitrogen oxides	7.88E-04	1.87E-05	7.70E-04
Nitrous oxide (laughing gas)	1.28E-06	1.03E-07	1.18E-06
Sulfur dioxide	4.36E-05	2.42E-05	1.95E-05
Sulfur hexafluoride	2.29E-14	2.29E-14	0.00E+00
Methane	6.52E-05	6.26E-05	2.63E-06
Methane (biotic)	0.00E+00	0.00E+00	0.00E+00
VOC (unspecified)	2.04E-04	2.61E-08	2.04E-04
Particulate Matter, unspecified	1.04E-04	0.00E+00	1.04E-04
Dust (unspecified)	3.56E-07	3.56E-07	0.00E+00

A.1.3.3 Construction Assumptions

This process encompasses the material inputs necessary for the construction of an SCPC power plant without CCS. The inputs and outputs are expressed in terms of units per megawatt-hour of

produced power. The data includes materials from three main components of an energy conversion facility – the power plant itself, the trunkline and switchyard to transmit electricity from the plant to the power grid, and a rail spur to get the fuel (coal) from the main rail line to the plant.

Data for the construction of the power plant were taken from several studies, each of which listed the amounts of between two to five major materials for construction. The materials for the construction of the plant, according to the various studies, were concrete, steel, steel pipes, iron, and aluminum (Spath, Mann et al., 1999; CWLP, 2009; Peterson, 2005; Tokimatsu, Kosugi et al., 2006; Widiyanto, 2003; Mithethwa, 2004). The amounts of each construction material given in the studies was divided by the net output of the plant in the study to put them on a per MW produced basis. Each material that was listed in more than one study or for more than a single plant was averaged and the value was converted to kilograms, to give construction material quantities on a kg/MW basis.

The data for the rail spur was taken from information from the American Railway Engineering Association (ICRR, 2007). The weight of rail, in lb/yd, was converted to kg/mile and then multiplied by 25, the assumed length of the rail spur from the main line to the power plant. The rail was assumed to be constructed of cold-rolled steel.

There are four components for the switchyard and trunkline – the transmission towers, the foundation for the towers, air break switches, and circuit breakers. The necessary materials for each component were calculated individually and then summed across the entire switchyard and trunkline.

The towers are assumed to be lattice steel towers, each weighing approximately 8.75 tons (Brune, 2008). Each leg (four on each tower) of a tower is supported by a cylindrical concrete foundation 3.50 ft. wide and 22.50 ft. deep (Aspen Environmental Group, 2008). The volume of each foundation was multiplied by four for the volume of concrete for one tower, and then multiplied by the density of concrete (Portland Cement Association, 2008) to get the total weight of concrete for a single tower. To determine the number of towers in the trunkline, it was assumed that it was 50 miles long (Skone, 2008) and that the towers were spaced approximately every 900 ft. (CapX 2020, 2007). This results in 293 towers over the 50 miles. Finally, to calculate the amount of concrete and steel in the trunkline towers, the weight of each for a single tower was multiplied by the total number of towers.

For the conductors, it was assumed that there was a single three-phase conductor running the length of the trunkline. There was no allowance for sag in the calculation of conductor length, and there was no consideration for electrical losses. The conductors are aluminum conductors, aluminum-clad steel reinforced (ACSR/AW), and are sized to carry the net plant output, based on cable ampacity. The ampacity of the conductors, based on an output of 640.25 MW, a voltage of 345,000, and a power factor of 90 percent is 1,190 amps. The smallest size conductor that can carry 1,190 amps is 1272 MCM (Phelps Dodge, 2005). For this size conductor, the aluminum and steel components were converted from lb/1000 ft. to kg/mile, and then multiplied by the assumed trunkline distance of 50 miles to get a total weight of aluminum and steel for the conductors.

The next component was the switchyard air break switch. It was assumed that there will be eight total air break switches – two for each SF₆ circuit breaker. Once again, the conductors coming

through the switchyard air break switches are three phase and there are assumed to be three sets of two 220-kV rated insulators to make an insulator rated for 345 kV. The weight of a single 220-kV insulator was gathered from vendor data (Keidy Electro-Mechanical Company, 2008). As stated previously, there are three sets of two insulator assemblies per phase, and taking that total times the number of phases gives the total weight of insulators for one air break switch.

To calculate the amount of steel in an air break switch, it was assumed that all components except for the insulators were constructed of steel. To get the weight of one air break switch, the weight of a switch for one phase (General Switchgear & Controls, 2008) was multiplied by the number of phases. The weight of the insulators was subtracted from the total weight of one air break switch to get a total estimated amount of steel for a single switch.

The last component of the air break switches is the concrete foundation. It was assumed that the foundation of one phase of a switch would be roughly the same size as the foundation of one leg of the conductor towers. The foundations are cylindrical, and the volume was multiplied by the density of concrete to determine the total weight for all three phases of one air break switch. One final step for the air break switches was to multiply each material (steel, concrete, and insulators) by the total number of switches for the switchyard, and then convert everything to kilograms.

The final component of the switchyard and trunkline are the SF₆ circuit breakers. There are a total of two, three-phase SF₆ breakers at the plant. There are two insulator assemblies per phase, and each assembly has two 220-kV insulators. The weights of a single circuit breaker and the amount of SF₆ in each breaker were taken from vendor specifications (HVB AE Power Systems, 2003). Again, the weight of insulators in a breaker was calculated by taking the weight of one insulator (Keidy Electro-Mechanical Company, 2008) and multiplying by the number of insulators in an assembly, the number of assemblies per phase, and the number of phases for one breaker. The amount of steel in one circuit breaker was determined by subtracting the weight of SF₆ and the weight of the insulator assemblies from the total weight of a single circuit breaker.

The concrete foundation assumptions and calculations are identical to those of the air break switches. The final step for the circuit breakers was to multiply the weight of each material (steel, concrete, SF₆, and insulators) by the total number of breakers in the switchyard and converting to kilograms.

The weights of all the construction materials for the switchyard and trunkline were summed – cold-rolled steel for the towers, conductors, air break switches, and SF₆ circuit breakers; concrete for the foundation of the tower, switches, and breakers; aluminum for the conductors; insulators for the switches and breakers; and SF₆ for the circuit breakers.

Finally, the construction materials for each plant site component (power plant, rail spur, switchyard and trunkline) were divided by the total megawatts of electricity produced during the lifetime of the plant. This put each major component on a kg/MWh produced basis. Lastly, materials present in more than one of the plant site components were added together to give a total for the process. **Figure A-14** represents the GaBi plan and **Table A-13** shows the air emissions and material profiles used for SCPC plant construction without CCS.




Figure A-14: GaBi Plan for SCPC Power Plant Construction without CCS

Table A-13: Air Emission Output for SCPC Power Plant Construction without CCS, kg/MWh Plant Output

Emissions (kg/MWh)	SERC Power Grid Mix 2005 (USEPA, eGRID2007)	DE: Cast iron part (sand casting) PE [pl]	RER: Aluminum sheet mix PE	US: Concrete, Ready Mixed, R-5-0 (100% Portland Cement)	Thermal energy from heavy fuel oil PE	Steel Pipe, Welded, BF, Manufacture	WOR: Steel Plate, BF, Manufacture NETL [MP-CG]	Total
Lead	1.21E-08	1.95E-10	1.19E-08	0.00E+00	2.80E-11	4.67E-08	9.03E-07	9.74E-07
Mercury	3.42E-09	7.57E-12	9.62E-10	0.00E+00	1.30E-13	1.24E-09	5.67E-08	6.24E-08
Ammonia	1.17E-06	7.61E-09	2.76E-07	0.00E+00	1.00E-09	0.00E+00	0.00E+00	1.45E-06
Carbon dioxide	2.44E-01	3.93E-03	7.39E-02	1.87E-01	1.73E-04	1.53E-02	4.56E-01	9.80E-01
Carbon monoxide	1.01E-04	4.98E-06	6.38E-04	2.41E-04	6.35E-08	1.13E-04	3.85E-03	4.94E-03
Nitrogen oxides	4.72E-04	3.08E-06	1.30E-04	5.70E-04	1.97E-07	2.50E-05	7.64E-04	1.96E-03
Nitrous oxide (laughing gas)	3.23E-06	5.64E-08	1.28E-06	0.00E+00	1.51E-09	8.56E-07	2.37E-05	2.91E-05
Sulfur dioxide	1.38E-03	2.21E-06	4.09E-04	4.34E-04	7.29E-07	4.35E-05	1.04E-03	3.31E-03
Sulfur hexafluoride	1.66E-12	1.34E-14	7.50E-12	0.00E+00	7.42E-17	0.00E+00	0.00E+00	9.18E-12
Methane	2.67E-04	3.14E-06	1.21E-04	0.00E+00	1.78E-07	1.62E-05	3.46E-04	7.54E-04
Methane (biotic)	0.00E+00	0.00E+00	0.00E+00	8.52E-06	0.00E+00	0.00E+00	0.00E+00	8.52E-06
VOC (unspecified)	3.40E-08	1.05E-10	2.92E-06	2.10E-05	7.17E-11	2.07E-06	6.78E-05	9.39E-05
Particulate Matter, unspecified	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Particles to air	2.62E-05	6.44E-06	1.25E-04	5.56E-04	3.22E-09	1.80E-05	1.09E-04	8.42E-04

A.1.3.4 Operation Assumptions

All primary operations of the SCPC plant without CCS plant are included in this unit process, using inputs of coal, air, and process water to produce electricity. Emissions output from operation of the plant also include those from an auxiliary boiler during 50 percent of plant downtime, and leakage of SF₆ from circuit breakers at the 345-kV switchyards at either end of the trunkline.

The SCPC plant without CCS was modeled using the Baseline Report results for Case 11, a supercritical Rankine cycle pulverized coal steam generator and steam turbine using Illinois #6 coal and producing a net output of 550 MWe (NETL, 2010). An 85 percent capacity factor is given, making the calculated net output 467.6 MWh (NETL, 2010).

Air Emissions

Auxiliary Boiler Operation

During SCPC plant non-operation, the Baseline Report specifies that a shop fabricated, 40,000 lb/hr, 400 psi water tube auxiliary boiler is used to replace the primary system. It is assumed that the auxiliary boiler is operated for 50 percent of the downtime such that operation time for the boiler is calculated to be 10 percent of one year.

The only mention of the auxiliary boiler in the Baseline Report is that it can use either oil or gas; no fuel use amounts or emissions associated with the auxiliary boiler operation are included. Therefore, natural gas was assumed as the fuel used (versus fuel oil), and consumption of the auxiliary boiler is estimated to be 53,000 standard ft³/hr based upon highest fuel consumption claims for two similarly sized boilers in the sited brochures (Wabash Power Equipment Company, 2009). Using 23.8 ft³/lb as the specific volume of natural gas, auxiliary boiler natural gas consumption is calculated to be 0.1578 kg/MWh.

A controlled burn emissions profile is added for natural gas combustion in a large-walled boiler from AP 42, under the assumption that a low-NO_x burner is used (EPA, 1998). The boiler emits NO_x, CO, CO₂, N₂O, PM, SO₂, CH₄, VOC, and Pb. Hg emissions from natural gas were assumed to be negligible as reliable data were not found and Hg is not a typical contaminant in natural gas supplies. Emission rates for each pollutant or gas is included in **Table A-14**. These values were converted to kg/MWh of net output. No NH₃ emission values for the auxiliary boiler were identified.

Table A-14: Air Releases from Auxiliary Boiler

Pollutant	lb/ 10 ⁶ SCF	kg/MWh
NO _x (controlled)	140	4.59 x 10 ⁻⁰⁴
CO	84	2.75 x 10 ⁻⁰⁴
CO ₂	120000	0.39
N ₂ O (controlled)	0.64	2.1 x 10 ⁻⁰⁶
PM (total)	7.6	2.49 x 10 ⁻⁰⁵
SO ₂	0.6	1.97 x 10 ⁻⁰⁶
CH ₄	2.3	7.54 x 10 ⁻⁰⁶
VOC	5.5	1.80 x 10 ⁻⁰⁵
Pb	0.0005	1.64 x 10 ⁻⁰⁹
Hg	N/A	N/A

Primary SCPC Plant Operation

The SCPC plant without CCS consumes 409,528 lb/hr of coal as specified in the Baseline Report, which is equivalent to an average of 337.753 kg/MWh net electricity output. On the basis of these flows, air releases from plant operation are given in the Baseline Report Case 11, Exhibit ES-2 (NETL, 2010). These air releases include CO₂, Hg, NO_x, PM, and SO₂ as shown in **Table A-15**.

Table A-15: Air Releases from SCPC Plant without CCS

Emissions	lb/hr	kg/MWh
CO ₂	972,404	801.98
Hg	0.005	4.12 x 10 ⁻⁰⁶
NO _x	334	0.275
PM	62	0.051
SO ₂	410	0.338

Pb emissions data are not available in the Baseline Report. In order to generate an estimate for lead emissions, data were incorporated from a prior environmental assessment of SCPC power systems in the Midwest (EPA, 2008a; EIA, 2002). Reported airborne lead emissions for these plants were normalized to a pound of lead per MW basis using the nameplate electricity production capacity of each plant. The median value of lead emissions from these six plants was found to be 0.08 lb/MW, or 4.14 x 10⁻⁵ kg/MWh.

NH₃ (to air) emissions were not given in the Baseline Report for the SCPC plants. However, due to the use of selective catalytic reduction (SCR) for NO_x control, some ammonia is emitted. The Baseline Report states a 2 ppmv ammonia slip rate (through the stack) at the end of the catalyst life. Further investigation showed that as the SCR catalyst degrades, the ammonia slip increases; once new catalyst is added to the system the slip rate goes to zero. The following was assumed to simplify the calculation of an ammonia emission rate: the 2 ppmv rate was is the maximum rate at the end of the catalyst life, each layer (in the two layer catalyst system) has a two year

lifetime (Mack and Patchett, 1997), and the slip rate is linear to catalyst activity. Using the available data and assumptions, a 1 ppmv average slip rate was calculated for the lifetime of the plant.

Circuit Breaker SF₆ Leakage

Once electricity is produced in the SCPC plant, circuit breakers are used for safety during electricity transmission. It was assumed that 4 circuit breakers would be needed to operate the SCPC plant; 3 at the output of each generator (2 CTG and 1 ST) and one at the end of the switchyard. It is common practice to use sulfur hexafluoride (SF₆) gas in the breakers, which is a greenhouse gas with a high global warming potential. The amount of SF₆ used in each circuit breaker is given in the literature as 690 lbs; therefore the SCPC plant requires 1251.92 kg of SF₆ (HVB AE Power Systems, 2003). Although estimates vary, the national electrical manufacturers association states that the management guidelines for leakage of SF₆ from circuit breakers are 0.1 percent/year (Blackman and Averyt, 2006). This calculates to a leakage rate of 3.056×10^{-7} kg/MWh net output. This leakage rate is noted as a data limitation.

Water Withdrawal and Emissions

System requirements for water input to the SCPC plant with CCS are given by Case 11, Exhibit 4-30 of the Baseline Report as shown in **Table A-16**. This information sets a total water input rate 20.1 m³/min, or 2.193 m³/MWh of electricity delivered. Because the Baseline Report also states a 1:1 ratio of water input from municipal and groundwater supplies, the total input water to the plant from each of the two sources is calculated to be 10.05 m³/min and 1.096 m³/MWh.

Table A-16: Water Withdrawal for Case 11 from the Baseline Report

Water Withdrawal	Water Demand m ³ /min (gpm)	Internal Recycle m ³ /min (gpm)	Raw Water Makeup m ³ /min (gpm)
FGD Makeup	3.6 (951)	0.0 (0)	3.6 (951)
BFW Makeup	0.0 (0)	0.0 (0)	0.0 (0)
Cooling Tower Makeup	18.4 (4,863)	1.9 (492)	16.5 (4,370)
Total	22.0 (5,813)	1.9 (492)	20.1 (5,321)

Within these systems the Baseline report does not differentiate between water use (wastewater discharged to sewer) and consumption (evaporated water).

Therefore a second NETL study was used to determine the fractions of water discharged and evaporated (consumed) by the system (NETL, 2007b). The overall water balance incorporated from the NETL study into the current SCPC plant is shown in **Table A-17**.

Table A-17: SCPC Overall Water Balance

Water In/Location	Flow (gpm)	Water Out/Location	Flow (gpm)
Moisture in Coal	42.7	PC Boiler Flue Gas	817.8
Coal Combustion of H ₂ in Boiler	287.7	Water Associated with Gypsum	71.3
Combustion of Air for PC Boiler	56.8	Cooling Tower Evaporation	3468
Oxidation air for FGD	0.3	Cooling Tower Blowdown	1155
Raw Water	5125		
Total Water In	5512	Total Water Out	5512

Table A-18 sums the water loss attributed to each system within the SCPC power plant. Of these losses, all except cooling tower blowdown are consumed through evaporation. Evaporative losses were calculated to be 79 percent of the total water input. Translating this consumption rate to the Baseline Report water input, 1.775 m³ of water is consumed per MWh of electricity delivered. Cooling tower blowdown is discharged in liquid form and totals 21 percent of the water input. Translating this discharge rate to the Baseline Report water input yields a total wastewater discharge rate of 0.47 m³/MWh.

Table A-18: SCPC Water Loss by Function

Function	gpm	gal/MWh
FGD Losses		
Water with Gypsum	71.3	8.3
Flue Gas Loss		
PC Boiler Flue Gas	817.8	94.8
Cooling Water Losses		
Cooling Tower Blowdown	1155	133.8
Cooling Tower Evaporation	3468	401.9
Total	5512	639

Figure A-15 and **Table A-19** show the GaBi plan inputs and air emissions outputs for the operation of the SCPC power plant without CCS.




Figure A-15: GaBi Plan for SCPC Power Plant Operation without CCS

Table A-19: Air Emissions associated with SCPC Power Plant Operations without CCS, kg/MWh Plant Output

Emissions (kg/MWh)	US: Natural gas mix PE	SCPC Power Plant Operation (w/o CCS)	Total
Lead	4.66E-09	4.79E-05	4.79E-05
Mercury	4.38E-10	4.77E-06	4.77E-06
Ammonia	2.02E-07	2.56E-03	2.56E-03
Carbon dioxide	6.31E-02	9.28E+02	9.28E+02
Carbon monoxide	8.73E-05	3.18E-04	4.06E-04
Nitrogen oxides	1.90E-04	3.19E-01	3.19E-01
Nitrous oxide (laughing gas)	1.24E-06	2.43E-06	3.66E-06
Sulfur dioxide	2.62E-04	3.91E-01	3.91E-01
Sulfur hexafluoride	5.32E-13	3.53E-07	3.53E-07
Methane	7.50E-04	8.72E-06	7.58E-04
Methane (biotic)	0.00E+00	0.00E+00	0.00E+00
VOC (unspecified)	4.94E-07	2.08E-05	2.13E-05
Particulate Matter, unspecified	0.00E+00	5.91E-02	5.91E-02
Particles to air	5.42E-06	0.00E+00	5.42E-06

A.1.4 Life Cycle Stage #3, Case 2: SCPC Energy Conversion Facility with CCS

Stage #3, Case 2 includes the commissioning, construction, operation, and decommissioning of a 546-MWe net output SCPC plant with CCS; as with the operation of the SCPC plant without CCS most data were taken directly from the Baseline Report (NETL, 2010).

A.1.4.1 GaBi Plan

Figure A-16 defines the second level GaBi plan for the SCPC case with CCS. This plan is based on a reference flow of 1 MW electricity output. The addition of the pipeline third level plan is the main differences between Stage #3 in the two cases. Assumptions on the commissioning/decommissioning, construction, and operation of the pipeline are included in the following sections.




Figure A-16: GaBi Plan for Stage #3, Case 2: SCPC with CCS

A.1.4.2 Commissioning, Installation, and Decommissioning Assumptions

There are no case-specific power plant installation/deinstallation parameters within this study; **Section A.1.3.2** and **Figure A-13** represent both cases. However, the CO₂ pipeline is only used for the case with CCS and is therefore discussed here.

Emissions consistent with underground pipeline laying/construction include heavy construction equipment exhaust emissions, emissions from transport of pipes and associated materials (200 miles round-trip), and fugitive dust. PM, NO_x, SO_x, CO, and VOC emissions were estimated for pipeline installation based on the installation of a natural gas pipeline (SMUD, 2001). Emissions were placed on a per-mile-installed basis. Diesel consumption was also estimated from the aforementioned report.

The emissions of four other pollutants – CH₄, N₂O, NH₃, and Hg – were calculated using different sources in conjunction with the estimated diesel consumption (SMUD 2001). The emissions factors for CH₄ and N₂O were pulled from Appendix H of a report from DOE that cited the EPA GHG emission inventory (EPA, 2008e). It was assumed that the diesel-powered construction equipment would be representative of the diesel-powered construction equipment. These emission factors were 0.58 g/gallon of diesel for CH₄ and 0.26 g/gallon for N₂O. The NH₃ emission factor was obtained from a report published by the EPA documenting the development and selection of emission factors for NH₃. The emission factor for the combustion of diesel from mobile sources was given as 0.11 kg/1000 L of diesel (Battye, Battye et al., 1994). The emission factor of the final pollutant, Hg, was determined by dividing the average concentration of Hg in diesel from various studies by the number of samples to get 0.1564 ng/g diesel (Conaway, Mason et al., 2005).

Water usage for hydrotesting pipeline is ignored because water is assumed returned to source after use. Deinstallation emissions are assumed to be 10 percent of installation emissions, as consistent with the rest of the study assumptions for decommissioning. **Figure A-17** represents the GaBi plan for pipeline installation. It is important to note that the values in **Figure A-17** and the air emissions presented in **Table A-20** are on a per mile basis.




Figure A-17: GaBi Plan for Pipeline Installation/Deinstallation

Table A-20: Air Emissions for On-Shore Pipeline Installation/Deinstallation, kg/mile pipeline

Emissions (kg/mile pipeline)	US: Diesel at refinery PE	Pipeline Installation/Deinstallation	Total
Lead	1.51E-10	0.00E+00	1.51E-10
Mercury	1.28E-11	1.27E-12	1.40E-11
Ammonia	2.23E-08	1.05E-06	1.07E-06
Carbon dioxide	3.33E-03	3.23E-02	3.57E-02
Carbon monoxide	4.86E-06	1.15E-04	1.19E-04
Nitrogen oxides	1.03E-05	3.31E-04	3.41E-04
Nitrous oxide (laughing gas)	5.71E-08	6.54E-07	7.11E-07
Sulfur dioxide	1.34E-05	0.00E+00	1.34E-05
Sulfur hexafluoride	1.27E-14	0.00E+00	1.27E-14
Methane	3.46E-05	1.46E-06	3.61E-05
Methane (biotic)	0.00E+00	0.00E+00	0.00E+00
VOC (unspecified)	1.44E-08	2.43E-05	2.43E-05
Particulate Matter, unspecified	0.00E+00	6.54E-05	6.54E-05
Dust (unspecified)	1.97E-07	0.00E+00	1.97E-07

A.1.4.3 Construction Assumptions

This process encompasses the material inputs necessary for the construction of an SCPC power plant with CCS. The inputs and outputs are expressed in terms of units per megawatt-hour of produced power. The data includes materials from three main components of an energy conversion facility – the power plant itself with a pipeline to the sequestration facility; the trunkline and switchyard to transmit electricity from the plant to the power grid, and a rail spur to get the fuel (coal) from the main rail line to the plant. The construction of the rail spur and the trunkline and switchyard system are the same as for the case without CCS, and are therefore not repeated here.

Data for the construction of the power plant were taken from several studies, each of which listed the amounts of between two to five major materials for construction. The materials for the construction of the plant, according to the various studies, were concrete, steel, steel pipes, iron, and aluminum (Pehnt and Henkel, 2009; Spath, Mann et al., 1999; CWLP, 2009; Peterson, 2005; Tokimatsu, Kosugi et al., 2006; Widiyanto, 2003; Mithethwa, 2004; Koornneef, van Keulen et al., 2008). The amounts of each construction material given in the studies was divided by the net output of the plant in the study to put them on a per MW produced basis. Each material that was listed in more than one study or for more than a single plant was averaged and the value was converted to kilograms, to give construction material quantities on a kg/MW basis. The Koornneef (2008) and Pehnt (2008) study data were utilized to adjust material quantities to account for carbon capture equipment.

The amount of pipeline for CO₂ transport and sequestration was determined as follows. The internal diameter of the pipe was calculated as described in Section 2.4.1 of the MIT report of the economics of CO₂ storage (Heddl, Herzog et al., 2003) and was based on the flowrate of CO₂ to

be sequestered (NETL 2007). Pipe weight was calculated using data from the Engineering Toolbox (The Engineering ToolBox, 2009). The weight included the entire pipeline from the plant to the sequestration site, and from the ground surface at the site to the injection well depth, both from the Baseline Report. An adjustable parameter was provided to account for the extra weight (a percentage) associated with pipeline valves, fittings, and sections of heavy walled pipe (for sections buried below roads, railroad tracks, river beds, etc.). The assumed value is 10 percent but is variable.

The concrete casing for the sequestration pipeline is poured in layers that get larger as the pipeline gets closer to ground surface. The 'production' casing surrounds the pipeline over its entire length. The 'surface' casing surrounds the pipeline from ground surface to a depth of approximately 750 ft., and encompasses the production casing as well as the pipeline. The 'conductor' casing surrounds the pipeline from ground surface to a depth of approximately 40 ft., and encompasses the production and surface casings as well as the pipeline (Brown, 2008). The depth of the injection well is a variable (NETL, 2010). The volume of concrete required for all three casing levels was summed and converted to a mass (Portland Cement Association, 2008).

Finally, the construction materials for each plant site component (power plant, rail spur, switchyard and trunkline, CO₂ pipeline, injection well) were divided by the total megawatts of electricity produced during the lifetime of the plant. This put each major component on a kg/MWh produced basis. Lastly, materials present in more than one of the plant site components were added together to give a total for the process. Figure A-18 represents the GaBi plan and **Table A-21** shows the air emissions and material profiles used for SCPC plant construction with CCS.




Figure A-18: GaBi Plan for SCPC Power Plant Construction with CCS

Table A-21: Air Emissions from SCPC Power Plant Construction with CCS, kg/MWh Plant Output

Emissions (kg/MWh Plant Output)	US: SERC Power Grid Mix 2005 (USEPA, eGRID2007)	DE: Cast iron part (sand casting) PE [pl]	RER: Aluminum sheet mix PE	US: Concrete, Ready Mixed, R-5-0 (100% Portland Cement)	US: Thermal energy from heavy fuel oil PE	WOR: Steel Pipe, Welded, BF, Manufacture NETL [MP-CG]	WOR: Steel Plate, BF, Manufacture NETL [MP-CG]	WOR: Steel, Stainless, 316 2B, 80% Recycled NETL [MP-CG]	Total
Lead	1.25E-08	2.00E-10	1.26E-08	0.00E+00	2.87E-11	9.32E-07	9.27E-07	0.00E+00	1.89E-06
Mercury	3.53E-09	7.76E-12	1.02E-09	0.00E+00	1.33E-13	2.47E-08	5.83E-08	0.00E+00	8.75E-08
Ammonia	1.21E-06	7.80E-09	2.93E-07	0.00E+00	1.03E-09	0.00E+00	0.00E+00	0.00E+00	1.51E-06
Carbon dioxide	2.51E-01	4.03E-03	7.84E-02	1.92E-01	1.77E-04	3.06E-01	4.68E-01	2.63E-02	1.33E+00
Carbon monoxide	1.04E-04	5.10E-06	6.76E-04	2.48E-04	6.51E-08	2.26E-03	3.95E-03	4.71E-05	7.30E-03
Nitrogen oxides	4.86E-04	3.16E-06	1.38E-04	5.87E-04	2.02E-07	4.99E-04	7.84E-04	5.97E-05	2.56E-03
Nitrous oxide (laughing gas)	3.33E-06	5.79E-08	1.36E-06	0.00E+00	1.55E-09	1.71E-05	2.43E-05	0.00E+00	4.62E-05
Sulfur dioxide	1.42E-03	2.26E-06	4.34E-04	4.47E-04	7.47E-07	8.69E-04	1.07E-03	1.21E-04	4.36E-03
Sulfur hexafluoride	1.71E-12	1.37E-14	7.96E-12	0.00E+00	7.61E-17	0.00E+00	0.00E+00	0.00E+00	9.68E-12
Methane	2.75E-04	3.22E-06	1.29E-04	0.00E+00	1.82E-07	3.24E-04	3.55E-04	0.00E+00	1.09E-03
Methane (biotic)	0.00E+00	0.00E+00	0.00E+00	8.77E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.77E-06
VOC (unspecified)	3.50E-08	1.07E-10	3.10E-06	2.16E-05	7.35E-11	4.13E-05	6.96E-05	0.00E+00	1.36E-04
Particulate Matter, unspecified	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Particles to air	2.70E-05	6.60E-06	1.33E-04	5.73E-04	3.30E-09	3.59E-04	1.12E-04	3.46E-05	1.25E-03

A.1.4.4 Operation Assumptions

All primary operations of the SCPC plant with CCS are included in this unit process, using inputs of coal, air, and process water to produce electricity. Emissions output from operation of the plant also include those from an auxiliary boiler operated during 50 percent of plant downtime, leakage of SF₆ from circuit breakers at the 345-kV switchyards at either end of the trunkline, and leakage of captured CO₂ from both the transport pipeline and the sequestration site.

The SCPC plant with CCS was modeled using the Baseline Report results for Case 12, a supercritical Rankine cycle pulverized coal steam generator and steam turbine using Illinois #6 coal and producing a net output of 550 MWe (NETL, 2010). An 85 percent capacity factor is given, making the calculated net output 467.5 MWh (NETL, 2010). Operation of the auxiliary boiler and trunkyard and switchyard system are the same as for the case without CCS and are therefore not repeated here.

Air Emissions

Primary SCPC Plant Operation

The SCPC plant with CCS consumes 565,820 lb/hr of coal as specified in the Baseline Report, which is equivalent to an average of 466.67 kg/MWh net electricity output. On the basis of these flows, air releases from plant operation are given in the Baseline Report Case 12, Exhibit ES-2 (NETL, 2010). These air releases include CO₂, Hg, NO_x, PM, and SO₂ as shown in **Table A-22**.

Table A-22: Air Releases from SCPC Plant without CCS

Emissions	lb/hr	kg/MWh
CO ₂	134351	110.8
Hg	0.008	6.60 x10 ⁻⁰⁶
NO _x	462	0.381
PM	86	0.071
SO ₂	11	0.009

Lead emission data were not available in the Baseline Report. In order to generate an estimate for lead emissions, data were incorporated from a prior environmental assessment of SCPC power systems in the Midwest (EPA, 2008a; EIA, 2002). Reported airborne lead emissions for these plants were normalized to a lb of lead per MW basis using the nameplate electricity production capacity of each plant. The median value of lead emissions from these six plants was found to be 0.08 lb/MW, or 4.14 x 10⁻⁵ kg/MWh.

NH₃ emissions were not given in the Baseline Report for the SCPC plants. However, due to the use of selective catalytic reduction (SCR) for NO_x control, some ammonia is emitted. The Baseline Report states a 2 ppmv ammonia slip rate (through the stack) at the end of the catalyst life. Further investigation showed that as the SCR catalyst degrades, the ammonia slip increases; once new catalyst is added to the system the slip rate goes to zero. The following was assumed to simplify the calculation of an ammonia emission rate: the 2 ppmv rate was is the maximum

rate at the end of the catalyst life, each layer (in the two layer catalyst system) has a two year lifetime (Mack and Patchett, 1997), and the slip rate is linear to catalyst activity. Using the available data and assumptions, a 1 ppmv average slip rate was calculated for the lifetime of the plant.

CCS System CO₂ Leakage

The captured CO₂ from this system is dried and pressurized to a supercritical state before being placed into a pipeline for transport to the saline sequestration site. CO₂ becomes more dense when in its supercritical phase, making transport easier and more economical (Gale and Davison, 2004). Once in the pipeline, it can be assumed that some leakage might occur, but because CO₂ pipelines are a relatively new infrastructure, little data is available on leak rates. Once in the pipeline, it can be assumed that some leakage might occur, but because CO₂ pipelines are a relatively new infrastructure, little data is available on leak rates. Personal correspondence with a representation from Kinder Morgan gave a leak rate of 0.0165 percent based on their data for CO₂ pipeline leakage from 2002-2008 (Roncal, 2009).

This study includes little in the way of operations of the saline sequestration site. No energy or emissions associated with the day-to-day operation of the site are modeled, but a leak rate is assumed for the loss of CO₂ over the lifetime of the system. Again, this is not an established infrastructure and little is known about sequestration potential over an extended period of time. Therefore, the arbitrary value of one percent is applied as a leak rate parameter for the sequestration site. NETL believes that a saline site which may leak more than one percent would not be a candidate for CO₂ sequestration in the first place.

Water Withdrawal and Emissions

System requirements for water input to the SCPC plant with CCS are given by Case 12, Exhibit 4-30 of the Baseline Report as shown in **Table A-23**. This information sets a total water input rate 38.1 m³/min, or 4.16 m³/MWh of electricity delivered. Because the Baseline Report also states a 1:1 ratio of water input from municipal and groundwater supplies, the total input water to the plant from each of the two sources is calculated to be 19.05 m³/min and 2.08 m³/MWh.

The increase in water withdrawal for the case with CCS (compared to 2.193 m³/MWh groundwater plus municipal supply for the without CCS case) is due to additional water needs during the carbon capture process to cool both the flue gas before it enters the amine absorber and the column during absorption (the reaction between CO₂ and the amine solvent is exothermic) (Reddy, Johnson et al., 2008).

Table A-23: Water Withdrawal for Case 12 from the Baseline Report

Water Withdrawal	Water Demand m ³ /min (gpm)	Internal Recycle m ³ /min (gpm)	Raw Water Makeup m ³ /min (gpm)
FGD Makeup	5.1 (1,340)	0	5.1 (1,340)
BFW Makeup	0.0 (0)	0	0.0 (0)
Cooling Tower Makeup	39.4 (10,399)	6.5 (1,703)	32.9 (8,696)
Total	44.6 (11,774)	6.5 (1,703)	38.1 (10,071)

Within these systems the Baseline report does not differentiate between water use (wastewater discharged to sewer) and consumption (evaporated water).

Therefore a second NETL study was used to determine the fractions of water discharged and consumed by the system (NETL, 2007b). The overall water balance incorporated from the NETL study into the current SCPC plant is shown in **Table A-24**.

The NETL water loss study does not consider a plant with CCS, so some assumptions were made to account for the additional water usage. This is noted as a data limitation.

Table A-24: SCPC Overall Water Balance

Water In/Location	Flow (gpm)	Water Out/Location	Flow (gpm)
Moisture in Coal	42.7	PC Boiler Flue Gas	817.8
Coal Combustion of H ₂ in Boiler	287.7	Water Associated with Gypsum	71.3
Combustion of Air for PC Boiler	56.8	Cooling Tower Evaporation	3468
Oxidation air for FGD	0.3	Cooling Tower Blowdown	1155
Raw Water	5125		
Total Water In	5512	Total Water Out	5512

Table A-25 sums the water loss attributed to each system within the SCPC power plant. Of these losses, all except cooling tower blowdown are consumed through evaporation. Evaporative losses were calculated to be 79percent of the total water input. Translating this consumption rate to the Baseline Report water input, 3.43 m³ of water is consumed per MWh of electricity delivered. Cooling tower blowdown is discharged in liquid form and totals 21percent of the water input. Translating this discharge rate to the Baseline report water input yields a total wastewater discharge rate of 0.91 m³/MWh.

Table A-25: SCPC Water Loss by Function

Function	gpm	Electricity (gal/MWh)
FGD Losses		
Water with Gypsum	71.3	8.3
Flue gas loss		
PC Boiler Flue Gas	817.8	94.8
Cooling Water Losses		
Cooling Tower Blowdown	1155	133.8
Cooling Tower Evaporation	3468	401.9
Grand Total	5512	639

Figure A-19 and Table A-26 show the GaBi plan inputs and air emissions outputs for the operation of the SCPC power plant with CCS.




Figure A-19: GaBi Plant for SCPC Plant Operation with CCS

Table A-26: Air Emissions from SCPC Plant Operations with CCS, kg/MWh Plant Output

Emissions (kg/MWh Plant Output)	SCPC Power Plant Operation (with CCS) NETL	US: Natural gas mix PE	Total
Lead	4.79E-05	4.66E-09	4.79E-05
Mercury	7.63E-06	4.39E-10	7.63E-06
Ammonia	2.95E-03	2.02E-07	2.95E-03
Carbon dioxide	1.40E+02	6.31E-02	1.40E+02
Carbon monoxide	3.18E-04	8.73E-05	4.06E-04
Nitrogen oxides	4.41E-01	1.90E-04	4.41E-01
Nitrous oxide (laughing gas)	2.43E-06	1.24E-06	3.66E-06
Sulfur dioxide	1.05E-02	2.62E-04	1.08E-02
Sulfur hexafluoride	3.53E-07	5.32E-13	3.53E-07
Methane	8.72E-06	7.50E-04	7.59E-04
Methane (biotic)	0.00E+00	0.00E+00	0.00E+00
VOC (unspecified)	2.08E-05	4.94E-07	2.13E-05
Particulate Matter, unspecified	8.20E-02	0.00E+00	8.20E-02
Particles to air	0.00E+00	5.42E-06	5.42E-06

A.1.5 Life Cycle Stage #4: Product Transportation – Electrical Grid

Once the electricity is produced and sent through the switchyard and trunkline system it is ready for transmission, via the grid, to the user. A seven percent loss in electricity during transmissions was assumed for all the NETL Power LCA studies (Bergerson, 2005; EIA, 2007). This loss only impacts the cost parameters as no environmental inventories are associated with transmission loss. **Table A-27** shows how this loss is captured in the GaBi modeling framework. The transmission line was considered existing infrastructure, therefore the construction of the line, along with the associated costs, emissions and land use changes was not included within the system boundaries for this study.

Table A-27: Stage #4 Transmission Loss

Parameter	Formula	Value	Comments
Elec_loss		7%	Transmission line loss (EIA 2005)
Pow_loss	$100/(100-\text{Elec_loss})$	1.0753	[%] Electricity input to the transmission line.

SF₆ leakage rate from the U.S. transmission and distribution grid are estimated using information collected and compiled from the US EPA's "SF₆ Emission Reduction Partnership for Electric Power Systems" (EPA, 2007). Data is collected and compiled from various members of the partnership, which in 2006, represented 42 percent of the U.S. grid in terms of U.S. transmission mileage.

EPA utilizes the aforementioned data to develop the "Inventory of US Greenhouse Gas Emissions and Sinks" (EPA, 2008e). In preparing the national SF₆ leakage estimate, EPA assumes that "partners commit to reducing SF₆ emissions through technically and economically feasible means. However, non-partners were assumed not to have implemented any changes that would have reduced emissions over time."

It was noted that in 2007 and 2008, the partnership continued to grow but there was no quantification of the percent representation of the U.S. power grid. Therefore, it has been assumed that in 2007, the partnership represented 42 percent of the U.S. grid (conservative estimate which will result in slightly higher SF₆ emissions estimate). For this analysis, it is assumed that the SF₆ leak rate for non-partners (remaining 58 percent of the U.S. grid transmission mileage) will be twice that of non-partners. This value could be entered as a parameter and could be varied in a sensitivity analysis. Note that SF₆ emissions calculated in this manner exceed EPA's estimates by 5 percent (EPA, 2008e).

A.1.6 Life Cycle Stage #5: End User – Electricity Consumption

Finally, the electricity is delivered to the end user in LC Stage #5. All NETL power generation LCA studies assume electricity is used by a non-specific, 100 percent efficient process. This assumption avoids the need to define a unique user profile, and allows all power generation studies to be compared on equal footing. Therefore, no environmental inventories were collected for Stage #5.

References

- American Petroleum Institute,(2004). Compendium of Greenhouse Gas Emissions. API.
http://www.api.org/ehs/climate/new/upload/2004_COMPENDIUM.pdf.
- Amsted Rail,(2008). ASF Truck Assemblies, Side Frames, Bolsters [cited November 10 2008]
Available from: <http://www.amstedrail.com/freightcar/sideframesbolsters.asp>.
- Aspen Environmental Group,(2008). Transmission Line Construction [cited July 30 2008]
Available from: ftp://ftp.cpuc.ca.gov/gopher-data/environ/tehachapi_renewables/FS6.pdf.
- Australian Taxation Office,(2008). Taxation Ruling. Australian Government [cited March 3 2009] Available from:
<http://law.ato.gov.au/atolaw/view.htm?docid=TXR/TR20084/NAT/ATO/00001>.
- Battye, R., Battye, W., Overcash, C., et al.,(1994). Development and Selection of Ammonia Emission Factors. U.S. Environmental Protection Agency, Office of Research and Development.
- Bay Area Rapid Transit,(2004). BART Facilities Standards, Section 07 60 00 [cited November 10, 2008] Available from: http://www.bart.gov/docs/STD_SPEC/076000.pdf.
- Bergerson, Joule Andrea. (2005). Future Electricity Generation: An Economic and Environmental Perspective on Near-, Mid- and Long-Term Technology Options and Policy Implementations, Carnegie Mellon University, Pittsburgh, Pennsylvania.
- Blackman, J. and Averyt, M. (2006). SF₆ Leak Rates from High Voltage Circuit Breakers - U.S. E.P.A. Investigates Potential Greenhouse Gas Emissions Source. Paper presented at IEEE Power Engineering Society General Meeting, at Montreal, Quebec, Canada.
- BNSF Railway Company, Canadian Pacific, CSX Transportation, et al.,(2009). Railroad Performance Measures, Updated Weekly (1999-2009) [cited April 6, 2009] Available from: <http://www.railroadpdm.org/home/rpm.aspx>.
- Brown, Bruce. (2008). Personal Communication via Email.
- Brune, P. (2008). A Pain in the Ice: Nebraska Public Power District 2007 Ice Storm. Paper presented at Edison Electric Institute Spring 2008 Conference.
- Bruniany, Cas. (2008). E-mail Interview.
- Bryja, James J., Conklin, Douglas R., Robinson, Robert L., et al. (2004). "Two Meter Shields: From Vision to Reality". Engineering and Mining Journal.
http://findarticles.com/p/articles/mi_qa5382/is_/ai_n21354951
- Bucyrus,(2008). Bucyrus International, Inc. Continuous Miners] Available from:
<http://www.bucyrus.com/continuousminers.htm>.
- Buildings Direct,(2009). Paneling System. Buildingsdirect.net [cited February 17, 2009]
Available from: http://buildingsdirect.net/building-products_paneling.html.
- Calpine/Bechtel,(2001). Application for Certification: Russell City Energy Center, Appendix 8.1E: Construction Emissions and Impact Analysis. California Energy Commission, Hayward, California. <http://www.energy.ca.gov/sitingcases/russellcity/index.html>.
- CapX 2020,(2007). Proposed Transmission Line Infrastructure [cited October 28 2008]
Available from: http://www.capx2020.com/Images/Transmission_Line_Factsheet_1.pdf
- Conaway, Christopher H., Mason, Robert P., Steding, Douglas J., et al. (2005). "Estimate of mercury emission from gasoline and diesel fuel consumption, San Francisco Bay area, California". Atmospheric Environment **39** (1):101-105.
<http://www.sciencedirect.com/science/article/B6VH3-4DPC3KY-2/2/f5afa2357561d9a8485df82f60084a68>

- Cornell Hatch,(2008). Interim Report: Environmental Evaluation of Fugitive Coal Dust Emissions from Coal Trains Goonyella, Blackwater, and Moura Coal Rail Systems. Queensland Rail Limited, Australia. Reference H_327578.
- CRSI, Concrete Reinforcing Steel Institute. (2008). "ASTM Standard Inch-Pound Reinforcing Bars". <http://www.crsi.org/rebar/metric.html>.
- CWLP,(2009). Building a New Power Plant. City Water, Light & Power, Electric Division, Springfield, Illinois [cited April 9 2009] Available from: http://www.cwlp.com/electric_division/generation/build_new_plant.htm.
- Davis, Leroy,(2007). Reference & Information: American Wire Gauge Cable Descriptions. Interfacebus.com [cited February 17, 2009] Available from: http://www.interfacebus.com/Copper_Wire_AWG_Size.html.
- Department of Transport [UK],(2009). Regulatory Impact Assessment (RIA) on NRMM Emissions. <http://www.dft.gov.uk/pdf/consultations/aboutria/ria/nrmmemissions>.
- DNR. (2006). "Annual Statistic Report". Illinois Department of Natural Resources, <http://dnr.state.il.us/mines/public/>.
- DNR, Department of Natural Resources,(2008). Applications for Underground Mine Permits, #382 and #399. State of Illinois [cited 10/08/2008] Available from: <http://dnr.state.il.us/mines/lrd/applications.htm>.
- DOI,(2009). Draft Environmental Impact Statement - Proposed Red Cliff Mine Project and Federal Coal Lease by Applications, Appendix H: Air Quality Analysis Modeling Report. Bureau of Land Management. <http://www.blm.gov/rmp/co/redcliffmine/documents.htm>.
- DOT,(2002). 2002 Pavement Design Guide: Appendix C. Structural and Climatic Input Federal Highway Administration. <http://www.fhwa.dot.gov/pavement/ltp/pubs/05079/appc.cfm#toc132080751>.
- DOT,(2008). National Transportation Statistics, Table 4-17: Class 1 Rail Freight Fuel Consumption and Travel. Bureau of Transportation Statistics, Department of Transportation. http://www.bts.gov/publications/national_transportation_statistics/html/table_04_17.html
- EIA,(2002). Inventory of Electric Utility Power Plants in the United States 2000. Energy Information Administration, Office of Coal, Nuclear, Electric, and Alternate Fuels. <http://www.eia.doe.gov/cneaf/electricity/ipp/ipp00.pdf>.
- EIA,(2007). Annual Energy Outlook 2007 with Projections to 2030. Energy Information Administration. <http://www.eia.doe.gov/oiaf/archive/aeo07/index.html>. Report Number DOE/EIA-0383(2007).
- Engineers Edge,(2009). Sheet Metal Gauge Sizes. Engineersedge.com [cited February 17, 2009] Available from: <http://www.engineersedge.com/gauge.htm>.
- EPA,(1998). AP 42 Chapter 1: External Combustion Sources, 1.4 Natural Gas Combustion, Supplement D. Available from: <http://www.epa.gov/ttn/chief/ap42/ch01/final/c01s04.pdf>.
- EPA,(2004). Final Regulatory Analysis: Control of Emissions from Nonroad Diesel Engines. U.S. Environmental Protection Agency, Office of Transportation and Air Quality. Report Number EPA420-R-04-007.
- EPA,(2005a). Emission Facts. U.S. Environmental Protection Agency, Office of Transportation and Air Quality. <http://www.epa.gov/OMS/climate/420f05001.htm#calculating>. Report Number EPA420-F-05-001.

- EPA,(2005b). National Emissions Inventory Data & Documentation. U.S. Environmental Protection Agency. Available for download:
<http://www.epa.gov/ttn/chief/net/2005inventory.html>.
- EPA,(2007). SF6 Emission Reduction Partnership for Electric Power Systems : 2006 Annual Report. http://www.epa.gov/electricpower-sf6/documents/sf6_2006_ann_report.pdf.
- EPA,(2008a). Facility Registry System. U.S Environmental Protection Agency. Available from:
http://www.epa.gov/enviro/html/fii/fii_query_java.html.
- EPA,(2008b). Federal Registry: Control of Emissions of Air Pollution From Locomotive Engines and Marine Compression-Ignition Engines Less Than 20 Liters per Cylinder. <http://www.epa.gov/fedrgstr/EPA-AIR/2008/June/Day-30/a7999a.pdf>. 40 CFR Parts 9.85. et al.
- EPA,(2008c). Galatia Mine NPDES Permit Reports 2005-2008. U.S Environmental Protection Agency, Office of Waste Management NPDES.
- EPA,(2008d). Identifying Opportunities for Methane Recovery at U.S. Coal Mines: Profiles of Selected Gassy Underground Coal Mines 2002-2006. U.S. Environmental Protection Agency, Coalbed Methane Outreach Program. Report Number: EPA 430-K-04-003.
- EPA,(2008e). Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990-2006. U.S. Environmental Protection Agency.
<http://www.epa.gov/climatechange/emissions/usinventoryreport.html>. Report Number: US EPA 430-R-08-005.
- EPA,(2009). Clean Energy: eGRID, January 28, 2009 [cited April 6, 2009] Available from:
<http://www.epa.gov/cleanenergy/energy-resources/egrid/index.html>.
- FreightCar America, Inc.,(2008). The BethGon II. [cited November 10 2008] Available from:
<<http://www.freightcaramerica.com/Aluminum-BethGonII.htm>>
- Gale, John and Davison, John. (2004). "Transmission of CO₂ - Safety and Economic Considerations". *Energy* **29**:1319-1328.
- Gay,(2006). Xstrata Rolleston Coal Stacker- Award Winning Design. [cited November 10, 2008] Available from:
<http://www.gayconstructions.com/projects/projects/infrastructure/gcproject.2006-07-19.3975948791>.
- GE Transportation,(2009). Locomotive Facts & History April 6, 2009]] Available from:
<http://www.getransportation.com/na/en/locofacts.html>.
- General Electric,(2008). The Evolution Series Locomotives [cited August 14 2008] Available from: [http://www.getransportation.com/na/en/docs/806527_20020%20-%20B%20Evo\[1\]\[1\].Series.lores.pdf](http://www.getransportation.com/na/en/docs/806527_20020%20-%20B%20Evo[1][1].Series.lores.pdf).
- General Switchgear & Controls,(2008). Aluminum Vertical Break Disconnect Switch 7.5kV. to 345kV. 1200 to 4000 Amp, Bulletin T2050-1 [cited August 4 2008] Available from:
<http://www.gs.on.ca/acrobat/AVBCAT.PDF>.
- George Third & Son. (2006). "Advertisement ". *Construction Business* **3** (6).
http://www.accesshealthabbotford.ca/pdf/AHACConstruction_BusinessOct2006.pdf
- Goodyear,(2008a). Conveyor Belt- Heavyweight [cited November 10, 2008] Available from:
<http://www.goodyear.com/ProductsDetail.aspx?id=1596>.
- Goodyear,(2008b). Flexsteel Belt Construction [cited April 3, 2009] Available from:
<http://pdf.directindustry.com/pdf/goodyear-conveyor-belts/flexsteel-14258-23620.html>.
- Gorokhov, Victor, Manfredo, Lynn, Ratafia-Brown, Jay, et al. (2002). "Life-cycle Analysis of Advanced Power Generation Systems". *Technology* **8**:217-228.

- Heddle, Gemma, Herzog, Howard and Klett, Michael,(2003). The Economics of CO₂ Storage. Massachusetts Institute of Technology, Laboratory for Energy and the Environment. http://sequestration.mit.edu/pdf/LFEE_2003-003_RP.pdf. MIT LFEE 2003-003 RP.
- Hill, Robert, O'Keefe, Phil and Snape, Colin. (1995). The Future of Energy Use: Macmillan.
- Hillsboro Energy. (2007). Coal Mining and Reclamations Permit Application for Deer Run Mine.
- HVB AE Power Systems,(2003). Dead Tank SF₆ Gas Circuit Breakers. HVB AE Power Systems, Inc. [cited July 30 2008] Available from: http://www.hvbi.com/Products/GCB/HPI/GCB%20362kV-550%20HPI%20info_V2.pdf.
- ICRR,(2007). Rail Specifications: American Railway Engineering Association Rails. Mississippi Information Web Site, [cited November 10 2008] Available from: <http://www.icrr.net/rails.htm>
- Joy Mining Machinery. (2008). "New Mountain Laurel Complex Successfully Installs State-of-the-Art JOY Longwall System". ThomasNet Industrial News Room, <http://news.thomasnet.com/companystory/816524>.
- Keidy Electro-Mechanical Company,(2008). SF₆ Circuit Breaker Porcelain Bushing [cited August 4 2008] Available from: <http://www.keidy.com/electric/1-1/16-1.htm>.
- Koornneef, Joris, van Keulen, Tim, Faaij, André, et al. (2008). "Life cycle assessment of a pulverized coal power plant with post-combustion capture, transport and storage of CO₂". International Journal of Greenhouse Gas Control 2 (4):448-467. <http://www.science-direct.com/science/article/B83WP-4T24FXP-2/2/7b014fe251d8ab6d3b0962e992e4c248>
- Leed. (2006). "Onesteel SMR Crushing Plant Upgrade: Concrete Works and Reinforced Earth Wall Construction, Iron Duke, SA". Leed Engineering and Construction, http://www.leed.net.au/pdfs_projects/J101%20-%20Iron%20Duke%20Crushing%20Plant.pdf.
- Lexco,(2006). Custom Cable Assemblies: 7x7 GAC (Galvanized Aircraft Cable) [cited November 10, 2008] Available from: http://www.lexcocable.com/7x7_aircraft_cable.html#gac.
- Loos,(2006). Item # GC 18877 7x7 Preformed Galvanized Aircraft Cable [cited November 10, 2008] Available from: <http://www.loosco.com/>.
- Mack, Stanley and Patchett, Joseph. (1997). SCR Catalyst Management Strategies to Reduce Operating Expenses. Paper presented at Conference on Selective Catalytic and Non-Catalytic Reduction for NO_x Control.
- Metal Suppliers Online,(2009). Carbon Steels Cold Rolled Steel. Suppliersonline.com [cited February 17, 2009] Available from: <http://www.suppliersonline.com/Research/Property/result.asp?FamilyID=4&MetalID=1075&Chemical=1&Physical=1&Mechanical=1>.
- Mithethwa, Mzingaye,(2004). The Impact of Power Generation Projects on the Steel Industry. China Steel Construction Society [cited April 1 2009] Available from: <http://www.cncscs.org/saisc/The%20impact%20of%20power%20generation%20projects%20on%20the%20steel%20industry.pdf>
- NETL,(2010). Cost and Performance Baseline for Fossil Energy Plants: Volume 1. Department of Energy, National Energy Technology Laboratory, Pittsburgh, Pennsylvania. Report Number DOE/NETL-2007/1281.
- NETL,(2007b). Power Plant Usage and Loss Study. National Energy Technology Laboratory.

- Odeh, Naser A. and Cockerill, Timothy T. (2008). "Life Cycle Analysis of UK Coal Fired Power Plants". *Energy Conversion and Management* **49**:212-220.
- Pehnt, Martin and Henkel, Johannes. (2009). "Life cycle assessment of carbon dioxide capture and storage from lignite power plants". *International Journal of Greenhouse Gas Control* **3** (1):49-66. <http://www.sciencedirect.com/science/article/B83WP-4T72K6K-1/2/98dc4f678050645d3752da6a8f069507>
- Penncrusher,(2008). Reversible Impactors [cited November 12, 2008] Available from: http://www.penncrusher.com/Size_Reduction/Models/Impactors_reversible.cfm.
- Penncrusher,(2009). Bradford Breakers [cited April 3, 2009] Available from: http://www.penncrusher.com/Size_Reduction/Size_Reduction_Brochures.cfm.
- Peterson, P.,(2005). The Future of Nuclear Energy Policy: A California Perspective. Department of Nuclear Engineering, University of California [cited April 1 2009] Available from: http://www.nuc.berkeley.edu/news/CEC/CEC_Nuclear_Workshop_PFP_8=051.pdf
- Phelps Dodge,(2005). Aluminum Conductors, Aluminum-Clad Steel Reinforced. Phelps Dodge International Corporation [cited October 6 2008] Available from: <http://www.pdic.com/NR/rdonlyres/23379782-8EF2-498B-894A-95D881E64BEB/0/PDIC01048.pdf>
- Phillips Machine Service,(2007). Phillips Machine The Freedom Car [cited September 15th, 2008] Available from: <http://www.phillipsmachine.com/freedomcar.php>.
- Portland Cement Association,(2008). Concrete Technology [cited July 30 2008] Available from: http://www.cement.org/tech/faq_unit_weights.asp.
- Power Prime Pumps,(2008). DV-300E Product Specifications [cited November 14, 2008] Available from: <http://www.powerprime.com/default.htm>.
- Reddy, Satish, Johnson, Dennis and Gilmartin, John,(2008). Fluor's Econamine FG PlusSM Technology for CO₂ Capture at Coal-fired Power Plants. Fluors.
- Roberts & Schaefer,(2007). Slope Conveyor: Kerr McGee Coal Corporation Slope Conveyor for the Galatia Mine, Galatia, Illinois. Roberts & Schaefer Company [cited November 10, 2008] Available from: <http://www.r-s.com/projects/84KZ16.htm>
- Roberts & Schaefer Company,(2007). Slope Conveyor: Kerr McGee Coal Corporation Slope Conveyor for the Galatia Mine [cited 5/27/2008] Available from: <http://www.r-s.com/projects/84KZ16.htm>.
- Roncal, Marco. (2009). Citation of Personal Communication for NETL Power LCA.
- Saginaw,(2009). Steel Reference Handbook. Saginawpipe.com [cited February 19, 2009] Available from: http://www.saginawpipe.com/Saginaw_Steel_Reference_Handbook.pdf.
- Sandvik. (2003). "Sandvick Conveyor Components: Conveyor Pulley". Sandvik Mining and Construction, [http://www.miningandconstruction.sandvik.com/sandvik/0120/Internet/global/S003713.nsf/Alldocs/Products*5CConveyors*and*conveyor*components*5CPulleys*and*take*2D up*devices*2AMedium*duty*locking*element*pulleys/\\$file/DK-BK-eng.pdf](http://www.miningandconstruction.sandvik.com/sandvik/0120/Internet/global/S003713.nsf/Alldocs/Products*5CConveyors*and*conveyor*components*5CPulleys*and*take*2D up*devices*2AMedium*duty*locking*element*pulleys/$file/DK-BK-eng.pdf).
- Sandvik. (2004). "Pulleys, Idlers, and Materials Handling Systems: Catalogue Medium to Heavy Duty Idler". Sandvik Mining and Construction, [http://www.miningandconstruction.sandvik.com/sandvik/0120/Internet/global/S003713.nsf/Alldocs/Products*5CConveyors*and*conveyor*components*5CIdlers*2AMedium*Duty*Idlers/\\$file/Idlers%20-%20Medium%20to%20Heavy%20Duty.pdf](http://www.miningandconstruction.sandvik.com/sandvik/0120/Internet/global/S003713.nsf/Alldocs/Products*5CConveyors*and*conveyor*components*5CIdlers*2AMedium*Duty*Idlers/$file/Idlers%20-%20Medium%20to%20Heavy%20Duty.pdf).
- Skone, Tim. (2008). Life Cycle Assesment Meeting Notes.Pittsburgh PA.

- SMUD,(2001). Application for Certification for the Consumnes Power Plant Project. Sacramento Municipal Utility District. <http://www.energy.ca.gov/sitingcases/smud/>.
- Spath, Pamela L., Mann, Margaret K. and Keer, Dawn R.,(1999). Life Cycle Assessment of Coal-fired Power Production. NREL. NREL/TP-570-25119.
- Steel Building,(2009). General Specification for Steel Buildings. Steelbuilding.com [cited February 17, 2009] Available from: http://www.steelbuilding.com/buildings/panel_specifications.htm.
- The Engineering ToolBox,(2009). Resource Tools and Basic Information for Engineering and Design of Technical Applications] Available from: <http://www.engineeringtoolbox.com/>.
- TIAX LLC,(2007). Full Fuel Cycle Assessment Well to Tank Energy Inputs, Emissions, and Water Impacts. California Energy Commission. <http://www.energy.ca.gov/2007publications/CEC-600-2007-002/CEC-600-2007-002-D.PDF>.
- Tokimatsu, Koji, Kosugi, Takanobu, Asami, Takayoshi, et al. (2006). "Evaluation of lifecycle CO₂ emissions from the Japanese electric power sector in the 21st century under various nuclear scenarios". *Energy Policy* **34** (7):833-852. <http://www.sciencedirect.com/science/article/B6V2W-4DDR74D-1/2/0ba452ea277fb229a1c99e7be30915fe>
- Trinity Rail,(2008). 4,402 Cubic Foot Aluminum Rotary Gondola [cited November 10, 2008] Available from: <http://www.trinityrail.com/railcars/coal/pdfs/Web%204402%20Alum%20Rotary%20Gondola%20Spec.pdf>.
- U.S. Department of Commerce,(2004). Bituminous Coal Underground Mining: 2002. US Census Bureau, Economics and Statistics Administration. <http://www.census.gov/prod/ec02/ec0221i212112.pdf>.
- Wabash Power Equipment Company,(2009). 40000 PPH Nebraska, Watertube, Trailer mounted, 350 psi, gas/oil. Surplusrecord.com, [cited February 2 2009] Available from: <http://www.surplusrecord.com/cgi-bin/adpop.pl?097693>.
- Weather Bureau,(2008). Frostline Map [cited November 10, 2008] Available from: http://www.nextlevelsolutionz.com/images/Frostline_Map.jpg.
- Widiyanto, Anugerah. (2003). "Environmental Impact Analysis of Indonesian Electric Generation Systems". *JSME International Journal Series B* **46** (4):650-659.