

# COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES



April 12, 2022

DOE/NETL-2022/3241

## **Disclaimer**

This project was funded by the United States Department of Energy, National Energy Technology Laboratory, in part, through a site support contract. Neither the United States Government nor any agency thereof, nor any of their employees, nor the support contractor, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

All images in this report were created by NETL, unless otherwise noted.

**Eric Lewis**<sup>1</sup>: Methodology, Formal Analysis, Writing;  
**Shannon McNaul**<sup>1,2</sup>: Formal Analysis, Writing; **Matthew Jamieson**<sup>1</sup>:  
Data Curation, Validation, Writing; **Megan S. Henriksen**<sup>1,2</sup>: Formal  
Analysis, Writing; **H. Scott Matthews**<sup>1,2</sup>: Writing; **John White**<sup>1,2</sup>: Formal  
Analysis; **Liam Walsh**<sup>1,2</sup>: Writing; **Jadon Grove**<sup>1,2</sup>: Formal Analysis; **Travis  
Shultz**<sup>1</sup>: Conceptualization, Supervision; **Timothy J. Skone, P.E.**<sup>1</sup>:  
Conceptualization, Supervision; **Robert Stevens**<sup>1\*</sup>: Project  
Administration

<sup>1</sup>National Energy Technology Laboratory (NETL)

<sup>2</sup>NETL support contractor

\*Corresponding contact: [Robert.Stevens@netl.doe.gov](mailto:Robert.Stevens@netl.doe.gov)

*This report was peer reviewed by independent subject matter experts to ensure that information presented is based on sound and credible science, considered technically proficient, properly documented, and compliant with established quality requirements. We thank the valuable efforts of the independent peer reviewers for their contributions to this report. Any omission or errors are the responsibility of the authors and not the peer reviewers.*

---

This page intentionally left blank



# TABLE OF CONTENTS

---

List of Exhibits .....	v
Acronyms and Abbreviations.....	x
Executive Summary .....	1
Results Analysis.....	5
Opportunities for Future R&D .....	13
1 Introduction.....	14
1.1 Unit Configurations.....	15
1.1.1 Literature Review.....	15
1.1.2 Case Selection Rationale.....	18
2 General Evaluation Basis .....	21
2.1 Site Characteristics.....	21
2.2 Coal Characteristics .....	24
2.3 Natural Gas Characteristics .....	26
2.4 Biomass Characteristics .....	26
2.5 Biomass Supply and Cost .....	27
2.6 Hydrogen Product Specification.....	29
2.7 Environmental Targets .....	30
2.7.1 Air Emissions Targets .....	30
2.7.2 Water Emissions Targets .....	31
2.7.3 Carbon Dioxide .....	32
2.8 Life Cycle Analysis of Greenhouse Gas Emissions.....	33
2.9 Capacity Factor.....	38
2.9.1 Capacity Factor Assumptions .....	38
2.9.2 Capacity Factor for Reforming Plants .....	38
2.9.3 Capacity Factor for Gasification Plants .....	38
2.9.4 Capacity Factor for Plants with Carbon Capture .....	39
2.10 Raw Water Withdrawal and Consumption .....	39
2.11 Cost Estimating Methodology .....	40
2.11.1 Capital Costs .....	41
2.11.2 Operation and Maintenance Costs .....	45
2.11.3 CO <sub>2</sub> Transport and Storage.....	47
2.11.4 LCOH and Breakeven CO <sub>2</sub> Sales Price and Stack Emissions Penalty .....	48
3 Reforming Plants.....	51
3.1 Key System Assumptions.....	51
3.1.1 Balance of Plant.....	52
3.2 Sparing Philosophy .....	52
3.3 Reforming Common Process Areas .....	53
3.3.1 Natural Gas Supply System .....	53
3.3.2 Sulfur Polishing.....	53
3.3.3 Prereformer .....	53
3.3.4 Water Gas Shift Reactors.....	54

3.3.5	Hydrogen Production .....	54
3.3.6	Accessory Electric Plant .....	55
3.3.7	Process Water Systems .....	55
3.3.8	Instrumentation and Control.....	56
3.3.9	Miscellaneous Systems.....	56
3.3.10	Performance Summary Metrics .....	56
3.4	Case 1 – Steam Methane Reforming Plant Without CO <sub>2</sub> Capture Process	
	Description.....	58
3.4.1	Steam Methane Reformer .....	62
3.4.2	Convective Heat Recovery Section .....	62
3.5	Case 1 – Performance Results.....	62
3.5.1	Environmental Performance .....	64
3.5.2	Energy and Mass Balance Diagrams.....	66
3.6	Case 1 – Major Equipment List .....	69
3.7	Case 1 – Cost Estimating .....	71
3.8	Case 2 – Steam Methane Reforming Plant with CO <sub>2</sub> Capture Process	
	Description.....	77
3.8.1	Steam Methane Reformer .....	81
3.8.2	Convective Heat Recovery Section .....	81
3.8.3	Acid Gas Removal .....	81
3.8.4	CO <sub>2</sub> Compression and Drying System .....	83
3.9	Case 2 – Performance Results.....	85
3.9.1	Environmental Performance .....	87
3.9.2	Energy and Mass Balance Diagrams.....	90
3.10	Case 2 – Major Equipment List .....	93
3.11	Case 2 – Cost Estimating .....	95
3.12	Case 3 – Autothermal Reforming Plant with CO <sub>2</sub> Capture Process	
	Description.....	101
3.12.1	Air Separation Unit .....	105
3.12.2	Autothermal Reformer.....	106
3.12.3	Acid Gas Removal .....	107
3.12.4	CO <sub>2</sub> Compression and Drying System .....	107
3.12.5	Fired Heater .....	107
3.13	Case 3 – Performance Results.....	108
3.13.1	Environmental Performance .....	109
3.13.2	Energy and Mass Balance Diagrams.....	112
3.14	Case 3 – Major Equipment List .....	115
3.15	Case 3 – Cost Estimating .....	117
3.16	Reforming Case Summary.....	123
3.16.1	Performance Results Summary .....	124
3.16.2	Environmental Results Summary .....	126
3.16.3	Cost Results Summary .....	129
4	Gasification Plants.....	133
4.1	Gasifier Background .....	133
4.2	Key System Assumptions .....	134

4.2.1	Balance of Plant.....	135
4.3	Sparing Philosophy .....	136
4.4	Gasification Common Process Areas .....	136
4.4.1	Coal Receiving and Storage .....	137
4.4.2	Coal Preparation and Feed System.....	137
4.4.3	Air Separation Unit .....	138
4.4.4	Gasifier .....	138
4.4.5	Raw Gas Cooling and Particulate Removal.....	138
4.4.6	Quench Gas Compressor .....	139
4.4.7	Syngas Scrubber.....	139
4.4.8	Water Gas Shift Reactors.....	139
4.4.9	Low Temperature Heat Recovery .....	140
4.4.10	Mercury Removal.....	140
4.4.11	Sulfur Recovery/Tail Gas Cleanup.....	141
4.4.12	Slag Handling .....	144
4.4.13	Steam Generation .....	144
4.4.14	Process Water Systems .....	148
4.4.15	Accessory Electric Plant .....	163
4.4.16	Instrumentation and Control.....	163
4.4.17	Miscellaneous Systems.....	163
4.4.18	Performance Summary Metrics .....	164
4.5	Case 4 – Shell Gasification Plant Without CO <sub>2</sub> Capture Process Description....	165
4.5.1	Acid Gas Removal.....	171
4.5.2	Hydrogen Production .....	172
4.5.3	Steam Generation .....	172
4.6	Case 4 – Performance Results.....	172
4.6.1	Environmental Performance .....	175
4.6.2	Energy and Mass Balance Diagrams.....	178
4.7	Case 4 – Major Equipment List .....	183
4.8	Case 4 – Cost Estimating .....	187
4.9	Case 5 – Shell Gasification Plant with CO <sub>2</sub> Capture Process Description .....	194
4.9.1	Acid Gas Removal.....	200
4.9.2	CO <sub>2</sub> Compression and Drying System .....	202
4.9.3	Hydrogen Production .....	204
4.9.4	Steam Generation .....	204
4.10	Case 5 – Performance Results.....	204
4.10.1	Environmental Performance .....	206
4.10.2	Energy and Mass Balance Diagrams.....	209
4.11	Case 5 – Major Equipment List .....	215
4.12	Case 5 – Cost Estimating .....	220
4.13	Case 6 – Shell Co-Gasification Plant with CO <sub>2</sub> Capture Process Description ...	227
4.13.1	Biomass Receiving and Storage.....	233
4.13.2	Biomass Preparation and Feed Systems.....	233
4.13.3	Acid Gas Removal.....	233

4.13.4	CO <sub>2</sub> Compression and Drying System .....	233
4.13.5	Hydrogen Production .....	233
4.13.6	Steam Generation .....	233
4.14	Case 6 – Performance Results.....	233
4.14.1	Environmental Performance .....	236
4.14.2	Energy and Mass Balance Diagrams .....	239
4.15	Case 6 – Major Equipment List .....	245
4.16	Case 6 – Cost Estimating .....	250
4.17	Gasification Case Summary.....	257
4.17.1	Performance Results Summary .....	258
4.17.2	Environmental Results Summary .....	259
4.17.3	Cost Results Summary .....	263
5	Results Analysis.....	266
5.1	Performance .....	266
5.1.1	Energy Efficiency .....	266
5.1.2	Environmental Emissions .....	267
5.1.3	Water Use .....	272
5.2	Cost Results .....	273
5.2.1	TOC and TASC .....	273
5.2.2	LCOH .....	276
5.2.3	Stack CO <sub>2</sub> Emissions Penalty/Sales Price .....	277
5.3	Sensitivity Analysis .....	278
5.4	Other Analyses.....	286
5.4.1	Hydrogen Compression Credit .....	286
5.4.2	Export Steam Sales Price .....	288
5.4.3	Gasifier Capacity Factor and Sparing.....	288
6	Future Work .....	290
6.1	Reducing Life Cycle GHG Emissions.....	290
6.1.1	Renewable Natural Gas Blending.....	290
6.1.2	Direct Air Capture Pairing .....	291
6.1.3	Low Carbon Auxiliary Power .....	291
6.1.4	Higher CO <sub>2</sub> Capture Rates.....	291
6.2	Advanced Technology Assessments .....	291
6.2.1	Advanced Reforming Concepts.....	292
6.2.2	NG Pyrolysis .....	292
6.2.3	Supercritical Water Gasification.....	292
6.2.4	Advanced H <sub>2</sub> /CO <sub>2</sub> Separation Concepts.....	293
7	References .....	295
	Appendix A: Hydrogen Unit Conversions.....	303
	Appendix B: Detailed Life Cycle Results.....	304

## LIST OF EXHIBITS

---

Exhibit ES-1. Case configuration summary .....	2
Exhibit ES-2. Performance summary and environmental profile for all cases .....	6
Exhibit ES-3. Net plant efficiency (HHV basis) .....	7
Exhibit ES-4. CO <sub>2</sub> e life cycle emissions for all cases.....	9
Exhibit ES-5. Cost summary for all cases .....	11
Exhibit ES-6. LCOH by cost component .....	12
Exhibit 1-1. Global merchant hydrogen fleet production route profile (by supplier) .....	16
Exhibit 1-2. Global merchant hydrogen fleet capacity profile (by supplier) .....	17
Exhibit 1-3. Chinese hydrogen from coal (for ammonia) technology profile .....	17
Exhibit 1-4. Hydrogen production with CCUS (operating and planned) .....	18
Exhibit 1-5. Case descriptions .....	20
Exhibit 2-1. Site characteristics.....	21
Exhibit 2-2. Site ambient conditions .....	22
Exhibit 2-3. Design makeup water quality .....	23
Exhibit 2-4. Design coal .....	24
Exhibit 2-5. Probability distribution of mercury concentration in the Illinois No. 6 coal .....	25
Exhibit 2-6. Natural gas composition .....	26
Exhibit 2-7. Design biomass .....	27
Exhibit 2-8. Wood chip supply chain.....	27
Exhibit 2-9. Woody biomass torrefaction system economic summary .....	28
Exhibit 2-10. Hydrogen product specification .....	29
Exhibit 2-11. BACT environmental design basis for reforming cases .....	30
Exhibit 2-12. BACT environmental design basis for gasification cases .....	31
Exhibit 2-13. New source treated gasification wastewater discharge limits [39].....	32
Exhibit 2-14. Fossil-based hydrogen projects with CO <sub>2</sub> capture .....	32
Exhibit 2-15. Fossil GWP values for select GHGs.....	34
Exhibit 2-16. Case 1 system boundary, steam methane reforming plant without CO <sub>2</sub> capture .....	34
Exhibit 2-17. Case 2 system boundary, steam methane reforming plant with CO <sub>2</sub> capture .....	35
Exhibit 2-18. Case 3 system boundary, autothermal reforming plant with CO <sub>2</sub> capture .....	35
Exhibit 2-19. Case 4 system boundary, coal gasification plant without CO <sub>2</sub> capture .....	36
Exhibit 2-20. Case 5 system boundary, coal gasification plant with CO <sub>2</sub> capture.....	36
Exhibit 2-21. Case 6 system boundary, coal/biomass co-gasification plant with CO <sub>2</sub> capture .....	37
Exhibit 2-22. Capital cost uncertainty ranges .....	40
Exhibit 2-23. Capital cost levels and their elements.....	42
Exhibit 2-24. CO <sub>2</sub> transport and storage costs .....	47
Exhibit 2-25. Nominal and real rates financial structure for hydrogen production .....	48
Exhibit 3-1. Reforming plant study configuration matrix .....	51
Exhibit 3-2. Balance of plant assumptions.....	52
Exhibit 3-3. Case 1 block flow diagram, steam methane reforming plant without CO <sub>2</sub> capture .....	59
Exhibit 3-4. Case 1 stream table, steam methane reforming plant without capture .....	60
Exhibit 3-5. Case 1 plant performance summary .....	63

Exhibit 3-6. Case 1 plant power summary .....	64
Exhibit 3-7. Case 1 air emissions.....	64
Exhibit 3-8. Case 1 carbon balance .....	65
Exhibit 3-9. Case 1 sulfur balance .....	65
Exhibit 3-10. Case 1 water balance.....	66
Exhibit 3-11. Case 1 overall energy balance (0 °C [32 °F] reference) .....	66
Exhibit 3-12. Case 1 steam methane reforming plant without CO <sub>2</sub> capture energy and mass balance.....	67
Exhibit 3-13. Case 1 total plant cost details .....	72
Exhibit 3-14. Case 1 owner's costs .....	75
Exhibit 3-15. Case 1 initial and annual operating and maintenance costs.....	76
Exhibit 3-16. Case 1 LCOH breakdown .....	77
Exhibit 3-17. Case 2 block flow diagram, steam methane reforming plant with CO <sub>2</sub> capture.....	78
Exhibit 3-18. Case 2 stream table, steam methane reforming plant with capture .....	79
Exhibit 3-19. MDEA CO <sub>2</sub> capture process typical flow diagram for reforming plants .....	82
Exhibit 3-20. Cansolv CO <sub>2</sub> capture process typical flow diagram for reforming plants....	83
Exhibit 3-21. CO <sub>2</sub> compressor interstage pressures .....	84
Exhibit 3-22. Case 2 CO <sub>2</sub> vapor dome.....	85
Exhibit 3-23. Case 2 plant performance summary .....	86
Exhibit 3-24. Case 2 plant power summary.....	87
Exhibit 3-25. Case 2 air emissions.....	87
Exhibit 3-26. Case 2 carbon balance .....	88
Exhibit 3-27. Case 2 sulfur balance .....	89
Exhibit 3-28. Case 2 water balance.....	89
Exhibit 3-29. Case 2 overall energy balance (0 °C [32 °F] reference) .....	89
Exhibit 3-30. Case 2 steam methane reforming plant with CO <sub>2</sub> capture energy and mass balance.....	91
Exhibit 3-31. Case 2 total plant cost details .....	96
Exhibit 3-32. Case 2 owner's costs .....	99
Exhibit 3-33. Case 2 initial and annual operating and maintenance costs.....	100
Exhibit 3-34. Case 2 LCOH breakdown .....	101
Exhibit 3-35. Case 3 block flow diagram, autothermal reforming plant with CO <sub>2</sub> capture .....	102
Exhibit 3-36. Case 3 stream table, autothermal reforming plant with capture .....	103
Exhibit 3-37. Typical ASU process schematic .....	105
Exhibit 3-38. Case 3 plant performance summary .....	108
Exhibit 3-39. Case 3 plant power summary.....	109
Exhibit 3-40. Case 3 air emissions.....	109
Exhibit 3-41. Case 3 carbon balance .....	110
Exhibit 3-42. Case 3 sulfur balance .....	111
Exhibit 3-43. Case 3 water balance.....	111
Exhibit 3-44. Case 3 overall energy balance (0 °C [32 °F] reference) .....	112
Exhibit 3-45. Case 3 autothermal reforming plant with CO <sub>2</sub> capture energy and mass balance.....	113
Exhibit 3-46. Case 3 total plant cost details .....	118
Exhibit 3-47. Case 3 owner's costs .....	121
Exhibit 3-48. Case 3 initial and annual operating and maintenance costs.....	122

Exhibit 3-49. Case 3 LCOH breakdown .....	123
Exhibit 3-50. Estimated performance results for all reforming cases .....	123
Exhibit 3-51. Net plant efficiency (HHV basis) for all reforming cases .....	125
Exhibit 3-52. CO <sub>2</sub> e life cycle emissions for all reforming cases .....	126
Exhibit 3-53. Water use for all reforming cases .....	128
Exhibit 3-54. Plant capital cost for all reforming cases.....	129
Exhibit 3-55. LCOH for all reforming cases.....	130
Exhibit 4-1. Gasification plant study configuration matrix.....	134
Exhibit 4-2. Balance of plant assumptions.....	135
Exhibit 4-3. Typical three-stage Claus sulfur plant .....	142
Exhibit 4-4. Gasification steam conditions .....	145
Exhibit 4-5. Example diagram of an ejector type venturi scrubber .....	149
Exhibit 4-6. Simplified syngas scrubber block flow diagram.....	150
Exhibit 4-7. Simplified low temperature heat recovery system .....	151
Exhibit 4-8. Typical operating parameters for sour water strippers.....	152
Exhibit 4-9. Simplified sour water stripper diagram.....	153
Exhibit 4-10. Example diagram of a spray tower absorption column.....	155
Exhibit 4-11. Example diagram of a process water drum .....	156
Exhibit 4-12. Gasification wastewater quality .....	157
Exhibit 4-13. Simplified diagram of vacuum flash system.....	159
Exhibit 4-14. Example diagram of a brine concentrator .....	161
Exhibit 4-15. Example diagram of a forced-circulation, steam-driven crystallizer.....	162
Exhibit 4-16. Case 4 block flow diagram, Shell gasification plant without CO <sub>2</sub> capture	166
Exhibit 4-17. Case 4 stream table, Shell gasification plant without capture .....	167
Exhibit 4-18. Flow diagram for a conventional single-stage AGR unit .....	171
Exhibit 4-19. Case 4 plant performance summary .....	173
Exhibit 4-20. Case 4 plant power summary .....	174
Exhibit 4-21. Case 4 air emissions.....	175
Exhibit 4-22. Case 4 carbon balance .....	176
Exhibit 4-23. Case 4 sulfur balance .....	176
Exhibit 4-24. Case 4 water balance .....	176
Exhibit 4-25. Case 4 overall energy balance (0 °C [32 °F] reference) .....	177
Exhibit 4-26. Case 4 coal gasification and ASU energy and mass balance .....	179
Exhibit 4-27. Case 4 syngas cleanup energy and mass balance .....	180
Exhibit 4-28. Case 4 hydrogen purification and power block energy and mass balance .....	181
Exhibit 4-29. Case 4 total plant cost details .....	188
Exhibit 4-30. Case 4 owner's costs .....	192
Exhibit 4-31. Case 4 initial and annual operating and maintenance costs.....	192
Exhibit 4-32. Case 4 LCOH breakdown .....	194
Exhibit 4-33. Case 5 block flow diagram, Shell gasification plant with CO <sub>2</sub> capture.....	195
Exhibit 4-34. Case 5 stream table, Shell gasification plant with capture.....	196
Exhibit 4-35. Flow diagram for a conventional two-stage AGR unit .....	200
Exhibit 4-36. CO <sub>2</sub> compressor interstage pressures .....	202
Exhibit 4-37. Case 5 CO <sub>2</sub> compressor enthalpy versus pressure operating profile .....	203
Exhibit 4-38. Case 5 plant performance summary .....	204
Exhibit 4-39. Case 5 plant power summary .....	205
Exhibit 4-40. Case 5 air emissions.....	207

Exhibit 4-41. Case 5 carbon balance .....	207
Exhibit 4-42. Case 5 sulfur balance .....	208
Exhibit 4-43. Case 5 water balance .....	208
Exhibit 4-44. Case 5 overall energy balance (0 °C [32 °F] reference) .....	209
Exhibit 4-45. Case 5 coal gasification and ASU energy and mass balance .....	211
Exhibit 4-46. Case 5 syngas cleanup energy and mass balance .....	212
Exhibit 4-47. Case 5 hydrogen purification and power block energy and mass balance .....	213
Exhibit 4-48. Case 5 total plant cost details .....	221
Exhibit 4-49. Case 5 owner's costs .....	225
Exhibit 4-50. Case 5 initial and annual operating and maintenance costs .....	225
Exhibit 4-51. Case 5 LCOH breakdown .....	227
Exhibit 4-52. Case 6 block flow diagram, Shell co-gasification plant with CO <sub>2</sub> capture	228
Exhibit 4-53. Case 6 stream table, Shell co-gasification plant with capture .....	229
Exhibit 4-54. Case 6 plant performance summary .....	234
Exhibit 4-55. Case 6 plant power summary .....	235
Exhibit 4-56. Case 6 air emissions .....	236
Exhibit 4-57. Case 6 carbon balance .....	237
Exhibit 4-58. Case 6 sulfur balance .....	237
Exhibit 4-59. Case 6 water balance .....	237
Exhibit 4-60. Case 6 overall energy balance (0 °C [32 °F] reference) .....	238
Exhibit 4-61. Case 6 coal gasification and ASU energy and mass balance .....	241
Exhibit 4-62. Case 6 syngas cleanup energy and mass balance .....	242
Exhibit 4-63. Case 6 hydrogen purification and power block energy and mass balance .....	243
Exhibit 4-64. Case 6 total plant cost details .....	251
Exhibit 4-65. Case 6 owner's costs .....	255
Exhibit 4-66. Case 6 initial and annual operating and maintenance costs .....	255
Exhibit 4-67. Case 6 LCOH breakdown .....	256
Exhibit 4-68. Estimated performance results for all gasification cases .....	257
Exhibit 4-69. Net plant efficiency (HHV basis) for all gasification cases .....	259
Exhibit 4-70. CO <sub>2</sub> e life cycle emissions for all gasification cases .....	260
Exhibit 4-71. Water use for all gasification cases .....	262
Exhibit 4-72. Plant capital cost for all gasification cases .....	263
Exhibit 4-73. LCOH for all gasification cases .....	264
Exhibit 5-1. Estimated performance results for all cases .....	266
Exhibit 5-2. Plant efficiencies for all cases (HHV basis) .....	267
Exhibit 5-3. SO <sub>2</sub> , NO <sub>x</sub> , and PM emissions for all cases .....	268
Exhibit 5-4. Hg emissions for all cases .....	269
Exhibit 5-5. CO <sub>2</sub> e life cycle emissions for all cases .....	270
Exhibit 5-6. Water use for all cases .....	272
Exhibit 5-7. Cost summary for all cases .....	273
Exhibit 5-8. Plant capital costs .....	275
Exhibit 5-9. LCOH by cost component .....	277
Exhibit 5-10. Breakeven stack CO <sub>2</sub> emissions penalty/sales price using equivalent non-capture cases .....	278
Exhibit 5-11. LCOH sensitivity to coal fuel costs .....	279
Exhibit 5-12. LCOH sensitivity to biomass fuel costs .....	280

Exhibit 5-13. LCOH sensitivity to natural gas fuel costs.....	281
Exhibit 5-14. LCOH sensitivity to grid electricity price .....	282
Exhibit 5-15. LCOH sensitivity to capacity factor .....	283
Exhibit 5-16. LCOH sensitivity to stack CO <sub>2</sub> emissions price .....	284
Exhibit 5-17. GWP sensitivity to electricity source .....	285
Exhibit 5-18. GWP sensitivity to natural gas supply chain methane emissions .....	286
Exhibit 5-21. Hydrogen compression credit applied to LCOH for all cases .....	288
Exhibit 5-22. LCOH impact from gasifier train sparing.....	289
Exhibit 6-1. NETL-funded advanced H <sub>2</sub> /CO <sub>2</sub> R&D projects .....	293
Exhibit A-1. Equivalent hydrogen capacities in various units .....	303
Exhibit B-1. Life cycle GHG emissions for all hydrogen scenarios (IPCC AR5, 100-yr) (lb CO <sub>2</sub> e/lb H <sub>2</sub> ) .....	304
Exhibit B-2. Life cycle GHG emissions for all hydrogen scenarios (IPCC AR5, 100-yr) (lb CO <sub>2</sub> e/MMBtu H <sub>2</sub> ) .....	304
Exhibit B-3. Life cycle GHG emissions for all hydrogen scenarios (IPCC AR5, 100-yr) (kg CO <sub>2</sub> e/MJ H <sub>2</sub> ) .....	305
Exhibit B-4. GWP results for all cases by IPCC scenario (lb CO <sub>2</sub> e/lb H <sub>2</sub> ) .....	305
Exhibit B-5. GWP results for all cases and across six GWP methods (lb CO <sub>2</sub> e/lb H <sub>2</sub> ) .....	306
Exhibit B-6. Summary of GWP factors used in all IPCC scenarios [41] [111] .....	307

## ACRONYMS AND ABBREVIATIONS

---

AACE	Association for the Advancement of Cost Engineering	CCUS	Carbon capture, utilization, and storage
abs	Absolute	CDR	Carbon dioxide recovery
AC	Alternating current	CF	Capacity factor
acfm	Actual cubic feet per minute	CFR	Code of Federal Regulations
ACI	Activated carbon injection	CGCU	Cold gas cleanup
ADIP	Aqueous di-isopropanol	CGE	Cold gas efficiency
AF	Availability factor	CH <sub>4</sub>	Methane
AFB	Ash Agglomerating Fluidized Bed	CH <sub>4</sub> S	Methanethiol
AGR	Acid gas removal	Cl <sup>-</sup>	Chloride ion
ANSI	American National Standards Institute	CL	Closed-loop
Ar	Argon	cm	Centimeter
Aspen	Aspen Plus®	CO	Carbon monoxide
ASU	Air separation unit	CO <sub>2</sub>	Carbon dioxide
atm	Atmosphere	CO <sub>2</sub> e	Carbon dioxide equivalent
ATR	Autothermal reforming	COE	Cost of electricity
B&V	Black & Veatch	COS	Carbonyl sulfide
BACT	Best Available Control Technology	CS	Carbon steel
Bara	Bar absolute	CT	Combustion turbine
barg	Bar gauge	CTG	Combustion turbine-generator
BDL	Blowdown losses	CWP	Circulating water pump
BEC	Bare erected cost	CWR	Cooling water return
BEP	Breakeven emissions penalty	CWS	Circulating water system
BFD	Block flow diagram	CWT	Cold water temperature
BFW	Boiler feedwater	DAC	Direct air capture
BOP	Balance of plant	db, DB	Dry basis
BSP	Breakeven sales price	DBQ	Dry Bottom Quench
Btu	British thermal unit	DC	Direct current
Btu/hr	British thermal units per hour	DCS	Distributed control system
Btu/kWh	British thermal units per kilowatt hour	DI	De-ionized
Btu/lb	British thermal units per pound	DIPA	Diisopropanolamine
Btu/scf	British thermal units per standard cubic foot	DLN	Dry low NO <sub>x</sub>
CaCO <sub>3</sub>	Calcium carbonate	DME	Di-methyl ether
CaSO <sub>4</sub>	Calcium sulfate	DOE	Department of Energy
CB&I	Chicago Bridge & Iron Company	DSC	Dry Syngas Cooler
CCS	Carbon capture and storage	DSI	Dry sorbent injection
		E-Gas™	CB&I gasifier technology
		EAF	Equivalent availability factor
		ECUST	East China University of Science and Technology
		EGU	Electric utility steam generating unit
		ELG	Effluent Limitation Guidelines

EMF	Emission modification factors	H <sub>2</sub> S	Hydrogen sulfide
Eng'g CM H.O.& Fee	Engineering, construction management, home office and fees	HCl	Hydrochloric acid
EOR	Enhanced oil recovery	HCO <sub>3</sub>	Bicarbonate
EPA	Environmental Protection Agency	HDPE	High-density polyethylene
EPC	Engineering, procurement and construction	Hg	Mercury
EPCC	Engineering, procurement and construction cost	HHV	Higher heating value
EPRI	Electric Power Research Institute	hp	Horsepower
ERC	Emission reduction credit	HP	High-pressure
ESP	Electrostatic precipitator	HRSG	Heat recovery steam generator
ETE	Effective thermal efficiency	HSS	Heat stable salt
FC	Flow controller	HTL	Hantian Lu
FD	Forced draft	HVAC	Heating, ventilating, and air conditioning
FE	Fossil Energy	HWT	Hot water temperature
FG	Flue gas	HX	Heat exchanger
FGD	Flue gas desulfurization	Hz	Hertz
FRC	Flow rate controller	I&C	Instrumentation and control
FRP	Fiberglass-reinforced plastic	ICR	Information Collection Request
FSQ	Full-slurry quench	ID	Induced draft
ft	Foot, feet	IGCC	Integrated gasification combined cycle
ft <sup>3</sup>	Cubic feet	IGV	Inlet guide vane
FW	Feedwater	in.	Inch
GADS	Generating Availability Data System	in. Hg	Inch mercury
gal	Gallon	IOU	Investor-owned utility
GDP	Gross domestic product	IP	Intermediate pressure
GEP	General Electric Power	IPCC AR5	International Panel on Climate Change 5 <sup>th</sup> Assessment Report
GFB	Gas-fired boiler	IPM	Integrated Planning Model
GHG	Greenhouse gas	IRROE	Internal rate of return on equity
GJ	Gigajoule	ISO	International Organization for Standardization
GJ/hr	Gigajoules per hour	kg/GJ	Kilograms per gigajoule
gpd	Gallons per day	kg/hr	Kilograms per hour
gpm	Gallons per minute	kg/s	Kilograms per second
gr/100 scf	Grains per one hundred standard cubic feet	kgmol	Kilogram mole
GSR	Gas switching reforming	kgmol/hr	Kilogram moles per hour
Gt	Gigatonne	kJ	Kilojoule
GWP	Global warming potential	kJ/hr	Kilojoules per hour
h, hr	Hour	kJ/kg	Kilojoules per kilogram
H <sub>2</sub>	Hydrogen	kJ/m <sup>3</sup>	Kilojoules per cubic meter
H <sub>2</sub> O	Water	kJ/Nm <sup>3</sup>	Kilojoules per normal cubic meter
		km	Kilometer

KO	Knockout	MEA	Monoethanolamine
kV	Kilovolt	mi	Mile
kW, kWe	Kilowatt electric	MISO	Midwest Independent System Operator
kWh	Kilowatt-hour	MJ	Megajoule
kWt	Kilowatt thermal	MJ/Nm <sup>3</sup>	Megajoules per normal cubic meter
LAER	Lowest Achievable Emission Rate	MJ/scm	Megajoule per standard cubic meter
lb	Pound	mm	Millimeter
lb/gal	Pound per gallon	MM	Million
lb/ft <sup>2</sup>	Pounds per square foot	MMacf	Million actual cubic feet
lb/ft <sup>3</sup>	Pounds per cubic foot	MMBtu	Million British thermal units
lb/hr	Pounds per hour	MMBtu/hr	Million British thermal units per hour
lb/MMBtu	Pounds per million British thermal units	MNQC	Multi Nozzle Quiet Combustor
lb/MWh	Pounds per megawatt hour	MMSCFD	Million standard cubic feet per day
lb/s	Pounds per second	mol%	Percent by mole
lb/TBtu	Pounds per trillion British thermal units	MPa	Megapascal
lbmol/hr	Pound moles per hour	MSW	Municipal solid waste
LCA	Life cycle analysis	MVA	Mega volt-amperes
LCC	Levelized capital cost	MW	Megawatt
LCOH	Levelized cost of hydrogen	MWe	Megawatt electric
LCV	Low calorific value	MWh	Megawatt-hour
LFP	Levelized fuel price	N <sub>2</sub>	Nitrogen
LHV	Lower heating value	N/A	Not applicable
LIW	Loss-in-weight	NaCl	Sodium chloride
LNB	Low NOx burner	NaOH	Sodium hydroxide
LOM	Levelized operating and maintenance cost	NEMA	National Electrical Manufacturers Association
LP	Low pressure	NERC	North American Electric Reliability Council
lpm	Liters per minute	NETL	National Energy Technology Laboratory
LTHR	Low temperature heat recovery	NFPA	National Fire Protection Association
m	Meter	NG	Natural gas
M	Thousand	NGCC	Natural gas combined cycle
m/min	Meters per minute	NH <sub>3</sub>	Ammonia
m <sup>3</sup> /min	Cubic meters per minute	NH <sub>4</sub> Cl	Ammonium chloride
MA-ATR	Membrane assisted autothermal reforming	Nm <sup>3</sup>	Normal cubic meter
MAC	Main air compressor	Nm <sup>3</sup> /hr	Normal cubic meter per hour
MAF	Moisture and ash free	NOAK	N <sup>th</sup> -of-a-kind
MATS	Mercury and Air Toxics Standards	NO <sub>2</sub>	Nitrogen dioxide
MCR	Maximum continuous rate	NOx	Nitrogen oxides
MCSF	Multi-component slurry gasifier		
MDEA	Methyl diethanolamine		

NSPS	New Source Performance Standards	RH	Reheater
NSR	New Source Review	RO	Reverse osmosis
NTU	Nephelometric turbidity unit	RR	Ramp rate
O <sub>2</sub>	Oxygen	SC	Supercritical
O&M	Operation and maintenance	scfh	Standard cubic feet per hour
OEM	Original equipment manufacturers	scfm	Standard cubic feet per minute
OFA	Overfire air	Sch.	Schedule
O-H, OH	Overhead	SCOT	Shell Claus Off-gas Treating
OP/VWO	Over pressure/valve wide open	SCR	Selective catalytic reduction
P	Absolute pressure	SCWG	Supercritical water gasification
PA	Primary air	SDA	Spray dryer absorber
PAC	Powdered activated carbon	SDE	Spray dryer evaporator
PC	Pulverized coal	SGC	Synthesis gas cooler
PEM	Proton-exchange membrane	Shell	Shell Global Solutions
p.f.	Power factor	SMR	Steam methane reforming
ph	Phase	SNCR	Selective non-catalytic reduction
pH	Power of hydrogen	SNG	Synthetic natural gas
PM	Particulate matter	SO <sub>2</sub>	Sulfur dioxide
POTW	Publicly-owned treatment works	SO <sub>3</sub>	Sulfur trioxide
POX	Partial oxidation	SRU	Sulfur recovery unit
ppb	Parts per billion	SS	Stainless steel
ppm	Parts per million	STE	Steam turbine efficiency
ppmv	Parts per million volume	STG	Steam turbine generator
ppmvd	Parts per million volume, dry	STHR	Steam turbine heat rate
ppmw	Parts per million weight	STP	Steam turbine power
ppmwd	Parts per million weight, dry	SubC	Subcritical
ppt	Parts per trillion	SWS	Sour water stripper
PRB	Powder River Basin	T	Temperature
PSA	Pressure swing absorption	T&S	Transport and storage
PSD	Prevention of Significant Deterioration	TASC	Total as-spent cost
psi	Pounds per square inch	Tbtu	Trillion British thermal units
psia	Pound per square inch absolute	TDS	Total dissolved solids
psid	Pound per square inch differential	TEG	Triethylene glycol
psig	Pound per square inch gauge	TEWAC	Totally Enclosed Water-to-Air Cooled
QGESS	Quality Guidelines for Energy System Studies	TG	Tail gas
R&D	Research and development	TGTU	Tail gas treating unit
R+Q	Radiant plus quench	TI	Thermal input
RD&D	Research, development, and demonstration	TO	Thermal output
		TOC	Total overnight cost
		tonne	Metric ton (1,000 kg)
		TPC	Total plant cost
		tpd	Ton per day
		tph	Tons per hour

U.S.	United States	wtr	Water
UAN	Urea ammonium nitrate	yr	Year
UCC	United Conveyor Corporation	ZLD	Zero liquid discharge
USC	Ultra-supercritical	\$/GJ	Dollars per gigajoule
V	Volt	\$/kW	Dollars per kilowatt
V-L	Vapor liquid portion of stream (excluding solids)	\$/MMBtu	Dollars per million British thermal units
vol%	Percent by volume	\$M	Millions of dollars
VSA	Vacuum swing adsorption	μS/cm	Micro Siemens per cm
VT	Voltage transformers	°C	Degrees Celsius
WGS	Water gas shift	°F	Degrees Fahrenheit
wt%	Percent by weight	5-10s	50-hour work week

## EXECUTIVE SUMMARY

---

This report presents an independent assessment of the cost and performance of select hydrogen production plants utilizing fossil fuel resources as the primary feedstocks – specifically, natural gas (NG), steam methane reforming (SMR), NG autothermal reforming (ATR), coal gasification, and coal/biomass co-gasification – using a systematic, transparent technical and economic approach. Study cases were selected to reflect the capabilities of current, commercial technologies within plant configurations, and at scales, representative of next commercial offerings facing no fundamental research and development (R&D) obstacles. Additionally, several areas of R&D are identified as potential pathways for performance improvements and cost reductions.

Attributional global warming potential (GWP) profiles of the impactful energy and material streams entering and exiting the plant boundaries were used to develop life cycle greenhouse gas (GHG) emissions results for each case based on the quantity of each stream. The results are deemed to be commensurate with an International Organization for Standardization (ISO) 14040/14044 life cycle analysis (LCA) [1, 2] and are expressed as carbon dioxide equivalents (CO<sub>2</sub>e). A life cycle GHG emissions target of 0 pounds (lb) CO<sub>2</sub>e/lb H<sub>2</sub> produced, or “net-zero,” was targeted in one plant.

The cost and performance of fossil fuel-based hydrogen production technologies represented in this report are important inputs to assessments and determinations of technology combinations to be utilized to meet the projected demands of the nascent hydrogen economy. In addition to informing technology comparisons, the reference plant configurations found in this report provide perspective for regulators and policy makers. From an R&D perspective, this report may be used to assess goals and metrics and to provide a consistent basis for comparing developing technologies.

Six hydrogen plant configurations are analyzed in this report. A summary of the configurations is shown in Exhibit ES-1:

- Three natural gas reforming configurations—two NG SMR cases (with and without carbon dioxide [CO<sub>2</sub>] capture) and one NG ATR case (with CO<sub>2</sub> capture).
- Three gasification configurations — two coal gasification cases (with and without CO<sub>2</sub> capture) and one coal/biomass co-gasification case (with CO<sub>2</sub> capture).

The CO<sub>2</sub> capture strategy employed for each case recovers greater than 90 percent of the carbon entering the plant boundary, minus the slag formed in gasification cases. High levels of capture are achieved by using a combination of water gas shift (WGS) reactors and solvent-based CO<sub>2</sub> separation technologies. The solvent technologies used include methyl diethanolamine (MDEA) (SMR and ATR), Shell Cansolv (SMR), and two-stage Selexol (coal and coal/biomass gasification).

This report reflects varying degrees of technology vendor input for each case. However, the final assessment of performance and cost was determined independently and is not endorsed by individual vendors.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit ES-1. Case configuration summary**

Case <sup>A</sup>	Plant Type	Feedstock(s)	Reformer Type	Gasifier Type	CO <sub>2</sub> Capture (%)	H <sub>2</sub> Purification	Hydrogen Production Capacity
1	Reforming	Natural Gas	SMR	N/A	0	Pressure Swing Absorber (PSA)	200 MMSCFD 483,000 kg/day 44,400 lb/hr
2					96.2		
3			ATR		94.5		
4	Gasification	Illinois No. 6 Coal	N/A	Shell <sup>B</sup>	0		274 MMSCFD 660,000 kg/day 60,600 lb/hr
5					92.5		
6		Illinois No. 6 Coal/ Torrefied Woody Biomass			92.6		

<sup>A</sup>All plants in this report are assumed to be located at a generic plant site in the midwestern United States.

<sup>B</sup>The Shell gasifier has been used in multiple prior NETL studies. As of May 2018, Air Products has acquired the coal gasification technology licensing business from Shell. To be consistent with prior NETL studies and avoid confusion, the gasifier will continue to be labeled the “Shell” gasifier.

## COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

To ensure methodologically-sound, consistent, and transparent technology assessments and comparisons, NETL relies upon its Quality Guidelines for Energy System Studies (QGESS) reports, which provide guidance on topics such as recommended feedstock specifications and pricing, [3] [4] recommended performance modeling assumptions, [5] and guidance for cost estimation methodology. [6]

The methodology for developing the performance results presented in this report included performing steady-state simulations of the hydrogen plant configurations at the design capacity using the Aspen Plus® (Aspen) process modeling software. The major plant equipment performance and process limits were based on published reports, information obtained from vendors and users of the technology, performance data from design/build utility projects, and/or best engineering judgment. [5] Mass and energy balance data from the Aspen models were used to size major pieces of equipment, which formed the basis for developing the cost estimates presented.

Full, bottom-up estimates for each case in this study were not pursued. Instead, the capital and operation and maintenance (O&M) costs for each of the cases were estimated using a combined bottom-up and scaling approach. Black & Veatch (B&V) leveraged an in-house database and conceptual estimating models. Costs were further calibrated using a combination of adjusted vendor-furnished data and scaled estimates from previous design/build projects. In addition, cost scaling was performed on select plant areas using reference costs from prior NETL studies according to the 2019 revision of the QGESS document “Capital Cost Scaling Methodology: Revision 4 Report.” [7] The cost results are reported in 2018 dollars.

The baseline NG and coal costs for this analysis are specified in the 2019 revision of the QGESS report on “Fuel Prices for Selected Feedstocks in National Energy Technology Laboratory [NETL] Studies.” [8] The levelized price for Illinois No. 6 coal delivered to the Midwest is \$2.11/gigajoule (GJ) (\$2.23/million British thermal units [MMBtu]), on a higher heating value (HHV) basis and in 2018 United States (U.S.) dollars. The levelized price for natural gas delivered to the Midwest is \$4.19/GJ (\$4.42/MMBtu), on an HHV basis and in 2018 U.S. dollars. The levelized price of torrefied, woody biomass was estimated using an NETL model based on vendor data and is \$5.14/GJ (\$5.43/MMBtu), on an HHV basis and in 2018 U.S. dollars.

The cost metric used in this report is the levelized cost of hydrogen (LCOH) reported in real 2018 dollars, which is the revenue that must be received by the producer per kilogram of hydrogen produced to meet the desired return on equity after meeting all debt and tax obligations and operating expenses. Detailed information pertaining to LCOH calculations is available in the 2019 revision of the QGESS report “Cost Estimation Methodology for NETL Assessment of Power Plant Performance.” [6] The cost of CO<sub>2</sub> transport and storage (T&S), on an equivalent dollar per kilogram basis, is added to the LCOH and represents a 62 km (100 mile) CO<sub>2</sub> pipeline and storage in a deep saline formation in the Midwest.<sup>a</sup> On a unit basis, the cost of CO<sub>2</sub> T&S applied is \$10 per tonne (\$9/ton) of CO<sub>2</sub>.

---

<sup>a</sup> Estimated using the Office of Fossil Energy (FE)/NETL CO<sub>2</sub> Transport Cost Model and the FE/NETL CO<sub>2</sub> Saline Storage Cost Model. Additional detail on development of these costs is available in the 2019 revision of the QGESS report “Carbon Dioxide Transport and Storage Costs in NETL Studies.” [56]

The LCOH results shown for the cases considered in this study are not intended to reflect all the potential market pressures experienced by plants operating today, or the price consumers can expect to pay. Rather, the primary focus is on a sound, transparent, consistent methodology to develop those results, built with industry and vendor input, which ultimately leads to an independent benchmark for the cases considered. This outcome is of significant value to internal and external stakeholders.

LCA models considered a cradle-to-gate system boundary with a functional unit of 1 lb of hydrogen at the plant gate. Results were reported as GWP in units lb CO<sub>2</sub>e/lb H<sub>2</sub> for all hydrogen cases considered. Similar to the approach for the cost analysis, full models of each case were not pursued. Instead, the general approach to generating the GHG emissions results in this study was to leverage the engineering results to identify the upstream energy inputs needed, and to apply GHG emissions factors to those inputs in order to estimate cradle-to-gate emissions. Facility level emissions were directly estimated from the engineering analyses and are also part of the overall cradle-to-gate emissions.

The upstream NG emissions for this analysis are specified in the NETL natural gas baseline report [9], and extended to the year 2017 [10], and the boundaries are from natural gas extraction through transmission (i.e., for a large-scale industrial user). Electricity emissions are modeled using the NETL electricity baseline [11, 12], represented by the U.S. average consumption mix at user. Emissions from the upstream production of biomass, specifically the torrefied Southern Yellow Pine (SYP) used in this study, followed work previously done for the Connecticut Center for Advanced Technology (CCAT) [13] with some modifications. The upstream production of coal leverages modeling and default assumptions from NETL's Supercritical Pulverized Coal (SCPC) Power Plant study [14], assuming Illinois underground bituminous coal. Emissions for storage of CO<sub>2</sub> in saline aquifer followed modeling and assumptions used in the SCPC Power Plant Study [14]. Overall, the greenhouse gas emissions data is representative of the time period 2016 to 2017.

Additionally, the cases considered are not meant to depict all available technologies, process arrangements, and potential scales. Therefore, the study results only reflect the technologies and arrangements considered and can change based on alternatives. Ultimately, selection of new hydrogen production technologies will depend on many factors, including, but not limited to:

- Capital and operating costs
- Overall efficiency
- Operational flexibility (e.g., ramp rate, turndown, start-up time)
- Feedstock prices
- Project financial requirements
- Availability, reliability, and environmental performance
- Current and potential regulations governing air, water, and solid waste discharges from fossil-based hydrogen plants
- Specific site and application constraints and requirements

## **RESULTS ANALYSIS**

Exhibit ES-2 shows the performance and environmental profile summary for all cases. A graph of the net plant efficiency (HHV basis) is provided in Exhibit ES-3. The results are described in greater detail in the following paragraphs.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES


**Exhibit ES-2. Performance summary and environmental profile for all cases**

Case Name	Reforming			Gasification		
	SMR		ATR	Shell Gasifier		
	1	2	3	4	5	6
CO <sub>2</sub> Capture	0%	96.2%	94.5%	0%	92.5%	92.7%
Capacity Factor	90%	90%	90%	80%	80%	80%
Hydrogen Production Rate (lb/hr)	44,369	44,369	60,627	60,622	60,627	12,194
Gross Power Output (MWe)	0	0	0	89	109	37
Auxiliary Power Requirement (MWe)	13	41	110	114	148	37
Net Power Output (MWe)	-13	-41	-110	-25	-39	1
Coal Flowrate (lb/hr)	N/A	N/A	N/A	467,308	467,308	65,917
Biomass Flowrate (lb/hr)	N/A	N/A	N/A	N/A	N/A	50,750
Natural Gas Flowrate (lb/hr)	156,482	166,387	213,694	N/A	N/A	N/A
HHV Thermal Input (kW <sub>t</sub> )	1,031,068	1,096,328	1,408,040	1,597,711	1,597,711	370,367
HHV Effective Thermal Efficiency (%)	75.4%	68.4%	67.9%	65.0%	64.1%	57.9%
HHV Cold Gas Efficiency (%)	76.7%	72.1%	75.7%	66.6%	66.6%	57.7%
Raw Water Withdrawal (gpm)	1,457	2,727	3,720	3,188	3,638	1,035
Process Water Discharge (gpm)	63	586	775	672	773	220
Raw Water Consumption (gpm)	1,395	2,140	2,945	2,516	2,866	814
CO <sub>2</sub> Emissions (lb/MMBtu)	118	5	7	199	15	15
SO <sub>2</sub> Emissions <sup>A</sup> (lb/MMBtu)	0.000	0.000	0.000	0.027	0.000	0.000
NO <sub>x</sub> Emissions (lb/MMBtu)	0.003	0.002	0.000	0.017	0.007	0.010
PM Emissions (lb/MMBtu)	0.000	0.000	0.000	0.007	0.007	0.007
Hg Emissions (lb/TBtu)	0.000	0.000	0.000	0.571	0.571	0.348

<sup>A</sup> Trace amounts of sulfur emissions may exist in the flue gas stream to the stack in capture cases

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit ES-3. Net plant efficiency (HHV basis)**



Cold gas efficiency (CGE) is calculated as the ratio of the thermal content of the hydrogen product to the thermal input to the system. The effective thermal efficiency (ETE) is calculated similarly to the CGE but the numerator is adjusted for the net electrical power imported or exported. Therefore, importing electrical power lowers the ETE.

- The reforming cases have on average about 10 percentage points higher cold gas efficiencies than the gasification cases. The highest CGE (76.7 percent) is from the SMR plant without capture (Case 1), and the lowest CGE (57.7 percent) is from the coal/biomass co-gasification case with capture (Case 6).
- Adding capture to the SMR plant decreases the ETE by about seven percentage points due to a greater percentage of the NG feedstock being combusted to satisfy the thermal demands of the CO<sub>2</sub> removal processes; while adding capture to the coal gasification plant decreases the CGE by less than one percentage point since additional feedstock is not required to support CO<sub>2</sub> removal.
- The coal/biomass co-gasification plant with carbon capture and storage (CCS) (Case 6) is the only case in which the ETE is higher than the cold gas efficiency due to the positive net power production of the system. This reflects the design assumption made for this

## COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES


case to eliminate power imports, so life cycle GHG emissions associated with power imports are eliminated.

Life cycle GHG emissions are reported for each study case. A greenhouse gas life cycle assessment (LCA) was performed in accordance with ISO 14040/14044 [1, 2], and results have been divided into emissions sources, including stack emissions, downstream CO<sub>2</sub> management, and key upstream processes: natural gas, coal, grid electricity, and biomass. Since Case 1 (SMR without CCS) produces excess steam as a co-product, parallel models of Case 1 (A and B) were created to estimate effects with and without consideration of the steam displacing production from other sources. Note that Case 1A aligns with Case 1's levelized cost of hydrogen result which represents a conservative scenario in which no end use nor corresponding value of the steam byproduct is considered. In Case 1B, SMR hydrogen production is integrated or co-located with an industrial operation that can utilize the excess steam, thus a commensurate emissions credit based on system expansion using a natural gas boiler to produce steam of equivalent quality is used. Case 1B is only represented with LCA results within this report and represents current industrial hydrogen production with co-located use of the steam product. Case 1B best represents the baseline for current U.S. SMR plants at the modeled compressed hydrogen product pressure of 925 psig.

Exhibit ES-4 shows the life cycle global warming potential (GWP) with a 100-year time horizon, in lb CO<sub>2</sub>e per lb H<sub>2</sub>, for each of the cases. The error bars represent overall ranges of variability in the emissions results calculated from a Monte Carlo simulation with 5,000 iterations, as well as regional variability in natural gas scenarios based upon high and low basin values.

# COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit ES-4. CO<sub>2</sub>e life cycle emissions for all cases**



The variability in the natural gas-based Cases (1-3) is largely from the known variability within the average of upstream processes used to extract, process, and transport natural gas. Cases 2 and 3 have variability that is also influenced by the higher amount of grid electricity needed for the CCS systems. Cases involving only coal (4-5) have comparable error bars, largely associated with known variability in coal mine methane emissions based on the methane content of the coal seams in the Illinois basin. Finally, error bars for Case 6 of coal with biomass is due to variation in yields and fertilization rates along with the coal variability.

The following observations can be made about the life cycle emissions:

- The configuration with the highest global warming potential on a life cycle basis is the coal gasification plant without CCS (Case 4, 20 lb CO<sub>2</sub>e/lb H<sub>2</sub>). The configuration with the lowest GWP is the coal/biomass co-gasification plant with CCS (Case 6, -1.0 lb CO<sub>2</sub>e/lb H<sub>2</sub>).

The average life cycle GHG emissions of the reforming cases with capture (Case 2, 4.6 lb CO<sub>2</sub>e/lb H<sub>2</sub> and Case 3, 5.7 lb CO<sub>2</sub>e/lb H<sub>2</sub>) is approximately 10 to 40 percent higher than the life cycle GWP of the coal gasification case with capture (Case 5, 4.1 lb CO<sub>2</sub>e/lb H<sub>2</sub>). This is primarily due to the life cycle GHG emissions of the grid electricity and natural gas

## COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

feedstock procurement, which make up approximately 90 percent of the life cycle emissions of the reforming cases with capture.

- Considering steam displacement for Case 1 leads to a notable 17 percent reduction in GWP. This suggests that the value of steam as a co-product has a significant impact on life cycle results.
- The life cycle emissions of Case 6 include a small credit (0.053 lb CO<sub>2</sub>e/lb H<sub>2</sub>) for electricity sold back to the grid. This credit is further described in Section 2.8.

Exhibit ES-5 shows the cost summary for all cases. A graph of the levelized cost of hydrogen as \$/kilogram (kg) is provided in Exhibit ES-6. The error bars included represent the potential LCOH range relative to the maximum and minimum capital cost uncertainty ranges. The LCOH ranges presented are not reflective of other changes, such as variations in fuel price, labor price, CF, or other factors.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit ES-5. Cost summary for all cases**

Case Name	Reforming <sup>A</sup>			Gasification <sup>A</sup>		
	SMR		ATR	Shell Gasifier		
	1	2	3	4	5	6
<b>Total Plant Cost (2018\$/[kg H<sub>2</sub>/day])</b>	554	1,394	1,092	4,264	4,901	5,241
<b>Total Overnight Cost (2018\$/[kg H<sub>2</sub>/day])</b>	713	1,735	1,372	5,243	6,044	6,515
<i>Owner's Costs</i>	159	341	280	979	1,142	1,274
<i>Process Contingency</i>	0	52	1	231	304	211
<i>Project Contingency</i>	94	252	114	628	734	765
<i>Home Office Expenses</i>	77	182	163	456	516	538
<b>Bare Erected Cost</b>	384	908	814	2,949	3,347	3,726
<b>Total As-Spent Cost (2018\$/[kg H<sub>2</sub>/day])</b>	763	1,856	1,467	5,853	6,747	7,273
<b>LCOH (\$/kg H<sub>2</sub>) (excluding T&amp;S)</b>	1.06	1.54	1.51	2.58	2.92	3.44
<i>Capital Costs</i>	0.14	0.33	0.26	1.17	1.35	1.46
<i>Fixed Costs</i>	0.07	0.15	0.11	0.53	0.60	0.75
<i>Variable Costs</i>	0.09	0.24	0.36	0.43	0.52	0.43
<i>Fuel Costs</i>	0.77	0.82	0.77	0.44	0.44	0.80
<b>LCOH (\$/kg H<sub>2</sub>) (including T&amp;S)</b>	1.06	1.64	1.59	2.58	3.09	3.64
<i>CO<sub>2</sub> T&amp;S Costs</i>	0.00	0.10	0.09	0.00	0.17	0.20
<b>Breakeven CO<sub>2</sub> Sales Price (ex. T&amp;S), \$/tonne<sup>B</sup></b>	N/A	50.1	50.4	N/A	20.8	42.9
<b>Breakeven CO<sub>2</sub> Emissions Penalty (incl. T&amp;S), \$/tonne<sup>B</sup></b>	N/A	64.1	60.3	N/A	30.8	65.0

<sup>A</sup>Financing structures are presented in NETL's "QGESS: Cost Estimation Methodology for NETL Assessments of Power Plant Performance" [6]


<sup>B</sup>Both the breakeven CO<sub>2</sub> sales price and emissions penalty were calculated based on the respective non-capture cases within the reforming cases (Case 1) and gasification cases (Case 4)

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

The primary observations that can be made are:

- The lowest LCOH is \$1.06/kg H<sub>2</sub> from the SMR plant without capture (Case 1). The highest LCOH is \$3.64/kg H<sub>2</sub> from the coal/biomass co-gasification case with capture (Case 6).
- The average LCOH for the gasification cases is about two times greater than the average LCOH for the reforming cases. This is mainly due to the higher capital and fixed costs needed in the gasification cases compared to the reforming cases.
- The largest contributor to the LCOH for the reforming cases is the fuel cost, accounting for between 49 and 73 percent of the total LCOH. The largest contributor for the gasification cases is the capital cost, accounting for between 40 and 46 percent of the total LCOH. The cost of the feedstock, on a per thermal content unit basis, is about double for natural gas compared to coal. On the other hand, the greater complexity of the gasification plants explains the large contribution of capital costs on the LCOH.
- The addition of CO<sub>2</sub> capture technology impacts the reforming plant’s LCOH more than the gasification plant’s LCOH. Adding CCS to the reforming cases increases the LCOH by 54 percent for the SMR plant (Case 2). Adding capture to the coal gasification plant (Case 5) increases the LCOH by 20 percent.

**Exhibit ES-6. LCOH by cost component**



\*Financing structures are presented in NETL’s “QGESS: Cost Estimation Methodology for NETL Assessments of Power Plant Performance” [6]

## **Costs of Mature Technologies and Designs**

The cost estimates for plant designs that only contain fully mature technologies, which have been widely deployed at commercial scale (e.g., SMR and gasification without CO<sub>2</sub> capture), reflect N<sup>th</sup>-of-a-kind (NOAK) on the technology commercialization maturity spectrum. The costs of such plants have dropped over time due to “learning by doing” and risk reduction benefits that result from serial deployments as well as from continuing R&D.

## **Costs of Emerging Technologies and Designs**

The cost estimates for plant designs that include technologies that are not yet fully mature (e.g., any plant with CO<sub>2</sub> capture) use the same cost estimating methodology as for mature plant designs, which does not fully account for the unique cost premiums associated with the initial, complex integrations of emerging technologies in a commercial application. Thus, it is anticipated that early deployments of these plants may incur costs higher than those reflected within this report.

## **Other Factors**

Actual reported project costs for all the plant types are also expected to deviate from the cost estimates in this report due to project- and site-specific considerations (e.g., contracting strategy, local labor costs, seismic conditions, water quality, financing parameters, local environmental concerns, weather delays) that may make construction more costly. Such variations are not captured by the reported cost uncertainty.

## **Future Cost Trends**

Continuing research, development, and demonstration (RD&D) is expected to result in designs that are more advanced than those assessed by this report, leading to costs that are lower than those estimated here.

## **OPPORTUNITIES FOR FUTURE R&D**

This report also identifies several potential areas for R&D and supporting analysis that may open avenues for performance improvements and/or cost reductions beyond what the technologies included in this study provide. Opportunities are classified as either approaches to drive down the life cycle GHG emission profiles of existing technologies or incorporation of advanced technology concepts. Reducing the life cycle GHG emissions, for example, can be accomplished by blending renewable natural gas (RNG), pairing direct air capture (DAC), sourcing low-carbon auxiliary power, and increasing CO<sub>2</sub> capture rates.

# 1 INTRODUCTION

---

This report presents an independent assessment of the cost and performance of select hydrogen production plants utilizing fossil fuel resources as the primary feedstocks – specifically, natural gas (NG) steam methane reforming (SMR), NG autothermal reforming (ATR), coal gasification, and coal/biomass co-gasification – using a systematic, transparent technical and economic approach. Study cases were selected to reflect the capabilities of current, commercial technologies within plant configurations, and at scales, representative of next commercial offerings facing no fundamental research and development (R&D) obstacles. Additionally, several areas of R&D are identified as potential pathways for performance improvements and cost reductions.

Global warming potential (GWP) profiles of the impactful energy and material streams entering and exiting the plant boundaries were used to develop life cycle greenhouse gas (GHG) emissions results for each case based on the quantity of each stream. The results are deemed to be commensurate with an International Organization for Standardization (ISO) 14040/47 life cycle analysis (LCA) and are expressed as carbon dioxide equivalents (CO<sub>2</sub>e). A life cycle GHG emissions target of 0 lb CO<sub>2</sub>e/lb H<sub>2</sub> produced, or “net-zero,” was targeted in the coal/biomass co-gasification case.

The cost and performance of fossil fuel-based hydrogen production technologies represented in this report are important inputs to assessments and determinations of technology combinations to be utilized to meet the projected demands of the nascent hydrogen economy. In addition to informing technology comparisons, the reference plant configurations found in this report provide perspective for regulators and policy makers. From a R&D perspective, this report may be used to assess goals and metrics and to provide a consistent basis for comparing developing technologies.

Six hydrogen plant configurations are analyzed in this report. A summary of the configurations is shown in Exhibit 1-5:

- Three natural gas reforming configurations—two NG SMR cases (with and without carbon dioxide [CO<sub>2</sub>] capture) and one NG ATR case (with CO<sub>2</sub> capture).
- Three gasification configurations — two coal gasification cases (with and without CO<sub>2</sub> capture) and one coal/biomass co-gasification case (with CO<sub>2</sub> capture).

The CO<sub>2</sub> capture strategy employed for each case recovers greater than 90 percent of the carbon entering the plant boundary. High levels of capture are achieved by using a combination of water gas shift (WGS) reactors and solvent-based CO<sub>2</sub> separation technologies. The solvent technologies used include methyl diethanolamine (MDEA) (SMR and ATR), Shell Cansolv (SMR) and two-stage Selexol (coal and coal/biomass gasification).

This report reflects varying degrees of technology vendor input for each case. However, the final assessment of performance and cost was determined independently and is not endorsed by individual vendors.

## 1.1 UNIT CONFIGURATIONS

A summary of study cases and their corresponding plant configurations considered in this report is presented in Exhibit 1-5. Components of each plant configuration are described in more detail in the corresponding report sections.

As previously stated, study cases were selected to represent the capabilities of current, commercial technologies within plant configurations, and at scales, representative of next commercial offerings facing no fundamental R&D obstacles. Additionally, a plant configuration capable of achieving net-zero greenhouse gas emissions over the plant life cycle using a carbon negative biomass feedstock, while adhering to these criteria, was evaluated.

### 1.1.1 Literature Review

A literature review was undertaken to inform the study case selection process. The objectives of the literature review were to:

- Survey a market sample of commercially operating, and commercially available, natural gas-, coal-, and alternative feedstock-derived, dedicated, high-purity hydrogen production sources, both within the U.S. and abroad
- Gather information on commercial H<sub>2</sub>/CO<sub>2</sub> separation technologies

The primary data sources for the literature review included:


- Merchant hydrogen production data representing approximately 10 percent of the annual, global pure hydrogen market [15]
- Production data representing approximately 10 percent of the annual, global pure hydrogen produced from coal for ammonia [16]
- Global data of gasification facilities operating on biomass and alternative feedstocks (e.g., municipal solid waste (MSW)) [17]
- Miscellaneous sources including conference proceedings, recent project press releases, and discussions with industry contacts

The primary findings from the literature review follow:

- As seen in Exhibit 1-1, merchant, high-purity hydrogen production facilities are spread globally and predominantly use NG SMR, with additional production from processing of chlor-alkali byproducts and partial oxidation (POX)

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES


**Exhibit 1-1. Global merchant hydrogen fleet production route profile (by supplier)**



- Exhibit 1-2 shows the distribution of plant capacity ranges for hydrogen production facilities, broken out by technology supplier, Air Liquide, Linde/Praxair, Air Products, and by location, North America, Europe, Asia, or other
  - The chart shows that the majority of plants produce between 100 and 200 million standard cubic feet per day (MMSCFD) of high-purity hydrogen. The total capacity of plants drops significantly at capacities above 200 MMSCFD, indicating that this is likely an upper-limit of SMR plant capacity, which is the most common hydrogen production route
  - Even flow distribution of combustion gasses across the furnace reactor tubes is a primary scale-up limitation of SMR plants which limits the largest, single-train SMR facilities to approximately 200 MMSCFD [18]

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES


**Exhibit 1-2. Global merchant hydrogen fleet capacity profile (by supplier)**



Note: Total shown reflects the combined capacity of the three suppliers shown.

- Exhibit 1-3 shows high-purity hydrogen from coal for ammonia produced primarily in China using various gasification technologies in facilities with estimated median production rates of 50-100 MMSCFD. Looking at ammonia production serves as a proxy for hydrogen production capacity, as high-purity hydrogen is an intermediate in ammonia production.

**Exhibit 1-3. Chinese hydrogen from coal (for ammonia) technology profile**



## COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

- Exhibit 1-4 contains the results of a literature review search conducted in early 2022 of operating and planned hydrogen production facilities with CCUS. As can be seen, only a few hydrogen production facilities are currently operating with carbon capture, utilization, and storage (CCUS) (<90 percent capture); several others are in development (>90 percent capture)

**Exhibit 1-4. Hydrogen production with CCUS (operating and planned)**

	Plant/Project Name	Location	H <sub>2</sub> Production kNm <sup>3</sup> /hr (MMSCFD)	H <sub>2</sub> Production Platform	AGR Technology	Overall CO <sub>2</sub> Capture Rate (%)
Operating	Air Products Port Arthur [19]	USA	220 (200)	SMR	VSA	60
	Air Liquide Port Jerome [20]	France	50 (45)	SMR	Membranes, CRYOCAP™ H2	60
	Shell Quest [21] [22]	Canada	210 (191)	SMR	ADIP-X	50
Under Development	H-Vision	Netherlands	700 (636)	ATR	Rectisol™	88.0
	HyNet [23]	United Kingdom	100 (90)	ATR	TBD	97.2
	H21 [24] [25]	United Kingdom	3,200 (2,900) from 9 units	ATR	aMDEA	94.2
	Acorn [26]	Scotland	53 (48)	ATR	Amine	98.7
	H2Teesside [27]	United Kingdom	275 (250)	TBD	TBD	98
	Air Products Alberta [28]	Canada	>695 (>623)	ATR	TBD	95
Air Products Louisiana [29]	USA	>837 (>750)	ATR/POX	TBD	95	

- There are currently no commercial examples of facilities gasifying alternative feedstocks (e.g., biomass, MSW) to produce high-purity hydrogen as an end-product
- The decommissioned Buggenum integrated gasification combined cycle (IGCC) (coal/biomass co-gasification) and Eastman Kingsport (coal/waste plastics) facilities are the only examples of commercially operated facilities to co-gasify coal with an alternative feedstock. Neither facility produces high-purity hydrogen as an end-product

### 1.1.2 Case Selection Rationale

Several fossil-based hydrogen pathways were considered for inclusion into this study. Final selection of study cases emphasized the current landscape of the global, high-purity hydrogen production fleet, as well as the outlook for fossil-based, hydrogen projects with carbon capture and storage (CCS) currently under development. As a consequence, no screening, or down

selection, of potential study cases based on performance and/or economic criteria was performed. Additionally, it is recognized that not all fossil-based, hydrogen production pathways and configurations meeting the selection criteria are represented in this study.

### **1.1.2.1 Reforming Cases**

SMR without CCS is included to provide a current, commercial reference because it is the predominant high-purity production route in the current market. SMR and ATR with CCS are each included to assess future R&D benefits relative to the non-capture commercial reference in future analyses. The 200 MMSCFD production capacity basis of the SMR plants maximizes economies of scale with a single-reactor arrangement. This capacity reflects the upper range of commercially operating SMR plants today.

The single-train design capacity of ATR with CCS, unconstrained by the scale-up limitations inherent to SMR, matches the hydrogen production output of the coal gasification cases and results in a hydrogen production rate of 274 MMSCFD. This capacity falls within the expected plant sizes of the projects under development shown in Exhibit 1-4.

All reforming cases operate on pipeline natural gas. Assessment of the potential for net-zero greenhouse gas (GHG) emissions from blending alternative feedstocks (e.g., renewable natural gas [RNG]) is ongoing and are not considered in this study.

### **1.1.2.2 Gasification Cases**

The three gasification cases are based on performance data for an oxygen-blown, entrained-flow gasifier that is intended to be similar to the Shell gasifier, by which it is referred to from here on out. This gasifier has been included in numerous prior NETL studies, including most-recently in, the Fossil Energy Baseline. The estimates were derived from public literature and relied heavily on conference presentations given by Shell at the Gasification Technologies Conference in 2009. It is not intended to faithfully reproduce the operating point of any specific gasifier either currently operating, previously operating, or planned. It is a conceptual design that extends some of the features of the gasifier island, such as integration with other plant components. It was intended to keep the design basis comparable to how other gasifiers were represented in previous studies like the Fossil Energy Baseline. In 2018, the Shell gasifier technology was purchased and is now licensed by Air Products. It is recognized that the technology is now owned by Air Products, not Shell, but the gasifier will continue to be called the “Shell” gasifier to be consistent with the Fossil Energy Baseline and avoid confusion.

The primary motivation for the selection of the Shell gasifier was the historical, commercial experience of the Shell gasifier continuously co-gasifying coal with 30 percent woody biomass at the Buggenum IGCC facility with prior plans to increase to 50 percent. [30] Additional considerations were the prevalence of the Shell technology in the Chinese coal-to-ammonia market.

Consistent with the SMR cases, coal gasification without CCS was included as a current, commercial reference for coal gasification with CCS. The capacity basis of the coal gasification cases is the equivalent as-received coal feed rate from Case B1B from the NETL Fossil Energy

## COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Baseline study. [31] As indicated previously, the resulting hydrogen production rate for these cases is 274 MMSCFD and equal to the ATR with CCS case. Although larger than the commercially operating examples found, process design studies have been completed for coal-to-ammonia plants at comparable scales as indicated by conversations with Black and Veatch (B&V).

Co-gasification of coal and biomass is included as the only study case achieving net-zero greenhouse gas life cycle emissions. A torrefied, woody biomass is considered due to the compatibility with the dry-fed Shell gasifier, as well as the experience at Buggenum. [30] The capacity basis of 1,400 ton per day (tpd) of combined feed matches that of the Buggenum facility.

The remainder of this report is organized as follows:

- Section 2 provides the basis for technical, environmental, and cost evaluations
- Section 3 describes the reforming technologies modeled and presents the results for the three cases
- Section 4 describes the gasification technologies modeled and presents the results for the three cases
- Section 5 provides results analysis for all six cases
- Section 6 provides suggestions for future work

**Exhibit 1-5. Case descriptions**

Case <sup>A</sup>	Plant Type	Feedstock	Reformer Type	Gasifier Type	CO <sub>2</sub> Capture <sup>B</sup>	H <sub>2</sub> Purification	Capacity Basis
1	Reforming	Natural Gas	SMR	N/A	0%	PSA	Single Train SMR Max (200 MMSCFD H <sub>2</sub> )
2					Max		
3			ATR		Max		Match H <sub>2</sub> output of Cases 4 & 5
4	Gasification	Illinois No. 6 Coal	N/A	Shell	0%		5,608 AR tpd coal
5					Max		
6		Illinois No. 6 Coal/ Torrefied Woody Biomass			Max		

<sup>A</sup>All plants in this report are assumed to be located at a generic plant site in the midwestern United States

<sup>B</sup>CO<sub>2</sub> capture targets the maximum amount of feedstock carbon captured from the syngas (ATR and gasification cases) and syngas plus furnace flue gas (SMR case)

## 2 GENERAL EVALUATION BASIS

For each of the plant configurations analyzed in this report, an Aspen Plus® (Aspen) model was developed and used to generate material and energy balances which were, in turn, used to provide a design basis for items in the major equipment list. The equipment list and material balances were used as the basis for generating the capital and operating cost estimates. Performance and process limits were based upon published reports, information obtained from vendors and users of the technology, performance data from design/build projects, and/or best engineering judgment. Capital and operating costs include scaled estimates from prior studies using National Energy Technology Laboratory (NETL) Quality Guidelines for Energy System Studies (QGESS) methodology as well as estimates provided by B&V based on simulation results using an in-house database and conceptual estimating models. The estimating models are based on a United States (U.S.) Gulf Coast location and the labor cost was factored to reflect a Midwest location. Costs were further calibrated using a combination of adjusted vendor-furnished data and scaled estimates from previous design/build projects. All costs are in 2018 dollars. Ultimately, a levelized cost of hydrogen (LCOH) was calculated for each of the cases and is reported as the revenue requirement figure-of-merit.

The balance of this section discusses the design basis common to all technologies, as well as environmental targets and cost assumptions used in this report. Technology specific design criteria are covered in subsequent chapters.

### 2.1 SITE CHARACTERISTICS

All plants in this report are assumed to be located at a generic plant site in the midwestern United States, with site characteristics and ambient conditions as presented in Exhibit 2-1 and Exhibit 2-2. The ambient conditions are the same as International Organization for Standardization (ISO) conditions.

*Exhibit 2-1. Site characteristics*

Parameter	Value
Location	Greenfield, Midwestern U.S.
Topography	Level
Size (Gasification), acres	300
Size (Reforming), acres	100
Transportation	Rail or Highway
Slag Disposal	Off-Site
Water	50% Municipal and 50% Ground Water

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 2-2. Site ambient conditions**

Parameter	Value
Elevation, m (ft)	0 (0)
Barometric Pressure, MPa (psia)	0.101 (14.696)
Average Ambient Dry Bulb Temperature, °C (°F)	15 (59)
Average Ambient Wet Bulb Temperature, °C (°F)	10.8 (51.5)
Design Ambient Relative Humidity, %	60
Cooling Water Temperature, °C (°F) <sup>A</sup>	15.6 (60)
<b>Air composition based on published psychrometric data, mass %</b>	
N <sub>2</sub>	75.055
O <sub>2</sub>	22.998
Ar	1.280
H <sub>2</sub> O	0.616
CO <sub>2</sub>	0.050
Total	100.00

<sup>A</sup>The cooling water temperature is the cooling tower cooling water exit temperature. This is set to 4.8 °C (8.5 °F) above ambient wet bulb conditions in ISO cases

The land area for gasification cases assumes that 30 acres are required for the plant proper, and the balance provides a buffer of approximately 0.4 km (0.25 mi) to the fence line. The extra land could also provide for a rail loop if required (rail loop is not included in this report). In the reforming cases it was assumed the plant proper occupies about 10 acres leaving a buffer of 0.24 km (0.15 mi) to the plant fence line.

The quality of plant makeup water will vary dramatically from source-to-source (municipal versus groundwater), as well as from site to site, and can be expected to vary significantly throughout any given site, particularly if ground water is utilized. In this study, 50 percent of the makeup water to the plants is sourced from a publicly owned treatment works, with the balance of the makeup water sourced from groundwater. The assumed design makeup water composition is provided in Exhibit 2-3.

The makeup water composition reported in the following table is based on water qualities from actual operations. The design concentration of each constituent is individually representative of a plant configuration comparable to those in this study. However, due to the interaction and interdependencies of each constituent and the multitude of potential species, the makeup water quality cannot be considered representative as a whole. The makeup water quality is intended to inform users of the contaminants likely present, and at what concentrations they may be expected, to facilitate appropriate equipment selection and design.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 2-3. Design makeup water quality**

Parameter	Groundwater (Range)	POTW Water (Range)	Makeup Water (Design Basis)
pH	6.6 – 7.9	7.1 – 8.0	7.4
Specific Conductance, $\mu\text{S}/\text{cm}$	1,096 – 1,484	1,150 – 1,629	1312
Turbidity, NTU		<50	<50
Total Dissolved Solids, ppm			906
M-Alkalinity as $\text{CaCO}_3$ , ppm <sup>A</sup>	200 – 325	184 – 596	278
Sodium as Na, ppm	102 – 150	172 – 336	168
Chloride as Cl, ppm	73 – 100	205 – 275	157
Sulfate as $\text{SO}_4$ , ppm	100 – 292	73 – 122	153
Calcium as Ca, ppm	106 – 160	71 – 117	106
Magnesium as Mg, ppm	39 – 75	19 – 33	40
Potassium as K, ppm	15 – 41	11 – 21	18
Silica as $\text{SiO}_2$ , ppm	5 – 12	21 – 26	16
Nitrate as N, ppm	0.1 – 0.8	18 – 34	12
Total Phosphate as $\text{PO}_4$ , ppm	0.1 – 0.2	1.3 – 6.1	1.6
Strontium as Sr, ppm	2.48 – 2.97	0.319 – 0.415	1.5
Fluoride as F, ppm	0.5 – 1.21	0.5 – 0.9	0.8
Boron as B, ppm	0.7 – 0.77		0.37
Iron as Fe, ppm	0.099 – 0.629	0.1	0.249
Barium as Ba, ppm	0.011 – 0.52	0.092 – 0.248	0.169
Aluminum as Al, ppm	0.068 – 0.1	0.1 – 0.107	0.098
Selenium as Se, ppm	0.02 – 0.15	0.0008	0.043
Lead as Pb, ppm	0.002 – 0.1		0.026
Arsenic as As, ppm	0.005 – 0.08		0.023
Copper as Cu, ppm	0.004 – 0.03	0.012 – 0.055	0.018
Nickel as Ni, ppm	0.02 – 0.05		0.018
Manganese as Mn, ppm	0.007 – 0.015	0.005 – 0.016	0.009
Zinc as Zn, ppm	0.005 – 0.024		0.009
Chromium as Cr, ppm	0.01 – 0.02		0.008
Cadmium as Cd, ppm	0.002 – 0.02		0.006
Silver as Ag, ppm	0.002 – 0.02		0.006
Mercury as Hg, ppm	0.0002 – 0.001		3E-04

<sup>A</sup>Alkalinity is reported as  $\text{CaCO}_3$  equivalent, rather than the concentration of  $\text{HCO}_3$ . The concentration of  $\text{HCO}_3$  can be obtained by dividing the alkalinity by 0.82

In the gasification cases, it was assumed that the steam turbine is enclosed in a turbine building. The gasifiers are not enclosed. In the reforming cases, it was assumed that the steam methane reformer is enclosed. The autothermal reformer is not enclosed.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

The following design parameters are considered site-specific and are not quantified for this report. Allowances for normal conditions and construction are included in the cost estimates.

- Flood plain considerations
- Existing soil/site conditions
- Water discharges and reuse
- Rainfall/snowfall criteria
- Seismic design
- Buildings/enclosures
- Local code height requirements
- Weather delays
- Other local environmental concerns
- Noise regulations

## 2.2 COAL CHARACTERISTICS

The design coal is Illinois No. 6 with characteristics presented in Exhibit 2-4. The coal properties are from the 2019 revision of the QGESS document “Detailed Coal Specifications.” [3]

**Exhibit 2-4. Design coal**

Rank	Bituminous	
Seam	Illinois No. 6	
Proximate Analysis (weight %) <sup>A</sup>		
	As Received	Dry
Moisture	11.12	0.00
Ash	9.70	10.91
Volatile Matter	34.99	39.37
Fixed Carbon	44.19	49.72
Total	100.00	100.00
Sulfur	2.51	2.82
HHV, kJ/kg (Btu/lb)	27,113 (11,666)	30,506 (13,126)
LHV, kJ/kg (Btu/lb)	26,151 (11,252)	29,544 (12,712)
Ultimate Analysis (weight %)		
	As Received	Dry
Moisture	11.12	0.00
Carbon	63.75	71.72
Hydrogen	4.50	5.06
Nitrogen	1.25	1.41
Chlorine	0.15	0.17
Sulfur	2.51	2.82
Ash	9.70	10.91
Oxygen <sup>B</sup>	7.02	7.91
Total	100.00	100.00

<sup>A</sup>The proximate analysis assumes sulfur as volatile matter


<sup>B</sup>By difference

The chlorine content of 34 samples of Illinois No. 6 coal has an arithmetic mean value of 1,671 parts per million weight, dry (ppmwd) with a standard deviation of 1,189 ppmwd based on coal samples shipped by Illinois mines. [32]

Based on the location of the Illinois No. 6 mine, along with the Herrin coal chlorine map published by the Illinois State Geological Survey [33], it was determined that Illinois No. 6 coal could be expected to have a chlorine content between 0.1 and 0.2 percent, on a dry basis. Therefore, the coal chloride content for this report was assumed to be the arithmetic mean value of 1,671 ppmwd.

The mercury (Hg) content of 34 samples of Illinois No. 6 coal has an arithmetic mean value of 0.09 ppmwd with standard deviation of 0.06 based on coal samples shipped by Illinois mines. [32] Hence, as illustrated in Exhibit 2-5, there is a 50 percent probability that the Hg content in the Illinois No. 6 coal would not exceed 0.09 ppmwd. The coal Hg content for this report was assumed to be 0.15 ppmwd, which corresponds to the mean plus one standard deviation and encompasses about 84 percent of the samples. It was further assumed that all the coal Hg enters the gas phase and none leaves with the slag in gasification cases. [34]

**Exhibit 2-5. Probability distribution of mercury concentration in the Illinois No. 6 coal**



Fuel costs used in this report are specified according to the 2019 QGESS document “Fuel Prices for Selected Feedstocks in NETL Studies.” [8] The current levelized coal price is \$2.11/gigajoule (GJ) (\$2.23/million British thermal units [MMBtu]) on a higher heating value (HHV) basis for Illinois No. 6 bituminous coal delivered to the Midwest and reported in 2018 dollars. Fuel costs are levelized over an assumed 30-year plant operational period with an assumed on-line year of 2023.

## 2.3 NATURAL GAS CHARACTERISTICS

Natural gas is utilized as the feedstock in the reforming cases, and its composition is presented in Exhibit 2-6. The natural gas properties are from the 2019 revision of the QGESS document “Specification for Selected Feedstocks” [4] including the addition of methanethiol (mercaptan). [35]

The current levelized natural gas price is \$4.19/GJ (\$4.42/MMBtu) on an HHV basis, delivered to the Midwest, and reported in 2018 U.S. dollars.<sup>b</sup> Fuel costs are levelized over an assumed 30-year plant operational period with an assumed on-line year of 2023.

**Exhibit 2-6. Natural gas composition**

Component		Volume Percentage
Methane	CH <sub>4</sub>	93.1
Ethane	C <sub>2</sub> H <sub>6</sub>	3.2
Propane	C <sub>3</sub> H <sub>8</sub>	0.7
<i>n</i> -Butane	C <sub>4</sub> H <sub>10</sub>	0.4
Carbon Dioxide	CO <sub>2</sub>	1.0
Nitrogen	N <sub>2</sub>	1.6
Methanethiol <sup>A</sup>	CH <sub>4</sub> S	5.75x10 <sup>-6</sup>
	<b>Total</b>	100.0
	<b>LHV</b>	<b>HHV</b>
	<b>kJ/kg (Btu/lb)</b>	<b>52,295 (22,483)</b>
	<b>MJ/scm (Btu/scf)</b>	<b>38.25 (1,027)</b>

<sup>A</sup>The sulfur content of natural gas is primarily composed of added mercaptan (methanethiol [CH<sub>4</sub>S]) with trace levels of hydrogen sulfide (H<sub>2</sub>S) [35]

Note: Fuel composition is normalized, and heating values are calculated using Aspen

## 2.4 BIOMASS CHARACTERISTICS

A torrefied, non-pelletized, short rotation, woody biomass is utilized as a co-feedstock in Case 6, and its composition is presented in Exhibit 2-7.

It is assumed that the torrefaction of the biomass is accomplished in dedicated torrefaction facilities beyond the boundaries of the hydrogen production facility. Assumptions pertaining to the torrefied biomass supply and cost are explained in Section 2.5.

<sup>b</sup> As specified in the 2019 QGESS document on “Fuel Prices for Selected Feedstocks in NETL Studies.” [8]


**Exhibit 2-7. Design biomass**

Torrefied, Woody Biomass		
Ultimate Analysis (weight %)		
	As Received	Dry
Moisture	5.72	0.00
Carbon	59.89	63.52
Hydrogen	5.11	5.42
Nitrogen	0.41	0.44
Chlorine	0.00	0.00
Sulfur	0.00	0.00
Ash	0.51	0.54
Oxygen	28.36	30.08
Total	100.00	100.00
HHV, kJ/kg (Btu/lb)	22,676 (9,749)	24,051 (10,340)
LHV, kJ/kg (Btu/lb)	21,406 (9,203)	22,853 (9,825)

## 2.5 BIOMASS SUPPLY AND COST

Torrefied biomass is delivered to the Case 6 hydrogen production facility gate in trucks and consists of torrefied chips. The delivered cost of the torrefied biomass was determined using a performance and economic model developed in a prior NETL study which leveraged work completed by the Idaho National Laboratory (INL). [36] [37] The model considers a wood chip supply chain design that uses conventional technologies and operations prior to delivery to the torrefaction facilities. The supply chain steps, and the pre-processing steps undertaken at the torrefaction plants are shown in Exhibit 2-8.

**Exhibit 2-8. Wood chip supply chain**



The model incorporates the cost of the wood chips delivered to the torrefaction facility as well as vendor-provided performance and cost data for a 63 kiloton per year woody biomass torrefaction system. Modeling parameter adjustments were made to reflect the total required torrefied biomass supply rate, capital charge factor, capital cost escalation, and cost for electric

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

power to maintain consistency with the assumptions for Case 6. The equivalent output of 3.2 torrefaction systems operating at a capacity factor of 90 percent are required to meet the torrefied biomass demand of Case 6. The results of the model are shown in Exhibit 2-9.

**Exhibit 2-9. Woody biomass torrefaction system economic summary**

Process Parameters/Category	Value	Units
<b>Feed Prep and Drying</b>		
Raw Wood Feed Rate	1,315	Tons/day
Raw Wood Moisture	43.3 <sup>A</sup>	wt. %
Dried Wood Moisture	8.2 <sup>B</sup>	wt. %
Dryer Thermal Capacity	52.2	MMBtu/hr
<b>Torrefaction</b>		
Feed Mass Flow	812	Tons/day
Mass Yield	.753	lb torrefied solid/lb feed
Energy Yield to Mass Yield Ratio	1.185	N/A
Torrefied Product HHV (dry basis)	10,340	Btu/lb
Torrefied Solids Product	609	Tons/day
Capacity Factor	90	%
<b>Cost Estimate</b>		
Capital Cost of Torrefaction Equipment	50.9	MM\$
Capital Charge Factor	0.0654	N/A
Capital Component	3.3	MM\$
Raw Wood (@\$22.63/ton)	9.8	MM\$
Natural Gas (\$4/mcf)	1.4	MM\$
Electric Power (2.2 MW @ \$71.7/MWh)	1.2	MM\$
Operations and Maintenance Costs	2.5	MM\$
Annual Revenue Requirement	18.3	MM\$
Required Selling Price (Torrefaction Plant Gate)	91.5	\$ per ton

<sup>A</sup> The chips enter the torrefaction facility with about 50% moisture content. After storage at the plant, moisture is lost and on reclaiming the woody biomass is assumed to have an average moisture content of 43.3%. [36]

<sup>B</sup> The process of torrefaction dries the wood to 8.2% moisture before torrefaction. The torrefied material has a moisture content of 5.72%. [36]

The required selling price of torrefied biomass is \$91.5/ton at the torrefaction plant gate. An additional cost of \$5.73/ton must be added for transportation of the torrefied biomass to the hydrogen production facility. A 40-mile transport distance at a cost of \$0.14 per mile-ton is

used. This brings the total price of as-received, torrefied biomass to \$97.2 per ton. The levelized price is \$117/tonne (\$106/ton) or \$5.15/GJ (\$5.43/MMBtu) on an HHV basis, delivered to the site, and reported in 2018 U.S. dollars. Fuel costs are levelized over an assumed 30-year plant operational period with an assumed on-line year of 2023.

## 2.6 HYDROGEN PRODUCT SPECIFICATION

All plant configurations in this study produce a hydrogen product at the plant gate meeting or exceeding the specification shown in Exhibit 2-10. No site-specific, single end-use is considered. Instead, the study goal was to consider a hydrogen product reflective of current, centralized, fossil-based production facilities and suitable for a wide range of potential energy applications. The maximum impurity concentrations shown in the specification are suitable for ammonia grade hydrogen to avoid catalyst poisoning. The specification also results in a product suitable for the following applications per ISO: [38]

- Type I Grade A – Gaseous hydrogen; internal combustion engines for transportation; residential/commercial combustion appliances (e.g., boilers, cookers, and similar applications)
- Type I Grade B – Gaseous hydrogen; industrial fuel for power generation and heat generation except proton-exchange membrane (PEM) fuel cell applications

The hydrogen product pressure specification was determined based on feedback from a commercial owner/operator of large-scale, centralized merchant hydrogen production facilities and a hydrogen pipeline transportation and distribution network. The owner/operator advised that pipeline operating pressures vary nominally from 800 to 900 pound per square inch gauge (psig) depending on the location within the network. A nominal hydrogen product pressure at the plant fence is greater than 900 psig, and compression normally occurs within the plant boundary.

**Exhibit 2-10. Hydrogen product specification**

Characteristic	Specification
H <sub>2</sub> Purity (vol%)	99.90 (min.)
CO <sub>2</sub> (ppm)	A
CO (ppm)	A
H <sub>2</sub> S (ppb)	10 (max.)
H <sub>2</sub> O (ppm)	A
O <sub>2</sub> (ppm)	A
Pressure (psia)	939.7

<sup>A</sup> The maximum total concentration of all oxygen-containing species is 10 ppm

## 2.7 ENVIRONMENTAL TARGETS

### 2.7.1 Air Emissions Targets

The environmental approach for the study was to evaluate each case on the same regulatory design basis, considering differences in fuel and technology. Since all cases are located at a green-field site, permitting a new plant would likely invoke the New Source Review (NSR) permitting process. The NSR process requires installation of emission control technology meeting either Best Available Control Technology (BACT) determinations for new sources being located in areas meeting ambient air quality standards (attainment areas) or Lowest Achievable Emission Rate (LAER) technology for sources being located in areas not meeting ambient air quality standards (non-attainment areas).

BACT guidelines are used for the cases evaluated in this study. Low NO<sub>x</sub> burners will be included in the SMR and ATR cases to minimize the NO<sub>x</sub> emissions from the fired equipment to meet BACT requirements. Sulfur emissions are eliminated due to the pre-treatment of the feedstock to remove sulfur. For the production of hydrogen from coal gasification, the primary control standards that are expected to apply include emissions of particulates, nitrogen oxides, sulfur species, and mercury. Process technology is directed toward minimum sulfur content in the syngas and product. BACT for NO<sub>x</sub> emissions from the off-gas fired boilers will be utilized. BACT control technologies and emission limits are summarized in Exhibit 2-11 and Exhibit 2-12.

The following regulatory assumptions are used for assessing environmental control technologies:

- NO<sub>x</sub> Emission Reduction Credits (ERCs) and allowances are not available for the project emission requirements when located in the ozone attainment area.
- Solid waste disposal is either offsite at a fixed \$/ton fee or is classified as a byproduct for reuse, claiming no net revenue (\$/ton) or cost.
- Raw water is available to meet technology needs.
- Wastewater discharge will meet effluent guidelines rather than water quality standards.
- 90+ percent removal of carbon in design fuel.

*Exhibit 2-11. BACT environmental design basis for reforming cases*

Pollutant	Control Technology	Limit
Sulfur Dioxide (SO <sub>2</sub> )	Zinc oxide guard bed	Negligible
Nitrogen Oxides (NO <sub>x</sub> )	Low NO <sub>x</sub> Burners	2.5 ppmv (dry) @ 15% O <sub>2</sub>
Particulate Matter (PM)	N/A	Negligible
Mercury (Hg)	N/A	Negligible

**Exhibit 2-12. BACT environmental design basis for gasification cases**

Pollutant	Control Technology	Limit
Sulfur Dioxide (SO <sub>2</sub> )	Selexol/MDEA + Claus Plant or equivalent performing system	99+% or ≤ 0.050 lb/10 <sup>6</sup> Btu
Nitrogen Oxides (NOx)	Low NOx Burners	15 ppmvd (@ 15% O <sub>2</sub> )
Particulate Matter (PM)	Cyclone/Barrier Filter/Wet Scrubber/AGR Absorber	0.015 lb/10 <sup>6</sup> Btu
Mercury (Hg)	Activated Carbon Bed or equivalent performing system	95% removal

## 2.7.2 Water Emissions Targets

EPA issued updated Effluent Limitation Guidelines (ELG) and standards for the steam electric power generation point source category in November 2015 to strengthen controls on wastewater discharges.<sup>c</sup> [39] The ELG are national technology-based New Source Performance Standards (NSPS) derived from data collected from industry. They are intended to provide flexibility in implementation through use of technologies already installed and operating in the power industry. The federal standards established by this rule are the minimum discharge standards. As ELG are enforced under the National Pollutant Discharge Elimination System [40], more stringent water quality-based standards may be established by the local permitting authority; however, these additional requirements were not considered in this report.

The final ELG rule established new wastewater categories and discharge limits and updated discharge requirements for existing wastewater categories. Wastewater from facilities gasifying fuels such as coal and petroleum coke are covered by the final ELG rule. Although not explicitly categorized as a steam electric power generation point source under the final ELG rule, the rule is assumed to apply to the gasification cases in this study due to the identical wastewater sources.

For the gasification cases in this study, the gasification wastewater from the balance of plant is recycled within the gasification and syngas cleanup process, ultimately being utilized as makeup to the syngas scrubber. Therefore, only the syngas scrubber blowdown requires treatment.

Non-chemical metal cleaning wastewater was established as a new wastewater category in the updated ELG. However, new limits were not established for this category; therefore, treatment of this stream has not been evaluated in this report.

The landfill of plant byproducts is assumed to be outside the scope of the plants considered in this study; therefore, landfill leachate is not evaluated in this report.

Intermittent discharges (e.g., chemical metal cleaning wastewater), coal pile runoff, low volume waste (e.g., boiler blowdown), and cooling tower blowdown were assumed to be compliant with all applicable regulations with no additional treatment beyond conventional considerations.

<sup>c</sup> In April 2017, EPA announced plans to reconsider the power plant ELG rule—as they apply to existing sources—and their intent to request a stay of the regulations, pending litigation. [40]

## COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Under the assumptions established in this section, no additional control technology considerations are required for natural reforming compliance with the ELG rule.

The applicable wastewater discharge limits for the gasification cases are shown in Exhibit 2-13, respectively.

**Exhibit 2-13. New source treated gasification wastewater discharge limits [39]**

Effluent Characteristic	Long-Term Average	Daily Maximum Limit	Monthly Average Limit <sup>A</sup>
Arsenic, ppb	4.0	4	-
Mercury, ppt	1.08	1.8	1.3
Selenium, ppb	147	453	227
Total Dissolved Solids, ppm	15.2	38	22

<sup>A</sup>Monthly Average Limit refers to the highest allowable average of daily discharges over 30 consecutive days

The limits are applied at the discharge, prior to commingling with other plant water systems.

### 2.7.3 Carbon Dioxide

Global CO<sub>2</sub> emissions from the production of high-purity hydrogen are significant, accounting for 830 million tonnes (915 million tons) of CO<sub>2</sub> annually. This is roughly equivalent to the CO<sub>2</sub> emissions of Indonesia and the United Kingdom combined. [24] Large-scale CO<sub>2</sub> separation is commonly recovered from commercially-operating, hydrogen production processes and utilized for enhanced oil recovery, sold into the beverage market, or for synthesis of fertilizer products such as urea ammonium nitrate (UAN). However, the absence of environmental regulations targeting CO<sub>2</sub> emissions from industrial sources such as hydrogen production plants limits the overall CO<sub>2</sub> capture rate at such facilities as well as industry-wide adoption of CO<sub>2</sub> capture.<sup>d</sup> However, due to recent international government initiatives, several large-scale, fossil-based hydrogen production projects targeting high levels of CO<sub>2</sub> capture and storage (90+ percent) are currently under development in anticipation of future CO<sub>2</sub> regulations. Exhibit 2-14 provides an overview of some these projects and the targeted level of CO<sub>2</sub> capture.

**Exhibit 2-14. Fossil-based hydrogen projects with CO<sub>2</sub> capture**

Project Name	Location	H <sub>2</sub> Production kNm <sup>3</sup> /hr (MMSCFD)	H <sub>2</sub> Production Platform	AGR Technology	Targeted Overall CO <sub>2</sub> Capture Rate (%)
HyNet [23]	United Kingdom	100 (90)	ATR	TBD	97.2
H21 [24] [25]	United Kingdom	3,200 (2,900)	ATR	aMDEA	94.2

<sup>d</sup> The Infrastructure Investment and Jobs Acts (IIJA) of 2021 establishes a definition of clean hydrogen to mean hydrogen produced with a carbon intensity (CI) less than or equal to 2 kg CO<sub>2</sub>e produced at the site of production per kg of H<sub>2</sub> produced. The IIJA further requires an initial CI standard be developed in mid-2022 with consideration for adjustment in 2027.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Project Name	Location	H <sub>2</sub> Production kNm <sup>3</sup> /hr (MMSCFD)	H <sub>2</sub> Production Platform	AGR Technology	Targeted Overall CO <sub>2</sub> Capture Rate (%)
Acorn [26]	Scotland	53 (48)	ATR	Amine	98.7
H2Teesside [27]	United Kingdom	275 (250)	TBD	TBD	~98
Air Products Alberta [28]	Canada	>695 (>623)	ATR	TBD	95
Air Products Louisiana [29]	USA	>837 (>750)	ATR/POX	TBD	95

As led by the growing number of such projects, an objective of this study was to examine plant arrangements capable of achieving capture rates greater than 90 percent of the carbon in the plant feedstock. A study definition of “maximum CO<sub>2</sub> capture” was established which considers the following:

- A 2x3 water gas shift (WGS) reactor arrangement was incorporated into each plant to increase the CO conversion efficiency to 97.2 percent. The conversion rate matches that of the E-Gas™ IGCC cases studied in the NETL Fossil Energy Baseline study which employed the same reactor arrangement. [31]
- SMR with CCS incorporates CO<sub>2</sub> capture technologies to treat the pressurized syngas stream as well as the reactor furnace low-pressure flue gas
- The ATR and gasification cases with CCS incorporate CO<sub>2</sub> capture technologies treating only the pressurized syngas stream. No low-pressure CO<sub>2</sub> capture technologies are incorporated.
- No partial bypasses of the acid gas removal (AGR) technologies are included as control mechanisms for targeting specific levels of CO<sub>2</sub> capture in the plant flowsheets
- No adjustments have been made to vendor-provided CO<sub>2</sub> separation efficiencies of the AGR technologies

## 2.8 LIFE CYCLE ANALYSIS OF GREENHOUSE GAS EMISSIONS

The goal of the LCA performed was to generate attributional life cycle GHG emissions estimates for each study case.

Life cycle GHG emissions are reported for select processes occurring outside of the plant boundary as well as atmospheric CO<sub>2</sub> uptake during the regrowth of biomass. While LCA can include the inventory of many types of flows, such as criteria air pollutants, the focus of this LCA was greenhouse gases.

The final life cycle results were generated on a functional unit basis of 1 lb of H<sub>2</sub> produced. The life cycle impact assessment method used is from the International Panel of Climate Change 5<sup>th</sup> Assessment Report (IPCC AR5), [41] which, amongst other features, provides GWP values that

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

can be used to convert emissions of various greenhouse gases into equivalent emissions of carbon dioxide, or CO<sub>2</sub>e. The results reflect a 100-year timeframe with atmospheric carbon feedback, using the values shown in Exhibit 2-15. As such, the life cycle GHG emissions results are generated in units of lb CO<sub>2</sub>e/lb H<sub>2</sub>.


**Exhibit 2-15. Fossil GWP values for select GHGs**

Greenhouse Gas	Formula	GWP Value
Carbon dioxide	CO <sub>2</sub>	1
Methane	CH <sub>4</sub>	36
Nitrous oxide	N <sub>2</sub> O	298

The system boundary for the LCA of the different hydrogen pathways includes natural resources consumed, utilities, relevant waste, products, and co-products where applicable. Case 1 was modeled in two ways given the presence of steam as a co-product, once by ignoring the effect and once by using an LCA method called system expansion with displacement to credit the emissions that would otherwise be needed to produce the extra steam. Similarly, Case 6’s model performs system expansion to credit net negative electricity emissions due to the small amount of electricity that is sold back to the grid.


See Exhibit 2-16 through Exhibit 2-21 for diagrams of each study case’s system boundary. The parallelogram shapes indicate upstream emissions data whereas the rectangle shapes indicate downstream processes. Various non-GHG inventory flows are represented in the diagrams but were not included as results in this study.

**Exhibit 2-16. Case 1 system boundary, steam methane reforming plant without CO<sub>2</sub> capture**




COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 2-17. Case 2 system boundary, steam methane reforming plant with CO<sub>2</sub> capture**




**Exhibit 2-18. Case 3 system boundary, autothermal reforming plant with CO<sub>2</sub> capture**




COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 2-19. Case 4 system boundary, coal gasification plant without CO<sub>2</sub> capture**




**Exhibit 2-20. Case 5 system boundary, coal gasification plant with CO<sub>2</sub> capture**



## COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 2-21. Case 6 system boundary, coal/biomass co-gasification plant with CO<sub>2</sub> capture**



OpenLCA software and various existing NETL LCA resources were used to model the systems defined above. Notably, this effort builds upon past NETL work in which life cycle models were developed for producing various feedstocks for hydrogen production plants. The following gives more information about emissions data related to all modeled upstream and downstream processes:

- Upstream production of natural gas was modeled using the NETL natural gas model, which is documented in the NETL 2019 natural gas baseline report. [9] The boundaries for the model start at natural gas extraction and end at transmission, the same boundaries used in evaluating the electricity generation cases in Section 7 of the natural gas report. All parameters and assumptions used in the model are documented in the report. The U.S. average and basin-level data was updated to the year 2017 based on a more recent NETL report [10].
- Upstream production of biomass, specifically the torrefied Southern Yellow Pine (SYP) used in this study, followed work previously done for the Connecticut Center for Advanced Technology (CCAT). [13] All but two parameters used in the modeling of biomass came from this previous work. The biomass loss rate during harvesting was adjusted to be 5%. Upstream potash fertilizer production was updated to a more-recent value found in a 2018 journal article. [42]
- The upstream production of coal leverages modeling and default assumptions from the NETL Supercritical Pulverized Coal (SCPC) Power Plant study. [14] The SCPC study considers upstream production of coal from the Illinois basin, and Illinois underground bituminous coal was assumed to represent the Illinois #6 coal used in this study. The coal mine methane emissions found in the SCPC study were adjusted to 0.0086 lb CH<sub>4</sub>/lb coal. Transportation of coal from mine to plant assumes U.S. average distances of 3.8

miles by truck, 35.1 miles by barge, 42.1 miles by ocean/lake vessel, and 577 miles by train.

- Process information for the storage of CO<sub>2</sub> in a saline aquifer followed modeling and assumptions used in the NETL SCPC Power Plant study. [14]
- Electricity impacts are modeled using the NETL electricity baseline, represented by the U.S. average consumption mix at the user. [11] [12]

Excluded from the factors considered are life cycle GHG emissions associated with plant construction, additional upstream material and energy infrastructure necessary for deliveries to the hydrogen production facility (e.g., connector rail spurs, roads, pipelines), and emissions from water conditioning at the hydrogen production facility. Based on other GHG LCAs performed by NETL, impacts from these areas are assumed to be minor contributors to the overall life cycle GHG emission profiles of the study cases compared to the other emissions sources which occur throughout the operating lifetime of the plant. [43] [14]

## 2.9 CAPACITY FACTOR

### 2.9.1 Capacity Factor Assumptions

Availability is the percent of time during a specific period that a generating unit is capable of producing hydrogen. This report assumes that each new plant would be dispatched any time it is available and would be capable of generating the nameplate capacity when online. Therefore, the capacity factor (CF) and availability are equal. The calculations assume that the CF and availability are constant over the life of the plant, but in practice, a plant will have a higher peak availability to counter lower availability in the first several years of operation.

### 2.9.2 Capacity Factor for Reforming Plants

The overall availability of the reforming plants was assumed to be 90 percent, which is consistent with commercial plants. Each reforming plant assumes a single reactor operating at full capacity.

### 2.9.3 Capacity Factor for Gasification Plants

The Electric Power Research Institute (EPRI) has reported an availability goal for IGCC plants of 85 percent. [44] Plants built before 2000 have achieved availability of 80 percent for limited periods. Common projections from technology suppliers and EPRI are that IGCC plants are capable of 80–85 percent availability without a spare gasifier and could achieve greater than 90 percent availability with a spare gasifier. [45], [46], [47], [48], [49], [50]

While an availability of 85 percent is the goal, given the technology experience of the similar IGCC process to that of the gasification plants in this study, a CF of 80 percent was selected for gasification plants with no spare gasifier.

## 2.9.4 Capacity Factor for Plants with Carbon Capture

The implementation of carbon capture and storage adds extra equipment to the hydrogen plant. Preliminary reliability analyses show that small reductions in reliability may occur with the addition of carbon capture and storage technology. The solvent-based carbon capture and CO<sub>2</sub> compression technologies used in this study have commercial operating experience, although at smaller scales, and have demonstrated high reliability. Therefore, given the report basis and use of commercial technology, the assumption is made that the CFs for a given plant with and without carbon capture are the same.

## 2.10 RAW WATER WITHDRAWAL AND CONSUMPTION

A water balance was performed for each case on the major water consumers in the process. The total water demand for each subsystem was determined, and internal recycle water available from various sources like condensate from syngas, or from flue gas (in SMR with CO<sub>2</sub> capture cases) was applied to offset the water demand. The difference between demand and recycle is raw water withdrawal. Raw water withdrawal is the water removed from the ground or diverted from a municipal source for use in the plant. Raw water consumption is also accounted for as the portion of the raw water withdrawn that is evaporated, transpired, incorporated into products, or otherwise not returned to the water source from which it was withdrawn.

Raw water makeup was assumed to be provided 50 percent by a publicly owned treatment works (POTW) and 50 percent from groundwater. Raw water withdrawal is defined as the water metered from a raw water source and used in the plant processes for all purposes, such as cooling tower makeup, boiler feedwater (BFW) makeup, and reforming steam, depending on the technology examined. The difference between withdrawal and process water returned to the source is consumption. Consumption represents the net impact of the process on the water source.

BFW blowdown and air separation unit (ASU) knockout were assumed to be treated and recycled to the cooling tower. The cooling tower blowdown was assumed to be treated and 90 percent returned to the water source.

The largest consumer of raw water for SMR without CCS (Case 1) is steam generation for reforming and export. In all the remaining cases it is cooling tower makeup. It was assumed that all cases utilized a mechanical draft, evaporative cooling tower. The design ambient wet bulb temperature of 11 °C (51.5 °F) (Exhibit 2-1 and Exhibit 2-2) was used to achieve a cooling water temperature of 16 °C (60 °F) using an approach of 5 °C (8.5 °F). The cooling water range was assumed to be 11 °C (20 °F). The cooling tower makeup rate was determined using the following [51]:

- Evaporative losses of 0.8 percent of the circulating water flowrate per 5.5 °C (10 °F) of range
- Drift losses of 0.001 percent of the circulating water flowrate
- Blowdown losses (BDL) were calculated as follows:

$$BDL = \frac{EL}{CC - 1}$$

Where:

**EL** – Evaporative Losses

**CC** – Cycles of concentration

The cycles of concentration are a measure of water quality and a mid-range value of four was chosen for this report.

The water balances presented in subsequent sections include the water demand of the major water consumers within the process, the amount provided by internal recycle, the amount of raw water withdrawal by difference, the amount of process water returned to the source, and the raw water consumption, again by difference.

## 2.11 COST ESTIMATING METHODOLOGY

Detailed information pertaining to topics such as contracting strategy; engineering, procurement, and construction (EPC) contractor services; estimation of capital cost contingencies; owner’s costs; cost estimate scope; economic assumptions; finance structures; and LCOHs are available in the 2019 revision of the QGESS document “Cost Estimation Methodology for NETL Assessment of Power Plant Performance.” [6] Select portions are repeated in this report for completeness.

### Capital Costs:

The capital cost estimates documented in this report reflect different uncertainty ranges depending on the technology considered as shown in Exhibit 2-22.

*Exhibit 2-22. Capital cost uncertainty ranges*

Technology	Uncertainty Range	AACE Classification
Gasification	-25/+50	Class 5
Reforming	-15/+25	Class 4

Gasification cases carry an uncertainty range of -25 percent/+50 percent, consistent with Association for the Advancement of Cost Engineering (AACE) Class 5 cost estimates (i.e., feasibility study) [6] [52] [53], based on the level of engineering design performed. This range has been deemed reflective of recent commercial power IGCC experience in the NETL Fossil Energy Baseline study. [31] This uncertainty range is considered applicable to the gasification cases in this study given the number of common process systems with IGCC plants and the limited recent development of coal gasification projects in the United States in recent years.

Reforming cases carry smaller uncertainty ranges, and both fall within AACE Class 4 estimates. Given recent experience with SMR and ATR plants, the reforming uncertainty range is smaller than gasification.

In all cases, this report intends to represent the next commercial offering and relies on vendor cost estimates for component technologies. It also applies process contingencies at the appropriate subsystem levels in an attempt to account for expected but undefined costs, which can be a challenge for emerging technologies.

#### Costs of Mature Technologies and Designs:

The cost estimates for plant designs that only contain fully mature technologies, which have been widely deployed at commercial scale (e.g., SMR and gasification without CO<sub>2</sub> capture), reflect NOAK on the technology commercialization maturity spectrum. The costs of such plants have dropped over time due to “learning by doing” and risk reduction benefits that result from serial deployments as well as from continuing R&D.

#### Costs of Emerging Technologies and Designs:

The cost estimates for plant designs that include technologies that are not yet fully mature (e.g., any plant with CO<sub>2</sub> capture) use the same cost estimating methodology as for mature plant designs, which does not fully account for the unique cost premiums associated with the initial, complex integrations of emerging technologies in a commercial application. Thus, it is anticipated that early deployments of these plants may incur costs higher than those reflected within this report.

#### Other Factors:

Actual reported project costs for all the plant types are also expected to deviate from the cost estimates in this report due to project- and site-specific considerations (e.g., contracting strategy, local labor costs, seismic conditions, water quality, financing parameters, local environmental concerns, weather delays) that may make construction more costly. Such variations are not captured by the reported cost uncertainty.

#### Future Cost Trends:

Continuing research, development, and demonstration (RD&D) is expected to result in designs that are more advanced than those assessed by this report, leading to costs that are lower than those estimated here.

### **2.11.1 Capital Costs**

As illustrated in Exhibit 2-23, this report defines capital cost at five levels: BEC, EPCC, TPC, TOC, and TASC. BEC, EPCC, TPC, and TOC are “overnight” costs and are expressed in “base-year” dollars. The base year is the first year of capital expenditure. TASC is expressed in mixed, current-year dollars over the entire capital expenditure period, which is assumed in most NETL studies to last five years for coal plants and three years for natural gas plants.

The Bare Erected Cost (BEC) comprises the cost of process equipment, on-site facilities and infrastructure that support the plant (e.g., shops, offices, labs, road), and the direct and indirect labor required for its construction and/or installation. The cost of EPC services and contingencies are not included in BEC.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES


The Engineering, Procurement and Construction Cost (EPCC) comprises the BEC plus the cost of services provided by the EPC contractor. EPC services include: detailed design, contractor permitting (i.e., those permits that individual contractors must obtain to perform their scopes of work, as opposed to project permitting, which is not included here), and project/construction management costs.

The Total Plant Cost (TPC) comprises the EPCC plus project and process contingencies.

The Total Overnight Cost (TOC) comprises the TPC plus all other overnight costs, including owner’s costs. TOC does not include escalation during construction or interest during construction.

The Total As-Spent Cost (TASC) is the sum of all capital expenditures as they are incurred during the capital expenditure period including their escalation. TASC also includes interest during construction, comprising interest on debt and a return on equity.

*Exhibit 2-23. Capital cost levels and their elements*



**2.11.1.1 Cost Estimate Basis and Classification**

Full, bottom-up estimates for each case in this study were not pursued. Instead, the TPC and operation and maintenance (O&M) costs for each of the cases were estimated using a combined bottom-up and scaling approach. Black & Veatch leveraged an in-house database and conceptual estimating models. Costs were further calibrated using a combination of adjusted vendor-furnished data and scaled estimates from previous design/build projects. Costs were further calibrated using a combination of adjusted vendor-furnished data and scaled estimates from previous design/build projects. In addition, cost scaling was performed on select plant

areas using reference costs from prior NETL studies according to the 2019 revision of the QGESS document “Capital Cost Scaling Methodology: Revision 4 Report.” [7]

#### **2.11.1.2 System Code-of-Accounts**

The costs are grouped according to a process/system-oriented code of accounts. This type of code-of-account structure has the advantage of grouping all reasonably allocable components of a system or process, so they are included in the specific system account. (This would not be the case had a facility, area, or commodity account structure been chosen instead).

#### **2.11.1.3 Estimate Scope**

The estimates represent a complete hydrogen production facility on a generic site. The plant boundary limit is defined as the total plant facility within the “fence line” including feedstock receiving and water supply system but terminating at the injection point into the hydrogen pipeline network. Hydrogen pipeline and storage is beyond the estimate scope. CO<sub>2</sub> transport and storage (T&S) cost is not included in the reported capital cost or O&M costs but is treated separately and added to the LCOH.

#### **2.11.1.4 Capital Cost Assumptions**

Black & Veatch developed select portions of the capital cost estimates for each plant using the company’s in-house database and conceptual estimating methodology for each of the specific technologies. A reference bottom-up estimate for each major component provides the basis for the estimating models. The following assumptions are reflected in the bottom-up costs as well as the costs scaled according to NETL QGESS methodology:

- Labor costs are based on Midwest, Merit Shop. The estimating models are based on a U.S. Gulf Coast location and the labor cost has been factored to a Midwest location. Labor cost data were sourced from recent projects and proprietary Black & Veatch in-house references/cost databases.
- The estimates are based on a competitive bidding environment, with adequate skilled craft labor available locally.
- Labor is based on a 50-hour work week (5 days x 10 hours). No additional incentives such as per- diem allowances or bonuses have been included to attract craft labor.
- While not included at this time, labor incentives may ultimately be required to attract and retain skilled labor depending on the amount of competing work in the region, and the availability of skilled craft in the area at the time the projects proceed to construction.
- The estimates are based on a greenfield site.
- The site is considered to be Seismic Zone 1, relatively level, and free from hazardous materials, archeological artifacts, or excessive rock. Soil conditions are considered adequate for spread footing foundations. The soil bearing capability is assumed adequate such that piling is not needed to support the foundation loads.

- Engineering and Construction Management are estimated based on Black & Veatch’s historical experience in designing and building power projects. The cost, as a percentage of BEC, varies by technology; 20 percent for reforming and 15 percent for gasification. The percentages were selected based on those used for natural gas combined cycle (NGCC) and IGCC plant cost estimation in the NETL Fossil Energy Baseline study. [31] These costs consist of all home office engineering and procurement services as well as field construction management costs. Site staffing generally includes construction manager, resident engineer, scheduler, and personnel for project controls, document control, materials management, site safety, and field inspection.

### **2.11.1.5 Price Fluctuations**

During the writing of this report, the prices of equipment and bulk materials fluctuated as a result of various market forces. Some reference quotes pre-dated the 2018-year cost basis while others may be considered more historical. All vendor quotes used to develop these estimates were adjusted to December 2018 dollars accounting for the price fluctuations. Price indices, e.g., The Chemical Engineering Plant Cost Index [54] and the Gross Domestic Product Chain-type Price Index [55], were used as needed for these adjustments. While these overall indices are nearly constant, it should be noted that the cost of individual equipment types may still deviate from the December 2018 reference point.

#### **2.11.1.5.1 Process Contingency**

Process contingencies were applied to the gasification and reforming with capture estimates in this report, with justification provided, as follows:

- Gasifiers and Syngas Coolers: 14 percent on all cases—next-generation commercial offering
- Two-Stage Selexol: 20 percent on gasification with capture cases—unproven technology at commercial scale in gasification service
- Mercury Removal: 5 percent on all gasification cases—minimal commercial scale experience in gasification applications
- Instrumentation and Controls: 5 percent on most accounts—integration issues

Process contingencies were applied to the reforming estimates in this report as follows:

- Cansolv System: 18 percent on SMR with capture case—post-combustion capture process unproven at commercial scale for SMR applications. No contingency added for MDEA in any case due to the extensive commercial experience in hydrogen applications.
- Instrumentation and Controls: 5 percent on most accounts within reforming with capture cases—integration issues

#### **2.11.1.6 Owner’s Costs**

Detailed explanation of the owner’s costs is available in the 2019 revision of the QGESS document “Cost Estimation Methodology for NETL Assessment of Power Plant Performance.”

[6] Owner's costs are split into three categories: pre-production costs, inventory capital, and other costs.

Pre-production allocations are expected to carry the specific plants through substantial completion, and to commercial operation. Substantial completion is intended to represent the transfer point of the facility from the EPC contractor (development entity) to the end user or owner, and is typically contingent on mutually acceptable equipment closeout, successful completion of facility-wide performance testing, and full closeout of commercial items.

Two examples of what could be included in the "other" owner's costs are rail spur and switch yard costs. Rail spur costs would only be applied to the gasification cases; however, the switch yard costs would be included in all cases.

Switch yard costs are dependent on voltage, configuration, number of breakers, layout, and air-insulated versus gas-insulated. As a rule of thumb, a 345-kilovolt (kV) switchyard (air-insulated, ring bus) would cost roughly \$850,000 per breaker.

On-site only rails (excludes long runs) would be expected to cost in the range of \$850,000 to \$950,000 per mile (relatively flat level terrain) plus the costs of any switches/turnouts (approximately \$50,000 each) and road crossings (approximately \$300 per linear foot).

### **2.11.2 Operation and Maintenance Costs**

The production costs or operating costs and related maintenance expenses (O&M) pertain to those charges associated with operating and maintaining the hydrogen plants over their expected life. These costs include:

- Operating labor
- Maintenance – material and labor
- Administrative and support labor
- Consumables
- Fuel
- Waste disposal
- Co-product or by-product credit (that is, a negative cost for any by-products sold)

There are two components of O&M costs: fixed O&M, which is independent of hydrogen production, and variable O&M, which is proportional to hydrogen production. Taxes and insurance are included as fixed O&M costs, totaling 2 percent of the TPC.

#### **2.11.2.1 Operating Labor**

Operating labor cost was determined based on the number of operators required for each technology. The average base labor rate used to determine annual cost is \$38.50/hour. The associated labor burden is estimated at 30 percent of the base labor rate.

### **2.11.2.2 Maintenance Material and Labor**

Maintenance cost was evaluated on the basis of relationships of maintenance cost to initial capital cost. This represents a weighted analysis in which the individual cost relationships were considered for each major plant component or section.

### **2.11.2.3 Administrative and Support Labor**

Labor administration and overhead charges are assessed at a rate of 25 percent of the burdened O&M labor.

### **2.11.2.4 Consumables**

The cost of consumables, including fuel, was determined based on each consumable's individual rate of consumption, the unit cost of the specific consumable commodity, and the plant annual operating hours. The consumption rate is determined from process data for fuel and water, the initial fill amount and lifetime of the consumable for catalysts and adsorbents, or vendor input for other consumables.

Quantities for major consumables such as feedstock and sorbent were taken from technology-specific energy and mass balance diagrams developed for each plant application. Other consumables were evaluated on the basis of the quantity required using reference data.

The quantities for initial fills and daily consumables were calculated on a 100 percent operating capacity basis. The annual cost for the daily consumables was then adjusted to incorporate the annual plant operating basis, or CF.

Initial fills of the consumables, fuels, and chemicals may be accounted for directly in the O&M tables or included with the equipment pricing in the capital cost. Where applicable, the O&M tables state where this cost is included on a case-by-case basis.

### **2.11.2.5 Waste Disposal**

Waste quantities and disposal costs were determined/evaluated similarly to the consumables. Chemical and catalyst waste streams are individually reported, in addition to others such as slag. Spent reforming catalysts are assumed to carry a residual value in buyback from the supplier. No resale value is credited. Instead, a \$0/ft<sup>3</sup> disposal cost is assumed. Waste disposal costs were separated into two categories: non-hazardous and hazardous waste. Non-hazardous waste is disposed of at a rate of \$41.9/tonne (\$38.0/ton). Hazardous waste is disposed of at a rate of \$88.2/tonne (\$80.0/ton).

### **2.11.2.6 Co-Products and By-Products**

By-product quantities were also determined similarly to the consumables. For cases exporting power, a grid sales price of \$71.7/MWh was assumed, the same price at which cases importing power must purchase it. This price is the average price paid by an industrial consumer in the Midwest Independent System Operator (MISO) region in 2019<sup>e</sup>. However, due to the variable

---

<sup>e</sup> As reported in "Annual Electric Power Industry Report," Form EIA-861

marketability of other by-products, specifically export steam and sulfur, no credit was taken for their potential salable value.

It should be noted that by-product credits and/or disposal costs could potentially be an additional determining factor in the choice of technology for some companies and in selecting some sites. A high local value of the product can establish whether added capital should be included in the plant costs to produce a particular co-product. Slag is a potential by-product in certain markets. However, as stated above, these material streams are considered waste in this report with a concomitant disposal cost.

### 2.11.3 CO<sub>2</sub> Transport and Storage

The cost of CO<sub>2</sub> T&S in a deep saline formation is estimated using the Fossil Energy (FE)/NETL CO<sub>2</sub> Transport Cost Model (CO<sub>2</sub> Transport Cost Model) and the FE/NETL CO<sub>2</sub> Saline Storage Cost Model (CO<sub>2</sub> Storage Cost Model). Additional detail on development of these costs is available in the 2019 revision of the QGESS document “Carbon Dioxide Transport and Storage Costs in NETL Studies.” [56]

Due to the variances in the geologic formations that make up saline formations across the United States, the cost to store CO<sub>2</sub> will vary depending on location. Storage cost results from the CO<sub>2</sub> Storage Cost Model align with generic plant locations from the NETL studies that utilize the coal found in those particular basins:

- Midwest plant location – Illinois Basin
- Texas plant location – East Texas Basin
- North Dakota plant location – Williston Basin
- Montana plant location – Powder River Basin

The far-right column of Exhibit 2-24 shows the total T&S costs used in NETL system studies for each plant location rounded to the nearest whole dollar. Only the \$10/tonne (\$9/ton) value is used in this study report since all cases are in the Midwest.

**Exhibit 2-24. CO<sub>2</sub> transport and storage costs**

Plant Location	Basin	Transport (2018 \$/tonne)	Storage Cost at 25 Gt (2018 \$/tonne)	T&S Value for System Studies <sup>A</sup> (2018 \$/tonne)
Midwest	Illinois	2.07	8.32	10
Texas	East Texas		8.66	11
North Dakota	Williston		12.98	15
Montana	Powder River		19.84	22

<sup>A</sup>The sum of transport and storage costs rounded to the nearest whole dollar

### 2.11.4 LCOH and Breakeven CO<sub>2</sub> Sales Price and Stack Emissions Penalty

The LCOH is the amount of revenue required per kilogram of H<sub>2</sub> produced during the plant’s operational life to meet all capital and operational costs. The real LCOH can be obtained from the following formula:

$$LCOH = LCC + LOM + LFP$$

Where:

**LCOH** – the levelized cost of hydrogen, reported in \$/kg

**LCC** – the levelized capital cost

**LOM** – the levelized operating and maintenance cost

**LFP** – the levelized fuel price

The method used to determine capital recovery factor and levelization factors for operating and maintenance and fuel costs is found in the Cost Estimating Quality Guideline. [6] No changes were made to the standard global economic assumptions. However, changes to the financial structure assumed were made to reflect the financing of hydrogen production facilities. These customized assumptions are shown in Exhibit 2-25.

*Exhibit 2-25. Nominal and real rates financial structure for hydrogen production*

Type of Security	% of Total	Current Dollar Cost	Weighted Average Cost of Capital	After-Tax Weighted Average Cost of Capital
<b>Nominal</b>				
Debt	38%	7.25%	2.76%	2.05%
Equity	62%	5.16%	3.20%	3.20%
<b>Total</b>			5.96%	5.25%
<b>Real (based on 2.01% average real GDP deflator, 1990-2018) [57]</b>				
Debt	38%	5.15%	1.96%	1.45%
Equity	62%	3.10%	1.92%	1.92%
<b>Total</b>			3.88%	3.37%

The breakeven CO<sub>2</sub> sales price represents the minimum CO<sub>2</sub> plant gate sales price that will incentivize carbon capture relative to a defined reference non-capture plant. The breakeven CO<sub>2</sub> sales price is calculated using the following formula:

$$Breakeven\ CO_2\ Sales\ Price\ \left(\frac{\$}{tonne}\right) = \frac{(LCOH_{CCS} - LCOH_{Non\ CCS})}{CO_2\ Captured}$$

The breakeven stack CO<sub>2</sub> emissions penalty represents the minimum stack CO<sub>2</sub> emissions price, when applied to both the capture and non-capture plant, that will incentivize carbon capture

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

relative to a defined reference non-capture plant. The breakeven stack CO<sub>2</sub> emissions penalty is calculated using the following formula:

$$\text{Breakeven Stack CO}_2 \text{ Emissions Penalty } \left( \frac{\$}{\text{tonne}} \right) = \frac{(LCOH_{CCS \text{ with T\&S}} - LCOH_{Non \text{ CCS}})}{CO_2 \text{ Emissions}_{Non \text{ CCS}} - CO_2 \text{ Emissions}_{CCS}}$$

Where:

**CCS** – the capture plant for which the breakeven CO<sub>2</sub> sales price/emissions penalty is being calculated (excluding T&S unless otherwise noted)

**Non-CCS** – the reference non-capture plant, as described below

**LCOH** – the levelized cost of hydrogen, reported in \$/kg

The CCS plant includes CO<sub>2</sub> compression to 15.3 MPa at 2,215 pounds per square inch absolute (psia)

For CO<sub>2</sub> Sales Price, the levelized cost of hydrogen (LCOH) excludes T&S costs

For CO<sub>2</sub> Emissions Penalty, the LCOH includes T&S costs

**CO<sub>2</sub> Captured** – the rate of CO<sub>2</sub> captured, reported in tonne/kg H<sub>2</sub>

**Stack CO<sub>2</sub> Emissions** – the rate of CO<sub>2</sub> emitted out the stack, reported in tonne/kg H<sub>2</sub>

For a greenfield reforming plant (SMR or ATR) with CCS, the reference plant used to calculate the breakeven CO<sub>2</sub> sales price/emission penalty is a non-capture SMR plant.

For today's greenfield gasification plant with CCS, the reference non-capture plant used to calculate the breakeven CO<sub>2</sub> sales price/emission penalty is a coal gasification plant without capture.

## **REFORMING PLANTS**

---

### 3 REFORMING PLANTS

Three natural gas reforming plant configurations were evaluated, and the results are presented in this section. Each design is based on a market-ready technology that is assumed to be commercially available to support startup.

Cases 1 and 2 use a steam methane reformer and differ in that Case 1 does not include CO<sub>2</sub> capture while Case 2 does. The cases were sized based on the maximum hydrogen production capacity for a single-train steam methane reforming plant of 200 MMSCFD. The third case, Case 3, uses an autothermal reformer and employs CO<sub>2</sub> capture. This case was sized to match the hydrogen production rate of coal gasification Cases 4 and 5, which is 274 MMSCFD.

#### 3.1 KEY SYSTEM ASSUMPTIONS

System assumptions for cases 1, 2, and 3 are compiled in Exhibit 3-1.

*Exhibit 3-1. Reforming plant study configuration matrix*

Case	1	2	3
Feedstock	Natural Gas		
Fuel Pressure at Plant Battery Limit, MPa (psia)	3.1 (450)		
Reforming	Prereformer and single-train, vertical tube steam methane reformer (externally heated)		Prereformer and single train autothermal reformer (O <sub>2</sub> -blown)
Plant Capacity	222 kNm <sup>3</sup> /hr (200 MMSCFD) H <sub>2</sub> – single train maximum		304 kNm <sup>3</sup> /hr (274 MMSCFD) H <sub>2</sub> – match Cases 4 & 5
H <sub>2</sub> Product Purity	99.90 vol%		
H <sub>2</sub> Product Pressure	939.7 psia		
Oxidant	N/A		95 vol% O <sub>2</sub>
Water Gas Shift	2x3 train configuration, high-temperature, 97.2% conversion		
H <sub>2</sub> Purification	Pressure Swing Adsorption		
PSA Off-Gas	Recycled as reformer fuel		Recycle to amine unit and fuel
Auxiliar Power Block	None		
Sulfur Control	Zinc Oxide Guard Bed		
NO <sub>x</sub> Control	LNB		
Particulate Control	N/A		
Mercury Control	N/A		
CO <sub>2</sub> Control	N/A	MDEA and Cansolv	MDEA
CO <sub>2</sub> Storage	N/A	Off-site Saline Formation	
CO <sub>2</sub> Product Pressure	2,215 psia		

### 3.1.1 Balance of Plant

The balance of plant assumptions are common to all three cases and presented in Exhibit 3-2.

*Exhibit 3-2. Balance of plant assumptions*

Parameters	Values
<b><u>Cooling System</u></b>	Recirculating Wet Cooling Tower
<b><u>Fuel and Other Storage</u></b>	
Natural Gas	Pipeline supply at 3.0 MPa (450 psia) and 15 °C (59 °F)
<b><u>Plant Distribution Voltage</u></b>	
Motors below 1 hp	110/220 V
Motors between 1 hp and 250 hp	480 V
Motors between 250 hp and 5,000 hp	4,160 V
Motors above 5,000 hp	13,800 V
Grid Interconnection Voltage	345 kV
<b><u>Water and Wastewater</u></b>	
Makeup Water	The water supply is 50 percent from a local POTW and 50 percent from groundwater and is assumed to be in sufficient quantities to meet plant makeup requirements Makeup for potable, process, and de-ionized (DI) water is drawn from municipal sources
Process Wastewater	Storm water that contacts equipment surfaces is collected and treated for discharge
Sanitary Waste Disposal	Design includes a packaged domestic sewage treatment plant with effluent discharged to the industrial wastewater treatment system. Sludge is hauled off site. Packaged plant is sized for 5.68 cubic meters per day (1,500 gallons per day)
Water Discharge	Blowdown from the cooling tower is softened and passed through a two-stage reverse osmosis (RO) with pre-treatment and demineralizer before being discharged

### 3.2 SPARING PHILOSOPHY

The sparing philosophy for cases 1, 2, and 3 is provided below. Only a single train is necessary at the scales of hydrogen production considered. There is no redundancy other than normal sparing of rotating equipment. The plant design consists of the following major subsystems:

- One train of reforming, including prereformer and reformer (1 x 100 percent)
- One train ASU in Case 3 (1 x 100 percent)
- Two trains of three water gas shift reactors in series (2 x 50 percent)

- One train of MDEA in Case 2 and Case 3 and one train of Cansolv in Case 2 (1 x 100 percent)
- One train of CO<sub>2</sub> compression and drying (1 x 100 percent) in Case 2 and Case 3
- One train of H<sub>2</sub> production and compression systems (1 x 100 percent)

### 3.3 REFORMING COMMON PROCESS AREAS

The reforming cases have process areas which are common to each plant configuration. As detailed descriptions of these process areas for each case would be repetitious, they are presented in this section for general background information. Where there is case-specific performance information, the performance features are presented in relevant case sections.

#### 3.3.1 Natural Gas Supply System

It was assumed that a natural gas main with adequate capacity is near to the site fence line (within 16 km [10 mi]) and that a suitable right-of-way is available to install a branch line to the site. For the purposes of this report, it was also assumed that the gas will be delivered to the plant custody transfer point at sufficient pressure such that natural gas is available at a pressure of 3.1 MPa (450 psia) and a temperature of 15 °C (59 °F). Hence, neither a pressure reducing station, nor a booster compressor is required.

A new gas metering station is assumed to be added on the site. The meter may be of the rate-of-flow type, with input to the plant computer for summing and recording or may be of the positive displacement type. In either case, a complete timeline record of gas consumption rates and cumulative consumption is provided.




#### 3.3.2 Sulfur Polishing

The natural gas feed contains 5.7 parts per million volume (ppmv) of a mercaptan additive methanethiol (CH<sub>4</sub>S). Since even a small amount of sulfur present can poison the reformer catalysts, sulfur removal before the prereformer is necessary.

A zinc oxide sulfur guard bed is employed to polish the natural gas feed. The sulfur guard bed is a fixed bed, catalytic reactor type. The NG feedstock is preheated to 370 °C (698 °F) and 98 percent of the CH<sub>4</sub>S in the natural gas is removed, resulting in a maximum sulfur content of 0.1 ppm exiting the sulfur guard bed.

#### 3.3.3 Prereformer


The desulfurized natural gas feedstock is preheated further to a temperature of 500 °C (932 °F) before being mixed with process steam and sent to the prereformer unit. The prereformer is a fixed-bed, catalytic, adiabatic reactor. It serves the primary purpose of reforming the C<sub>2+</sub> hydrocarbons, such as ethane (C<sub>2</sub>H<sub>6</sub>), propane (C<sub>3</sub>H<sub>8</sub>), and butane (C<sub>4</sub>H<sub>10</sub>) in the natural gas feed prior to the primary reformer to reduce carbon deposition on the downstream catalyst. This has the additional impacts of reducing the load on the primary reformer, increasing carbon capture ability, and improving product recovery. The following reactions take place in the prereformer:



The prereformer has been designed to ensure that the effluent stream contains less than 500 ppm of total C<sub>2+</sub> hydrocarbons. The primary reformer is discussed within each case's individual process descriptions.

### 3.3.4 Water Gas Shift Reactors

In all cases, the raw syngas exiting the reforming step is converted to a CO<sub>2</sub> and H<sub>2</sub>-rich syngas to maximize H<sub>2</sub> product yield and maximize the extent of CO<sub>2</sub> separation that can be performed on the high-pressure syngas stream. CO is converted to CO<sub>2</sub> by reacting with steam over a bed of catalyst. The exit steam to dry gas molar ratio of the shift reactors is maintained at 0.25 to prevent carbon deposition and deactivation of the catalyst. Ample steam is added to the process gas mixture prior to the prereformer to ensure this steam-to-dry gas ratio is met. There is also a loss of chemical energy associated with the exothermic conversion of water (H<sub>2</sub>O) and CO to CO<sub>2</sub> and H<sub>2</sub>. In the WGS configuration employed, intercooling is applied between stages and the recovered heat is used to generate steam for use elsewhere in the plant, thus offsetting some of this loss. The following chemical equation is the water gas shift reaction:



The CO shift converter can be located either upstream of the AGR step (sour gas shift) or immediately downstream (sweet gas shift). In the present cases, the WGS is located upstream of the AGR (i.e., sour gas shift) to achieve high levels of carbon capture.

The WGS consists of two paths of parallel fixed-bed reactors arranged in series. Three reactors in series are used in each parallel path to achieve conversion up to 97.2 percent, since one of the goals of this study is to maximize the carbon capture rates of the applicable analyzed configurations. Ample steam is added to the system prior to the prereformer so that the product stream from the reformer contains enough water vapor to drive the WGS reaction and to meet the necessary outlet steam to dry gas ratio.

### 3.3.5 Hydrogen Production

#### 3.3.5.1 Pressure Swing Adsorber

The pressure swing adsorber unit purifies the syngas into the highly pure hydrogen product meeting the specifications provided in Section 2.6. A design H<sub>2</sub> recovery efficiency of 85 percent is considered for all reforming cases. An H<sub>2</sub>-rich off-gas stream is produced as a byproduct which

is sent to the primary reformer furnace in the Cases 1 and 2. In Case 3, 31 percent of the mass flow is recycled to the AGR unit for additional CO<sub>2</sub> capture and H<sub>2</sub> recovery. The remaining amount is combusted in a gas-fired heater where process heat is recovered.

### **3.3.5.2 Hydrogen Compressor**

The hydrogen compressor is an integrally geared, multi-stage centrifugal compressor. Interstage cooling to a temperature of 30 °C (86 °F) is required to control the temperature increase. The high-purity hydrogen from the pressure swing adsorber (PSA) is compressed to a pipeline-ready pressure of 6.48 MPa (925 psig).

### **3.3.6 Accessory Electric Plant**

The accessory electric plant consists of all switchgear and control equipment, generator equipment, station service equipment, conduit and cable trays, wire, and cable. It also includes the main transformer, required foundations, and standby equipment.

### **3.3.7 Process Water Systems**

#### **3.3.7.1 Feedwater**

The function of the feedwater (FW) system is to pump the various FW streams to the boiler feedwater heaters before entering the medium pressure (MP) steam drum for reforming steam demands. Feedwater is recovered from multiple sources within the plant configurations as internal recycle. Two 100 percent capacity motor-driven feed pumps are provided for each FW stream. Each pump is provided with inlet and outlet isolation valves, outlet check valves, and individual minimum flow recirculation lines. The recirculation flow is controlled by pneumatic flow control valves. In addition, the suctions of the boiler feed pumps are equipped with strainers.

#### **3.3.7.2 Circulating Water System**

The function of the circulating water system (CWS) is to supply cooling water to the low temperature syngas coolers, for the AGR processes, and for the auxiliary cooling system. The system consists of two 50 percent capacity vertical circulating water pumps (CWPs), a mechanical draft evaporative cooling tower, and interconnecting piping.

The auxiliary cooling system is a closed-loop (CL) system. Plate and frame heat exchangers (HXs) with circulating water as the cooling medium are provided. The system provides cooling water to the following systems:

1. BFW pumps
2. Air compressors
3. Sample room chillers
4. Blowdown coolers

The AGR systems in Case 2 and Case 3 require a substantial amount of cooling water that is provided by the plant CWS. The additional cooling load imposed by the AGR system is reflected in the significantly larger CWPs and cooling tower in those cases compared to in Case 1.

### **3.3.7.3 Buildings and Structures**

Structures assumed for natural gas cases can be summarized as follows:

1. CWP House
2. Administration/Office/Control Room/Maintenance Building
3. Water Treatment Building
4. Fire Water Pump House

### **3.3.8 Instrumentation and Control**

An integrated plant-wide distributed control system (DCS) is provided. The DCS is a redundant microprocessor-based, functionally distributed system. The control room houses an array of video monitors and keyboard units. The monitor/keyboard units are the primary interface between the generating process and operations personnel. The DCS incorporates plant monitoring and control functions for all the major plant equipment. The DCS is designed to provide 99.5 percent availability.

### **3.3.9 Miscellaneous Systems**

An onsite water treatment facility treats all runoff, cleaning wastes, blowdown, and backwash. It is anticipated that the treated water will be suitable for discharge into existing systems and be within EPA standards for suspended solids, oil and grease, pH, and miscellaneous metals.

The waste treatment system is minimal and consists, primarily, of neutralization and oil/water separators (along with the associated pumps, piping, etc.).

Miscellaneous systems consisting of service air, instrument air, and service water are provided. All truck roadways and unloading stations inside the fence area are provided.

### **3.3.10 Performance Summary Metrics**

#### **3.3.10.1 Effective Thermal Efficiency**

The effective thermal efficiency is useful for comparing the overall system performance of hydrogen production systems while considering the electrical power net electrical power requirements to operate the facility. Facilities generating power sufficient to export to the grid will exhibit higher effective thermal efficiencies while configurations not exporting power to the grid will exhibit lower effective thermal efficiencies.

This metric is calculated by adding the thermal content of the hydrogen product to the net power and dividing that difference by the thermal input to the system, expressed as a

percentage. The efficiency can be calculated on both a HHV and a lower heating value (LHV) basis. This calculation is represented by the following equation:

$$ETE = \frac{(TP + P_{net})}{TI} * 100\%$$

Where:

**ETE** – effective thermal efficiency

**TP** – thermal content of the hydrogen product

**TI** – thermal input to the system

**P<sub>net</sub>** – net power of the system

The thermal input to the system is calculated by taking the feed rate into the system and multiplying by the heating value of the feedstock.

The thermal output is calculated by taking the mass flowrate of the hydrogen product and multiplying by the heating value of the product.

The net power of the system is the total gross power generated minus the total auxiliary load of the system. The net power is a negative value in all three reforming cases because none of these configurations generate power and require grid imports.

### 3.3.10.2 Cold Gas Efficiency

The cold gas efficiency is useful for comparing the overall system performance of hydrogen production alone and is calculated as the ratio of the thermal content of the hydrogen product to the thermal input to the system, expressed as a percentage. The efficiency can be calculated on both a HHV and a LHV basis. This calculation is represented by the following equation:

$$CGE = \frac{TP}{TI} * 100\%$$

Where:

**CGE** – cold gas efficiency

**TP** – thermal content of the hydrogen product

**TI** – thermal input to the system

The thermal input to the system is calculated by taking the feed rate into the system and multiplying by the heating value of the feedstock.

The thermal output is calculated by taking the mass flowrate of the hydrogen product and multiplying by the heating value of the product.

### **3.4 CASE 1 – STEAM METHANE REFORMING PLANT WITHOUT CO<sub>2</sub> CAPTURE PROCESS DESCRIPTION**


This section contains an evaluation of a plant design for Case 1, which is based on a natural gas steam methane reforming plant without CO<sub>2</sub> capture. The system descriptions follow the BFD provided in Exhibit 3-3 with the associated stream tables that show process data provided in Exhibit 3-4.

The balance of this section is organized as follows:

- Process Description – provides an overview of the technology operation as applied to Case 1. The systems that are common to all reforming cases were covered in Section 3.3 and only features that are unique to Case 1 are discussed further in this section
- Performance Results – provides the main modeling results from Case 1, including the performance summary, environmental performance, carbon balance, sulfur balance, water balance, energy balance, mass and energy balance diagrams. Note – some rounding error may be present in results reporting
- Equipment List – provides an itemized list of major equipment for Case 1
- Cost Estimates – provides a summary of capital and operating costs for Case 1

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 3-3. Case 1 block flow diagram, steam methane reforming plant without CO<sub>2</sub> capture**



Note: Block Flow Diagram is not intended to represent a complete material balance. Only major process streams and equipment are shown.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 3-4. Case 1 stream table, steam methane reforming plant without capture**

	1	2	3	4	5	6	7	8
V-L Mole Fraction								
Ar	0.0092	0.0092	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
CH <sub>4</sub>	0.0000	0.0000	0.9310	0.9310	0.9310	0.0000	0.2583	0.0411
CH <sub>4</sub> S	0.0000	0.0000	0.0000 <sup>A</sup>	0.0000	0.0000	0.0000	0.0000	0.0000
C <sub>2</sub> H <sub>6</sub>	0.0000	0.0000	0.0320	0.0320	0.0320	0.0000	0.0000	0.0000
C <sub>3</sub> H <sub>8</sub>	0.0000	0.0000	0.0070	0.0070	0.0070	0.0000	0.0000	0.0000
C <sub>4</sub> H <sub>10</sub>	0.0000	0.0000	0.0040	0.0040	0.0040	0.0000	0.0000	0.0000
CO	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0001	0.1432
CO <sub>2</sub>	0.0003	0.0003	0.0100	0.0100	0.0100	0.0000	0.0174	0.0124
H <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0439	0.4609
H <sub>2</sub> O	0.0099	0.0099	0.0000	0.0000	0.0000	1.0000	0.6760	0.3393
N <sub>2</sub>	0.7732	0.7732	0.0160	0.0160	0.0160	0.0000	0.0042	0.0030
O <sub>2</sub>	0.2074	0.2074	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	17,806	17,806	4,096	3,687	3,687	9,830	13,930	19,519
V-L Flowrate (kg/hr)	513,824	513,824	70,979	63,881	63,880	177,086	240,966	240,966
Solids Flowrate (kg/hr)	0	0	0	0	0	0	0	0
Temperature (°C)	15	24	15	15	370	399	395	871
Pressure (MPa, abs)	0.10	0.11	3.10	3.10	3.00	3.10	2.90	2.83
Steam Table Enthalpy (kJ/kg) <sup>B</sup>	30.23	39.78	-6.77	-6.77	969.07	3,217.36	2,587.64	3,639.90
AspenPlus Enthalpy (kJ/kg) <sup>C</sup>	-97.58	-88.02	-4,516.00	-4,516.00	-3,540.22	-12,753.76	-10,182.33	-6,233.86
Density (kg/m <sup>3</sup> )	1.2	1.3	24.4	24.4	9.7	10.4	9.3	3.7
V-L Molecular Weight	28.857	28.857	17.328	17.328	17.328	18.016	17.299	12.345
V-L Flowrate (lb <sub>mol</sub> /hr)	39,255	39,255	9,031	8,128	8,128	21,670	30,710	43,032
V-L Flowrate (lb/hr)	1,132,789	1,132,789	156,482	140,834	140,832	390,407	531,239	531,239
Solids Flowrate (lb/hr)	0	0	0	0	0	0	0	0
Temperature (°F)	59	76	59	59	698	750	743	1,600
Pressure (psia)	14.7	16.0	450.0	450.0	435.3	450.0	421.0	411.0
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	13.0	17.1	-2.9	-2.9	416.6	1,383.2	1,112.5	1,564.9
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	-42.0	-37.8	-1,941.5	-1,941.5	-1,522.0	-5,483.1	-4,377.6	-2,680.1
Density (lb/ft <sup>3</sup> )	0.076	0.080	1.525	1.525	0.605	0.652	0.578	0.229

<sup>A</sup>Natural gas entering battery limits contains 5.74 ppm of the mercaptan additive methanethiol (CH<sub>4</sub>S)

<sup>B</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>C</sup>AspenPlus thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 3-4. Case 1 stream table, steam methane reforming plant without capture (continued)**


	9	10	11	12	13	14	15	16
V-L Mole Fraction								
Ar	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0072
CH <sub>4</sub>	0.0411	0.0513	0.0000	0.0000	0.1410	0.9310	0.1940	0.0000
CH <sub>4</sub> S	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
C <sub>2</sub> H <sub>6</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0320	0.0022	0.0000
C <sub>3</sub> H <sub>8</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0070	0.0005	0.0000
C <sub>4</sub> H <sub>10</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0040	0.0003	0.0000
CO	0.1432	0.0050	0.0000	0.0000	0.0137	0.0000	0.0128	0.0000
CO <sub>2</sub>	0.0124	0.1891	0.0000	0.0000	0.5198	0.0100	0.4855	0.1858
H <sub>2</sub>	0.4609	0.7483	0.9998	0.9998	0.3085	0.0000	0.2878	0.0000
H <sub>2</sub> O	0.3393	0.0025	0.0000	0.0000	0.0069	0.0000	0.0065	0.1913
N <sub>2</sub>	0.0030	0.0038	0.0002	0.0002	0.0100	0.0160	0.0104	0.6012
O <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0146
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	19,519	15,654	9,959	9,959	5,695	410	6,104	23,005
V-L Flowrate (kg/hr)	240,966	171,320	20,126	20,126	151,195	7,098	158,293	672,117
Solids Flowrate (kg/hr)	0	0	0	0	0	0	0	0
Temperature (°C)	204	38	38	30	38	15	35	121
Pressure (MPa, abs)	2.80	2.45	2.39	6.48	0.14	3.10	0.14	0.10
Steam Table Enthalpy (kJ/kg) <sup>A</sup>	1,740.51	109.39	544.72	446.66	59.24	-6.77	56.28	426.36
AspenPlus Enthalpy (kJ/kg) <sup>B</sup>	-8,133.24	-7,225.03	188.98	90.92	-8,204.10	-4,516.00	-8,038.73	-3,980.71
Density (kg/m <sup>3</sup> )	8.8	10.4	1.8	5.0	1.4	24.4	1.4	0.9
V-L Molecular Weight	12.345	10.945	2.021	2.021	26.549	17.328	25.931	29.217
V-L Flowrate (lb <sub>mol</sub> /hr)	43,032	34,510	21,955	21,955	12,555	903	13,458	50,717
V-L Flowrate (lb/hr)	531,239	377,697	44,369	44,369	333,328	15,648	348,976	1,481,765
Solids Flowrate (lb/hr)	0	0	0	0	0	0	0	0
Temperature (°F)	400	100	100	86	100	59	95	250
Pressure (psia)	406.0	356.0	346.0	939.7	20.0	450.0	20.0	14.7
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	748.3	47.0	234.2	192.0	25.5	-2.9	24.2	183.3
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	-3,496.7	-3,106.2	81.2	39.1	-3,527.1	-1,941.5	-3,456.0	-1,711.4
Density (lb/ft <sup>3</sup> )	0.549	0.647	0.115	0.314	0.089	1.525	0.087	0.056

<sup>A</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>B</sup>AspenPlus thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm

### 3.4.1 Steam Methane Reformer

Partially reformed gas and steam effluent exiting the prereformer enter the primary steam methane reformer in Case 1 and Case 2. The mixture is reacted over a nickel-based catalyst contained inside a system of high alloy steel tubes. The following reaction takes place in the reformer:



The reforming reaction is strongly endothermic, with energy supplied by firing the reformer on the outside of the catalyst tubes with recycled syngas from the downstream hydrogen purification process plus supplemental natural gas. The metallurgy of the tubes usually limits the reaction to 760-925 °C (1,400-1,700 °F).

The reforming reaction quickly reaches equilibrium at all points in the catalyst bed. The equilibrium composition of the reformed gas is favored by the high steam-to-carbon ratio, low pressure, and high temperature. The process employs a molar steam-to-carbon ratio of 2.56 entering the reactor. The raw syngas exits the reactor at a temperature of 870 °C (1,600 °F) and pressures of 2.8 MPa (411 psia) to convert more than 77 percent of the methane in the primary reformer feed.

The flue gas path of the fired reformer is integrated with additional boiler surfaces to produce export steam in Case 1 or to provide steam for the regeneration of CO<sub>2</sub>-removal solvents from the AGR processes in Case 2.

### 3.4.2 Convective Heat Recovery Section

The steam methane reforming configuration (Case 1 and Case 2) has an integrated heat recovery section as a part of the primary reformer which allows for convective heat recovery of the reformer flue gas. The hot flue gas from the primary reformer is cooled by providing heat to various sections of the plant and improving plant efficiency, thereby minimizing the need to fire supplemental NG. This section generates superheated steam for the reforming reactions, provides feedwater preheating, and provides preheating of the natural gas feed prior to the sulfur guard and prereformer. Approximately 53 percent of the superheated steam generated is used for reforming while the remaining is exported from the plant.

## 3.5 CASE 1 – PERFORMANCE RESULTS

Overall performance for the entire plant is summarized in Exhibit 3-5. The plant produces 20,126 kilogram (kg)/hr (44,369 lb/hr) of hydrogen at an effective thermal efficiency of 75.4 percent (HHV basis). The total auxiliary load for the plant is 13 megawatts of electricity (MWe).

Exhibit 3-6 provides a detailed breakdown of the auxiliary power requirements. The hydrogen compressor accounts for about 79 percent of the total auxiliary load. The BFW pumps and cooling water system, including the circulating water pumps and cooling tower fan, accounts for approximately 6 percent of the auxiliary load. All other systems together constitute the remaining 15 percent of the auxiliary load.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 3-5. Case 1 plant performance summary**

Performance Summary	
Steam Turbine Power, MWe	0
<b>Total Gross Power, MWe</b>	<b>0</b>
CO <sub>2</sub> Capture/Removal Auxiliaries, kWe	0
CO <sub>2</sub> Compression, kWe	0
Balance of Plant, kWe	12,650
<b>Total Auxiliaries, MWe</b>	<b>13</b>
<b>Net Power, MWe</b>	<b>-13</b>
<b>Hydrogen Production, kg/hr (lb/hr)</b>	<b>20,126 (44,369)</b>
<b>CO<sub>2</sub> Capture, %</b>	<b>–</b>
HHV Effective Thermal Efficiency <sup>A</sup> , %	75.4%
HHV Cold Gas Efficiency <sup>B</sup> , %	76.7%
LHV Effective Thermal Efficiency <sup>A</sup> , %	70.5%
LHV Cold Gas Efficiency <sup>B</sup> , %	71.9%
AGR Cooling Duty, GJ/hr (MMBtu/hr)	–
Natural Gas Feed Flow, kg/hr (lb/hr)	70,979 (156,482)
HHV Thermal Input, kWt	1,031,068
LHV Thermal Input, kWt	930,641
Raw Water Withdrawal, m <sup>3</sup> /min (gpm)	5.5 (1,457)
Raw Water Consumption, m <sup>3</sup> /min (gpm)	5.3 (1,395)

<sup>A</sup>ETE = (Hydrogen Heating Value + Net Power) / Fuel Heating Value

<sup>B</sup>CGE = Hydrogen Heating Value / Fuel Heating Value

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 3-6. Case 1 plant power summary**

Power Summary	
Steam Turbine Power, MWe	0
<b>Total Gross Power, MWe</b>	<b>0</b>
Auxiliary Load Summary	
Air Blower, kWe	1,410
Circulating Water Pumps, kWe	280
Cooling Tower Fans, kWe	140
CO <sub>2</sub> Capture/Removal Auxiliaries, kWe	0
CO <sub>2</sub> Compression, kWe	0
Feedwater Pumps, kWe	320
Ground Water Pumps, kWe	130
Hydrogen Compressor, kWe	10,010
Miscellaneous Balance of Plant <sup>A</sup> , kWe	290
Transformer Losses, kWe	70
<b>Total Auxiliaries, MWe</b>	<b>13</b>
<b>Net Power, MWe</b>	<b>-13</b>

<sup>A</sup>Includes plant control systems, lighting, HVAC, and miscellaneous low voltage loads

### 3.5.1 Environmental Performance

The environmental targets for emissions of Hg, NO<sub>x</sub>, sulfur dioxide (SO<sub>2</sub>), and PM were presented in Section 2.6. A summary of the plant air emissions for Case 1 is presented in Exhibit 3-7.

**Exhibit 3-7. Case 1 air emissions**

	kg/GJ (lb/MMBtu)	Tonne/year (ton/year) <sup>A</sup>	lb/lb H <sub>2</sub>
SO <sub>2</sub>	0.000 (0.000)	1.4 (1.5)	0.000
NO <sub>x</sub>	0.001 (0.003)	35 (39)	0.000
Particulate	0.000 (0.000)	5 (6)	0.000
Hg	0.00E+0 (0.00E+0)	0.000 (0.000)	0.00E+0
CO	0.000 (0.000)	5 (6)	0.000
CO <sub>2</sub> <sup>B</sup>	51 (118)	1,482,893 (1,634,610)	9.3
CO <sub>2</sub> e <sup>C</sup>	72 (166)	2,092,674 (2,306,778)	12

<sup>A</sup>Calculations based on a 90 percent capacity factor

<sup>B</sup>Plant stack emissions

<sup>C</sup>Life cycle emissions

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

The natural gas feed contains 5.74 ppmv of the mercaptan additive methanethiol (CH<sub>4</sub>S). A zinc oxide sulfur guard bed was used to remove 98 percent of the sulfur in the feed, resulting in a maximum sulfur content of 0.1 ppm post-sulfur guard bed.

NO<sub>x</sub> emissions are limited by the use of low-NO<sub>x</sub> burners in the design. The production of PM is a result of system inefficiencies and is not produced or emitted in any significant amount. The pipeline natural gas was assumed to contain no Hg nor hydrochloric acid (HCl), resulting in zero emissions.

Plant stack CO<sub>2</sub> emissions represent the uncontrolled discharge from the process. Life cycle CO<sub>2</sub> emissions represent the total GWP, in CO<sub>2</sub>e emissions, of the process over the plant life cycle, as detailed in Section 2.8.

The carbon balance for the plant is shown in Exhibit 3-8. The carbon input to the plant consists of carbon in the air in addition to carbon in the natural gas. Carbon leaves the plant as a small portion of the export steam and hydrogen product as well as in the stack gas.

**Exhibit 3-8. Case 1 carbon balance**

Carbon In		Carbon Out	
	kg/hr (lb/hr)		kg/hr (lb/hr)
Natural Gas	51,267 (113,024)	Stack Gas	51,333 (113,169)
Air (CO <sub>2</sub> )	70 (154)	Export Steam	1 (3)
		Hydrogen Product	2 (5)
		Sulfur Guard Bed	0 (1)
		CO <sub>2</sub> Product	–
		CO <sub>2</sub> Dryer Vent	–
		CO <sub>2</sub> Knockout	–
<b>Total</b>	<b>51,337 (113,178)</b>	<b>Total</b>	<b>51,337 (113,178)</b>

Exhibit 3-9 shows the sulfur balance for the plant. Sulfur input comes solely from the mercaptan additive in the natural gas. Sulfur output includes sulfur recovered in the sulfur guard bed and small amounts of sulfur emitted in the stack gas.

**Exhibit 3-9. Case 1 sulfur balance**

Sulfur In		Sulfur Out	
	kg/hr (lb/hr)		kg/hr (lb/hr)
Natural Gas	1 (2)	Stack Gas	0 (0)
		Sulfur Guard Bed	1 (1)
<b>Total</b>	<b>1 (2)</b>	<b>Total</b>	<b>1 (2)</b>

Exhibit 3-10 shows the overall water balance for the plant. Water demand represents the total amount of water required for a particular process. Some water is recovered within the process, primarily as syngas condensate, and is re-used as internal recycle.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 3-10. Case 1 water balance**

Water Use	Water Demand	Internal Recycle	Raw Water Withdrawal	Process Water Discharge	Raw Water Consumption
	m <sup>3</sup> /min (gpm)				
CO <sub>2</sub> Drying	–	–	–	–	–
CO <sub>2</sub> Capture System Makeup	–	–	–	–	–
CO <sub>2</sub> Capture Recovery	–	–	–	–	–
CO <sub>2</sub> Compression Recovery	–	–	–	–	–
<b>Steam Generation</b>	<b>5.6 (1,485)</b>	<b>1.2 (307)</b>	<b>4.5 (1,178)</b>	–	<b>4.5 (1,178)</b>
Export Steam	2.7 (704)	–	2.7 (704)	–	2.7 (704)
SMR Steam	3.0 (781)	–	3.0 (781)	–	3.0 (781)
Syngas Condensate	–	1.2 (307)	-1.2 (-307)	–	-1.2 (-307)
<b>Cooling Tower</b>	<b>1.1 (280)</b>	–	<b>1.1 (280)</b>	<b>0.2 (63)</b>	<b>0.8 (217)</b>
<b>Total</b>	<b>6.7 (1,765)</b>	<b>1.2 (307)</b>	<b>5.5 (1,457)</b>	<b>0.2 (63)</b>	<b>5.3 (1,395)</b>

An overall plant energy balance is provided in tabular form in Exhibit 3-11.

**Exhibit 3-11. Case 1 overall energy balance (0 °C [32 °F] reference)**

	HHV	Sensible + Latent	Power	Total
<b>Heat In, GJ/hr (MMBtu/hr)</b>				
Natural Gas	3,712 (3,518)	2.5 (2.4)	–	3,714 (3,521)
Air	–	16 (15)	–	16 (15)
Raw Water Makeup	–	21 (20)	–	21 (20)
Auxiliary Power	–	–	46 (43)	46 (43)
<b>Total</b>	<b>3,712 (3,518)</b>	<b>39 (37)</b>	<b>46 (43)</b>	<b>3,796 (3,598)</b>
<b>Heat Out, GJ/hr (MMBtu/hr)</b>				
Hydrogen Product	2,846 (2,697)	9.0 (8.5)	–	2,855 (2,706)
Export Steam	–	514 (487)	–	514 (487)
Stack Gas	–	287 (272)	–	287 (272)
Sulfur	–	0.0 (0.0)	–	0.0 (0.0)
Motor Losses and Design Allowances	–	–	1.4 (1.3)	1.4 (1.3)
Cooling Tower Load <sup>A</sup>	–	138 (131)	–	138 (131)
CO <sub>2</sub> Product Stream	–	–	–	–
Power	–	–	0.0 (0.0)	0.0 (0.0)
<b>Total</b>	<b>2,846 (2,697)</b>	<b>947 (898)</b>	<b>1.4 (1.3)</b>	<b>3,795 (3,597)</b>
Unaccounted Energy <sup>B</sup>	–	1.3 (1.2)	–	1.3 (1.2)


<sup>A</sup>Includes compression and last stage syngas cooling loads

<sup>B</sup>By difference

### 3.5.2 Energy and Mass Balance Diagrams

The energy and mass balance diagram for Case 1 is shown in Exhibit 3-12.

Exhibit 3-12. Case 1 steam methane reforming plant without CO<sub>2</sub> capture energy and mass balance



This page intentionally left blank

### 3.6 CASE 1 – MAJOR EQUIPMENT LIST

Major equipment items for the steam methane reforming plant without CO<sub>2</sub> capture are shown in the following tables. In general, the design conditions include a 10 percent design allowance for flows and heat duties and a 21 percent design allowance for heads on pumps and fans.

#### Case 1 – Account 3: Feedwater and Miscellaneous Balance of Plant Systems

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Process Condensate Pumps	Horizontal, split case, multi-stage, centrifugal	640 lpm @ 90 m H <sub>2</sub> O (170 gpm @ 300 ft H <sub>2</sub> O)	2	1
2	Water Makeup Pumps	Horizontal, split case, multi-stage, centrifugal	2,470 lpm @ 380 m H <sub>2</sub> O (650 gpm @ 1,260 ft H <sub>2</sub> O)	2	2
3	Auxiliary Boiler	Shop fabricated, water tube	18,000 kg/hr, 2.8 MPa, 343 °C (40,000 lb/hr, 400 psig, 650 °F)	1	0
4	Service Air Compressors	Flooded Screw	13 m <sup>3</sup> /min @ 0.7 MPa (450 scfm @ 100 psig)	2	1
5	Instrument Air Dryers	Duplex, regenerative	13 m <sup>3</sup> /min (450 scfm)	2	1
6	Engine-Driven Fire Pump	Vertical turbine, diesel engine	3,785 lpm @ 110 m H <sub>2</sub> O (1,000 gpm @ 350 ft H <sub>2</sub> O)	1	1
7	Fire Service Booster Pump	Two-stage horizontal centrifugal	2,650 lpm @ 80 m H <sub>2</sub> O (700 gpm @ 250 ft H <sub>2</sub> O)	1	1
8	Raw Water Pumps	Stainless steel, single suction	3,000 lpm @ 20 m H <sub>2</sub> O (800 gpm @ 60 ft H <sub>2</sub> O)	2	1
9	Filtered Water Pumps	Stainless steel, single suction	150 lpm @ 50 m H <sub>2</sub> O (40 gpm @ 160 ft H <sub>2</sub> O)	2	1
10	Filtered Water Tank	Vertical, cylindrical	145,000 liter (38,000 gal)	1	0
11	Makeup Water Demineralizer	Multi-media filter, cartridge filter, RO membrane assembly and electro-deionization unit	330 lpm (90 gpm)	1	0
12	Liquid Waste Treatment System	–	10 years, 24-hour storm	1	0
13	Gas Pipeline	Underground, coated carbon steel, wrapped cathodic protection	53 m <sup>3</sup> /min @ 3.1 MPa (1,882 acfm @ 450 psia) 39 cm (16 in) standard wall pipe	16 km (10 mile)	0
14	Gas Metering Station	–	53 m <sup>3</sup> /min (1,882 acfm)	1	0

#### Case 1 – Account 4: Reformer and Accessories

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Primary Reformer	Steam Methane Reformer (SMR), side fired, fixed bed, catalytic	Syngas Production: 265,000 kg/hr @ 2.8 MPa, 871 °C (584,000 lb/hr @ 411 psia, 1600 °F)	1	0
2	Air Blower	Centrifugal	283,000 kg/hr @ 4,000 m <sup>3</sup> /min, 3 cm WG (623,000 lb/hr @ 129,000 acfm, 1 in. WG)	2	1
3	Sulfur Guard Bed	Fixed Bed, catalytic (ZnO)	Inlet: 70,000 kg/hr @ 3.0 MPa, 370 °C (155,000 lb/hr @ 441 psia, 698 °F)	1	0
4	Prereformer	Fixed Bed, catalytic	NG In: 70,000 kg/hr @ 2.9 MPa, 500 °C (155,000 lb/hr @ 427 psia, 932 °F) Steam In: 195,000 kg/hr @ 3.1 MPa, 399 °C (429,000 lb/hr @ 450 psia, 750 °F)	1	0

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
5	Syngas Coolers	Shell and tube heat exchanger	Syngas Cooler: 457 GJ/hr (434 MMBtu/hr) BFW Heater 3: 93 GJ/hr (88 MMBtu/hr) BFW Heater 2: 13 GJ/hr (12 MMBtu/hr) BFW Heater 1: 179 GJ/hr (170 MMBtu/hr) AGR Precooler: 101 GJ/hr (96 MMBtu/hr)	5	0

**Case 1 – Account 6: Syngas Cleanup**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Water Gas Shift Reactors	Fixed bed, catalytic	88,000 kg/hr (292,000 lb/hr) 204 °C (400 °F) 2.8 MPa (410 psia)	6	0

**Case 1 – Account 7: Hydrogen Production**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Pressure Swing Adsorber	Polybed Proprietary	Syngas: 171,320 kg/hr (377,697 lb/hr) 38 °C (100 °F) 2.5 MPa (356.0 psia) Hydrogen: 20,126 kg/hr (44,369 lb/hr) 38 °C (100 °F) 2.4 MPa (346.0 psia) Off Gas: 151,195 kg/hr (333,328 lb/hr) 38 °C (100 °F) 0.1 MPa (20.0 psia)	1	0
2	Hydrogen Compressor	Integrally geared, multi-stage centrifugal	73 m <sup>3</sup> /min @ 6.5 MPa (2,587 acfm @ 940 psia)	1	1

**Case 1 – Account 9: Cooling Water System**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Circulating Water Pumps	Vertical, wet pit	27,000 lpm @ 30 m (7,000 gpm @ 100 ft)	2	1
2	Cooling Tower	Evaporative, mechanical draft, multi-cell	11 °C (52 °F) wet bulb/16 °C (60 °F) CWT/27 °C (80 °F) HWT/ 150 GJ/hr (140 MMBtu/hr) heat duty	1	0

**Case 1 – Account 11: Accessory Electric Plant**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	High Voltage Auxiliary Transformer	Oil-filled	345 kV/13.8 kV, 0 MVA, 3-ph, 60 Hz	2	0
2	Medium Voltage Transformer	Oil-filled	18 kV/4.16 kV, 12 MVA, 3-ph, 60 Hz	1	1
3	Low Voltage Transformer	Dry ventilated	4.16 kV/480 V, 2 MVA, 3-ph, 60 Hz	1	1
4	Medium Voltage Switchgear	Metal clad	4.16 kV, 3-ph, 60 Hz	1	1
5	Low Voltage Switchgear	Metal enclosed	480 V, 3-ph, 60 Hz	1	1
6	Emergency Diesel Generator	Sized for emergency shutdown	750 kW, 480 V, 3-ph, 60 Hz	1	0

**Case 1 – Account 12: Instrumentation and Control**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	DCS – Main Control	Monitor/keyboard; Operator printer (laser color); Engineering printer (laser B&W)	Operator stations/printers and engineering stations/printers	1	0
2	DCS – Processor	Microprocessor with redundant input/output	N/A	1	0
3	DCS – Data Highway	Fiber optic	Fully redundant, 25% spare	1	0

**3.7 CASE 1 – COST ESTIMATING**

The cost estimating methodology was described previously in Section 2.11. Exhibit 3-13 shows a detailed breakdown of the capital costs; Exhibit 3-14 shows the owner’s costs, TOC, and TASC; Exhibit 3-15 shows the initial and annual O&M costs; and Exhibit 3-16 shows the LCOH breakdown.

The estimated TOC of the steam methane reforming plant without CO<sub>2</sub> capture is \$713/[kg H<sub>2</sub>/day]. Process contingency represents 0 percent of the TOC and project contingency represents 13.1 percent. The LCOH is \$1.06/kg H<sub>2</sub>.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 3-13. Case 1 total plant cost details**

Case:		1		– Steam Methane Reforming w/o CCS				Estimate Type:		Conceptual	
Plant Size (kg H <sub>2</sub> /day):		483,014						Cost Base:		Dec 2018	
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost	
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]
<b>3 Feedwater &amp; Miscellaneous BOP Systems</b>											
3.1	Feedwater System	\$25	\$52	\$139	\$109	\$325	\$65	\$0	\$58	\$448	\$1
3.2	Water Makeup & Pretreating	\$2,272	\$227	\$1,287	\$0	\$3,786	\$757	\$0	\$909	\$5,452	\$11
3.3	Other Feedwater Subsystems	\$741	\$243	\$231	\$0	\$1,215	\$243	\$0	\$219	\$1,677	\$3
3.4	Service Water Systems	\$689	\$1,316	\$4,261	\$0	\$6,267	\$1,253	\$0	\$1,504	\$9,024	\$19
3.5	Other Boiler Plant Systems	\$230	\$84	\$209	\$0	\$523	\$105	\$0	\$94	\$721	\$1
3.6	Natural Gas Pipeline and Start-Up System	\$9,304	\$400	\$300	\$0	\$10,005	\$2,001	\$0	\$1,801	\$13,807	\$29
3.7	Wastewater Treatment Equipment	\$945	\$0	\$579	\$0	\$1,524	\$305	\$0	\$366	\$2,195	\$5
3.8	Open	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
3.9	Miscellaneous Plant Equipment	\$14,217	\$1,865	\$7,225	\$0	\$23,306	\$4,661	\$0	\$5,594	\$33,561	\$69
	<b>Subtotal</b>	<b>\$28,424</b>	<b>\$4,186</b>	<b>\$14,232</b>	<b>\$109</b>	<b>\$46,951</b>	<b>\$9,390</b>	<b>\$0</b>	<b>\$10,544</b>	<b>\$66,885</b>	<b>\$138</b>
<b>4 Reformer &amp; Accessories</b>											
4.1	Primary Reformer	\$25,327	\$756	\$8,076	\$6,299	\$40,458	\$8,092	\$0	\$12,137	\$60,687	\$126
4.2	Air Blower	\$634	\$507	\$821	\$640	\$2,602	\$520	\$0	\$468	\$3,590	\$7
4.3	Sulfur Guard Bed	\$192	\$236	\$362	\$283	\$1,073	\$215	\$0	\$193	\$1,481	\$3
4.4	Prereformer	\$1,273	\$302	\$462	\$361	\$2,398	\$480	\$0	\$719	\$3,597	\$7
4.5	Syngas Coolers	\$9,113	\$1,318	\$1,413	\$1,102	\$12,946	\$2,589	\$0	\$3,884	\$19,418	\$40
4.6	Air Separation Unit/Oxidant Compression	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
4.7	Steam Drum(s)	w/4.1	w/4.1	w/4.1	w/4.1	\$0	\$0	\$0	\$0	\$0	\$0
	<b>Subtotal</b>	<b>\$36,539</b>	<b>\$3,119</b>	<b>\$11,134</b>	<b>\$8,684</b>	<b>\$59,476</b>	<b>\$11,895</b>	<b>\$0</b>	<b>\$17,402</b>	<b>\$88,773</b>	<b>\$184</b>
<b>5 Flue Gas Cleanup</b>											
5.1	Cansolv Carbon Dioxide (CO <sub>2</sub> ) Removal System	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
5.4	Carbon Dioxide (CO <sub>2</sub> ) Compression & Drying	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
5.5	Carbon Dioxide (CO <sub>2</sub> ) Compressor Aftercooler	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
5.12	Gas Cleanup Foundations	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
	<b>Subtotal</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case:		1		– Steam Methane Reforming w/o CCS				Estimate Type:			Conceptual		
Plant Size (kg H <sub>2</sub> /day):		483,014		Cost Base:								Dec 2018	
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost			
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]		
<b>6</b>		<b>Syngas Cleanup</b>											
6.1	Recycle Compressor	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
6.2	Methyl Diethanolamine (MDEA) – Low Temperature Acid Gas Removal	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
6.7	Water Gas Shift (WGS) Reactors	\$1,764	\$1,882	\$2,769	\$2,160	\$8,576	\$1,715	\$0	\$2,058	\$12,349	\$26		
6.12	Gas Cleanup Foundations	w/ 6.7	w/ 6.7	w/ 6.7	w/ 6.7	\$0	\$0	\$0	\$0	\$0	\$0		
	<b>Subtotal</b>	<b>\$1,764</b>	<b>\$1,882</b>	<b>\$2,769</b>	<b>\$2,160</b>	<b>\$8,576</b>	<b>\$1,715</b>	<b>\$0</b>	<b>\$2,058</b>	<b>\$12,349</b>	<b>\$26</b>		
<b>7</b>		<b>Hydrogen Production</b>											
7.1	Pressure Swing Adsorber	\$16,112	\$23	\$730	\$569	\$17,434	\$3,487	\$0	\$4,184	\$25,105	\$52		
7.2	Hydrogen Compressor	\$6,844	\$187	\$501	\$391	\$7,922	\$1,584	\$0	\$1,901	\$11,408	\$24		
	<b>Subtotal</b>	<b>\$22,956</b>	<b>\$211</b>	<b>\$1,230</b>	<b>\$960</b>	<b>\$25,356</b>	<b>\$5,071</b>	<b>\$0</b>	<b>\$6,085</b>	<b>\$36,513</b>	<b>\$76</b>		
<b>8</b>		<b>Fired Heater, Ductwork, &amp; Stack</b>											
8.1	Fired Heater	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
8.2	Fired Heater Accessories	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
8.3	Ductwork	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
8.4	Stack	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
8.5	Fired Heater, Ductwork & Stack Foundations	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
	<b>Subtotal</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>		
<b>9</b>		<b>Cooling Water System</b>											
9.1	Cooling Towers	\$1,485	\$0	\$453	\$0	\$1,938	\$388	\$0	\$349	\$2,674	\$6		
9.2	Circulating Water Pumps	\$200	\$0	\$12	\$0	\$212	\$42	\$0	\$38	\$292	\$1		
9.3	Circulating Water System Auxiliaries	\$2,605	\$0	\$344	\$0	\$2,949	\$590	\$0	\$531	\$4,069	\$8		
9.4	Circulating Water Piping	\$0	\$569	\$515	\$0	\$1,084	\$217	\$0	\$195	\$1,496	\$3		
9.5	Make-up Water System	\$230	\$0	\$295	\$0	\$525	\$105	\$0	\$95	\$725	\$2		
9.6	Component Cooling Water System	\$84	\$0	\$64	\$0	\$148	\$30	\$0	\$27	\$205	\$0		
9.7	Circulating Water System Foundations	\$0	\$132	\$219	\$0	\$350	\$70	\$0	\$84	\$504	\$1		
	<b>Subtotal</b>	<b>\$4,604</b>	<b>\$700</b>	<b>\$1,902</b>	<b>\$0</b>	<b>\$7,206</b>	<b>\$1,441</b>	<b>\$0</b>	<b>\$1,318</b>	<b>\$9,965</b>	<b>\$21</b>		
<b>11</b>		<b>Accessory Electric Plant</b>											
11.2	Station Service Equipment	\$0	\$840	\$63	\$49	\$951	\$190	\$0	\$171	\$1,313	\$3		
11.3	Switchgear & Motor Control	\$0	\$436	\$133	\$104	\$673	\$135	\$0	\$121	\$929	\$2		
11.4	Conduit & Cable Tray	\$0	\$189	\$237	\$185	\$612	\$122	\$0	\$110	\$845	\$2		
11.5	Wire & Cable	\$0	\$249	\$180	\$140	\$569	\$114	\$0	\$102	\$785	\$2		
11.6	Protective Equipment	\$0	\$235	\$443	\$346	\$1,024	\$205	\$0	\$184	\$1,413	\$3		

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case:		1		– Steam Methane Reforming w/o CCS				Estimate Type:		Conceptual	
Plant Size (kg H <sub>2</sub> /day):		483,014						Cost Base:		Dec 2018	
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost	
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]
11.7	Standby Equipment	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
11.8	Main Power Transformers	\$0	\$226	\$71	\$56	\$353	\$71	\$0	\$63	\$487	\$1
11.9	Electrical Foundations	\$0	\$5	\$14	\$11	\$30	\$6	\$0	\$7	\$43	\$0
	<b>Subtotal</b>	<b>\$0</b>	<b>\$2,179</b>	<b>\$1,142</b>	<b>\$890</b>	<b>\$4,212</b>	<b>\$842</b>	<b>\$0</b>	<b>\$760</b>	<b>\$5,814</b>	<b>\$12</b>
<b>12</b>		<b>Instrumentation &amp; Control</b>									
12.4	Other Major Component Control Equipment	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
12.5	Signal Processing Equipment	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
12.6	Control Boards, Panels & Racks	\$0	\$159	\$16	\$13	\$188	\$38	\$0	\$34	\$259	\$1
12.7	Distributed Control System Equipment	\$6,704	\$0	\$204	\$0	\$6,908	\$1,382	\$0	\$1,243	\$9,533	\$20
12.8	Instrument Wiring & Tubing	\$0	\$137	\$252	\$197	\$585	\$117	\$0	\$105	\$808	\$2
12.9	Other Instrumentation & Controls Equipment	\$0	\$1,001	\$240	\$188	\$1,429	\$286	\$0	\$257	\$1,973	\$4
	<b>Subtotal</b>	<b>\$6,704</b>	<b>\$1,297</b>	<b>\$713</b>	<b>\$397</b>	<b>\$9,111</b>	<b>\$1,822</b>	<b>\$0</b>	<b>\$1,640</b>	<b>\$12,573</b>	<b>\$26</b>
<b>13</b>		<b>Improvements to Site</b>									
13.1	Site Preparation	\$0	\$502	\$10,650	\$0	\$11,152	\$2,230	\$0	\$2,676	\$16,058	\$33
13.2	Site Improvements	\$0	\$199	\$794	\$619	\$1,612	\$322	\$0	\$387	\$2,321	\$5
13.3	Site Facilities	\$1,548	\$0	\$1,624	\$0	\$3,173	\$635	\$0	\$761	\$4,569	\$9
	<b>Subtotal</b>	<b>\$1,548</b>	<b>\$701</b>	<b>\$13,068</b>	<b>\$619</b>	<b>\$15,937</b>	<b>\$3,187</b>	<b>\$0</b>	<b>\$3,825</b>	<b>\$22,949</b>	<b>\$48</b>
<b>14</b>		<b>Buildings &amp; Structures</b>									
14.2	Interconnecting Pipe	\$0	\$425	\$990	\$772	\$2,188	\$438	\$0	\$394	\$3,019	\$6
14.4	Administration Building	\$0	\$334	\$227	\$0	\$561	\$112	\$0	\$101	\$774	\$2
14.5	Circulation Water Pumphouse	\$0	\$8	\$4	\$0	\$12	\$2	\$0	\$2	\$17	\$0
14.6	Water Treatment Buildings	\$0	\$198	\$181	\$0	\$379	\$76	\$0	\$68	\$523	\$1
14.7	Machine Shop	\$0	\$499	\$319	\$0	\$818	\$164	\$0	\$147	\$1,129	\$2
14.8	Warehouse	\$0	\$390	\$236	\$0	\$626	\$125	\$0	\$113	\$863	\$2
14.9	Structural Steel Pipe Racks	\$0	\$1,041	\$598	\$466	\$2,105	\$421	\$0	\$379	\$2,905	\$6
14.10	Waste Treating Building & Structures	\$0	\$658	\$1,173	\$0	\$1,831	\$366	\$0	\$330	\$2,527	\$5
	<b>Subtotal</b>	<b>\$0</b>	<b>\$3,554</b>	<b>\$3,727</b>	<b>\$1,239</b>	<b>\$8,520</b>	<b>\$1,704</b>	<b>\$0</b>	<b>\$1,534</b>	<b>\$11,758</b>	<b>\$24</b>
	<b>Total</b>	<b>\$102,539</b>	<b>\$17,831</b>	<b>\$49,917</b>	<b>\$15,057</b>	<b>\$185,344</b>	<b>\$37,069</b>	<b>\$0</b>	<b>\$45,166</b>	<b>\$267,578</b>	<b>\$554</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 3-14. Case 1 owner's costs**

Description	\$/1,000	\$/[kg H <sub>2</sub> /day]
<b>Pre-Production Costs</b>		
6 Months All Labor	\$2,641	\$5
1 Month Maintenance Materials	\$282	\$1
1 Month Non-Fuel Consumables	\$993	\$2
1 Month Waste Disposal	\$2	\$0
25% of 1 Months Fuel Cost at 100% CF	\$2,838	\$6
2% of TPC	\$5,352	\$11
<b>Total</b>	<b>\$12,107</b>	<b>\$25</b>
<b>Inventory Capital</b>		
60-day supply of fuel and consumables at 100% CF	\$540	\$1
0.5% of TPC (spare parts)	\$1,338	\$3
<b>Total</b>	<b>\$1,878</b>	<b>\$4</b>
<b>Other Costs</b>		
Initial Cost for Catalyst and Chemicals	\$15,295	\$32
Land	\$300	\$1
Other Owner's Costs	\$40,137	\$83
Financing Costs	\$7,225	\$15
<b>Total Overnight Costs (TOC)</b>	<b>\$344,520</b>	<b>\$713</b>
TASC Multiplier (IOU, 35 year)	1.070	
<b>Total As-Spent Cost (TASC)</b>	<b>\$368,568</b>	<b>\$763</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 3-15. Case 1 initial and annual operating and maintenance costs**

Case:	1 – Steam Methane Reforming w/o CCS			Cost Base:	Dec 2018	
Plant Size (kg H <sub>2</sub> /day):	483,014			Capacity Factor (%):	90	
<b>Operating &amp; Maintenance Labor</b>						
<b>Operating Labor</b>				<b>Operating Labor Requirements per Shift</b>		
Operating Labor Rate (base):		38.50	\$/hour	Skilled Operator:	1.0	
Operating Labor Burden:		30.00	% of base	Operator:	2.0	
Labor O-H Charge Rate:		25.00	% of labor	Foreman:	1.0	
				Lab Techs, etc.:	1.0	
				<b>Total:</b>	<b>5.0</b>	
<b>Fixed Operating Costs</b>						
				<b>Annual Cost</b>		
				(\$)	(\$/[kg H <sub>2</sub> /day])	
Annual Operating Labor:				\$2,192,190	\$4.539	
Maintenance Labor:				\$2,033,595	\$4.210	
Administrative & Support Labor:				\$1,056,446	\$2.187	
Property Taxes and Insurance:				\$5,351,567	\$11.080	
<b>Total:</b>				<b>\$10,633,798</b>	<b>\$22.015</b>	
<b>Variable Operating Costs</b>						
				(\$)	(\$/kg H <sub>2</sub> )	
Maintenance Material:				\$3,050,393	\$0.02	
<b>Consumables</b>						
	<b>Initial Fill</b>	<b>Per Day</b>	<b>Per Unit</b>	<b>Initial Fill</b>		
Water (gal/1000):	0	1,049	\$1.90	\$0	\$654,947	\$0.00413
Makeup and Wastewater Treatment Chemicals (ton):	0	3.1	\$550	\$0	\$564,762	\$0.00356
Zinc Oxide Sulfur Guard Catalyst (ft <sup>3</sup> ):	705	0.5	\$600	\$423,000	\$95,175	\$0.00060
Prereformer Catalyst (ft <sup>3</sup> ):	818	0.6	\$1,250	\$1,022,500	\$230,063	\$0.00145
Primary Reformer Catalyst (ft <sup>3</sup> ):	2770	1.5	\$525	\$1,454,250	\$261,765	\$0.00165
Water Gas Shift Catalyst (ft <sup>3</sup> ):	13949	9.6	\$480	\$6,695,503	\$1,506,488	\$0.00949
Methyl Diethanolamine Solution (gal):	0	0	\$2.80	\$0	\$0	\$0.00000
Post-Combustion CO <sub>2</sub> Capture System <sup>^</sup> :	Proprietary				\$0	\$0.00000
PSA Unit Adsorbent (ft <sup>3</sup> ):	38000	5.2	\$150	\$5,700,000	\$256,500	\$0.00162
Triethylene Glycol (gal):	w/equip.	0	\$6.80	\$0	\$0	\$0.00000
Electricity (MWh):	0	304	\$71.70	\$0	\$7,150,827	\$0.04507
<b>Subtotal:</b>				<b>\$15,295,253</b>	<b>\$10,720,528</b>	<b>\$0.06756</b>
<b>Waste Disposal</b>						
Zinc Oxide Sulfur Guard Catalyst (ft <sup>3</sup> ):	0	0.5	\$40.00	\$0	\$6,345	\$0.00004
Prereformer Catalyst (ft <sup>3</sup> ):	0	0.6	\$0.00	\$0	\$0	\$0.00000
Primary Reformer Catalyst (ft <sup>3</sup> ):	0	1.5	\$0.00	\$0	\$0	\$0.00000
Water Gas Shift Catalyst (ft <sup>3</sup> ):	0	9.6	\$2.50	\$0	\$7,846	\$0.00005
Methyl Diethanolamine Solution (gal):	0	0	\$0.35	\$0	\$0	\$0.00000
PSA Unit Adsorbent (ft <sup>3</sup> ):	0	5.2	\$1.50	\$0	\$2,565	\$0.00002
Triethylene Glycol (gal):	0	0	\$0.35	\$0	\$0	\$0.00000
Amine Purification Unit Waste (ton):	0	0	\$38.0	\$0	\$0	\$0.00000
Thermal Reclaimer Unit Waste (ton):	0	0	\$38.0	\$0	\$0	\$0.00000
<b>Subtotal:</b>				<b>\$0</b>	<b>\$16,756</b>	<b>\$0.00011</b>

## COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case:	1 – Steam Methane Reforming w/o CCS			Cost Base:	Dec 2018	
Plant Size (kg H <sub>2</sub> /day):	483,014			Capacity Factor (%):	90	
<b>By-Products</b>						
					(\$)	(\$/kg H <sub>2</sub> )
Steam (ton):	0	4,223	\$0.00	\$0	\$0	\$0.00000
Electricity (MWh):	0	0	\$71.70	\$0	\$0	\$0.00000
<b>Subtotal:</b>				<b>\$0</b>	<b>\$0</b>	<b>\$0.00000</b>
<b>Variable Operating Costs Total:</b>				<b>\$15,295,253</b>	<b>\$13,787,677</b>	<b>\$0.08690</b>
<b>Fuel Cost</b>						
Natural Gas (MMBtu):	0	84,436	\$4.42	\$0	\$122,603,526	\$0.77269
<b>Total:</b>				<b>\$0</b>	<b>\$122,603,526</b>	<b>\$0.77269</b>

<sup>A</sup>Post-combustion CO<sub>2</sub> capture system chemicals includes ion exchange resin, sodium hydroxide (NaOH), and Cansolv solvent

**Exhibit 3-16. Case 1 LCOH breakdown**


Component	Value, \$/kg H <sub>2</sub>	Percentage
Capital	0.14	13%
Fixed	0.07	6%
Variable	0.09	8%
Fuel	0.77	73%
<b>Total (Excluding T&amp;S)</b>	<b>1.06</b>	<b>N/A</b>
CO <sub>2</sub> T&S	0.00	0%
<b>Total (Including T&amp;S)</b>	<b>1.06</b>	<b>N/A</b>

### 3.8 CASE 2 – STEAM METHANE REFORMING PLANT WITH CO<sub>2</sub> CAPTURE PROCESS DESCRIPTION

This section contains an evaluation of a plant design for Case 2, which is based on a natural gas steam methane reforming plant with CO<sub>2</sub> capture. The plant configuration is nearly identical to that of Case 1, with the exception that this case is configured to produce hydrogen with CO<sub>2</sub> capture. The hydrogen production rate of Case 2 is equal to the Case 1 capacity. The system descriptions follow the BFD provided in Exhibit 3-17 with the associated stream tables that show process data provided in Exhibit 3-18. Rather than repeating the entire process description, only differences from Case 1 are reported here.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 3-17. Case 2 block flow diagram, steam methane reforming plant with CO<sub>2</sub> capture**



Note: Block Flow Diagram is not intended to represent a complete material balance. Only major process streams and equipment are shown.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 3-18. Case 2 stream table, steam methane reforming plant with capture**

	1	2	3	4	5	6	7	8	9	10
V-L Mole Fraction										
Ar	0.0092	0.0092	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
CH <sub>4</sub>	0.0000	0.0000	0.9310	0.9310	0.9310	0.0000	0.2583	0.0411	0.0411	0.0411
CH <sub>4</sub> S	0.0000	0.0000	0.0000 <sup>A</sup>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
C <sub>2</sub> H <sub>6</sub>	0.0000	0.0000	0.0320	0.0320	0.0320	0.0000	0.0000	0.0000	0.0000	0.0000
C <sub>3</sub> H <sub>8</sub>	0.0000	0.0000	0.0070	0.0070	0.0070	0.0000	0.0000	0.0000	0.0000	0.0000
C <sub>4</sub> H <sub>10</sub>	0.0000	0.0000	0.0040	0.0040	0.0040	0.0000	0.0000	0.0000	0.0000	0.0000
CO	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0001	0.1432	0.1432	0.0040
CO <sub>2</sub>	0.0003	0.0003	0.0100	0.0100	0.0100	0.0000	0.0174	0.0124	0.0124	0.1517
H <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0440	0.4609	0.4609	0.6001
H <sub>2</sub> O	0.0099	0.0099	0.0000	0.0000	0.0000	1.0000	0.6760	0.3393	0.3393	0.2000
N <sub>2</sub>	0.7732	0.7732	0.0160	0.0160	0.0160	0.0000	0.0042	0.0030	0.0030	0.0030
O <sub>2</sub>	0.2074	0.2074	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	20,603	20,603	4,356	3,687	3,687	9,830	13,930	19,519	19,519	19,519
V-L Flowrate (kg/hr)	594,529	594,529	75,472	63,883	63,882	177,085	240,967	240,967	240,967	240,967
Solids Flowrate (kg/hr)	0	0	0	0	0	0	0	0	0	0
Temperature (°C)	15	24	15	15	370	399	395	871	204	38
Pressure (MPa, abs)	0.10	0.11	3.10	3.10	3.00	3.10	2.90	2.83	2.80	2.45
Steam Table Enthalpy (kJ/kg) <sup>B</sup>	30.23	39.78	-6.77	-6.77	969.07	3,216.15	2,587.78	3,639.94	1,740.54	94.92
AspenPlus Enthalpy (kJ/kg) <sup>C</sup>	-97.58	-88.02	-4,516.00	-4,516.00	-3,540.22	-12,753.89	-10,182.19	-6,233.87	-8,133.27	-9,735.53
Density (kg/m <sup>3</sup> )	1.2	1.3	24.4	24.4	9.7	10.4	9.3	3.7	8.8	14.5
V-L Molecular Weight	28.857	28.857	17.328	17.328	17.328	18.015	17.298	12.345	12.345	12.345
V-L Flowrate (lb <sub>mol</sub> /hr)	45,421	45,421	9,602	8,128	8,128	21,671	30,711	43,033	43,033	43,033
V-L Flowrate (lb/hr)	1,310,711	1,310,711	166,387	140,838	140,836	390,405	531,241	531,241	531,241	531,241
Solids Flowrate (lb/hr)	0	0	0	0	0	0	0	0	0	0
Temperature (°F)	59	76	59	59	698	750	743	1,600	400	100
Pressure (psia)	14.7	16.0	450.0	450.0	435.3	450.0	421.0	411.0	406.0	356.0
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	13.0	17.1	-2.9	-2.9	416.6	1,382.7	1,112.5	1,564.9	748.3	40.8
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	-42.0	-37.8	-1,941.5	-1,941.5	-1,522.0	-5,483.2	-4,377.6	-2,680.1	-3,496.7	-4,185.5
Density (lb/ft <sup>3</sup> )	0.076	0.080	1.525	1.525	0.605	0.652	0.578	0.229	0.549	0.906

<sup>A</sup>Natural gas entering battery limits contains 5.74 ppm of the mercaptan additive methanethiol (CH<sub>4</sub>S)

<sup>B</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>C</sup>AspenPlus thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 3-18. Case 2 stream table, steam methane reforming plant with capture (continued)**

	11	12	13	14	15	16	17	18	19	20	21
V-L Mole Fraction											
Ar	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0082	0.0000	0.0000	0.0000	0.0110
CH <sub>4</sub>	0.0627	0.0000	0.0000	0.2824	0.9310	0.4059	0.0000	0.0000	0.0000	0.0000	0.0000
CH <sub>4</sub> S	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
C <sub>2</sub> H <sub>6</sub>	0.0000	0.0000	0.0000	0.0000	0.0320	0.0061	0.0000	0.0000	0.0000	0.0000	0.0000
C <sub>3</sub> H <sub>8</sub>	0.0000	0.0000	0.0000	0.0000	0.0070	0.0013	0.0000	0.0000	0.0000	0.0000	0.0000
C <sub>4</sub> H <sub>10</sub>	0.0000	0.0000	0.0000	0.0000	0.0040	0.0008	0.0000	0.0000	0.0000	0.0000	0.0000
CO	0.0061	0.0000	0.0000	0.0274	0.0000	0.0222	0.0000	0.0000	0.0000	0.0000	0.0000
CO <sub>2</sub>	0.0116	0.0000	0.0000	0.0521	0.0100	0.0441	0.0746	0.9835	0.9728	0.9995	0.0100
H <sub>2</sub>	0.9150	0.9998	0.9998	0.6180	0.0000	0.5003	0.0000	0.0000	0.0002	0.0000	0.0000
H <sub>2</sub> O	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.2114	0.0165	0.0270	0.0005	0.0358
N <sub>2</sub>	0.0046	0.0002	0.0002	0.0201	0.0160	0.0193	0.6890	0.0000	0.0000	0.0000	0.9209
O <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0167	0.0000	0.0000	0.0000	0.0224
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	12,802	9,959	9,959	2,843	669	3,512	23,216	1,585	2,891	4,373	17,371
V-L Flowrate (kg/hr)	46,850	20,125	20,125	26,725	11,588	38,313	632,842	69,097	125,180	192,413	486,994
Solids Flowrate (kg/hr)	0	0	0	0	0	0	0	0	0	0	0
Temperature (°C)	38	38	30	38	15	29	121	30	49	30	30
Pressure (MPa, abs)	2.35	2.28	6.48	0.14	3.10	0.14	0.10	0.20	0.14	15.27	0.10
Steam Table Enthalpy (kJ/kg) <sup>A</sup>	302.69	544.39	446.67	124.41	-6.77	84.73	485.92	41.78	71.11	-231.09	88.99
AspenPlus Enthalpy (kJ/kg) <sup>B</sup>	-2,601.43	188.79	91.07	-4,698.89	-4,516.00	-4,643.57	-2,844.39	-8,969.58	-8,972.06	-9,194.65	-443.21
Density (kg/m <sup>3</sup> )	3.3	1.8	5.0	0.5	24.4	0.6	0.8	3.5	2.2	630.1	1.1
V-L Molecular Weight	3.660	2.021	2.021	9.400	17.328	10.909	27.258	43.581	43.301	43.997	28.035
V-L Flowrate (lb <sub>mol</sub> /hr)	28,223	21,955	21,955	6,268	1,474	7,743	51,184	3,495	6,373	9,642	38,296
V-L Flowrate (lb/hr)	103,287	44,369	44,369	58,918	25,548	84,466	1,395,178	152,333	275,974	424,198	1,073,638
Solids Flowrate (lb/hr)	0	0	0	0	0	0	0	0	0	0	0
Temperature (°F)	100	100	86	100	59	84	250	86	120	86	87
Pressure (psia)	341.0	331.0	939.7	20.0	450.0	20.0	14.7	28.9	20.0	2,214.7	14.8
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	130.1	234.0	192.0	53.5	-2.9	36.4	208.9	18.0	30.6	-99.4	38.3
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	-1,118.4	81.2	39.2	-2,020.2	-1,941.5	-1,996.4	-1,222.9	-3,856.2	-3,857.3	-3,953.0	-190.5
Density (lb/ft <sup>3</sup> )	0.206	0.110	0.314	0.031	1.525	0.037	0.053	0.217	0.140	39.338	0.071

<sup>A</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>B</sup>AspenPlus thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm

### **3.8.1 Steam Methane Reformer**

No differences from Case 1.

### **3.8.2 Convective Heat Recovery Section**


The steam methane reforming configuration (Case 1 and Case 2) has an integrated heat recovery section as a part of the primary reformer which allows for convective heat recovery from the reformer flue gas. The hot flue gas from the primary reformer is cooled by providing heat to various sections of the plant, improving plant efficiency. This section generates steam for the reforming reactions, provides feedwater preheating, and provides preheating of the natural gas feed prior to the sulfur guard and prereformer. Unlike Case 1, all of the steam generated is utilized within the plant due to the additional process steam demands of the AGR units.

### **3.8.3 Acid Gas Removal**

#### **3.8.3.1 MDEA**

Refrigerated methyl diethanolamine (MDEA) was selected as the pre-combustion CO<sub>2</sub> capture system for the reforming cases and is used in both the steam methane and autothermal reforming designs with capture, Case 2 and Case 3 respectively. The CO<sub>2</sub> is removed from the syngas stream prior to the PSA unit in both configurations by chemical absorption with a highly selective, hybrid amine. Cool, particulate-free syngas from the shift reactors enters the absorber unit at approximately 2.5 MPa (356 psia) and 38 °C (100 °F). The gas is passed through amine tower where it is contacted counter-currently with a circulating stream of lean aqueous amine solution. The absorber column is operated at 44 °C (112 °F) by refrigerating the lean MDEA solvent. CO<sub>2</sub> in the feed is removed from the gas stream by the circulating lean amine. The rich amine from the absorber is then sent to a stripper column where the amine is regenerated with a steam reboiler to remove the CO<sub>2</sub> by fractionation. Because of the steam load required to regenerate CO<sub>2</sub>, there is no steam export from these plant configurations. Regenerated lean amine is then cooled and sent back to the amine tower. The regenerated CO<sub>2</sub> stream is recovered at 20 psia and 120 °F and is sent to the CO<sub>2</sub> compressor for shipment off-site. A diagram of the MDEA CO<sub>2</sub> capture process for reforming plants is shown in Exhibit 3-19.

**Exhibit 3-19. MDEA CO<sub>2</sub> capture process typical flow diagram for reforming plants**



If the CO<sub>2</sub> were only captured from the shifted syngas stream, the overall CO<sub>2</sub> recovery would be about 62 percent for the steam methane reforming case. To increase the overall carbon recovery, a second CO<sub>2</sub> removal process is utilized in the reformer heater stack to remove CO<sub>2</sub> resulting from fuel gas combustion.

### 3.8.3.2 Cansolv

The CO<sub>2</sub> absorption/stripping/solvent reclamation process designed for post-combustion capture in the steam methane reforming with capture case (Case 2) is based on the Cansolv system. The following are characteristics of the Cansolv system used for post-combustion capture:


- The Cansolv solvent used for post-combustion reforming configurations provides increased reactivity in the low CO<sub>2</sub> content reforming flue gas environment. This is feasible given the lack of solvent contaminants (i.e., sulfur) present in the reforming plant flue gas stream.
- No SO<sub>2</sub> polishing step is required in reforming cases, as the pipeline natural gas sulfur content produces a flue gas with an SO<sub>2</sub> content below that which is required by the Cansolv process.
- No absorber inter-stage solvent cooling is employed in the reforming plant case.
- No lean solvent flash or vapor recovery, compression, and reinjection is employed in the reforming plant case.
- Solvent reclaiming considers an additional purification step, beyond thermal reclaiming, for the reforming plant case. In addition to the thermal reclaimer, an ion exchange reclaimer is also applied in the amine purification section. The acids formed by the oxidative degradation of the amine, as well as through reactions with nitrogen dioxide

(NO<sub>2</sub>) and SO<sub>2</sub> heat stable salt (HSS), neutralize a portion of the amine making it inactive to further CO<sub>2</sub> absorption. Therefore, excess HSS are removed via an ion exchange (resin bed contained within a column) before continuing to the thermal reclaimer.

- For the steady-state case described here, the low-pressure steam requirement for the reboiler only is calculated as approximately 2.8 megajoule (MJ)/kg (1,217 Btu/lb) CO<sub>2</sub> for the Cansolv process.

A diagram of the Cansolv CO<sub>2</sub> capture process for reforming plants is provided in Exhibit 3-20.

**Exhibit 3-20. Cansolv CO<sub>2</sub> capture process typical flow diagram for reforming plants**



The Cansolv system in the reforming plant case discharges CO<sub>2</sub> at a temperature of 30 °C (86 °F) and a pressure of 0.2 MPa (28.9 psia).

### 3.8.4 CO<sub>2</sub> Compression and Drying System

The CO<sub>2</sub> compressor specifications, stage pressure ratios and outlet stage pressures are identical for each of the CO<sub>2</sub> capture cases with the major differentiator being the inlet CO<sub>2</sub> flowrates.

The compression system was modeled based on vendor supplied data and using elements of the compressor design presented in the Carbon Capture Simulation Initiative’s paper “Centrifugal Compressor Simulation User Manual.” [58] The design was assumed to be an eight-stage front-loaded integrally geared centrifugal compressor. The stage discharge pressures are presented in Exhibit 3-21.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES


**Exhibit 3-21. CO<sub>2</sub> compressor interstage pressures**

Stage	Outlet Pressure, MPa (psia)	Stage Pressure Ratio
1	0.32 (47)	2.33
2	0.70 (102)	2.24
3	1.38 (199)	1.99
4	2.54 (369)	1.86
5	4.00 (581)	1.66
6	6.38 (925)	1.60
7	9.91 (1,437)	1.56
8	15.28 (2,217)	1.54

The CO<sub>2</sub> streams produced by the AGR processes contain approximately 99 percent CO<sub>2</sub> and are mixed prior to the compression train. The mixed CO<sub>2</sub> stream enters the first stage of the CO<sub>2</sub> compressor at 0.14 MPa (20 psia) and is compressed to 2.54 MPa (369 psia) in the first four compression stages with intercooling. Next, the CO<sub>2</sub> stream is dehydrated using a triethylene glycol (TEG) dryer. The dried CO<sub>2</sub> stream is then further compressed in the final four stages, with intercooling, to the target product pressure of 15.28 MPa (2,217 psia).

Intercooling is included for each stage with the first three stages including water knockout. The first five intercoolers cool the CO<sub>2</sub> to 29 °C (85 °F), the sixth intercooler cools the CO<sub>2</sub> to 40 °C (104 °F), and the final intercooler cools the CO<sub>2</sub> to 55 °C (131 °F). The increased temperature is utilized in the final two stages of intercooling to provide a suitable buffer between the compressor operating profile and SC CO<sub>2</sub> dome which is shown in Exhibit 3-22. A CO<sub>2</sub> product aftercooler is also included to cool the CO<sub>2</sub> 30 °C (86 °F). CO<sub>2</sub> transportation and storage costs assume that the CO<sub>2</sub> enters the transport pipeline as a dense phase liquid; thus, a pipeline inlet temperature of 30 °C (86 °F) is considered.

Exhibit 3-22. Case 2 CO<sub>2</sub> vapor dome



A TEG dehydration unit is included between stages 4 and 5, operating at 2.53 MPa (367 psia), to reduce the moisture concentration of the CO<sub>2</sub> stream to 500 ppmv, consistent with QGESS design point specifications for CO<sub>2</sub> for pipeline export. [59] The dryer was designed based on a paper published by the Norwegian University of Science and Technology. [60] In an absorption process, such as in a TEG dehydration unit, the gas containing water flows up through a column while the TEG flows downward. The solvent preferentially binds the water by physical absorption. The dried gas exits at the top of the column, while the solvent rich in water exits at the bottom. After depressurization to around atmospheric pressure, the solvent is regenerated by heating it and passing it through a regeneration column where the water is boiled off. A TEG unit is capable of reducing water concentrations to meet the QGESS design point of 500 ppmv. [59]

### 3.9 CASE 2 – PERFORMANCE RESULTS

Overall performance for the entire plant is summarized in Exhibit 3-23. The plant produces 20,125 kg/hr (44,369 lb/hr) of hydrogen at an effective thermal efficiency of 68.4 percent (HHV basis). The total auxiliary load for the plant is 41 MWe.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Exhibit 3-24 provides a detailed breakdown of the auxiliary power requirements. The hydrogen compressor accounts for about 26 percent of the total auxiliary load. About 57 percent of the auxiliary load is from the CO<sub>2</sub> capture, removal, and compression systems. The BFW pumps and cooling water system, including the circulating water pumps and cooling tower fan, accounts for approximately 10 percent of the auxiliary load. All other systems together constitute the remaining 7 percent of the auxiliary load.

**Exhibit 3-23. Case 2 plant performance summary**

Performance Summary	
Steam Turbine Power, MWe	0
<b>Total Gross Power, MWe</b>	<b>0</b>
CO <sub>2</sub> Capture/Removal Auxiliaries, kWe	6,710
CO <sub>2</sub> Compression, kWe	16,460
Balance of Plant, kWe	17,500
<b>Total Auxiliaries, MWe</b>	<b>41</b>
<b>Net Power, MWe</b>	<b>-41</b>
<b>Hydrogen Production, kg/hr (lb/hr)</b>	<b>20,125 (44,369)</b>
<b>CO<sub>2</sub> Capture, %</b>	<b>96.2%</b>
HHV Effective Thermal Efficiency <sup>A</sup> , %	68.4%
HHV Cold Gas Efficiency <sup>B</sup> , %	72.1%
LHV Effective Thermal Efficiency <sup>A</sup> , %	63.5%
LHV Cold Gas Efficiency <sup>B</sup> , %	67.6%
AGR Cooling Duty, GJ/hr (MMBtu/hr)	947 (898)
Natural Gas Feed Flow, kg/hr (lb/hr)	75,472 (166,387)
HHV Thermal Input, kWt	1,096,328
LHV Thermal Input, kWt	989,544
Raw Water Withdrawal, m <sup>3</sup> /min (gpm)	10.3 (2,727)
Raw Water Consumption, m <sup>3</sup> /min (gpm)	8.1 (2,140)

<sup>A</sup>ETE = (Hydrogen Heating Value + Net Power) / Fuel Heating Value

<sup>B</sup>CGE = Hydrogen Heating Value / Fuel Heating Value

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 3-24. Case 2 plant power summary**

Power Summary	
Steam Turbine Power, MWe	0
<b>Total Gross Power, MWe</b>	<b>0</b>
Auxiliary Load Summary	
Air Blower, kWe	1,640
Circulating Water Pumps, kWe	2,500
Cooling Tower Fans, kWe	1,290
CO <sub>2</sub> Capture/Removal Auxiliaries, kWe	6,710
CO <sub>2</sub> Compression, kWe	16,460
Feedwater Pumps, kWe	140
Ground Water Pumps, kWe	250
Hydrogen Compressor, kWe	10,430
Miscellaneous Balance of Plant <sup>A</sup> , kWe	1,000
Transformer Losses, kWe	250
<b>Total Auxiliaries, MWe</b>	<b>41</b>
<b>Net Power, MWe</b>	<b>-41</b>

<sup>A</sup>Includes plant control systems, lighting, HVAC, and miscellaneous low voltage loads

### 3.9.1 Environmental Performance

The environmental targets for emissions of Hg, NO<sub>x</sub>, SO<sub>2</sub>, and PM were presented in Section 2.7. A summary of the plant air emissions for Case 2 is presented in Exhibit 3-25.

**Exhibit 3-25. Case 2 air emissions**

	kg/GJ (lb/MMBtu)	Tonne/year (ton/year) <sup>A</sup>	lb/lb H <sub>2</sub>
SO <sub>2</sub>	0.000 (0.000)	0 (0)	0.000
NO <sub>x</sub>	0.001 (0.002)	31 (34)	0.000
Particulate	0.000 (0.000)	0 (0)	0.000
Hg	0.00E+0 (0.00E+0)	0.000 (0.000)	0.00E+0
CO	0.000 (0.000)	0 (0)	0.000
CO <sub>2</sub> <sup>B</sup>	2 (5)	60,298 (66,467)	0.4
CO <sub>2</sub> e <sup>C</sup>	28 (64)	858,396 (946,220)	4.6

<sup>A</sup>Calculations based on a 90 percent capacity factor

<sup>B</sup>Plant stack emissions

<sup>C</sup>Life cycle emissions

The natural gas feed contains 5.74 ppmv of the mercaptan additive methanethiol (CH<sub>4</sub>S). A zinc oxide sulfur guard bed was used to remove 98 percent of the sulfur in the feed, resulting in a maximum sulfur content of 0.1 ppm post-sulfur guard bed.

NO<sub>x</sub> emissions are limited by the use of low-NO<sub>x</sub> burners in the design. The production of PM is a result of system inefficiencies and is not produced or emitted in any significant amount. The pipeline natural gas was assumed to contain no Hg or HCl, resulting in zero emissions.

Ninety five percent of the CO<sub>2</sub> from the syngas is captured in the pre-combustion AGR system and ninety percent of the CO<sub>2</sub> from the stack gas is captured in the post-combustion AGR system and compressed for storage.

The carbon balance for the plant is shown in Exhibit 3-26. The carbon input to the plant consists of carbon in the air in addition to carbon in the natural gas. Carbon leaves the plant as a small portion of the hydrogen product, the captured CO<sub>2</sub> product, the carbon in the CO<sub>2</sub> dryer vent and knockout, and the CO<sub>2</sub> in the stack gas. The overall carbon capture efficiency is 96.2 percent, defined as one minus the mass of carbon in the stack gas and CO<sub>2</sub> dryer vent relative to the total carbon, represented by the following equation:

$$\text{Carbon Capture Efficiency (\%)} = \left( 1 - \left( \frac{\text{Carbon in Stack and CO}_2 \text{ Dryer Vent}}{\text{Total Carbon In}} \right) \right) * 100\%$$

**Exhibit 3-26. Case 2 carbon balance**

Carbon In		Carbon Out	
	kg/hr (lb/hr)		kg/hr (lb/hr)
Natural Gas	54,512 (120,178)	Stack Gas	2,081 (4,588)
Air (CO <sub>2</sub> )	81 (178)	Export Steam	–
		Hydrogen Product	2 (5)
		Sulfur Guard Bed	0 (1)
		CO <sub>2</sub> Product	52,502 (115,747)
		CO <sub>2</sub> Dryer Vent	6.9 (15)
		CO <sub>2</sub> Knockout	0.1 (0.3)
<b>Total</b>	<b>54,593 (120,356)</b>	<b>Total</b>	<b>54,593 (120,356)</b>

Exhibit 3-27 shows the sulfur balance for the plant. Sulfur input comes solely from the mercaptan additive in the natural gas. Sulfur output includes sulfur recovered in the sulfur guard bed and small amounts of sulfur recovered in the AGR system.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 3-27. Case 2 sulfur balance**

Sulfur In		Sulfur Out	
	kg/hr (lb/hr)		kg/hr (lb/hr)
Natural Gas	1 (2)	AGR Sulfur	0 (0)
		Sulfur Guard Bed	1 (1)
<b>Total</b>	<b>1 (2)</b>	<b>Total</b>	<b>1 (2)</b>

Exhibit 3-28 shows the overall water balance for the plant.

**Exhibit 3-28. Case 2 water balance**

Water Use	Water Demand	Internal Recycle	Raw Water Withdrawal	Process Water Discharge	Raw Water Consumption
	m <sup>3</sup> /min (gpm)				
CO <sub>2</sub> Drying	–	–	–	0.0 (0.9)	0.0 (-0.9)
CO <sub>2</sub> Capture System Makeup	0.1 (17)	–	0.1 (17)	–	0.1 (17)
CO <sub>2</sub> Capture Recovery	–	–	–	–	–
CO <sub>2</sub> Compression Recovery	–	–	–	0.0 (7.3)	0.0 (-7.3)
<b>Steam Generation</b>	<b>3.0 (781)</b>	<b>2.4 (642)</b>	<b>0.5 (138)</b>	–	<b>0.5 (138)</b>
Export Steam	–	–	–	–	–
SMR Steam	3.0 (781)	–	3.0 (781)	–	3.0 (781)
Syngas Condensate	–	2.4 (642)	-2.4 (-642)	–	-2.4 (-642)
<b>Cooling Tower</b>	<b>9.7 (2,571)</b>	–	<b>9.7 (2,571)</b>	<b>2.2 (578)</b>	<b>7.5 (1,993)</b>
<b>Total</b>	<b>13 (3,369)</b>	<b>2.4 (642)</b>	<b>10 (2,727)</b>	<b>2.2 (586)</b>	<b>8.1 (2,140)</b>

An overall plant energy balance is provided in tabular form in Exhibit 3-29.

**Exhibit 3-29. Case 2 overall energy balance (0 °C [32 °F] reference)**

	HHV	Sensible + Latent	Power	Total
Heat In, GJ/hr (MMBtu/hr)				
Natural Gas	3,947 (3,741)	2.6 (2.5)	–	3,949 (3,743)
Air	–	18 (17)	–	18 (17)
Raw Water Makeup	–	39 (37)	–	39 (37)
Auxiliary Power	–	–	146 (139)	146 (139)
<b>Total</b>	<b>3,947 (3,741)</b>	<b>59 (56)</b>	<b>146 (139)</b>	<b>4,153 (3,936)</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

	HHV	Sensible + Latent	Power	Total
Heat Out, GJ/hr (MMBtu/hr)				
Hydrogen Product	2,846 (2,697)	9.0 (8.5)	–	2,855 (2,706)
Stack Gas	–	43 (41)	–	43 (41)
Sulfur	–	0.0 (0.0)	–	0.0 (0.0)
Motor Losses and Design Allowances	–	–	4.5 (4.3)	4.5 (4.3)
Cooling Tower Load <sup>A</sup>	–	1,271 (1,205)	–	1,271 (1,205)
Cooling Tower Blowdown	–	16 (15)	–	16 (15)
CO <sub>2</sub> Product Stream	–	-44 (-42)	–	-44 (-42)
Power	–	–	0.0 (0.0)	0.0 (0.0)
<b>Total</b>	<b>2,846 (2,697)</b>	<b>1,295 (1,228)</b>	<b>4.5 (4.3)</b>	<b>4,146 (3,929)</b>
Unaccounted Energy <sup>B</sup>	–	6.9 (6.6)	–	6.9 (6.6)


<sup>A</sup>Includes AGR, compression, and last stage syngas cooling loads

<sup>B</sup>By difference

### 3.9.2 Energy and Mass Balance Diagrams

The energy and mass balance diagram for Case 2 is shown in Exhibit 3-30.

Exhibit 3-30. Case 2 steam methane reforming plant with CO<sub>2</sub> capture energy and mass balance



This page intentionally left blank

### 3.10 CASE 2 – MAJOR EQUIPMENT LIST

Major equipment items for the steam methane reforming plant with CO<sub>2</sub> capture are shown in the following tables. In general, the design conditions include a 10 percent design allowance for flows and heat duties and a 21 percent design allowance for heads on pumps and fans.

#### Case 2 – Account 3: Feedwater and Miscellaneous Balance of Plant Systems

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	LP Feedwater Pumps	Horizontal centrifugal	2,850 lpm @ 4 m H <sub>2</sub> O (750 gpm @ 10 ft H <sub>2</sub> O)	2	1
2	MP Feedwater Pumps	Horizontal, split case, multi-stage, centrifugal	710 lpm @ 379 m H <sub>2</sub> O (190 gpm @ 1,240 ft H <sub>2</sub> O)	2	1
			640 lpm @ 88 m H <sub>2</sub> O (170 gpm @ 290 ft H <sub>2</sub> O)	2	1
3	Water Makeup Pumps	Horizontal, split case, multi-stage, centrifugal	290 lpm @ 380 m H <sub>2</sub> O (80 gpm @ 1,240 ft H <sub>2</sub> O)	2	2
4	Auxiliary Boiler	Shop fabricated, water tube	18,000 kg/hr, 2.8 MPa, 343 °C (40,000 lb/hr, 400 psig, 650 °F)	1	0
5	Service Air Compressors	Flooded Screw	13 m <sup>3</sup> /min @ 0.7 MPa (450 scfm @ 100 psig)	2	1
6	Instrument Air Dryers	Duplex, regenerative	13 m <sup>3</sup> /min (450 scfm)	2	1
7	Engine-Driven Fire Pump	Vertical turbine, diesel engine	3,785 lpm @ 110 m H <sub>2</sub> O (1,000 gpm @ 350 ft H <sub>2</sub> O)	1	1
8	Fire Service Booster Pump	Two-stage horizontal centrifugal	2,650 lpm @ 80 m H <sub>2</sub> O (700 gpm @ 250 ft H <sub>2</sub> O)	1	1
9	Raw Water Pumps	Stainless steel, single suction	5,700 lpm @ 20 m H <sub>2</sub> O (1,500 gpm @ 60 ft H <sub>2</sub> O)	2	1
10	Filtered Water Pumps	Stainless steel, single suction	190 lpm @ 50 m H <sub>2</sub> O (50 gpm @ 160 ft H <sub>2</sub> O)	2	1
11	Filtered Water Tank	Vertical, cylindrical	182,000 liter (48,000 gal)	1	0
12	Makeup Water Demineralizer	Multi-media filter, cartridge filter, RO membrane assembly and electro-deionization unit	400 lpm (110 gpm)	1	0
13	Liquid Waste Treatment System	–	10 years, 24-hour storm	1	0
14	Gas Pipeline	Underground, coated carbon steel, wrapped cathodic protection	57 m <sup>3</sup> /min @ 3.1 MPa (2,001 acfm @ 450 psia) 39 cm (16 in) standard wall pipe	16 km (10 mile)	0
15	Gas Metering Station	–	57 m <sup>3</sup> /min (2,001 acfm)	1	0

#### Case 2 – Account 4: Reformer and Accessories

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Primary Reformer	SMR, side fired, fixed bed, catalytic	Syngas Production: 265,000 kg/hr @ 2.8 MPa, 871 °C (584,000 lb/hr @ 411 psia, 1600 °F)	1	0

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
2	Air Blower	Centrifugal	654,000 kg/hr @ 4,000 m <sup>3</sup> /min, 3cm WG (1,442,000 lb/hr @ 150,000 acfm, 1in. WG)	2	1
3	Sulfur Guard Bed	Fixed Bed, catalytic (ZnO)	Inlet: 70,000 kg/hr @ 3.0 MPa, 370 °C (155,000 lb/hr @ 441 psia, 698 °F)	1	0
4	Prereformer	Fixed Bed, catalytic	NG In: 70,000 kg/hr @ 2.9 MPa, 500 °C (155,000 lb/hr @ 427 psia, 932 °F) Steam In: 195,000 kg/hr @ 3.1 MPa, 399 °C (429,000 lb/hr @ 450 psia, 750 °F)	1	0
5	Syngas Coolers	Shell and tube heat exchanger	Syngas Cooler: 457 GJ/hr (434 MMBtu/hr) LP Steam Generator 1: 93 GJ/hr (88 MMBtu/hr) LP Steam Generator 2: 13 GJ/hr (12 MMBtu/hr) BFW Heater: 108 GJ/hr (103 MMBtu/hr) AGR Precooler: 172 GJ/hr (163 MMBtu/hr)	5	0

**Case 2 – Account 5: Flue Gas Cleanup**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Cansolv	Amine-based CO <sub>2</sub> capture technology	696,000 kg/hr (1,535,000 lb/hr) 12.0 wt % CO <sub>2</sub> concentration	1	0
2	CO <sub>2</sub> Dryer	Triethylene glycol	Inlet: 63 m <sup>3</sup> /min @ 2.5 MPa (2,222 acfm @ 367 psia) Outlet: 2.4 MPa (350 psia) Water Recovered: 204 kg/hr (450 lb/hr)	1	0
3	CO <sub>2</sub> Compressor	Integrally geared, multi-stage centrifugal	7.0 m <sup>3</sup> /min @ 15.3 MPa, 85 °C (264 acfm @ 2,217 psia, 185 °F)	1	0
4	CO <sub>2</sub> Aftercooler	Shell and tube heat exchanger	Outlet: 15.3 MPa, 30 °C (2,215psia, 86 °F) Duty: 32 GJ/hr (30 MMBtu/hr)	1	0

**Case 2 – Account 6: Syngas Cleanup**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Water Gas Shift Reactors	Fixed bed, catalytic	88,000 kg/hr (292,000 lb/hr) 204 °C (400 °F) 2.8 MPa (410 psia)	6	0
2	Acid Gas Removal Plant	MDEA	265,000 kg/hr (584,000 lb/hr) 38 °C (100 °F) 2.5 MPa (356 psia)	1	0

**Case 2 – Account 7: Hydrogen Production**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Pressure Swing Adsorber	Polybed Proprietary	Syngas: 46,850 kg/hr (103,287 lb/hr) 38 °C (100 °F) 2.4 MPa (341.0 psia) Hydrogen: 20,125 kg/hr (44,369 lb/hr) 38 °C (100 °F) 2.3 MPa (331.0 psia) Off Gas: 26,725 kg/hr (58,918 lb/hr) 38 °C (100 °F) 0.1 MPa (20.0 psia)	1	0
2	Hydrogen Compressor	Integrally geared, multi-stage centrifugal	73 m <sup>3</sup> /min @ 6.5 MPa (2,587 acfm @ 940 psia)	1	1

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Case 2 – Account 9: Cooling Water System**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Circulating Water Pumps	Vertical, wet pit	251,000 lpm @ 30 m (66,000 gpm @ 100 ft)	2	1
2	Cooling Tower	Evaporative, mechanical draft, multi-cell	11 °C (52 °F) wet bulb/16 °C (60 °F) CWT/ 27 °C (80 °F) HWT/ 1400 GJ/hr (1330 MMBtu/hr) heat duty	1	0

**Case 2 – Account 11: Accessory Electric Plant**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	High Voltage Auxiliary Transformer	Oil-filled	345 kV/13.8 kV, 9 MVA, 3-ph, 60 Hz	2	0
2	Medium Voltage Transformer	Oil-filled	18 kV/4.16 kV, 20 MVA, 3-ph, 60 Hz	1	1
3	Low Voltage Transformer	Dry ventilated	4.16 kV/480 V, 7 MVA, 3-ph, 60 Hz	1	1
4	Medium Voltage Switchgear	Metal clad	4.16 kV, 3-ph, 60 Hz	1	1
5	Low Voltage Switchgear	Metal enclosed	480 V, 3-ph, 60 Hz	1	1
6	Emergency Diesel Generator	Sized for emergency shutdown	750 kW, 480 V, 3-ph, 60 Hz	1	0

**Case 2 – Account 12: Instrumentation and Control**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	DCS – Main Control	Monitor/keyboard; Operator printer (laser color); Engineering printer (laser black and white)	Operator stations/printers and engineering stations/printers	1	0
2	DCS – Processor	Microprocessor with redundant input/output	N/A	1	0
3	DCS – Data Highway	Fiber optic	Fully redundant, 25% spare	1	0

### 3.11 CASE 2 – COST ESTIMATING

The cost estimating methodology was described previously in Section 2.11. Exhibit 3-31 shows a detailed breakdown of the capital costs; Exhibit 3-32 shows the owner’s costs, TOC, and TASC; Exhibit 3-33 shows the initial and annual O&M costs; and Exhibit 3-34 shows the LCOH breakdown.

The estimated TOC of the steam methane reforming plant with CO<sub>2</sub> capture is \$1,735/[kg H<sub>2</sub>/day]. An 8 percent increase in the primary reformer above Case 1 is observed due to the higher fired duty of the furnace from the addition of CO<sub>2</sub> capture equipment. Process contingency represents 3 percent of the TOC and project contingency represents 14.5 percent. The LCOH is \$1.64/kg H<sub>2</sub> with CO<sub>2</sub> T&S.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 3-31. Case 2 total plant cost details**

Case:		2		– Steam Methane Reforming w/ CCS				Estimate Type:		Conceptual	
Plant Size (kg H <sub>2</sub> /day):		483,007						Cost Base:		Dec 2018	
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost	
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]
<b>3</b>			<b>Feedwater &amp; Miscellaneous BOP Systems</b>								
3.1	Feedwater System	\$233	\$195	\$484	\$377	\$1,289	\$258	\$0	\$232	\$1,779	\$4
3.2	Water Makeup & Pretreating	\$3,553	\$355	\$2,014	\$0	\$5,922	\$1,184	\$0	\$1,421	\$8,528	\$18
3.3	Other Feedwater Subsystems	\$965	\$316	\$300	\$0	\$1,581	\$316	\$0	\$285	\$2,182	\$5
3.4	Service Water Systems	\$1,078	\$2,059	\$6,666	\$0	\$9,803	\$1,961	\$0	\$2,353	\$14,116	\$29
3.5	Other Boiler Plant Systems	\$230	\$84	\$209	\$0	\$523	\$105	\$0	\$94	\$722	\$1
3.6	Natural Gas Pipeline and Start-Up System	\$9,304	\$400	\$300	\$0	\$10,005	\$2,001	\$0	\$1,801	\$13,807	\$29
3.7	Wastewater Treatment Equipment	\$4,611	\$0	\$2,826	\$0	\$7,437	\$1,487	\$0	\$1,785	\$10,709	\$22
3.9	Miscellaneous Plant Equipment	\$14,217	\$1,865	\$7,225	\$0	\$23,306	\$4,661	\$0	\$5,594	\$33,561	\$69
	<b>Subtotal</b>	<b>\$34,191</b>	<b>\$5,273</b>	<b>\$20,024</b>	<b>\$377</b>	<b>\$59,866</b>	<b>\$11,973</b>	<b>\$0</b>	<b>\$13,564</b>	<b>\$85,403</b>	<b>\$177</b>
<b>4</b>			<b>Reformer &amp; Accessories</b>								
4.1	Primary Reformer	\$27,110	\$1,165	\$8,736	\$6,814	\$43,825	\$8,765	\$0	\$13,147	\$65,737	\$136
4.2	Air Blower	\$634	\$564	\$888	\$693	\$2,778	\$556	\$0	\$500	\$3,834	\$8
4.3	Sulfur Guard Bed	\$192	\$236	\$362	\$283	\$1,073	\$215	\$0	\$193	\$1,481	\$3
4.4	Prereformer	\$1,273	\$302	\$462	\$361	\$2,398	\$480	\$0	\$719	\$3,597	\$7
4.5	Syngas Coolers	\$9,007	\$1,425	\$1,504	\$1,173	\$13,108	\$2,622	\$0	\$3,932	\$19,662	\$41
4.6	Air Separation Unit/Oxidant Compression	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
4.7	Steam Drum(s)	w/4.1	w/4.1	w/4.1	w/4.1	\$0	\$0	\$0	\$0	\$0	\$0
	<b>Subtotal</b>	<b>\$38,214</b>	<b>\$3,693</b>	<b>\$11,953</b>	<b>\$9,322</b>	<b>\$63,182</b>	<b>\$12,636</b>	<b>\$0</b>	<b>\$18,493</b>	<b>\$94,311</b>	<b>\$195</b>
<b>5</b>			<b>Flue Gas Cleanup</b>								
5.1	Cansolv Carbon Dioxide (CO <sub>2</sub> ) Removal System	\$136,003	\$160	\$482	\$376	\$137,022	\$27,404	\$24,664	\$47,272	\$236,362	\$489
5.4	Carbon Dioxide (CO <sub>2</sub> ) Compression & Drying	\$40,280	\$1,383	\$3,438	\$2,681	\$47,783	\$9,557	\$0	\$14,335	\$71,674	\$148
5.5	Carbon Dioxide (CO <sub>2</sub> ) Compressor Aftercooler	\$1,662	\$396	\$708	\$552	\$3,318	\$664	\$0	\$597	\$4,578	\$9
5.12	Gas Cleanup Foundations	w/ 5.1,4,&5	w/ 5.1,4,&5	w/ 5.1,4,&5	w/ 5.1,4,&5	\$0	\$0	\$0	\$0	\$0	\$0
	<b>Subtotal</b>	<b>\$177,945</b>	<b>\$1,939</b>	<b>\$4,628</b>	<b>\$3,610</b>	<b>\$188,122</b>	<b>\$37,624</b>	<b>\$24,664</b>	<b>\$62,204</b>	<b>\$312,615</b>	<b>\$647</b>
<b>6</b>			<b>Syngas Cleanup</b>								

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case:		2		– Steam Methane Reforming w/ CCS				Estimate Type:		Conceptual	
Plant Size (kg H <sub>2</sub> /day):		483,007						Cost Base:		Dec 2018	
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O. & Fee	Contingencies		Total Plant Cost	
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]
6.1	Recycle Compressor	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
6.2	Methyl Diethanolamine (MDEA) – Low Temperature Acid Gas Removal	\$19,133	\$0	\$539	\$420	\$20,093	\$4,019	\$0	\$4,822	\$28,933	\$60
6.7	Water Gas Shift (WGS) Reactors	\$1,764	\$1,882	\$2,769	\$2,160	\$8,576	\$1,715	\$0	\$2,058	\$12,349	\$26
6.12	Gas Cleanup Foundations	w/ 6.2 & 7	w/ 6.2 & 7	w/ 6.2 & 7	w/ 6.2 & 7	\$0	\$0	\$0	\$0	\$0	\$0
	<b>Subtotal</b>	<b>\$20,897</b>	<b>\$1,882</b>	<b>\$3,308</b>	<b>\$2,580</b>	<b>\$28,668</b>	<b>\$5,734</b>	<b>\$0</b>	<b>\$6,880</b>	<b>\$41,282</b>	<b>\$85</b>
<b>7 Hydrogen Production</b>											
7.1	Pressure Swing Adsorber	\$16,112	\$23	\$730	\$569	\$17,434	\$3,487	\$0	\$4,184	\$25,105	\$52
7.2	Hydrogen Compressor	\$6,844	\$187	\$501	\$391	\$7,922	\$1,584	\$0	\$1,901	\$11,408	\$24
	<b>Subtotal</b>	<b>\$22,956</b>	<b>\$211</b>	<b>\$1,230</b>	<b>\$960</b>	<b>\$25,356</b>	<b>\$5,071</b>	<b>\$0</b>	<b>\$6,085</b>	<b>\$36,513</b>	<b>\$76</b>
<b>8 Fired Heater, Ductwork, &amp; Stack</b>											
8.1	Fired Heater	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
8.2	Fired Heater Accessories	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
8.3	Ductwork	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
8.4	Stack	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
8.5	Fired Heater, Ductwork & Stack Foundations	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
	<b>Subtotal</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>	<b>\$0</b>
<b>9 Cooling Water System</b>											
9.1	Cooling Towers	\$7,438	\$0	\$2,252	\$0	\$9,690	\$1,938	\$0	\$1,744	\$13,373	\$28
9.2	Circulating Water Pumps	\$985	\$0	\$60	\$0	\$1,046	\$209	\$0	\$188	\$1,443	\$3
9.3	Circulating Water System Auxiliaries	\$7,716	\$0	\$1,018	\$0	\$8,735	\$1,747	\$0	\$1,572	\$12,054	\$25
9.4	Circulating Water Piping	\$0	\$2,153	\$1,949	\$0	\$4,102	\$820	\$0	\$738	\$5,661	\$12
9.5	Make-up Water System	\$294	\$0	\$378	\$0	\$671	\$134	\$0	\$121	\$927	\$2
9.6	Component Cooling Water System	\$317	\$0	\$244	\$0	\$561	\$112	\$0	\$101	\$774	\$2
9.7	Circulating Water System Foundations	\$0	\$498	\$827	\$0	\$1,325	\$265	\$0	\$318	\$1,908	\$4
	<b>Subtotal</b>	<b>\$16,751</b>	<b>\$2,651</b>	<b>\$6,728</b>	<b>\$0</b>	<b>\$26,130</b>	<b>\$5,226</b>	<b>\$0</b>	<b>\$4,783</b>	<b>\$36,139</b>	<b>\$75</b>
<b>11 Accessory Electric Plant</b>											
11.2	Station Service Equipment	\$0	\$1,122	\$94	\$74	\$1,291	\$258	\$0	\$232	\$1,781	\$4
11.3	Switchgear & Motor Control	\$0	\$659	\$220	\$172	\$1,051	\$210	\$0	\$189	\$1,451	\$3
11.4	Conduit & Cable Tray	\$0	\$266	\$481	\$375	\$1,121	\$224	\$0	\$202	\$1,548	\$3
11.5	Wire & Cable	\$0	\$477	\$345	\$269	\$1,092	\$218	\$0	\$197	\$1,507	\$3

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case:		2		– Steam Methane Reforming w/ CCS				Estimate Type:		Conceptual	
Plant Size (kg H <sub>2</sub> /day):		483,007						Cost Base:		Dec 2018	
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost	
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]
11.6	Protective Equipment	\$0	\$444	\$769	\$600	\$1,813	\$363	\$0	\$326	\$2,501	\$5
11.7	Standby Equipment	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
11.8	Main Power Transformers	\$0	\$295	\$88	\$69	\$452	\$90	\$0	\$81	\$623	\$1
11.9	Electrical Foundations	\$0	\$7	\$22	\$17	\$46	\$9	\$0	\$11	\$66	\$0
	<b>Subtotal</b>	<b>\$0</b>	<b>\$3,270</b>	<b>\$2,020</b>	<b>\$1,575</b>	<b>\$6,865</b>	<b>\$1,373</b>	<b>\$0</b>	<b>\$1,239</b>	<b>\$9,477</b>	<b>\$20</b>
<b>12</b>		<b>Instrumentation &amp; Control</b>									
12.4	Other Major Component Control Equipment	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
12.5	Signal Processing Equipment	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
12.6	Control Boards, Panels & Racks	\$0	\$234	\$23	\$18	\$275	\$55	\$14	\$52	\$396	\$1
12.7	Distributed Control System Equipment	\$7,800	\$0	\$238	\$0	\$8,038	\$1,608	\$402	\$1,507	\$11,555	\$24
12.8	Instrument Wiring & Tubing	\$0	\$207	\$346	\$270	\$822	\$164	\$41	\$154	\$1,182	\$2
12.9	Other Instrumentation & Controls Equipment	\$0	\$1,771	\$317	\$247	\$2,336	\$467	\$117	\$438	\$3,358	\$7
	<b>Subtotal</b>	<b>\$7,800</b>	<b>\$2,212</b>	<b>\$925</b>	<b>\$535</b>	<b>\$11,472</b>	<b>\$2,294</b>	<b>\$574</b>	<b>\$2,151</b>	<b>\$16,491</b>	<b>\$34</b>
<b>13</b>		<b>Improvements to Site</b>									
13.1	Site Preparation	\$0	\$525	\$11,143	\$0	\$11,667	\$2,333	\$0	\$2,800	\$16,801	\$35
13.2	Site Improvements	\$0	\$307	\$1,303	\$1,016	\$2,627	\$525	\$0	\$630	\$3,783	\$8
13.3	Site Facilities	\$1,620	\$0	\$1,700	\$0	\$3,320	\$664	\$0	\$797	\$4,780	\$10
	<b>Subtotal</b>	<b>\$1,620</b>	<b>\$832</b>	<b>\$14,146</b>	<b>\$1,016</b>	<b>\$17,614</b>	<b>\$3,523</b>	<b>\$0</b>	<b>\$4,227</b>	<b>\$25,364</b>	<b>\$53</b>
<b>14</b>		<b>Buildings &amp; Structures</b>									
14.2	Interconnecting Pipe	\$0	\$656	\$1,558	\$1,215	\$3,430	\$686	\$0	\$617	\$4,734	\$10
14.4	Administration Building	\$0	\$333	\$226	\$0	\$559	\$112	\$0	\$101	\$771	\$2
14.5	Circulation Water Pumphouse	\$0	\$50	\$25	\$0	\$75	\$15	\$0	\$14	\$104	\$0
14.6	Water Treatment Buildings	\$0	\$298	\$271	\$0	\$569	\$114	\$0	\$102	\$785	\$2
14.7	Machine Shop	\$0	\$497	\$318	\$0	\$816	\$163	\$0	\$147	\$1,126	\$2
14.8	Warehouse	\$0	\$389	\$235	\$0	\$624	\$125	\$0	\$112	\$861	\$2
14.9	Structural Steel Pipe Racks	\$0	\$1,726	\$982	\$766	\$3,474	\$695	\$0	\$625	\$4,795	\$10
14.10	Waste Treating Building & Structures	\$0	\$655	\$1,170	\$0	\$1,826	\$365	\$0	\$329	\$2,519	\$5
	<b>Subtotal</b>	<b>\$0</b>	<b>\$4,606</b>	<b>\$4,785</b>	<b>\$1,981</b>	<b>\$11,373</b>	<b>\$2,275</b>	<b>\$0</b>	<b>\$2,047</b>	<b>\$15,694</b>	<b>\$32</b>
	<b>Total</b>	<b>\$320,374</b>	<b>\$26,569</b>	<b>\$69,748</b>	<b>\$21,958</b>	<b>\$438,648</b>	<b>\$87,730</b>	<b>\$25,237</b>	<b>\$121,673</b>	<b>\$673,289</b>	<b>\$1,394</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 3-32. Case 2 owner's costs**

Description	\$/1,000	\$/[kg H <sub>2</sub> /day]
<b>Pre-Production Costs</b>		
6 Months All Labor	\$4,934	\$10
1 Month Maintenance Materials	\$711	\$1
1 Month Non-Fuel Consumables	\$2,838	\$6
1 Month Waste Disposal	\$7	\$0
25% of 1 Months Fuel Cost at 100% CF	\$3,018	\$6
2% of TPC	\$13,466	\$28
<b>Total</b>	<b>\$24,972</b>	<b>\$52</b>
<b>Inventory Capital</b>		
60-day supply of fuel and consumables at 100% CF	\$1,191	\$2
0.5% of TPC (spare parts)	\$3,366	\$7
<b>Total</b>	<b>\$4,558</b>	<b>\$9</b>
<b>Other Costs</b>		
Initial Cost for Catalyst and Chemicals	\$15,867	\$33
Land	\$300	\$1
Other Owner's Costs	\$100,993	\$209
Financing Costs	\$18,179	\$38
<b>Total Overnight Costs (TOC)</b>	<b>\$838,157</b>	<b>\$1,735</b>
TASC Multiplier (IOU, 35 year)	1.070	
<b>Total As-Spent Cost (TASC)</b>	<b>\$896,662</b>	<b>\$1,856</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 3-33. Case 2 initial and annual operating and maintenance costs**

Case:	2 – Steam Methane Reforming w/ CCS			Cost Base:	Dec 2018	
Plant Size (kg H <sub>2</sub> /day):	483,007			Capacity Factor (%):	90	
<b>Operating &amp; Maintenance Labor</b>						
<b>Operating Labor</b>				<b>Operating Labor Requirements per Shift</b>		
Operating Labor Rate (base):		38.50	\$/hour	Skilled Operator:	1.0	
Operating Labor Burden:		30.00	% of base	Operator:	3.3	
Labor O-H Charge Rate:		25.00	% of labor	Foreman:	1.0	
				Lab Techs, etc.:	1.0	
				<b>Total:</b>	<b>6.3</b>	
<b>Fixed Operating Costs</b>						
					<b>Annual Cost</b>	
					(\$)	(\$/[kg H <sub>2</sub> /day])
Annual Operating Labor:					\$2,776,628	\$5.749
Maintenance Labor:					\$5,116,993	\$10.594
Administrative & Support Labor:					\$1,973,405	\$4.086
Property Taxes and Insurance:					\$13,465,770	\$27.879
<b>Total:</b>					<b>\$23,332,796</b>	<b>\$48.307</b>
<b>Variable Operating Costs</b>						
					(\$)	(\$/kg H <sub>2</sub> )
Maintenance Material:					\$7,675,489	\$0.05
<b>Consumables</b>						
	<b>Initial Fill</b>	<b>Per Day</b>	<b>Per Unit</b>	<b>Initial Fill</b>		
Water (gal/1000):	0	1,963	\$1.90	\$0	\$1,225,337	\$0.00772
Makeup and Wastewater Treatment Chemicals (ton):	0	5.8	\$550.00	\$0	\$1,056,610	\$0.00666
Zinc Oxide Sulfur Guard Catalyst (ft <sup>3</sup> ):	705	0.5	\$600.00	\$423,000	\$95,175	\$0.00060
Prereformer Catalyst (ft <sup>3</sup> ):	818	0.6	\$1,250.00	\$1,022,500	\$230,063	\$0.00145
Primary Reformer Catalyst (ft <sup>3</sup> ):	3160	1.7	\$525.00	\$1,659,000	\$298,620	\$0.00188
Water Gas Shift Catalyst (ft <sup>3</sup> ):	13983	9.6	\$480.00	\$6,711,929	\$1,510,184	\$0.00952
Methyl Diethanolamine Solution (gal):	392963	163	\$2.80	\$1,100,298	\$149,834	\$0.00094
Post-Combustion CO <sub>2</sub> Capture System <sup>Δ</sup> :	Proprietary				\$2,364,483	\$0.01490
PSA Unit Adsorbent (ft <sup>3</sup> ):	33000	4.5	\$150.00	\$4,950,000	\$222,750	\$0.00140
Triethylene Glycol (gal):	w/equip.	226	\$6.80	\$0	\$504,574	\$0.00318
Electricity (MWh):	0	976	\$71.70	\$0	\$22,990,051	\$0.14489
<b>Subtotal:</b>				<b>\$15,866,727</b>	<b>\$30,647,681</b>	<b>\$0.19316</b>
<b>Waste Disposal</b>						
Zinc Oxide Sulfur Guard Catalyst (ft <sup>3</sup> ):	0	0.5	\$40.00	\$0	\$6,345	\$0.00004
Prereformer Catalyst (ft <sup>3</sup> ):	0	0.6	\$0.00	\$0	\$0	\$0.00000
Primary Reformer Catalyst (ft <sup>3</sup> ):	0	1.7	\$0.00	\$0	\$0	\$0.00000
Water Gas Shift Catalyst (ft <sup>3</sup> ):	0	9.6	\$2.50	\$0	\$7,866	\$0.00005
Methyl Diethanolamine Solution (gal):	0	163	\$0.35	\$0	\$18,729	\$0.00012
PSA Unit Adsorbent (ft <sup>3</sup> ):	0	4.5	\$1.50	\$0	\$2,228	\$0.00001
Triethylene Glycol (gal):	0	226	\$0.35	\$0	\$25,971	\$0.00016
Amine Purification Unit Waste (ton):	0	0.8	\$38.00	\$0	\$10,388	\$0.00007
Thermal Reclaimer Unit Waste (ton):	0	0.07	\$38.00	\$0	\$923	\$0.00001
<b>Subtotal:</b>				<b>\$0</b>	<b>\$72,448</b>	<b>\$0.00046</b>

## COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case:	2 – Steam Methane Reforming w/ CCS			Cost Base:	Dec 2018	
Plant Size (kg H <sub>2</sub> /day):	483,007			Capacity Factor (%):	90	
<b>By-Products</b>						
					(\$)	(\$/kg H <sub>2</sub> )
Steam (ton):	0	0	\$0	\$0	\$0	\$0.00000
Electricity (MWh):	0	0	\$71.70	\$0	\$0	\$0.00000
<b>Subtotal:</b>				<b>\$0</b>	<b>\$0</b>	<b>\$0.00000</b>
<b>Variable Operating Costs Total:</b>				<b>\$15,866,727</b>	<b>\$38,395,618</b>	<b>\$0.24199</b>
<b>Fuel Cost</b>						
Natural Gas (MMBtu):	0	89,780	\$4.42	\$0	\$130,363,541	\$0.82161
<b>Total:</b>				<b>\$0</b>	<b>\$130,363,541</b>	<b>\$0.82161</b>

<sup>A</sup>Post-combustion CO<sub>2</sub> capture system chemicals includes ion exchange resin, NaOH, and Cansolv solvent.

**Exhibit 3-34. Case 2 LCOH breakdown**


Component	Value, \$/kg H <sub>2</sub>	Percentage
Capital	0.33	20%
Fixed	0.15	9%
Variable	0.24	15%
Fuel	0.82	50%
<b>Total (Excluding T&amp;S)</b>	<b>1.54</b>	<b>N/A</b>
CO <sub>2</sub> T&S	0.10	6%
<b>Total (Including T&amp;S)</b>	<b>1.64</b>	<b>N/A</b>

### 3.12 CASE 3 – AUTOTHERMAL REFORMING PLANT WITH CO<sub>2</sub> CAPTURE PROCESS DESCRIPTION

This section contains an evaluation of a plant design for Case 3, which is based on a natural gas autothermal reforming plant with CO<sub>2</sub> capture. The system descriptions follow the BFD provided in Exhibit 3-35 with the associated stream tables that show process data provided in Exhibit 3-36.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 3-35. Case 3 block flow diagram, autothermal reforming plant with CO<sub>2</sub> capture**



COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 3-36. Case 3 stream table, autothermal reforming plant with capture**

	1	2	3	4	5	6	7	8	9	10	11
V-L Mole Fraction											
Ar	0.0092	0.0024	0.0343	0.0000	0.0000	0.0000	0.0000	0.0051	0.0051	0.0051	0.0071
CH <sub>4</sub>	0.0000	0.0000	0.0000	0.9310	0.9310	0.0000	0.3603	0.0007	0.0007	0.0007	0.0010
CH <sub>4</sub> S	0.0000	0.0000	0.0000	0.0000 <sup>A</sup>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
C <sub>2</sub> H <sub>6</sub>	0.0000	0.0000	0.0000	0.0320	0.0320	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
C <sub>3</sub> H <sub>8</sub>	0.0000	0.0000	0.0000	0.0070	0.0070	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
C <sub>4</sub> H <sub>10</sub>	0.0000	0.0000	0.0000	0.0040	0.0040	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
CO	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0002	0.1385	0.1385	0.0039	0.0055
CO <sub>2</sub>	0.0003	0.0004	0.0000	0.0100	0.0100	0.0000	0.0210	0.0811	0.0811	0.2157	0.2111
H <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0486	0.4342	0.4342	0.5689	0.5749
H <sub>2</sub> O	0.0099	0.0086	0.0000	0.0000	0.0000	1.0000	0.5640	0.3345	0.3345	0.1999	0.1925
N <sub>2</sub>	0.7732	0.9850	0.0157	0.0160	0.0160	0.0000	0.0059	0.0057	0.0057	0.0057	0.0080
O <sub>2</sub>	0.2074	0.0035	0.9501	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	18,428	14,401	3,969	5,594	5,594	9,150	15,279	26,451	26,451	26,451	27,467
V-L Flowrate (kg/hr)	531,787	402,901	127,850	96,930	96,929	164,844	261,772	389,623	389,623	389,623	400,813
Solids Flowrate (kg/hr)	0	0	0	0	0	0	0	0	0	0	0
Temperature (°C)	15	21	27	15	370	399	407	1,093	204	38	38
Pressure (MPa, abs)	0.10	0.45	3.31	3.10	3.00	3.10	2.90	2.83	2.80	2.45	2.45
Steam Table Enthalpy (kJ/kg) <sup>B</sup>	30.23	28.12	14.67	-6.77	969.07	3,226.40	2,378.90	3,617.35	1,446.86	78.31	78.80
AspenPlus Enthalpy (kJ/kg) <sup>C</sup>	-97.58	-92.37	-7.83	-4,516.00	-3,540.22	-12,753.90	-9,165.98	-6,160.81	-8,331.31	-9,664.72	-9,497.97
Density (kg/m <sup>3</sup> )	1.2	5.2	43.9	24.4	9.7	10.4	8.9	3.7	10.5	17.4	17.1
V-L Molecular Weight	28.857	27.976	32.209	17.328	17.328	18.015	17.133	14.730	14.730	14.730	14.593
V-L Flowrate (lb <sub>mol</sub> /hr)	40,628	31,750	8,751	12,333	12,332	20,173	33,685	58,314	58,314	58,314	60,554
V-L Flowrate (lb/hr)	1,172,390	888,245	281,862	213,694	213,691	363,418	577,109	858,971	858,971	858,971	883,642
Solids Flowrate (lb/hr)	0	0	0	0	0	0	0	0	0	0	0
Temperature (°F)	59	70	80	59	698	750	765	2,000	400	100	100
Pressure (psia)	14.7	65.0	480.0	450.0	435.3	450.0	421.0	411.0	406.0	356.0	356.0
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	13.0	12.1	6.3	-2.9	416.6	1,387.1	1,022.7	1,555.2	622.0	33.7	33.9
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	-42.0	-39.7	-3.4	-1,941.5	-1,522.0	-5,483.2	-3,940.7	-2,648.7	-3,581.8	-4,155.1	-4,083.4
Density (lb/ft <sup>3</sup> )	0.076	0.322	2.743	1.525	0.605	0.652	0.558	0.228	0.656	1.086	1.066

<sup>A</sup>Natural gas entering battery limits contains 5.74 ppm of the mercaptan additive methanethiol (CH<sub>4</sub>S)

<sup>B</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>C</sup>AspenPlus thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 3-36. Case 3 stream table, autothermal reforming plant with capture (continued)**

	12	13	14	15	16	17	18	19	20	21	22
V-L Mole Fraction											
Ar	0.0000	0.0000	0.0116	0.0007	0.0007	0.0569	0.0569	0.0569	0.0569	0.0092	0.0278
CH <sub>4</sub>	0.0000	0.0000	0.0016	0.0000	0.0000	0.0082	0.0082	0.0082	0.0082	0.0000	0.0000
CH <sub>4</sub> S	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
C <sub>2</sub> H <sub>6</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
C <sub>3</sub> H <sub>8</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
C <sub>4</sub> H <sub>10</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
CO	0.0000	0.0000	0.0091	0.0000	0.0000	0.0466	0.0466	0.0466	0.0466	0.0000	0.0000
CO <sub>2</sub>	0.9811	0.9995	0.0174	0.0000	0.0000	0.0895	0.0895	0.0895	0.0895	0.0003	0.0525
H <sub>2</sub>	0.0001	0.0000	0.9471	0.9991	0.9991	0.7313	0.7313	0.7313	0.7313	0.0000	0.0000
H <sub>2</sub> O	0.0188	0.0005	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0099	0.2785
N <sub>2</sub>	0.0000	0.0000	0.0132	0.0001	0.0001	0.0674	0.0674	0.0674	0.0674	0.7732	0.6265
O <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.2074	0.0147
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	5,614	5,510	16,671	13,433	13,433	3,238	1,016	1,016	2,222	4,780	6,138
V-L Flowrate (kg/hr)	244,297	242,411	63,164	27,500	27,500	35,664	11,190	11,191	24,473	137,947	162,420
Solids Flowrate (kg/hr)	0	0	0	0	0	0	0	0	0	0	0
Temperature (°C)	49	30	38	38	30	38	38	38	38	15	121
Pressure (MPa, abs)	0.14	15.27	2.35	2.28	6.48	0.14	0.14	2.76	0.14	0.10	0.10
Steam Table Enthalpy (kJ/kg) <sup>A</sup>	61.61	-231.09	289.28	537.24	440.76	99.65	99.65	96.04	99.65	30.23	614.39
AspenPlus Enthalpy (kJ/kg) <sup>B</sup>	-8,956.76	-9,194.65	-2,002.40	186.44	89.95	-3,688.61	-3,688.61	-3,692.21	-3,688.61	-97.58	-3,215.03
Density (kg/m <sup>3</sup> )	2.3	630.1	3.4	1.8	5.1	0.6	0.6	11.7	0.6	1.2	0.8
V-L Molecular Weight	43.516	43.997	3.789	2.047	2.047	11.013	11.013	11.013	11.013	28.857	26.460
V-L Flowrate (lb <sub>mol</sub> /hr)	12,377	12,147	36,754	29,614	29,614	7,140	2,240	2,240	4,899	10,539	13,533
V-L Flowrate (lb/hr)	538,583	534,424	139,252	60,627	60,627	78,625	24,671	24,671	53,954	304,121	358,075
Solids Flowrate (lb/hr)	0	0	0	0	0	0	0	0	0	0	0
Temperature (°F)	120	86	100	100	86	100	100	100	100	59	250
Pressure (psia)	20.0	2,214.7	341.0	331.0	939.7	20.0	20.0	400.0	20.0	14.7	14.7
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	26.5	-99.4	124.4	231.0	189.5	42.8	42.8	41.3	42.8	13.0	264.1
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	-3,850.7	-3,953.0	-860.9	80.2	38.7	-1,585.8	-1,585.8	-1,587.4	-1,585.8	-42.0	-1,382.2
Density (lb/ft <sup>3</sup> )	0.141	39.338	0.213	0.112	0.318	0.037	0.037	0.728	0.037	0.076	0.051

<sup>A</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>B</sup>AspenPlus thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm


### 3.12.1 Air Separation Unit

An elevated pressure air separation design producing a 95 percent by volume (vol%) O<sub>2</sub> product at 3.3 MPa (480 psia) has been considered for Case 3. This pressure is needed to match the operating pressure of the ATR reactor and results in a main air compressor (MAC) discharge pressure of 1.6 MPa (236 psia). This is much greater than the MAC in a traditional ASU plant operating at about 0.7 MPa (105 psia). [61] The ASU power requirement for this Case 3 is 420 kWh/ton-O<sub>2</sub> (including the MAC, booster compressor, and auxiliaries, on a 100 percent pure O<sub>2</sub> basis). The amount of oxygen that is supplied to the ATR depends on the heating value of the fuel gas. Enough O<sub>2</sub> must be supplied to combust enough of the fuel gas to reach the reformer operating temperature of 2,000 °F. The residual nitrogen (N<sub>2</sub>) that is produced is vented.

#### 3.12.1.1 Air Separation Plant Process Description

The air separation plant is designed to produce 95 vol% O<sub>2</sub> for use in the ATR. The ASU is a single train design. The air compressor is powered by an electric motor. A process schematic of a typical elevated pressure ASU, which is based on vendor discussions and quotes, is shown in Exhibit 3-37. [62]

*Exhibit 3-37. Typical ASU process schematic*



The air feed to the ASU is supplied from the stand-alone MAC. Air to the compressor is first filtered in a suction filter upstream of the compressor. This air filter removes particulates, which

tend to cause compressor wheel erosion and foul intercoolers. The filtered air is then compressed in the centrifugal compressor, with intercooling and aftercooling.

Air from the MAC is cooled in a two-stage direct contact cooler. Cooling for the first stage is provided with plant-cooling water. Cooling for the second stage is provided by chilled water generated by contact with cold N<sub>2</sub> exiting the cold box.

Chilled air is fed to a molecular sieve adsorber pre-purifier system. The adsorbent removes water, CO<sub>2</sub>, and C<sub>4</sub>+ saturated hydrocarbons in the air. After passing through the adsorption beds, the air is filtered with a dust filter to remove any adsorbent fines that may be present. Downstream of the dust filter a small stream of air is withdrawn to supply the instrument air requirements of the ASU.

Regeneration of the adsorbent in the pre-purifiers is accomplished by passing a hot N<sub>2</sub> stream through the off-stream bed(s) in a direction counter-current to the normal airflow. The N<sub>2</sub> is heated against extraction steam (1.7 MPa [250 psia]) in a shell and tube heat exchanger (HX). [62] The regeneration N<sub>2</sub> drives off the adsorbed contaminants. Following regeneration, the heated bed is cooled to near normal operating temperature by passing a cool N<sub>2</sub> stream through the adsorbent beds. The bed is re-pressurized with air and placed on stream so that the current on-stream bed(s) can be regenerated.

The air from the pre-purifier is then split into three streams. About 70 percent of the air is fed directly to the cold box. About 25 percent of the air is compressed in an air booster compressor. This boosted air is then cooled in an aftercooler against cooling water. The remaining five percent of the air is fed to a turbine-driven, single-stage, centrifugal booster compressor. This stream is cooled in a shell and tube aftercooler against cooling water before it is fed to the cold box. [62]


All three air feeds are cooled in the cold box to cryogenic temperatures against returning product O<sub>2</sub> and N<sub>2</sub> streams in plate-and-fin HXs. The large air stream is fed directly to the first distillation column to begin the separation process. The second largest air stream is liquefied against boiling liquid O<sub>2</sub> before it is fed to the distillation columns. The third, smallest air stream is fed to the cryogenic expander to produce refrigeration to sustain the cryogenic separation process.

Inside the cold box the air is separated into O<sub>2</sub> and N<sub>2</sub> products. The O<sub>2</sub> product is withdrawn from the distillation columns as a liquid and is pressurized by a cryogenic pump. The pressurized liquid O<sub>2</sub> is then vaporized against the high-pressure (HP) air feed before being warmed to ambient temperature. The HP liquid O<sub>2</sub> exits the cold box and is pumped to the desired pressure before being heated to 27 °C (80 °F) and fed to the autothermal reformer. N<sub>2</sub> is produced from the cold box at two pressure levels; however, since N<sub>2</sub> is not needed elsewhere in the plant, it is vented to the atmosphere.


### **3.12.2 Autothermal Reformer**

In Case 3, the partially reformed gas from the prereformer enters an autothermal reformer. The ATR is a refractory lined vessel consisting of a partial oxidation section and a fixed bed catalytic

reforming section. The feed gas is mixed with oxygen from the ASU and partially oxidized via the following reaction:



This exothermic reaction is used to generate the heat needed to drive the following endothermic methane reforming reaction:



Unlike the steam methane reformer configuration, where reaction heat is generated outside of the catalyst tubes, both the heat-generating reactions and methane reforming reaction occurs within the single autothermal reformer unit. No supplemental natural gas is required in this configuration.

The process employs a molar steam-to-carbon ratio of 1.57 and oxygen-to-carbon ratio of 1.29 entering the reactor. Raw syngas exits the ATR at a temperature of 1,090 °C (2,000 °F) and a pressure of 2.8 MPa (411 psia). The methane conversion of the process is greater than 99 percent.

Leaving the reformer, the syngas passes through a syngas cooler which is used to generate LP steam before being fed into the series of WGS reactors.

### 3.12.3 Acid Gas Removal

The autothermal reforming plant with capture (Case 3) uses an MDEA unit for pre-combustion capture. There are no differences between the MDEA unit employed from Case 3 and the one from Case 2. In the ATR plant, there is no need for a post-combustion Cansolv system as in steam methane reforming plant because the volumetric flow of low-pressure flue gas emitted from the plant is significantly reduced due to the absence of an externally-heated reactor. This fundamental difference in technologies enables high levels of CO<sub>2</sub> capture exclusively through separation of CO<sub>2</sub> from the high-pressure syngas.

### 3.12.4 CO<sub>2</sub> Compression and Drying System

No differences from Case 2.

### 3.12.5 Fired Heater

The autothermal reforming configuration (Case 3) employs a fired heater for heat recovery. The off-gas from the PSA is combined with air and combusted in the fired heater to take advantage of the waste heat available. The hot flue gas is cooled by providing heat to various sections of the plant, improving plant efficiency. This section generates steam for the reforming reactions, provides feedwater preheating, and provides preheating of the natural gas feed prior to the sulfur guard and prereformer.

### 3.13 CASE 3 – PERFORMANCE RESULTS

Overall performance for the entire plant is summarized in Exhibit 3-38. The plant produces 27,500 kg/hr (60,627 lb/hr) of hydrogen at an effective thermal efficiency of 67.9 percent (HHV basis). The total auxiliary load for the plant is 110 MWe.

Exhibit 3-39 provides a detailed breakdown of the auxiliary power requirements. The hydrogen compressor accounts for about 13 percent of the total auxiliary load. About 25 percent of the auxiliary load is from the CO<sub>2</sub> capture, removal, and compression systems. The air separation unit power requirements make up about 51 percent of the auxiliary load. The BFW pumps and cooling water system, including the circulating water pumps and cooling tower fan, accounts for approximately 5 percent of the auxiliary load. All other systems together constitute the remaining 6 percent of the auxiliary load.

*Exhibit 3-38. Case 3 plant performance summary*

Performance Summary	
Steam Turbine Power, MWe	0
<b>Total Gross Power, MWe</b>	<b>0</b>
Air Separation Unit Main Air Compressor, kWe	51,070
Air Separation Unit Booster Compressor, kWe	4,020
CO <sub>2</sub> Capture/Removal Auxiliaries, kWe	6,680
CO <sub>2</sub> Compression, kWe	20,810
Balance of Plant, kWe	27,600
<b>Total Auxiliaries, MWe</b>	<b>110</b>
<b>Net Power, MWe</b>	<b>-110</b>
<b>Hydrogen Production, kg/hr (lb/hr)</b>	<b>27,500 (60,627)</b>
<b>CO<sub>2</sub> Capture, %</b>	<b>94.5%</b>
HHV Effective Thermal Efficiency <sup>A</sup> , %	67.9%
HHV Cold Gas Efficiency <sup>B</sup> , %	75.7%
LHV Effective Thermal Efficiency <sup>A</sup> , %	62.3%
LHV Cold Gas Efficiency <sup>B</sup> , %	70.9%
AGR Cooling Duty, GJ/hr (MMBtu/hr)	1,044 (989)
Natural Gas Feed Flow, kg/hr (lb/hr)	96,930 (213,694)
HHV Thermal Input, kWt	1,408,040
LHV Thermal Input, kWt	1,270,895
Raw Water Withdrawal, m <sup>3</sup> /min (gpm)	14.1 (3,720)
Raw Water Consumption, m <sup>3</sup> /min (gpm)	11.1 (2,945)

<sup>A</sup>ETE = (Hydrogen Heating Value + Net Power) / Fuel Heating Value

<sup>B</sup>CGE = Hydrogen Heating Value / Fuel Heating Value

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 3-39. Case 3 plant power summary**

Power Summary	
Steam Turbine Power, MWe	0
<b>Total Gross Power, MWe</b>	<b>0</b>
Auxiliary Load Summary	
Air Blower, kWe	390
Air Separation Unit Auxiliaries, kWe	780
Air Separation Unit Main Air Compressor, kWe	51,070
Air Separation Unit Booster Compressor, kWe	4,020
Circulating Water Pumps, kWe	3,310
Cooling Tower Fans, kWe	1,710
CO <sub>2</sub> Capture/Removal Auxiliaries, kWe	6,680
CO <sub>2</sub> Compression, kWe	20,810
Feedwater Pumps, kWe	120
Fuel Gas Recycle Compressor, kWe	3,530
Ground Water Pumps, kWe	340
Hydrogen Compressor, kWe	14,070
Miscellaneous Balance of Plant <sup>A</sup> , kWe	2,550
Oxygen Pump, kWe	150
Transformer Losses, kWe	650
<b>Total Auxiliaries, MWe</b>	<b>110</b>
<b>Net Power, MWe</b>	<b>-110</b>

<sup>A</sup>Includes plant control systems, lighting, HVAC, and miscellaneous low voltage loads

### 3.13.1 Environmental Performance

The environmental targets for emissions of Hg, NO<sub>x</sub>, SO<sub>2</sub>, and PM were presented in Section 2.6. A summary of the plant air emissions for Case 3 is presented in Exhibit 3-40.

**Exhibit 3-40. Case 3 air emissions**

	kg/GJ (lb/MMBtu)	Tonne/year (ton/year) <sup>A</sup>	lb/lb H <sub>2</sub>
SO <sub>2</sub>	0.000 (0.000)	0 (0)	0.000
NO <sub>x</sub>	0.000 (0.000)	8 (9)	0.000
Particulate	0.000 (0.000)	0 (0)	0.000
Hg	0.00E+0 (0.00E+0)	0.000 (0.000)	0.00E+0
CO	0.000 (0.000)	0 (0)	0.000
CO <sub>2</sub> <sup>B</sup>	3 (7)	112,140 (123,614)	0.5
CO <sub>2</sub> e <sup>C</sup>	35 (82)	1,404,284 (1,547,959)	5.6

<sup>A</sup>Calculations based on a 90 percent capacity factor

<sup>B</sup>Plant stack emissions

<sup>C</sup>Life cycle emissions

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

The natural gas feed contains 5.74 ppmv of the mercaptan additive methanethiol (CH<sub>4</sub>S). A zinc oxide sulfur guard bed was used to remove 98 percent of the sulfur in the feed, resulting in a maximum sulfur content of 0.1 ppm post-sulfur guard bed.

NO<sub>x</sub> emissions are limited by the use of low-NO<sub>x</sub> burners in the design. The production of PM is a result of system inefficiencies and is not produced or emitted in any significant amount. The pipeline natural gas was assumed to contain no Hg or HCl, resulting in zero emissions.

Ninety five percent of the CO<sub>2</sub> from the syngas is captured in the pre-combustion AGR system and compressed for storage. Additionally, an LCA was conducted to determine the total GWP of the plant.

The carbon balance for the plant is shown in Exhibit 3-41. The carbon input to the plant consists of carbon in the air in addition to carbon in the natural gas. Carbon leaves the plant as a small portion of the hydrogen product, the captured CO<sub>2</sub> product, the carbon in the CO<sub>2</sub> dryer vent and knockout, the carbon in the ASU vent, and the CO<sub>2</sub> in the stack gas. The overall carbon capture efficiency is 94.5 percent, defined as one minus the mass of carbon in the stack gas and CO<sub>2</sub> dryer vent relative to the total carbon, represented by the following equation:

$$\text{Carbon Capture Efficiency (\%)} = \left( 1 - \left( \frac{\text{Carbon in Stack and CO}_2 \text{ Dryer Vent}}{\text{Total Carbon In}} \right) \right) * 100\%$$

**Exhibit 3-41. Case 3 carbon balance**

Carbon In		Carbon Out	
	kg/hr (lb/hr)		kg/hr (lb/hr)
Natural Gas	70,011 (154,347)	Stack Gas	3,874 (8,541)
Air (CO <sub>2</sub> )	91 (201)	ASU Vent	72 (159)
		Hydrogen Product	3 (6)
		Sulfur Guard Bed	0 (1)
		CO <sub>2</sub> Product	66,144 (145,823)
		CO <sub>2</sub> Dryer Vent	8.0 (18)
		CO <sub>2</sub> Knockout	0.2 (0.3)
<b>Total</b>	<b>70,102 (154,548)</b>	<b>Total</b>	<b>70,102 (154,548)</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Exhibit 3-42 shows the sulfur balance for the plant. Sulfur input comes solely from the mercaptan additive in the natural gas. Sulfur output includes sulfur recovered in the sulfur guard bed and small amounts of sulfur in the stack gas.

**Exhibit 3-42. Case 3 sulfur balance**

Sulfur In		Sulfur Out	
	kg/hr (lb/hr)		kg/hr (lb/hr)
Natural Gas	1 (2)	Stack Gas	0 (0)
		Sulfur Guard Bed	1 (2)
<b>Total</b>	<b>1 (2)</b>	<b>Total</b>	<b>1 (2)</b>

Exhibit 3-43 shows the overall water balance for the plant.

**Exhibit 3-43. Case 3 water balance**

Water Use	Water Demand	Internal Recycle	Raw Water Withdrawal	Process Water Discharge	Raw Water Consumption
	m <sup>3</sup> /min (gpm)				
CO <sub>2</sub> Drying	–	–	–	0.0 (1.1)	0.0 (-1.1)
CO <sub>2</sub> Capture System Makeup	–	–	–	–	–
CO <sub>2</sub> Capture Recovery	–	–	–	–	–
CO <sub>2</sub> Compression Recovery	–	–	–	0.0 (7.2)	0.0 (-7.2)
<b>Steam Generation</b>	<b>2.8 (727)</b>	<b>1.6 (412)</b>	<b>1.2 (315)</b>	–	<b>1.2 (315)</b>
Export Steam	–	–	–	–	–
ATR Steam	2.8 (727)	–	2.8 (727)	–	2.8 (727)
Syngas Condensate	–	1.6 (412)	-1.6 (-412)	–	-1.6 (-412)
<b>Cooling Tower</b>	<b>13 (3,409)</b>	<b>0.0 (4.6)</b>	<b>13 (3,404)</b>	<b>2.9 (767)</b>	<b>10.0 (2,638)</b>
ASU Knockout	–	0.0 (4.6)	0.0 (-4.6)	–	0.0 (-4.6)
<b>Total</b>	<b>16 (4,136)</b>	<b>1.6 (416)</b>	<b>14 (3,720)</b>	<b>2.9 (775)</b>	<b>11 (2,945)</b>

An overall plant energy balance is provided in tabular form in Exhibit 3-44.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 3-44. Case 3 overall energy balance (0 °C [32 °F] reference)**

	HHV	Sensible + Latent	Power	Total
<b>Heat In, GJ/hr (MMBtu/hr)</b>				
Natural Gas	5,069 (4,804)	3.4 (3.2)	–	5,072 (4,808)
Air	–	20 (19)	–	20 (19)
Raw Water Makeup	–	53 (50)	–	53 (50)
Auxiliary Power	–	–	397 (376)	397 (376)
<b>Total</b>	<b>5,069 (4,804)</b>	<b>77 (73)</b>	<b>397 (376)</b>	<b>5,542 (5,253)</b>
<b>Heat Out, GJ/hr (MMBtu/hr)</b>				
Hydrogen Product	3,836 (3,636)	12 (11)	–	3,848 (3,647)
Stack Gas	–	111 (105)	–	111 (105)
Sulfur	–	0.0 (0.0)	–	0.0 (0.0)
Motor Losses and Design Allowances	–	–	12 (11)	12 (11)
Cooling Tower Load <sup>A</sup>	–	1,685 (1,597)	–	1,685 (1,597)
Cooling Tower Blowdown	–	22 (20)	–	22 (20)
CO <sub>2</sub> Product Stream	–	-56 (-53)	–	-56 (-53)
Power	–	–	0.0 (0.0)	0.0 (0.0)
<b>Total</b>	<b>3,836 (3,636)</b>	<b>1,774 (1,681)</b>	<b>12 (11)</b>	<b>5,622 (5,329)</b>
Unaccounted Energy <sup>B</sup>	–	-80 (-76)	–	-80 (-76)


<sup>A</sup>Includes AGR, compression, and last stage syngas cooling loads

<sup>B</sup>By difference

### 3.13.2 Energy and Mass Balance Diagrams

The energy and mass balance diagram for Case 3 is shown in Exhibit 3-45.

Exhibit 3-45. Case 3 autothermal reforming plant with CO<sub>2</sub> capture energy and mass balance



This page intentionally left blank

### 3.14 CASE 3 – MAJOR EQUIPMENT LIST

Major equipment items for the autothermal reforming plant with CO<sub>2</sub> capture are shown in the following tables. In general, the design conditions include a 10 percent design allowance for flows and heat duties and a 21 percent design allowance for heads on pumps and fans.

#### Case 3 – Account 3: Feedwater and Miscellaneous Balance of Plant Systems

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	LP Feedwater Pumps	Horizontal centrifugal	3,910 lpm @ 4 m H <sub>2</sub> O (1,030 gpm @ 10 ft H <sub>2</sub> O)	2	1
2	MP Feedwater Pumps	Horizontal, split case, multi-stage, centrifugal	860 lpm @ 90 m H <sub>2</sub> O (230 gpm @ 290 ft H <sub>2</sub> O)	2	1
3	Water Makeup Pumps	Horizontal, split case, multi-stage, centrifugal	660 lpm @ 90 m H <sub>2</sub> O (170 gpm @ 290 ft H <sub>2</sub> O)	2	2
4	Auxiliary Boiler	Shop fabricated, water tube	18,000 kg/hr, 2.8 MPa, 343 °C (40,000 lb/hr, 400 psig, 650 °F)	1	0
5	Service Air Compressors	Flooded Screw	13 m <sup>3</sup> /min @ 0.7 MPa (450 scfm @ 100 psig)	2	1
6	Instrument Air Dryers	Duplex, regenerative	13 m <sup>3</sup> /min (450 scfm)	2	1
7	Engine-Driven Fire Pump	Vertical turbine, diesel engine	3,785 lpm @ 110 m H <sub>2</sub> O (1,000 gpm @ 350 ft H <sub>2</sub> O)	1	1
8	Fire Service Booster Pump	Two-stage horizontal centrifugal	2,650 lpm @ 80 m H <sub>2</sub> O (700 gpm @ 250 ft H <sub>2</sub> O)	1	1
9	Raw Water Pumps	Stainless steel, single suction	6,600 lpm @ 20 m H <sub>2</sub> O (1,700 gpm @ 60 ft H <sub>2</sub> O)	2	1
10	Filtered Water Pumps	Stainless steel, single suction	150 lpm @ 50 m H <sub>2</sub> O (40 gpm @ 160 ft H <sub>2</sub> O)	2	1
11	Filtered Water Tank	Vertical, cylindrical	145,000 liter (38,000 gal)	1	0
12	Makeup Water Demineralizer	Multi-media filter, cartridge filter, RO membrane assembly and electro-deionization unit	330 lpm (90 gpm)	1	0
13	Liquid Waste Treatment System	–	10 years, 24-hour storm	1	0
14	Gas Pipeline	Underground, coated carbon steel, wrapped cathodic protection	73 m <sup>3</sup> /min @ 3.1 MPa (2,570 acfm @ 450 psia) 39 cm (16 in) standard wall pipe	16 km (10 mile)	0
15	Gas Metering Station	–	73 m <sup>3</sup> /min (2,570 acfm)	1	0

#### Case 3 – Account 4: Reformer and Accessories

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Primary Reformer	ATR, fixed bed, catalytic	Syngas Production: 429,000 kg/hr @ 2.8 MPa, 1093 °C (945,000 lb/hr @ 411 psia, 2000 °F)	1	0
2	Sulfur Guard Bed	Fixed Bed, catalytic (ZnO)	Inlet: 107,000 kg/hr @ 3.0 MPa, 370 °C (235,000 lb/hr @ 441 psia, 698 °F)	1	0

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
3	Prereformer	Fixed Bed, catalytic	NG In: 107,000 kg/hr @ 2.9 MPa, 500 °C (235,000 lb/hr @ 427 psia, 932 °F) Steam In: 181,000 kg/hr @ 3.1 MPa, 399 °C (400,000 lb/hr @ 450 psia, 750 °F)	1	0
4	Syngas Coolers	Shell and tube heat exchanger	Syngas Cooler: 845 GJ/hr (802 MMBtu/hr) LP Steam Generator 1: 120 GJ/hr (114 MMBtu/hr) LP Steam Generator 2: 18 GJ/hr (17 MMBtu/hr) LT Heat Recovery Exchanger: 141 GJ/hr (134 MMBtu/hr) AGR Precooler: 240 GJ/hr (228 MMBtu/hr)	5	0
5	ASU Main Air Compressor	Centrifugal, multi-stage	8,000 m <sup>3</sup> /min @ 1.6 MPa (283,000 scfm @ 236 psia)	1	0
6	Cold Box	Vendor design	3,400 tonne/day (3,700 tpd) of 95% purity oxygen	1	0
7	Oxygen Pump	Centrifugal, multi-stage	2,000 m <sup>3</sup> /min (61,000 scfm) Suction – 1.0 MPa (130 psia) Discharge – 3.3 MPa (480 psia)	1	0

**Case 3 – Account 5: Flue Gas Cleanup**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	CO <sub>2</sub> Dryer	Triethylene glycol	Inlet: 79 m <sup>3</sup> /min @ 2.5 MPa (2,799 acfm @ 367 psia) Outlet: 2.4 MPa (350 psia) Water Recovered: 256 kg/hr (565 lb/hr)	1	0
2	CO <sub>2</sub> Compressor	Integrally geared, multi-stage centrifugal	9.0 m <sup>3</sup> /min @ 15.3 MPa, 85 °C (333 acfm @ 2,217 psia, 185 °F)	1	0
3	CO <sub>2</sub> Aftercooler	Shell and tube heat exchanger	Outlet: 15.3 MPa, 30 °C (2,215psia, 86 °F) Duty: 40 GJ/hr (38 MMBtu/hr)	1	0

**Case 3 – Account 6: Syngas Cleanup**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Recycle Compressor	Centrifugal	12,000 kg/hr (27,000 lb/hr) 2.8 MPa (400 psia)	1	1
2	Water Gas Shift Reactors	Fixed bed, catalytic	143,000 kg/hr (472,000 lb/hr) 204 °C (400 °F) 2.8 MPa (410 psia)	6	0
3	Acid Gas Removal Plant	MDEA	441,000 kg/hr (972,000 lb/hr) 38 °C (100 °F) 2.5 MPa (356 psia)	1	0

**Case 3 – Account 7: Hydrogen Production**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Pressure Swing Adsorber	Polybed Proprietary	Syngas: 63,164 kg/hr (139,252 lb/hr) 38 °C (100 °F) 2.4 MPa (341.0 psia) Hydrogen: 27,500 kg/hr (60,627 lb/hr) 38 °C (100 °F) 2.3 MPa (331.0 psia) Off Gas: 35,664 kg/hr (78,625 lb/hr) 38 °C (100 °F) 0.1 MPa (20.0 psia)	1	0
2	Hydrogen Compressor	Integrally geared, multi-stage centrifugal	99 m <sup>3</sup> /min @ 6.5 MPa (3,490 acfm @ 940 psia)	1	1

## COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

### Case 3 – Account 8: Fired Heater, Ductwork & Stack

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Fired Heater	Bottom-Fired, PSA off-gas	Fired Duty: 510 GJ/hr, (484 MMBtu/hr)	1	0

### Case 3 – Account 9: Cooling Water System

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Circulating Water Pumps	Vertical, wet pit	333,000 lpm @ 30 m (88,000 gpm @ 100 ft)	2	1
2	Cooling Tower	Evaporative, mechanical draft, multi-cell	11 °C (52 °F) wet bulb/ 16 °C (60 °F) CWT/27 °C (80 °F) HWT/ 1850 GJ/hr (1760 MMBtu/hr) heat duty	1	0

### Case 3 – Account 11: Accessory Electric Plant

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	High Voltage Auxiliary Transformer	Oil-filled	345 kV/13.8 kV, 12 MVA, 3-ph, 60 Hz	2	0
2	Medium Voltage Transformer	Oil-filled	18 kV/4.16 kV, 80 MVA, 3-ph, 60 Hz	1	1
3	Low Voltage Transformer	Dry ventilated	4.16 kV/480 V, 18 MVA, 3-ph, 60 Hz	1	1
4	Medium Voltage Switchgear	Metal clad	4.16 kV, 3-ph, 60 Hz	1	1
5	Low Voltage Switchgear	Metal enclosed	480 V, 3-ph, 60 Hz	1	1
6	Emergency Diesel Generator	Sized for emergency shutdown	750 kW, 480 V, 3-ph, 60 Hz	1	0

### Case 3 – Account 12: Instrumentation and Control

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	DCS – Main Control	Monitor/keyboard; Operator printer (laser color); Engineering printer (laser B&W)	Operator stations/printers and engineering stations/printers	1	0
2	DCS – Processor	Microprocessor with redundant input/output	N/A	1	0
3	DCS – Data Highway	Fiber optic	Fully redundant, 25% spare	1	0

## 3.15 CASE 3 – COST ESTIMATING

The cost estimating methodology was described previously in Section 2.11. Exhibit 3-46 shows a detailed breakdown of the capital costs; Exhibit 3-47 shows the owner’s costs, TOC, and TASC; Exhibit 3-48 shows the initial and annual O&M costs; and Exhibit 3-49 shows the LCOH breakdown.

The estimated TOC of the autothermal reforming plant with CO<sub>2</sub> capture is \$1,372/[kg H<sub>2</sub>/day]. Process contingency represents less than 1 percent of the TOC and project contingency represents 8.3 percent. The LCOH is \$1.59/kg H<sub>2</sub> with CO<sub>2</sub> T&S.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 3-46. Case 3 total plant cost details**

Case:		3		– Autothermal Reforming w/ CCS				Estimate Type:		Conceptual	
Plant Size (kg H <sub>2</sub> /day):		659,999						Cost Base:		Dec 2018	
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost	
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]
<b>3</b>		<b>Feedwater &amp; Miscellaneous BOP Systems</b>									
3.1	Feedwater System	\$82	\$311	\$476	\$372	\$1,241	\$248	\$0	\$223	\$1,713	\$3
3.2	Water Makeup & Pretreating	\$4,458	\$446	\$2,526	\$0	\$7,429	\$1,486	\$0	\$1,783	\$10,698	\$16
3.3	Other Feedwater Subsystems	\$1,108	\$363	\$345	\$0	\$1,816	\$363	\$0	\$327	\$2,507	\$4
3.4	Service Water Systems	\$1,353	\$2,582	\$8,362	\$0	\$12,297	\$2,459	\$0	\$2,951	\$17,708	\$27
3.5	Other Boiler Plant Systems	\$230	\$84	\$209	\$0	\$523	\$105	\$0	\$94	\$722	\$1
3.6	Natural Gas Pipeline and Start-Up System	\$9,304	\$400	\$300	\$0	\$10,005	\$2,001	\$0	\$1,801	\$13,807	\$21
3.7	Wastewater Treatment Equipment	\$5,620	\$0	\$3,444	\$0	\$9,064	\$1,813	\$0	\$2,175	\$13,052	\$20
3.9	Miscellaneous Plant Equipment	\$14,217	\$1,865	\$7,225	\$0	\$23,306	\$4,661	\$0	\$5,594	\$33,561	\$51
	<b>Subtotal</b>	<b>\$36,372</b>	<b>\$6,050</b>	<b>\$22,888</b>	<b>\$372</b>	<b>\$65,682</b>	<b>\$13,136</b>	<b>\$0</b>	<b>\$14,948</b>	<b>\$93,766</b>	<b>\$142</b>
<b>4</b>		<b>Reformer &amp; Accessories</b>									
4.1	Primary Reformers	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
4.2	Air Blower	\$162	\$115	\$160	\$125	\$562	\$112	\$0	\$101	\$776	\$1
4.3	Sulfur Guard Bed	\$271	\$317	\$460	\$359	\$1,407	\$281	\$0	\$253	\$1,941	\$3
4.4	Prereformer	\$1,511	\$359	\$549	\$428	\$2,847	\$569	\$0	\$854	\$4,271	\$6
4.5	Syngas Coolers	\$10,541	\$586	\$766	\$597	\$12,491	\$2,498	\$0	\$3,747	\$18,736	\$28
4.6	Air Separation Unit/Oxidant Compression	\$153,064	\$255	\$39,871	\$31,097	\$224,287	\$44,857	\$0	\$0	\$269,144	\$408
4.7	Steam Drum(s)	\$953	\$428	\$696	\$543	\$2,619	\$524	\$0	\$471	\$3,614	\$5
4.11	Autothermal Reformer	\$4,777	\$500	\$1,017	\$793	\$7,086	\$1,417	\$0	\$2,126	\$10,629	\$16
	<b>Subtotal</b>	<b>\$171,278</b>	<b>\$2,560</b>	<b>\$43,519</b>	<b>\$33,942</b>	<b>\$251,299</b>	<b>\$50,260</b>	<b>\$0</b>	<b>\$7,553</b>	<b>\$309,112</b>	<b>\$468</b>
<b>5</b>		<b>Flue Gas Cleanup</b>									
5.1	Cansolv Carbon Dioxide (CO <sub>2</sub> ) Removal System	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
5.4	Carbon Dioxide (CO <sub>2</sub> ) Compression & Drying	\$43,131	\$1,481	\$3,681	\$2,871	\$51,165	\$10,233	\$0	\$15,349	\$76,747	\$116
5.5	Carbon Dioxide (CO <sub>2</sub> ) Compressor Aftercooler	\$827	\$571	\$1,397	\$1,090	\$3,884	\$777	\$0	\$699	\$5,360	\$8
5.12	Gas Cleanup Foundations	w/ 5.4 & 5	w/ 5.4 & 5	w/ 5.4 & 5	w/ 5.4 & 5	\$0	\$0	\$0	\$0	\$0	\$0
	<b>Subtotal</b>	<b>\$43,958</b>	<b>\$2,052</b>	<b>\$5,078</b>	<b>\$3,961</b>	<b>\$55,049</b>	<b>\$11,010</b>	<b>\$0</b>	<b>\$16,049</b>	<b>\$82,108</b>	<b>\$124</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case: 3		– Autothermal Reforming w/ CCS					Estimate Type:		Conceptual		
Plant Size (kg H <sub>2</sub> /day): 659,999							Cost Base:		Dec 2018		
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost	
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]
<b>6</b>		<b>Syngas Cleanup</b>									
6.1	Recycle Compressor	\$7,936	\$189	\$450	\$351	\$8,925	\$1,785	\$0	\$2,678	\$13,388	\$20
6.2	Methyl Diethanolamine (MDEA) – Low Temperature Acid Gas Removal	\$23,443	\$0	\$674	\$526	\$24,642	\$4,928	\$0	\$5,914	\$35,485	\$54
6.7	Water Gas Shift (WGS) Reactors	\$2,187	\$2,070	\$3,155	\$2,460	\$9,872	\$1,974	\$0	\$2,369	\$14,216	\$22
6.12	Gas Cleanup Foundations	w/ 6.1,2,&7	w/6.1,2,&7	w/ 6.1,2,&7	w/ 6.1,2,&7	\$0	\$0	\$0	\$0	\$0	\$0
	<b>Subtotal</b>	<b>\$33,566</b>	<b>\$2,259</b>	<b>\$4,278</b>	<b>\$3,337</b>	<b>\$43,440</b>	<b>\$8,688</b>	<b>\$0</b>	<b>\$10,961</b>	<b>\$63,088</b>	<b>\$96</b>
<b>7</b>		<b>Hydrogen Production</b>									
7.1	Pressure Swing Adsorber	\$20,140	\$23	\$898	\$700	\$21,762	\$4,352	\$0	\$5,223	\$31,337	\$47
7.2	Hydrogen Compressor	\$6,915	\$618	\$718	\$560	\$8,812	\$1,762	\$0	\$2,115	\$12,689	\$19
	<b>Subtotal</b>	<b>\$27,055</b>	<b>\$641</b>	<b>\$1,616</b>	<b>\$1,261</b>	<b>\$30,574</b>	<b>\$6,115</b>	<b>\$0</b>	<b>\$7,338</b>	<b>\$44,026</b>	<b>\$67</b>
<b>8</b>		<b>Fired Heater, Ductwork, &amp; Stack</b>									
8.1	Fired Heater	\$6,675	\$376	\$1,899	\$1,481	\$10,431	\$2,086	\$0	\$2,504	\$15,021	\$23
8.2	Fired Heater Accessories	w/8.1	w/8.1	w/8.1	w/8.1	\$0	\$0	\$0	\$0	\$0	\$0
8.3	Ductwork	w/8.1	w/8.1	w/8.1	w/8.1	\$0	\$0	\$0	\$0	\$0	\$0
8.4	Stack	w/8.1	w/8.1	w/8.1	w/8.1	\$0	\$0	\$0	\$0	\$0	\$0
8.5	Fired Heater, Ductwork & Stack Foundations	w/8.1	w/8.1	w/8.1	w/8.1	\$0	\$0	\$0	\$0	\$0	\$0
	<b>Subtotal</b>	<b>\$6,675</b>	<b>\$376</b>	<b>\$1,899</b>	<b>\$1,481</b>	<b>\$10,431</b>	<b>\$2,086</b>	<b>\$0</b>	<b>\$2,504</b>	<b>\$15,021</b>	<b>\$23</b>
<b>9</b>		<b>Cooling Water System</b>									
9.1	Cooling Towers	\$9,138	\$0	\$2,767	\$0	\$11,906	\$2,381	\$0	\$2,143	\$16,430	\$25
9.2	Circulating Water Pumps	\$1,207	\$0	\$74	\$0	\$1,281	\$256	\$0	\$231	\$1,768	\$3
9.3	Circulating Water System Auxiliaries	\$8,860	\$0	\$1,169	\$0	\$10,029	\$2,006	\$0	\$1,805	\$13,840	\$21
9.4	Circulating Water Piping	\$0	\$2,550	\$2,309	\$0	\$4,858	\$972	\$0	\$875	\$6,705	\$10
9.5	Make-up Water System	\$333	\$0	\$428	\$0	\$760	\$152	\$0	\$137	\$1,049	\$2
9.6	Component Cooling Water System	\$376	\$0	\$288	\$0	\$664	\$133	\$0	\$120	\$917	\$1
9.7	Circulating Water System Foundations	\$0	\$590	\$979	\$0	\$1,569	\$314	\$0	\$377	\$2,260	\$3
	<b>Subtotal</b>	<b>\$19,914</b>	<b>\$3,139</b>	<b>\$8,014</b>	<b>\$0</b>	<b>\$31,068</b>	<b>\$6,214</b>	<b>\$0</b>	<b>\$5,686</b>	<b>\$42,968</b>	<b>\$65</b>
<b>11</b>		<b>Accessory Electric Plant</b>									
11.2	Station Service Equipment	\$0	\$1,128	\$109	\$85	\$1,321	\$264	\$0	\$238	\$1,823	\$3
11.3	Switchgear & Motor Control	\$0	\$602	\$188	\$147	\$937	\$187	\$0	\$169	\$1,293	\$2
11.4	Conduit & Cable Tray	\$0	\$281	\$508	\$397	\$1,186	\$237	\$0	\$213	\$1,637	\$2
11.5	Wire & Cable	\$0	\$662	\$467	\$364	\$1,493	\$299	\$0	\$269	\$2,060	\$3
11.6	Protective Equipment	\$0	\$443	\$785	\$612	\$1,840	\$368	\$0	\$331	\$2,539	\$4
11.7	Standby Equipment	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case:		3		– Autothermal Reforming w/ CCS			Estimate Type:			Conceptual	
Plant Size (kg H <sub>2</sub> /day):		659,999					Cost Base:			Dec 2018	
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost	
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]
11.8	Main Power Transformers	\$0	\$151	\$71	\$56	\$278	\$56	\$0	\$50	\$384	\$1
11.9	Electrical Foundations	\$0	\$7	\$22	\$17	\$46	\$9	\$0	\$11	\$66	\$0
	<b>Subtotal</b>	<b>\$0</b>	<b>\$3,275</b>	<b>\$2,149</b>	<b>\$1,676</b>	<b>\$7,101</b>	<b>\$1,420</b>	<b>\$0</b>	<b>\$1,281</b>	<b>\$9,802</b>	<b>\$15</b>
<b>12</b>		<b>Instrumentation &amp; Control</b>									
12.4	Other Major Component Control Equipment	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
12.5	Signal Processing Equipment	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
12.6	Control Boards, Panels & Racks	\$0	\$340	\$40	\$31	\$411	\$82	\$21	\$77	\$591	\$1
12.7	Distributed Control System Equipment	\$9,148	\$0	\$280	\$0	\$9,428	\$1,886	\$471	\$1,768	\$13,552	\$21
12.8	Instrument Wiring & Tubing	\$0	\$238	\$408	\$318	\$965	\$193	\$0	\$174	\$1,332	\$2
12.9	Other Instrumentation & Controls Equipment	\$0	\$1,474	\$386	\$301	\$2,160	\$432	\$0	\$389	\$2,981	\$5
	<b>Subtotal</b>	<b>\$9,148</b>	<b>\$2,052</b>	<b>\$1,114</b>	<b>\$650</b>	<b>\$12,964</b>	<b>\$2,593</b>	<b>\$492</b>	<b>\$2,407</b>	<b>\$18,456</b>	<b>\$28</b>
<b>13</b>		<b>Improvements to Site</b>									
13.1	Site Preparation	\$0	\$533	\$11,312	\$0	\$11,845	\$2,369	\$0	\$2,843	\$17,056	\$26
13.2	Site Improvements	\$0	\$290	\$1,163	\$907	\$2,361	\$472	\$0	\$567	\$3,399	\$5
13.3	Site Facilities	\$1,645	\$0	\$1,725	\$0	\$3,370	\$674	\$0	\$809	\$4,853	\$7
	<b>Subtotal</b>	<b>\$1,645</b>	<b>\$823</b>	<b>\$14,201</b>	<b>\$907</b>	<b>\$17,575</b>	<b>\$3,515</b>	<b>\$0</b>	<b>\$4,218</b>	<b>\$25,308</b>	<b>\$38</b>
<b>14</b>		<b>Buildings &amp; Structures</b>									
14.2	Interconnecting Pipe	\$0	\$736	\$1,744	\$1,360	\$3,840	\$768	\$0	\$691	\$5,299	\$8
14.4	Administration Building	\$0	\$364	\$246	\$0	\$610	\$122	\$0	\$110	\$842	\$1
14.5	Circulation Water Pumphouse	\$0	\$64	\$31	\$0	\$95	\$19	\$0	\$17	\$131	\$0
14.6	Water Treatment Buildings	\$0	\$365	\$333	\$0	\$698	\$140	\$0	\$126	\$963	\$1
14.7	Machine Shop	\$0	\$544	\$348	\$0	\$892	\$178	\$0	\$161	\$1,232	\$2
14.8	Warehouse	\$0	\$424	\$255	\$0	\$679	\$136	\$0	\$122	\$937	\$1
14.9	Structural Steel Pipe Racks	\$0	\$1,726	\$982	\$766	\$3,474	\$695	\$0	\$625	\$4,795	\$7
14.10	Waste Treating Building & Structures	\$0	\$714	\$1,274	\$0	\$1,988	\$398	\$0	\$358	\$2,743	\$4
	<b>Subtotal</b>	<b>\$0</b>	<b>\$4,937</b>	<b>\$5,214</b>	<b>\$2,126</b>	<b>\$12,277</b>	<b>\$2,455</b>	<b>\$0</b>	<b>\$2,210</b>	<b>\$16,942</b>	<b>\$26</b>
	<b>Total</b>	<b>\$349,614</b>	<b>\$28,166</b>	<b>\$109,998</b>	<b>\$49,712</b>	<b>\$537,490</b>	<b>\$107,498</b>	<b>\$492</b>	<b>\$75,162</b>	<b>\$720,642</b>	<b>\$1,092</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 3-47. Case 3 owner's costs**

Description	\$/1,000	\$/[kg H <sub>2</sub> /day]
<b>Pre-Production Costs</b>		
6 Months All Labor	\$5,158	\$8
1 Month Maintenance Materials	\$761	\$1
1 Month Non-Fuel Consumables	\$6,430	\$10
1 Month Waste Disposal	\$9	\$0
25% of 1 Months Fuel Cost at 100% CF	\$3,876	\$6
2% of TPC	\$14,413	\$22
<b>Total</b>	<b>\$30,647</b>	<b>\$46</b>
<b>Inventory Capital</b>		
60-day supply of fuel and consumables at 100% CF	\$1,017	\$2
0.5% of TPC (spare parts)	\$3,603	\$5
<b>Total</b>	<b>\$4,620</b>	<b>\$7</b>
<b>Other Costs</b>		
Initial Cost for Catalyst and Chemicals	\$21,445	\$32
Land	\$300	\$0
Other Owner's Costs	\$108,096	\$164
Financing Costs	\$19,457	\$29
<b>Total Overnight Costs (TOC)</b>	<b>\$905,208</b>	<b>\$1,372</b>
TASC Multiplier (IOU, 35 year)	1.070	
<b>Total As-Spent Cost (TASC)</b>	<b>\$968,393</b>	<b>\$1,467</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 3-48. Case 3 initial and annual operating and maintenance costs**

Case:	3 – Autothermal Reforming w/ CCS			Cost Base:	Dec 2018	
Plant Size (kg H <sub>2</sub> /day):	659,999			Capacity Factor (%):	90	
<b>Operating &amp; Maintenance Labor</b>						
<b>Operating Labor</b>				<b>Operating Labor Requirements per Shift</b>		
Operating Labor Rate (base):		38.50	\$/hour	Skilled Operator:	1.0	
Operating Labor Burden:		30.00	% of base	Operator:	3.3	
Labor O-H Charge Rate:		25.00	% of labor	Foreman:	1.0	
				Lab Techs, etc.:	1.0	
				<b>Total:</b>	<b>6.3</b>	
<b>Fixed Operating Costs</b>						
					<b>Annual Cost</b>	
					(\$)	(\$/[kg H <sub>2</sub> /day])
Annual Operating Labor:					\$2,776,628	\$4.207
Maintenance Labor:					\$5,476,882	\$8.298
Administrative & Support Labor:					\$2,063,377	\$3.126
Property Taxes and Insurance:					\$14,412,847	\$21.838
<b>Total:</b>					<b>\$24,729,734</b>	<b>\$37.469</b>
<b>Variable Operating Costs</b>						
					(\$)	(\$/kg H <sub>2</sub> )
Maintenance Material:					\$8,215,323	\$0.04
<b>Consumables</b>						
	<b>Initial Fill</b>	<b>Per Day</b>	<b>Per Unit</b>	<b>Initial Fill</b>		
Water (gal/1000):	0	2,678	\$1.90	\$0	\$1,671,599	\$0.00771
Makeup and Wastewater Treatment Chemicals (ton):	0	8.0	\$550	\$0	\$1,441,422	\$0.00665
Zinc Oxide Sulfur Guard Catalyst (ft <sup>3</sup> ):	1120	0.8	\$600	\$672,000	\$151,200	\$0.00070
Prereformer Catalyst (ft <sup>3</sup> ):	1330	0.9	\$1,250	\$1,662,500	\$374,063	\$0.00173
Primary Reformer Catalyst (ft <sup>3</sup> ):	3600	2.0	\$450	\$1,620,000	\$291,600	\$0.00134
Water Gas Shift Catalyst (ft <sup>3</sup> ):	18809	12.9	\$480	\$9,028,174	\$2,031,339	\$0.00937
Methyl Diethanolamine Solution (gal):	847096	319	\$2.80	\$2,371,868	\$293,432	\$0.00135
Post-Combustion CO <sub>2</sub> Capture System <sup>A</sup> :	Proprietary				\$0	\$0.00000
PSA Unit Adsorbent (ft <sup>3</sup> ):	40600	5.6	\$150	\$6,090,000	\$274,050	\$0.00126
Triethylene Glycol (gal):	w/equip.	285	\$6.80	\$0	\$635,685	\$0.00293
Electricity (MWh):	0	2644	\$71.70	\$0	\$62,282,859	\$0.28727
<b>Subtotal:</b>				<b>\$21,444,542</b>	<b>\$69,447,248</b>	<b>\$0.32031</b>
<b>Waste Disposal</b>						
Zinc Oxide Sulfur Guard Catalyst (ft <sup>3</sup> ):	0	0.8	\$40.00	\$0	\$10,080	\$0.00005
Prereformer Catalyst (ft <sup>3</sup> ):	0	0.9	\$0.00	\$0	\$0	\$0.00000
Primary Reformer Catalyst (ft <sup>3</sup> ):	0	2.0	\$0.00	\$0	\$0	\$0.00000
Water Gas Shift Catalyst (ft <sup>3</sup> ):	0	12.9	\$2.50	\$0	\$10,580	\$0.00005
Methyl Diethanolamine Solution (gal):	0	319	\$0.35	\$0	\$36,679	\$0.00017
PSA Unit Adsorbent (ft <sup>3</sup> ):	0	5.6	\$1.50	\$0	\$2,741	\$0.00001
Triethylene Glycol (gal):	0	285	\$0.35	\$0	\$32,719	\$0.00015
Amine Purification Unit Waste (ton):	0	0	\$38.0	\$0	\$0	\$0.00000
Thermal Reclaimer Unit Waste (ton):	0	0	\$38.0	\$0	\$0	\$0.00000
<b>Subtotal:</b>				<b>\$0</b>	<b>\$92,798</b>	<b>\$0.00043</b>

## COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case:	3 – Autothermal Reforming w/ CCS			Cost Base:	Dec 2018	
Plant Size (kg H <sub>2</sub> /day):	659,999			Capacity Factor (%):	90	
<b>By-Products</b>						
					(\$)	(\$/kg H <sub>2</sub> )
Steam (ton):	0	0	\$0.00	\$0	\$0	\$0.00000
Electricity (MWh):	0	0	\$71.70	\$0	\$0	\$0.00000
<b>Subtotal:</b>				<b>\$0</b>	<b>\$0</b>	<b>\$0.00000</b>
<b>Variable Operating Costs Total:</b>				<b>\$21,444,542</b>	<b>\$77,532,003</b>	<b>\$0.35760</b>
<b>Fuel Cost</b>						
Natural Gas (MMBtu):	0	115,306	\$4.42	\$0	\$167,428,981	\$0.77224
<b>Total:</b>				<b>\$0</b>	<b>\$167,428,981</b>	<b>\$0.77224</b>

<sup>A</sup>Post-combustion CO<sub>2</sub> capture system chemicals includes ion exchange resin, NaOH, and Cansolv solvent.

**Exhibit 3-49. Case 3 LCOH breakdown**

Component	Value, \$/kg H <sub>2</sub>	Percentage
Capital	0.26	16%
Fixed	0.11	7%
Variable	0.36	22%
Fuel	0.77	48%
<b>Total (Excluding T&amp;S)</b>	<b>1.51</b>	<b>N/A</b>
CO <sub>2</sub> T&S	0.09	6%
<b>Total (Including T&amp;S)</b>	<b>1.59</b>	<b>N/A</b>

### 3.16 REFORMING CASE SUMMARY

The performance and cost results of the three reforming plant configurations modeled in this report are summarized in Exhibit 3-50. The following section provides a discussion on the reforming performance, environmental, and cost results.

**Exhibit 3-50. Estimated performance results for all reforming cases**

Case Name	Reforming		
	SMR		ATR
	1	2	3
<b>PERFORMANCE</b>			
Nominal CO <sub>2</sub> Capture	0%	96.2%	94.5%
Capacity Factor	90%	90%	90%
Hydrogen Production Rate (lb/hr)	44,369	44,369	60,627
Gross Power Output (MWe)	0	0	0
Auxiliary Power Requirement (MWe)	13	41	110
Net Power Output (MWe)	-13	-41	-110
Coal Flowrate (lb/hr)	N/A	N/A	N/A

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Case Name	Reforming		
	SMR		ATR
	1	2	3
Biomass Flowrate (lb/hr)	N/A	N/A	N/A
Natural Gas Flowrate (lb/hr)	156,482	166,387	213,694
HHV Thermal Input (kW <sub>t</sub> )	1,031,068	1,096,328	1,408,040
HHV Effective Thermal Efficiency (%)	75.4%	68.4%	67.9%
HHV Cold Gas Efficiency (%)	76.7%	72.1%	75.7%
Raw Water Withdrawal (gpm)	1,457	2,727	3,720
Process Water Discharge (gpm)	63	586	775
Raw Water Consumption (gpm)	1,395	2,140	2,945
CO <sub>2</sub> Emissions (lb/MMBtu)	118	5	7
SO <sub>2</sub> Emissions <sup>A</sup> (lb/MMBtu)	0.000	0.000	0.000
NO <sub>x</sub> Emissions (lb/MMBtu)	0.003	0.002	0.000
PM Emissions (lb/MMBtu)	0.000	0.000	0.000
Hg Emissions (lb/TBtu)	0.000	0.000	0.000
COST			
Total Plant Cost (2018\$/[kg H <sub>2</sub> /day])	554	1,394	1,092
Total Overnight Cost (2018\$/[kg H <sub>2</sub> /day])	713	1,735	1,372
<i>Owner's Costs</i>	159	341	280
<i>Process Contingency</i>	0	52	1
<i>Project Contingency</i>	94	252	114
<i>Home Office Expenses</i>	77	182	163
<i>Bare Erected Cost</i>	384	908	814
Total As-Spent Cost (2018\$/[kg H <sub>2</sub> /day])	763	1,856	1,467
LCOH (\$/kg H <sub>2</sub> ) (excluding T&S)	1.06	1.54	1.51
<i>Capital Costs</i>	0.14	0.33	0.26
<i>Fixed Costs</i>	0.07	0.15	0.11
<i>Variable Costs</i>	0.09	0.24	0.36
<i>Fuel Costs</i>	0.77	0.82	0.77
LCOH (\$/kg H <sub>2</sub> ) (including T&S)	1.06	1.64	1.59
<i>CO<sub>2</sub> T&amp;S Costs</i>	0.00	0.10	0.09

<sup>A</sup>Trace amounts of sulfur emissions may exist in the flue gas stream to the stack in capture cases

### 3.16.1 Performance Results Summary


A graph of the net plant efficiency (HHV basis) is provided in Exhibit 3-51.

The following observations can be made regarding plant performance:

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

- The SMR plant without capture (Case 1) performs the best, with a cold gas efficiency of 76.7 percent on an HHV-basis and an effective thermal efficiency of 75.4 percent on an HHV-basis. The worst performing configuration on a cold gas efficiency basis is the SMR plant with capture (Case 2), having a 72.1 percent efficiency on an HHV-basis. The ATR plant with capture (Case 3) configuration has the lowest effective thermal efficiency metric of 67.9 percent on an HHV-basis.
- The two cases that employ carbon capture, Case 2 and Case 3, have the lowest efficiency values. This is due to the energy penalty associated with adding CO<sub>2</sub> capture as additional energy is needed for the thermal demand and auxiliary load for the CO<sub>2</sub> separation and compression equipment. The reduction in effective thermal efficiency is about 7 percentage points (about 9.3 percent relative to non-capture) between the SMR cases, Case 1 and Case 2.
- The configuration with the highest auxiliary power requirement (110 MWe) is the ATR plant with capture (Case 3) due to the carbon capture energy penalty as well as the addition of the ASU in the plant configuration. The SMR plant without capture (Case 1) has the lowest auxiliary power requirement (13 MWe).


**Exhibit 3-51. Net plant efficiency (HHV basis) for all reforming cases**



### 3.16.2 Environmental Results Summary

A graph of the life cycle equivalent CO<sub>2</sub> emissions breakdown is shown in Exhibit 3-52. To generate these results, a Monte Carlo simulation with 5,000 iterations was used. The bars represent median values, and the error bars show results from the 5<sup>th</sup> and 95<sup>th</sup> percentiles. For the upstream natural gas contribution, the error bars also represent variability across basins. The case of SMR without CCS includes parallel models without and with steam displacement, labeled Case 1A and Case 1B, respectively. Further discussion of this steam credit is below.

Exhibit 3-52. CO<sub>2</sub>e life cycle emissions for all reforming cases



- The highest total equivalent CO<sub>2</sub> life cycle emissions (12 lb CO<sub>2</sub>e/lb H<sub>2</sub>) comes from the SMR plant without capture and without steam displacement (Case 1A), which is expected. Seventy five percent of the total CO<sub>2</sub>e emissions are from CO<sub>2</sub> stack emissions (9.3 lb CO<sub>2</sub>e/lb H<sub>2</sub>). Twenty two percent comes from natural gas procurement (3.6 lb CO<sub>2</sub>e/lb H<sub>2</sub>) and 3 percent comes from grid electricity usage (0.37 lb CO<sub>2</sub>e/lb H<sub>2</sub>). With the inclusion of steam displacement in the SMR plant without capture (Case 1B), the total equivalent CO<sub>2</sub> life cycle emissions reduce to 10 lb CO<sub>2</sub>e/lb H<sub>2</sub>.

## COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

- For the SMR case with CO<sub>2</sub> capture (Case 2), the total life cycle CO<sub>2</sub>e emissions are more than 10 times that of the stack emissions alone. CO<sub>2</sub> stack emissions are eight percent of the total CO<sub>2</sub>e emissions (0.38 lb CO<sub>2</sub>e/lb H<sub>2</sub>). Sixty two percent comes from natural gas procurement (2.9 lb CO<sub>2</sub>e/lb H<sub>2</sub>), 26 percent comes from grid electricity usage (1.2 lb CO<sub>2</sub>e/lb H<sub>2</sub>), and 3 percent comes from CO<sub>2</sub> management after it has been captured (0.15 lb CO<sub>2</sub>e/lb H<sub>2</sub>).
- Adding capture to the SMR plant cuts the total CO<sub>2</sub>e emissions by more than half, about a 62 percent reduction. Compared to Case 1A, the SMR plant with capture has higher life cycle emissions sourced from grid electricity due to the higher power demand of this case. Similarly, life cycle GHG emissions from carbon management activities are included in the system boundary to account for the transport and geologic sequestration of the captured carbon.
- The ATR with capture case (Case 3) has a total equivalent CO<sub>2</sub> life cycle emissions value of 5.7 lb CO<sub>2</sub>e/lb H<sub>2</sub>. Nine percent of the total CO<sub>2</sub>e emissions are sourced from the CO<sub>2</sub> stack emissions (0.51 lb CO<sub>2</sub>e/lb H<sub>2</sub>). Forty seven percent comes from natural gas procurement (2.7 lb CO<sub>2</sub>e/lb H<sub>2</sub>), 42 percent comes from grid electricity usage (2.4 lb CO<sub>2</sub>e/lb H<sub>2</sub>), and 2 percent comes from carbon management (0.14 lb CO<sub>2</sub>e/lb H<sub>2</sub>).

For these cases, the variability in the GWP results is fairly high (about 25%), and is primarily driven by differences in the upstream life cycle emissions from extraction through delivery of the natural gas to the facility, and to a lesser extent, the upstream grid electricity. More details on the sources of variability are in Section 5.1.2.

Hydrogen production today is commonly integrated or co-located with industrial operations that utilize the hydrogen directly within the industrial processes. Steam methane reforming of natural gas to produce hydrogen, the predominant commercial technology for hydrogen production today, often produces excess steam that is commonly used by integrated or co-located industrial operations. Future deployments of hydrogen production facilities may or may not be integrated or co-located with industrial operations with adequate demand for the excess steam produced from various hydrogen production methods. We model two types of SMR configurations without CCS. In Case 1A, the SMR plant configuration is assumed to be a stand-alone hydrogen production facility with no viable use for excess steam produced with the hydrogen product. In Case 1B, SMR hydrogen production is integrated or co-located with an industrial operational that can utilize the excess steam, thus a commensurate emissions credit based on system expansion using a natural gas boiler to produce steam of equivalent quality is used. The emissions credit for excess steam is calculated using the Case 1 modeled steam output of 514 GJ/hr, or 26 MJ/kg H<sub>2</sub>, and an assumed 85 percent efficient (HHV basis) natural gas boiler, requiring the combustion of approximately 0.57 kg natural gas/kg H<sub>2</sub> [63]. Overall, the estimated GWP results for Case 1A and 1B are 12 and 10 kg CO<sub>2</sub>e/kg H<sub>2</sub>, respectively.


Each of the cases satisfies the appropriate hydrogen production facility air emissions targets for SO<sub>2</sub>, NO<sub>x</sub>, particulate matter, and Hg. All three configurations have negligible SO<sub>2</sub>, Hg, and PM emissions, on a lb of pollutant per MMBtu thermal input basis. The NO<sub>x</sub> emissions are highest

## COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

in the SMR plant without capture (Case 1) configuration (0.003 lb/MMBtu) and lowest in the ATR with capture (Case 3) configuration (0.000 lb/MMBtu).

Finally, water use for the three reforming cases has been summarized in Exhibit 3-53.

**Exhibit 3-53. Water use for all reforming cases**




- The results are as expected for the three reforming cases. The SMR plant without capture (Case 1) has the lowest water demands of all three cases, with a raw water consumption of 1.9 gal/lb H<sub>2</sub>. In this case, 2.0 gal/lb H<sub>2</sub> is needed for raw water withdrawal and 0.1 gal/lb H<sub>2</sub>.
- The SMR (Case 2) and ATR (Case 3) plants with capture have approximately equal water demands, with raw water consumptions for both cases of 2.9 gal/lb H<sub>2</sub>, about a 50 percent increase from the non-capture configuration. This is due to the increased cooling demands required by the CO<sub>2</sub> capture system. The raw water withdrawal for this case is 3.7 gal/lb H<sub>2</sub> and the process discharge is 0.8 gal/lb H<sub>2</sub>.

### 3.16.3 Cost Results Summary

The components of TOC and the overall TASC of the three reforming cases are shown in Exhibit 3-54. The error bars included represent the potential TOC range relative to the maximum and minimum of the capital cost uncertainty range which is -15 percent/+25 percent for reforming cases.

*Exhibit 3-54. Plant capital cost for all reforming cases*



The following TOC observations are made with the caveat that the differences between cases are less than the estimated accuracy. However, all cases are evaluated using a common set of technical and economic assumptions allowing meaningful comparison among the cases:

- The SMR plant without capture (Case 1) has the lowest TOC (\$713/[kg H<sub>2</sub>/day]) and TASC (\$763/[kg H<sub>2</sub>/day]) values of all reforming cases. The primary contributor to the TOC is the bare erected cost, accounting for 54 percent of the TOC for Case 1. The next largest contributor is the owner's costs, accounting for 22 percent. There are no process contingencies in this case.
- The SMR plant with capture (Case 2) has the highest TOC (\$1,735/[kg H<sub>2</sub>/day]) and TASC (\$1,856/[kg H<sub>2</sub>/day]) values of all reforming cases. A small fraction of the TOC, about


COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

three percent, goes towards process contingency, unlike Case 1. Like Case 1, the bare erected cost accounts for more than half of the TOC, about 52 percent.

- The ATR plant with capture (Case 3) has a TOC of \$1,372/[kg H<sub>2</sub>/day] and TASC of \$1,467/[kg H<sub>2</sub>/day]. The bare erected cost accounts for 59 percent of the TOC.

The LCOH is shown for all three reforming cases in Exhibit 3-55. The error bars included represent the potential LCOH range relative to the maximum and minimum capital cost uncertainty ranges. The LCOH ranges presented are not reflective of other changes, such as variation in fuel price, labor price, CF, or other factors.

*Exhibit 3-55. LCOH for all reforming cases*



The following observations can be made:

- The lowest LCOH is from the SMR plant without CCS (Case 1, \$1.06/kg H<sub>2</sub>) and the highest LCOH is from the SMR plant with CCS (Case 2, \$1.64/kg H<sub>2</sub>). The ATR plant with CCS has a slightly lower LCOH than the SMR plant with CCS (Case 3, \$1.59/kg H<sub>2</sub>).
- The largest contributor to the LCOH is the fuel, making up between 48 and 73 percent of the LCOH for the reforming cases.

- In the cases with capture (Case 2 and Case 3), the variable costs make up a larger portion, while the fuel costs make up a smaller portion of the LCOH in comparison to the non-capture case (Case 1). The capital costs make up a larger portion in the SMR plant with capture (Case 2) than the other two reforming cases.

As presented in Section 2.11.4, the breakeven CO<sub>2</sub> sales price and emissions penalty were calculated by using the steam methane reforming plant with capture (Case 2) and the autothermal reforming plant with capture (Case 3). The breakeven CO<sub>2</sub> sales price represents the minimum CO<sub>2</sub> plant gate sales price that will incentivize carbon capture in lieu of a defined reference non-capture plant. The breakeven CO<sub>2</sub> emissions penalty represents the minimum CO<sub>2</sub> emissions price, when applied to both the capture and non-capture plant that will incentivize carbon capture in lieu of a defined reference non-capture plant. Both the breakeven CO<sub>2</sub> sales price and emissions penalty were calculated using the steam methane reforming plant without capture (Case 1) as a non-capture reference.

The breakeven CO<sub>2</sub> sales price (excluding T&S) for the reforming cases with capture are \$50.1/tonne (\$45.4/ton) for the SMR plant with capture (Case 2) and \$50.4/tonne (\$45.7/ton) for the ATR plant with capture (Case 3). The breakeven CO<sub>2</sub> sales prices is roughly equivalent between the SMR and ATR plant configurations with CCS. The breakeven CO<sub>2</sub> emissions penalty for the reforming cases with capture are \$64.1/tonne (\$58.1/ton) for the SMR plant with capture (Case 2) and \$60.3/tonne (\$54.7/ton) for the ATR plant with capture (Case 3). A lower carbon tax is required to encourage the use of an ATR plant with capture as opposed to an SMR plant with capture, for which the CO<sub>2</sub> emissions penalty needs to be about \$4/tonne greater.

## **GASIFICATION PLANTS**

---

## 4 GASIFICATION PLANTS

---

Three gasification plant configurations were evaluated, and the results are presented in this section. Each design is based on a market-ready technology that is assumed to be commercially available to support startup.

The first two gasification cases, Case 4 and Case 5, use a Shell gasifier and differ in that Case 4 does not include CO<sub>2</sub> capture while Case 5 does. The cases were sized based on the as-received coal feed rate for the Shell IGCC without CO<sub>2</sub> capture (Case B1B) in the NETL Fossil Energy Baseline study. [31] The original size selection was based on the constraints imposed by the fixed combustion turbine (CT) output of a comparable IGCC plant.

Since a coal/biomass co-gasification case was of interest in this study, the design total feedstock flowrate of the Buggenum facility was chosen as a reference facility for Case 6. Owned and operated by Nuon Power, the Buggenum facility was an IGCC plant of commercial size located in the Netherlands. In an effort to reduce CO<sub>2</sub> emissions, up to 30 percent by weight of biomass, including chicken litter, sewage sludge, and milled wood, was co-fed into the system with coal at a total gasifier feed rate of 1,400 tpd. [30] This Buggenum total feed rate was used as the capacity basis for Case 6; however, the percent of biomass was adjusted to achieve net zero life cycle CO<sub>2</sub> emissions.

The evaluation scope included developing energy and mass balances and estimating plant performance. Equipment lists were developed for each design. Section 4.1 covers general information that is common to all of the cases; case-specific information is subsequently presented in sections 4.5, 4.9, and 4.13.

### 4.1 GASIFIER BACKGROUND

The three gasification cases are based on performance data for an oxygen-blown, entrained-flow gasifier that is intended to be similar to the Shell gasifier, by which it is referred to from here on out. This gasifier has been published in numerous prior NETL studies, including most-recently, the Fossil Energy Baseline. The estimates were derived from public literature and relied heavily on conference presentations given by Shell at the Gasification Technologies Conference in 2009. It is not intended to faithfully reproduce the operating point of any specific gasifier either currently operating, previously operating, or planned. It is a conceptual design that extends some of the features of the gasifier island, such as integration with other plant components. It was intended to keep the design basis comparable to how other gasifiers were represented in previous studies like the Fossil Energy Baseline. In 2018, the Shell gasifier technology was purchased and is now licensed by Air Products. It is recognized that the technology is now owned by Air Products, not Shell, but the gasifier will continue to be called the “Shell” gasifier to be consistent with the Fossil Energy Baseline and avoid confusion.

The “Coal Gasification Guidebook: Status, Application, and Technologies” report published by EPRI provides a detailed history of the development of several types of gasifier technology, including the Shell gasifier, as well as gasifier capacity, distinguishing characteristics, and important coal characteristics. [64] As of 2009, Shell reported ten gasifiers in operation,

producing 100,000–150,000 Nm<sup>3</sup>/hr of syngas each and three of the same size in construction. Another three ranging from 150,000 to 250,000 Nm<sup>3</sup>/hr are also in construction. [65] The large gasifier operating in the Netherlands has a bituminous coal-handling capacity of 1,633 tonnes/day (1,800 tpd) and produces dry gas at a rate of 158,575 Nm<sup>3</sup>/hr (5.6 million scf/hr) with an energy content of about 1,792 GJ/hr (1,700 MMBtu/hr) (HHV). This gasifier was sized to match the fuel gas requirements for the Siemens/Kraftwerk Union V-94.2 CT and could easily be scaled up to match state-of-the-art 2008 F-class turbine requirements. [65]

Shell gasifiers are capable of utilizing a wide variety of coal types, and compared to slurry fed gasifiers, the dry-fed, cooled-refractory lined, Shell gasifier has a lower O<sub>2</sub> requirement and produces a gas with a higher H<sub>2</sub>S/COS ratio, which improves sulfur recovery. [64]

While the use of dry feed allows for lower O<sub>2</sub> consumption, the feed system—which includes the coal drying system—is more complicated. [64]

The Shell gasifier has demonstrated the ability to handle coal types with an ash content up to 37%. The slag viscosity is a critical parameter, and this is tuned by the addition of fluxants such as limestone. The negative impact that high ash coals have on the operation of gasifiers are reduced in dry feed systems in comparison to slurry fed gasifiers. [64]

## 4.2 KEY SYSTEM ASSUMPTIONS

System assumptions for cases 4, 5, and 6 (coal gasification without and with CO<sub>2</sub> capture and coal/biomass co-gasification with CO<sub>2</sub> capture) are compiled in Exhibit 4-1.

*Exhibit 4-1. Gasification plant study configuration matrix*

Case	4	5	6
Gasifier Pressure, MPa (psia)	4.2 (615)		
O <sub>2</sub> :Coal Ratio, kg O <sub>2</sub> /kg As-Received coal	0.720		
Carbon Conversion, %	99.5		
Steam Cycle, MPa/°C/°C (psig/°F/°F)	11.7/482/482 (1,700/900/900)	12.4/510/510 (1,800/950/950)	12.4/532/532 (1,800/990/990)
Condenser Pressure, mm Hg (in. Hg)	51 (2.0)		
Gasifier Technology	Shell		
Oxidant	95 vol% O <sub>2</sub>		
Feedstock	Illinois No. 6 Coal	Illinois No. 6 Coal/torrefied, woody biomass	
Coal Feed Moisture Content, %	5		
Plant Capacity	304 kNm <sup>3</sup> /hr (274 MMSCFD) Match Case 3	61 kNm <sup>3</sup> /hr (55 MMSCFD)	

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case	4	5	6
			~1,400 tpd AR feedstock
Water Gas Shift	2x3 train configuration, high-temperature, 97.2% conversion		
H <sub>2</sub> Product Purity	99.90 vol%		
H <sub>2</sub> Product Pressure	939.7 psia		
H <sub>2</sub> Purification	Pressure Swing Adsorption		
COS Hydrolysis	Occurs in WGS		
H <sub>2</sub> S Separation	MDEA	Selexol 1 <sup>st</sup> Stage	
Sulfur Removal, %	99.6%	~100.0	
Sulfur Recovery	Claus Plant with Tail Gas Treatment/Elemental Sulfur		
Particulate Control	Cyclone, Candle Filter, Scrubber, Quench, and AGR Absorber		
Chloride Control	Venturi Scrubber, Vacuum Flash, Brine Concentrator, Crystallizer		
Mercury Control	Carbon Bed		
NO <sub>x</sub> Control	Low-NO <sub>x</sub> Burners (LNB)		
CO <sub>2</sub> Separation	N/A	Selexol 2 <sup>nd</sup> Stage	
CO <sub>2</sub> Storage	N/A	Off-site Saline Formation	

#### 4.2.1 Balance of Plant

The balance of plant assumptions are common to all three cases and presented in Exhibit 4-2.

*Exhibit 4-2. Balance of plant assumptions*

Parameters	Values
<b>Cooling System</b>	Recirculating Wet Cooling Tower
<b>Fuel and Other Storage</b>	
Coal/Biomass	30 days
Slag	30 days
Sulfur	30 days
Sorbent	30 days
<b>Plant Distribution Voltage</b>	
Motors below 1 hp	110/220 V
Motors between 1 hp and 250 hp	480 V
Motors between 250 hp and 5,000 hp	4,160 V
Motors above 5,000 hp	13,800 V
Steam Turbine Generators	24,000 V

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Parameters	Values
Grid Interconnection Voltage	345 kV
<b><u>Water and Wastewater</u></b>	
Makeup Water	The water supply is 50 percent from a local POTW and 50 percent from groundwater and is assumed to be in sufficient quantities to meet plant makeup requirements Makeup for potable, process, and de-ionized (DI) water is drawn from municipal sources
Process Wastewater	Storm water that contacts equipment surfaces is collected and treated for discharge
Sanitary Waste Disposal	Design includes a packaged domestic sewage treatment plant with effluent discharged to the industrial wastewater treatment system. Sludge is hauled off site. Packaged plant is sized for 5.68 cubic meters per day (1,500 gallons per day)
Water Discharge	Blowdown from the cooling tower is softened and passed through a two-stage RO with pre-treatment and demineralizer before being discharged

### 4.3 SPARING PHILOSOPHY

The sparing philosophy for cases 4, 5, and 6 is provided below. Dual trains are used to accommodate the scale of the hydrogen production. There is no redundancy other than normal sparing of rotating equipment. The plant design consists of the following major subsystems:

- Two ASUs in Cases 4 & 5 (2 x 50 percent) and one ASU in Case 6 (1 x 100 percent)
- Two trains of gasification, including feedstock drying & feed, gasifier, synthesis gas cooler (SGC), and slag handling (2 x 50 percent)
- Two trains of syngas clean-up process (2 x 50 percent)
- Two trains of refrigerated MDEA in Case 4 (1 x 50) and one train of two-stage Selexol in Cases 5 & 6 (1 x 100 percent)
- One train of CO<sub>2</sub> compression (1 x 100 percent) in Case 5 and Case 6
- Two trains of process water treatment systems (2 x 50 percent)
- One train of Claus-based sulfur recovery (1 x 100 percent)
- One train of H<sub>2</sub> production and compression systems (1 x 100 percent)
- One steam turbine (1 x 100 percent)

### 4.4 GASIFICATION COMMON PROCESS AREAS

The cases have process areas, which are common to each plant configuration, such as coal receiving and storage, O<sub>2</sub> supply, gas cleanup, hydrogen production, etc. As detailed

descriptions of these process areas for each case would be repetitious, they are presented in this section for general background information. Where there is case-specific performance information, the performance features are presented in the relevant case sections.

#### **4.4.1 Coal Receiving and Storage**

The function of the coal receiving and storage system is to unload, convey, prepare, and store the coal delivered to the plant. The scope of the system is from the trestle bottom dumper and coal receiving hoppers up to and including the slide gate valves at the outlet of the coal storage silos. Coal receiving and storage is identical in design for all three cases.

The coal is delivered to the site by rail cars. The unloading is done by a trestle bottom dumper, which unloads the coal into two receiving hoppers. Coal from each hopper is fed directly into a vibratory feeder. The 8-centimeter (cm) x 0 (3-in. x 0) coal from the feeder is discharged onto a belt conveyor. Two conveyors with an intermediate transfer tower are assumed to convey the coal to the coal stacker, which transfer the coal to either the long-term storage pile or to the reclaim area. The conveyor passes under a magnetic plate separator to remove tramp iron and then to the reclaim pile.

The reclaimer loads the coal into two vibratory feeders located in the reclaim hopper under the pile. The feeders transfer the coal onto a belt conveyor that transfers the coal to the coal surge bin located in the crusher tower. The coal is reduced in size to 3 cm x 0 (1.25 in. x 0) by the crusher. A conveyor then transfers the coal to a transfer tower. In the transfer tower, the coal is routed to the tripper, which loads the coal into one of three silos. Two sampling systems are supplied: the as-received sampling system and the as-fired sampling system. Data from the analyses are used to support the reliable and efficient operation of the plant.

#### **4.4.2 Coal Preparation and Feed System**

The receiving and handling subsystem ends at the coal silo. The Shell process uses a dry feed system, which is sensitive to the coal moisture content. Coal moisture consists of two parts, surface moisture and inherent moisture. For coal to flow smoothly through the lock hoppers, the surface moisture must be removed. The Illinois No. 6 coal used in this report contains 11.12 percent total moisture on an as-received basis. It was assumed that the coal must be dried to 5 percent moisture to allow for smooth flow through the dry feed system.

The coal is simultaneously crushed and dried in the coal mill then delivered to a surge hopper with an approximate two-hour capacity. A slipstream of clean syngas is combusted with air in an incinerator, resulting in a flue gas with an O<sub>2</sub> content of 6 vol%, which is determined by the amount of air added to the drying loop. The incinerator's flue gas is used to dry the coal in the mill before being vented to the atmosphere.

The coal is drawn from the surge hoppers and fed through a pressurization lock hopper system to a dense phase pneumatic conveyor, which uses N<sub>2</sub> from the ASU to convey the coal to the gasifiers.

### 4.4.3 Air Separation Unit

A high-pressure ASU, nearly identical in design to the ATR with CO<sub>2</sub> capture case (Case 3) described in Section 3.12.1, is considered in each of the three gasification cases with the following modifications:

- Nominal ASU capacities for the gasification cases are 4,400 tpd for Cases 4 and 5, and 1,100 tpd for Case 6 of 95 vol% O<sub>2</sub>
- The 95 vol% O<sub>2</sub> is compressed to 740 psia to meet the design pressure of the Shell gasifier
- HP N<sub>2</sub> is also produced from the cold box and is further compressed to 815 psia for feedstock transport

The ASU process description can be found in Section 3.12.1 and is not repeated here.

### 4.4.4 Gasifier

There are two Shell dry feed, pressurized, up-flow, entrained, slagging gasifiers, operating at 4.2 MPa (615 psia). The air separation plant supplies 95 percent O<sub>2</sub> to the gasifiers. Coal reacts with O<sub>2</sub> and steam at a temperature of 1,427 °C (2,600 °F) in the gasifier to produce principally H<sub>2</sub> and CO with little CO<sub>2</sub> formed. The gasifier's refractory-lined water wall is protected by molten slag that partly solidifies on the cooled walls.

Note that the presented gasifier design is conceptual, not based on vendor quote, and may differ from operating plants.

### 4.4.5 Raw Gas Cooling and Particulate Removal

High-temperature heat recovery in each gasifier train is accomplished in three steps, including the gasifier jacket, which cools and solidifies slag touching the gasifier walls and maintains the syngas temperature at 1,427 °C (2,600 °F). The product gas from the gasifier is cooled below 1,093 °C (2,000 °F) by adding cooled recycled syngas to lower the temperature below the ash melting point. The mixed gas then goes through a duct cooler, which lowers the gas temperature to 899 °C (1,650 °F). Following the duct cooler is a direct contact water quench, which cools the raw syngas to a temperature of 399 °C (750 °F) while providing a portion of the water required for WGS and removing a significant portion of the PM from the syngas. The duct cooler produces HP steam for use in the steam cycle.

The majority of the fine particulates in the cooled gas from the syngas cooler are removed by passing through a cyclone collector, followed by an array of raw gas metallic or ceramic candle filter elements in a pressure vessel. Recycled syngas is used as the pulse gas to clean the candle filters. A carbon conversion of 99.5 percent is achieved by recycling the recovered fines, which are returned to the gasifier with the fuel.

The ash that is not carried out with the gas forms slag and runs down the interior walls, exiting the gasifier in liquid form. The slag is solidified in a quench tank for disposal. Lockhoppers are

used to reduce the pressure of the solids from 4.2 to 0.1 MPa (615 to 15 psia). The syngas scrubber removes additional PM further downstream.

The syngas from the candle filter is further cooled to 232 °C (450 °F) by producing intermediate pressure (IP) steam at 5.1 MPa (740 psia) for use in the gasifier and producing LP steam at 0.4 MPa (65 psia).

#### 4.4.6 Quench Gas Compressor

A portion of the cooled syngas is recycled back to the gasifier exit as quench gas. A single-stage compressor is utilized to boost the pressure of the cooled syngas stream to 4.3 MPa (625 psia).

#### 4.4.7 Syngas Scrubber

The ejector-type venturi scrubber is common to all cases. The raw syngas exiting the final raw gas cooler at 232 °C (450 °F) enters the scrubber for removal of HCl and remaining PM. The treated syngas leaves the scrubber at saturation. Due to the wet nature of the syngas, a recycle of the scrubber effluent is required; however, a minimum blowdown is maintained to limit the chloride concentration buildup in the scrubber effluent to 5,000 ppmv. The recycled scrubber effluent is cooled to 44 °C (112 °F) by exchanging heating with feedwater to the WGS steam generator before being further cooled through the addition of process water. Process water and zero liquid discharge (ZLD) condensate are cooled to 32 °C (90 °F) by preheating fuel gas prior to the gas-fired boiler (GFB) and subsequently cooled further to 21 °C (70 °F) with cooling water before the water stream is injected into the scrubber. Since the chloride concentration is maintained by adjusting the rate of effluent recycle, the rate of process water addition is used to maintain the HCl removal rate at 96 percent, along with removing essentially all traces of entrained particles (principally unconverted carbon, slag, and metals).


A 50 percent by weight (wt%) solution of NaOH is added to the scrubber to maintain pH and form the HSS sodium chloride NaCl.

The blowdown from the syngas scrubber is sent to the process water treatment system for chloride removal and recycle.

#### 4.4.8 Water Gas Shift Reactors

In all cases, the gasifier product must be converted to a CO<sub>2</sub> and H<sub>2</sub>-rich syngas in order to maximize H<sub>2</sub> product yield. The water gas shift technology, which is also used in the reforming cases, has been previously described in Section 3.3.4.

The CO shift converter is located upstream of the AGR step (sour gas shift) in order to promote COS hydrolysis without a separate catalyst bed. The COS hydrolysis reaction is equimolar with a slightly exothermic heat of reaction, as shown in the following reaction:



Since the reaction is exothermic, higher conversion is achieved at lower temperatures. However, at lower temperatures the reaction kinetics are slower.

Steam injection upstream of the shift reactors is extracted from the steam cycle and is used to drive the reaction and control the outlet steam to dry gas ratio.

Cooling is provided between the series of reactors to control the exothermic temperature rise. In all cases, the HXs are used to raise steam for injection or otherwise integrated into the plant, such as for syngas reheating.

The heat generated from the first reactor is used to produce more steam than is required (3.9 MPa (563 psia) steam is exported for use in the steam cycle) to maintain the desired steam to dry gas ratio while cooling the syngas to 253 °C (487 °F) prior to entering the second stage. After the second WGS reactor, the syngas is again cooled to a temperature of 253 °C (487 °F) by exchanging heat with the feed water of the WGS steam generator. Prior to the syngas being sent to the low temperature heat recovery (LTHR) system, the warm syngas from the third stage of WGS is cooled to 202 °C (395 °F) by preheating the feed water of the WGS steam generator.

#### **4.4.9 Low Temperature Heat Recovery**

The raw syngas from the WGS unit is cooled through a series of four shell and tube HXs. The first stage cools the syngas from 202 °C (395 °F) to 162 °C (323 °F) by raising 0.4 MPa (65 psia) process steam. The second stage further cools the syngas to a temperature of 134 °C (274 °F) by preheating the cold feedwater for the WGS steam generator. The third stage cools the syngas from 59 °C (138 °F) by preheating FW to the GFB. Finally, the syngas is cooled to a temperature of 29 °C (85 °F) in the fourth stage by cooling water. During cooling, part of the water vapor condenses, along with significant amounts of NH<sub>3</sub>, and is combined with the effluent of the NH<sub>3</sub> wash.

#### **4.4.10 Mercury Removal**

A conceptual design for a sulfur-impregnated, activated carbon bed adsorption system was developed for mercury control, where mercury is captured in the reduced state. Data on the performance of carbon bed systems were obtained from the Eastman Chemical Company, which uses carbon beds at its syngas facility in Kingsport, Tennessee. [66] The coal mercury content (0.15 ppmvd) and carbon bed removal efficiency (95 percent) were discussed previously in Section 2.

##### **4.4.10.1 Carbon Bed Location**

The packed carbon bed vessels are located after the ammonia wash section, upstream of the AGR process. Syngas is preheated from temperatures between 27 °C (80 °F) and 29 °C (85 °F), to temperatures of 37 °C (98 °F) and 38 °C (100 °F) before entering the bed. The preheating is necessary to avoid condensation within the bed. Eastman Chemical operates their beds ahead of their sulfur recovery unit (SRU) at a temperature of 30 °C (86 °F). [66]

##### **4.4.10.2 Process Parameters**

An empty vessel basis gas residence time of approximately 20 seconds was used based on Eastman Chemical's experience. [66] Allowable gas velocities are limited by considerations of

particle entrainment, bed agitation, and pressure drop. One-foot-per-second superficial velocity is in the middle of the range normally encountered [67] and was selected for this application.

The bed density of 480 kg/m<sup>3</sup> (30 lb/ft<sup>3</sup>) was based on the Calgon Carbon Corporation HGR<sup>®</sup>-P sulfur-impregnated pelleted activated carbon offering as of 2002. [68] These parameters determined the size of the vessels and the amount of carbon required. Each gasifier train has two sequential mercury removal beds; the first bed achieves 90 percent of the necessary removal, with the second bed removing the balance of the mercury necessary to meet the emissions limit of 95 percent removal. Since there are two gasifier trains per case, each case has four total carbon beds.

#### 4.4.10.3 Carbon Replacement Time

Eastman Chemicals replaces its bed every 18 to 24 months. [66] However, bed replacement is not due to mercury loading, but rather from:



- A buildup in pressure drop
- A buildup of water in the bed
- A buildup of other contaminants

For this report, a 24-month carbon replacement cycle was assumed. Under these assumptions, the mercury loading in the bed would build up to 0.6–1.1 percent by weight (wt%). Mercury capacity of sulfur-impregnated carbon can be as high as 30 wt%. [69] The mercury laden carbon is considered to be a hazardous waste.


#### 4.4.11 Sulfur Recovery/Tail Gas Cleanup

Sulfur compounds in syngas need to be removed in most gasification applications due to environmental regulations or to avoid catalyst poisoning. The Claus process is still the industry standard for sulfur recovery. Conventional three-stage Claus plants, with indirect reheat and feeds with a high H<sub>2</sub>S content, can approach 98 percent sulfur recovery efficiency. However, since environmental regulations have become more stringent, sulfur recovery plants are required to recover sulfur with over 99.8 percent efficiency. To meet these stricter regulations, the Claus process underwent various modifications and add-ons. [70]

The add-on modification to the Claus plant selected for this report can be considered a separate option from the Claus process. In this context, it is often called a tail gas treating unit (TGTU) process. The Claus process converts H<sub>2</sub>S to elemental sulfur via the following reactions:



The second reaction, the Claus reaction, is equilibrium limited. The overall reaction is:




The sulfur in the vapor phase exists as  $S_2$ ,  $S_6$ , and  $S_8$ , with the  $S_2$  predominant at higher temperatures, and  $S_8$  predominant at lower temperatures.

A simplified process flow diagram of a typical three-stage Claus plant is shown in Exhibit 4-3. [70] One-third of the  $H_2S$  is burned in the furnace with  $O_2$  from the air to give sufficient  $SO_2$  to react with the remaining  $H_2S$ . Since these reactions are highly exothermic, a boiler that recovers this heat to generate HP steam usually follows the furnace. Sulfur is condensed in a condenser that follows the HP steam recovery section. LP steam is raised in the condenser. The tail gas from the first condenser then goes to several catalytic conversion stages, usually two to three, where the remaining sulfur is recovered via the Claus reaction. Each catalytic stage consists of gas preheat, a catalytic reactor, and a sulfur condenser. The liquid sulfur goes to the sulfur pit, while the tail gas proceeds to the incinerator or for further processing in a TGTU.

#### 4.4.11.1 Claus Plant Sulfur Recovery Efficiency

The Claus reaction is equilibrium limited, and sulfur conversion is sensitive to the reaction temperature. The highest sulfur conversion in the thermal zone is limited to about 75 percent. Typical furnace temperatures are in the range of 1,093–1,427 °C (2,000–2,600 °F), and as the temperature decreases, conversion increases dramatically.

Exhibit 4-3. Typical three-stage Claus sulfur plant



Used with permission from Beychok [71]

Claus plant sulfur recovery efficiency depends on many factors:

- $H_2S$  concentration of the feed gas
- Number of catalytic stages
- Gas reheat method

In order to keep Claus plant recovery efficiencies approaching 94 to 96 percent for feed gases that contain about 20 to 50 percent H<sub>2</sub>S, a split-flow design is often used. In this version of the Claus plant, part of the feed gas is bypassed around the furnace to the first catalytic stage, while the rest of the gas is oxidized in the furnace to mostly SO<sub>2</sub>. This results in a more stable temperature in the furnace.

#### **4.4.11.2 Oxygen-Blown Claus**

One way to reduce diluent flows through the Claus plant and to obtain stable temperatures in the furnace for dilute H<sub>2</sub>S streams is the O<sub>2</sub>-blown Claus process.

The O<sub>2</sub>-blown Claus process was originally developed to increase capacity at existing conventional Claus plants and to increase flame temperatures of low H<sub>2</sub>S content gases. The process has also been used to provide the capacity and operating flexibility for sulfur plants where the feed gas is variable in flow and composition such as often found in refineries. The application of the process has now been extended to greenfield installations, even for rich H<sub>2</sub>S feed streams, to provide operating flexibility compared to conventional Claus units. At least four of the gasification plants in Europe use O<sub>2</sub>-enriched Claus units.

O<sub>2</sub> enrichment results in higher temperatures in the front-end furnace, potentially reaching temperatures as high as 1,593–1,649 °C (2,900–3,000 °F) as the enrichment moves beyond 40–70 vol% O<sub>2</sub> in the oxidant feed stream. Although O<sub>2</sub> enrichment has many benefits, its primary benefit for lean H<sub>2</sub>S feeds is a stable furnace temperature. O<sub>2</sub> enrichment also allows for tail gas recycle without N<sub>2</sub> diluent, which would be needed for an air-blown Claus system. Sulfur recovery is not significantly enhanced by O<sub>2</sub> enrichment. Because the gasification process already requires an ASU, the O<sub>2</sub>-blown Claus plant was chosen for all cases.

#### **4.4.11.3 Tail Gas Treating**

Tail gas from a typical Claus process, whether a conventional Claus or one of the extended versions of the process, usually contains small but varying quantities of COS, CS<sub>2</sub>, H<sub>2</sub>S, SO<sub>2</sub>, and elemental sulfur vapors. In addition, there may be H<sub>2</sub>, CO, and CO<sub>2</sub> in the tail gas. In order to remove the rest of the sulfur compounds from the tail gas, all the sulfur-bearing species must first be converted to H<sub>2</sub>S. Then, the resulting H<sub>2</sub>S is absorbed into a solvent and the clean gas vented or recycled for further processing. The clean gas resulting from the hydrolysis step can undergo further cleanup in a dedicated absorption unit or be integrated with an upstream AGR unit. The latter option is particularly suitable with physical absorption solvents. The approach of treating the tail gas in a dedicated amine absorption unit and recycling the resulting acid gas to the Claus plant is the one used by the Shell Claus Off-gas Treating (SCOT) process. With tail gas treatment, Claus plants can achieve overall removal efficiencies in excess of 99.9 percent.

In the case of gasification applications, the tail gas from the Claus plant can be catalytically hydrogenated and then recycled back into the system with the choice of location being technology dependent, or it can be treated with a SCOT-type process. In each of the three gasification cases the Claus plant tail gas is hydrogenated, water is separated out, the tail gas is compressed, and the gas is returned to the AGR process for further treatment.

#### **4.4.11.4 Flare Stack**

In most Claus plants, a self-supporting, refractory-lined, carbon steel (CS) flare stack is typically provided to combust and dispose of unreacted gas during startup, shutdown, and upset conditions. However, in all three gasification cases, a flare stack was included for syngas dumping during startup, shutdown, etc. Hence, a separate dedicated Claus plant flare was not required.

#### **4.4.12 Slag Handling**

The slag handling system conveys, stores, and disposes of slag removed from the gasification process. Spent material drains from the gasifier bed into a water bath in the bottom of the gasifier vessel. A slag crusher receives slag from the water bath and grinds the material into pea-sized fragments. A slag/water slurry that is between 5 and 10 percent solids leaves the gasifier pressure boundary using lockhoppers to a series of dewatering bins.

The general aspects of slag handling are the same for all three gasification cases. The slag is dewatered, the water is clarified and recycled, and the dried slag is transferred to a storage area for disposal.

In this report, the slag bins were sized for a nominal holdup capacity of 72 hours of full-load operation. At periodic intervals, a convoy of slag-hauling trucks will transit the unloading station underneath the hopper and remove a quantity of slag for disposal. While the slag is suitable for use as a component of road paving mixtures, or potentially as a landfill cover material, it was assumed in this report that the slag would be landfilled with a disposal cost.

#### **4.4.13 Steam Generation**

##### **4.4.13.1 Gas-Fired Boiler**

The gas-fired boiler (GFB) is an air-fired, multi-pressure, drum-type piece of equipment within the steam generation island. The H<sub>2</sub>-rich fuel gas exiting the PSA is mixed with air and combusted in the GFB to recover the large quantity of thermal energy that remains.

In addition to generating and superheating steam, the GFB performs reheat duty for the cold/hot reheat steam for the steam turbine, provides condensate and feedwater (FW) heating, and provides deaeration of the condensate.

Natural circulation of BFW and steam is accomplished in the GFB by utilizing differences in densities due to temperature differences of the steam. The GFB drums include moisture separators, internal baffles, and piping for FW/steam. All tubes, including economizers, superheaters, and headers and drums, are equipped with drains.

Safety relief valves are furnished in order to comply with appropriate codes and ensure a safe workplace.

Superheater, boiler, and economizer sections are supported by shop-assembled structural steel. Inlet and outlet ducts are provided to route the gases from the PSA outlet to the GFB inlet and

to the outlet. A diverter valve is included in the inlet duct to bypass the gas when appropriate. Suitable expansion joints are also included.

#### 4.4.13.2 Steam Turbine Generator and Auxiliaries

The steam turbine consists of an HP section, an IP section, and one double-flow LP section, all connected to the generator by a common shaft. The HP and IP sections are contained in a single-span, opposed-flow casing, with the double-flow LP section in a separate casing.

Main steam from the GFB and gasifier island is combined in a header, and then passes through the stop valves and control valves and enters the turbine at stream conditions shown in Exhibit 4-4. The steam initially enters the turbine near the middle of the HP span, flows through the turbine, and returns to the GFB for reheating. The reheat steam flows through the reheat stop valves and intercept valves and enters the IP section at stream conditions shown in Exhibit 4-4.

*Exhibit 4-4. Gasification steam conditions*

Steam Conditions		
Steam Parameter	Capture	Non-Capture
Main Pressure, MPa (psig)	12.4 (1,800)	11.7 (1,700)
Main Temperature, °C (°F)	510-532 (950-990)	482 (900)
Reheat Pressure, MPa (psig)	3.4 (491)	3.4 (491)
Reheat Temperature, °C (°F)	510-532 (950-990)	482 (900)

After passing through the IP section, the steam enters a crossover pipe, which transports the steam to the LP section. The steam divides into two paths and flows through the LP sections, exhausting downward into the condenser.

Turbine bearings are lubricated by a closed-loop (CL), water-cooled, pressurized oil system. The oil is contained in a reservoir located below the turbine floor. During startup or unit trip, an emergency oil pump mounted on the reservoir pumps the oil. When the turbine reaches 95 percent of synchronous speed, the main pump mounted on the turbine shaft pumps oil. The oil flows through water-cooled HXs prior to entering the bearings. The oil then flows through the bearings and returns by gravity to the lube oil reservoir.

Turbine shafts are sealed against air in-leakage or steam blowout using a positive pressure variable clearance shaft sealing design arrangement connected to an LP steam seal system. During startup, seal steam is provided from the main steam line. As the unit increases load, HP turbine gland leakage provides the seal steam. Pressure-regulating valves control the gland header pressure and dump any excess steam to the condenser. A steam packing exhauster maintains a vacuum at the outer gland seals to prevent leakage of steam into the turbine room. Any collected steam is condensed in the packing exhauster and returned to the condensate system.

The generator is a H<sub>2</sub>-cooled synchronous type, generating power at 24 kV. A static, transformer type exciter is provided. The generator is cooled with a H<sub>2</sub> gas recirculation system using fans mounted on the generator rotor shaft. The heat absorbed by the gas is removed as it passes over finned tube gas coolers mounted in the stator frame. Gas is prevented from escaping at the rotor shafts by a CL oil seal system. The oil seal system consists of storage tank, pumps, filters, and pressure controls, all skid-mounted.

The steam turbine generator (STG) is controlled by a triple-redundant, microprocessor-based electro-hydraulic control system. The system provides digital control of the unit in accordance with programmed control algorithms, operator interface, and datalink interfaces to the balance-of-plant distributed control system (DCS) and incorporates on-line repair capability.

#### **4.4.13.3 Condensate System**

The condensate system transfers condensate from the condenser hotwell, through a series of economizers, to the deaerator. The economizers may exchange heat with either the tail-gas recycle coolers, LTHR system, and/or the low-temperature economizer section in the GFB, depending on the case. The system consists of one main condenser; two 50 percent capacity, motor-driven, vertical condensate pumps; one gland steam condenser; and a low-temperature tube bundle in the GFB. Condensate is delivered to a common discharge header through separate pump discharge lines, each with a check valve and a gate valve. A common minimum flow recirculation line discharging to the condenser is provided to maintain minimum flow requirements for the gland steam condenser and the condensate pumps.

#### **4.4.13.4 Feedwater System**

The function of the FW system is to pump the various FW streams from the deaerator storage tank in the GFB to the respective steam drums. Two 50 percent capacity boiler feed pumps are provided for each pressure level (HP and LP). Each pump is provided with inlet and outlet isolation valves, and outlet check valve. Minimum flow recirculation to prevent overheating and cavitation of the pumps during startup and low loads is provided by an automatic recirculation valve and associated piping that discharges back to the deaerator storage tank. Pneumatic flow control valves control the recirculation flow.

The FW pumps are supplied with instrumentation to monitor and alarm on low oil pressure, or high-bearing temperature. FW pump suction pressure and temperature are also monitored. In addition, the suction of each boiler feed pump is equipped with a startup strainer.

#### **4.4.13.5 Main and Reheat Steam Systems**

The function of the main steam system is to convey main steam generated in the synthesis gas cooler (SGC) and GFB from the GFB superheater outlet to the HP turbine stop valves. The function of the reheat system is to convey steam from the HP turbine exhaust to the GFB reheater (RH), and to the turbine reheat stop valves.

Main steam at conditions shown previously in Exhibit 4-4 exits the GFB superheater through a motor-operated stop/check valve and a motor-operated gate valve and then is routed to the HP turbine. Cold reheat steam exits the HP turbine, flows through a motor-operated isolation gate

valve, to the GFB reheater. Hot reheat steam at the conditions shown previously in Exhibit 4-4 exits the GFB RH through a motor-operated gate valve and is routed to the IP turbines.

Steam piping is sloped from the GFB to the drip pots located near the steam turbine for removal of condensate from the steam lines. Condensate collected in the drip pots and in low-point drains is discharged to the condenser through the drain system.

Steam flow is measured by means of flow nozzles in the steam piping. The flow nozzles are located upstream of any branch connections on the main headers.

Safety valves are installed to comply with appropriate codes and to ensure the safety of personnel and equipment.

#### **4.4.13.6 Circulating Water System**

The circulating water system (CWS) is a closed-cycle cooling water system that supplies cooling water to the condenser to condense the main turbine exhaust steam. The system also supplies cooling water to the AGR plant as required, and to the auxiliary cooling system. The auxiliary cooling system is a CL process that utilizes a higher quality water to remove heat from compressor intercoolers, oil coolers, and other ancillary equipment and transfers that heat to the main circulating cooling water system in plate and frame HXs. The heat transferred to the circulating water in the condenser and other applications is removed by a cooling tower.

The system consists of two 50 percent capacity vertical circulating water pumps (CWPs), a mechanical draft evaporative cooling tower, and CS cement-lined interconnecting piping. The pumps are single-stage vertical pumps. The piping system is equipped with butterfly isolation valves and all required expansion joints. The cooling tower is a multi-cell wood frame counterflow mechanical draft cooling tower.

The condenser is a single-pass, horizontal type with divided water boxes. There are two separate circulating water circuits in each box. One-half of the condenser can be removed from service for cleaning or for plugging tubes. This can be done during normal operation at reduced load.

The condenser is equipped with an air extraction system to evacuate the condenser steam space for removal of non-condensable gases during steam turbine operation and to rapidly reduce the condenser pressure from atmospheric pressure before unit startup and admission of steam to the condenser.

#### **4.4.13.7 Raw Water, Fire Protection, and Cycle Makeup Water Systems**

The raw water system supplies cooling tower makeup, steam cycle makeup, service water and potable water requirements. The water source is 50 percent from a POTW and 50 percent from groundwater (makeup water quality is provided in Section 2.1). Booster pumps within the plant boundary provide the necessary pressure.

The fire protection system provides water under pressure to the fire hydrants, hose stations, and fixed water suppression system within the buildings and structures. The system consists of pumps, underground and aboveground supply piping, distribution piping, hydrants, hose

stations, spray systems, and deluge spray systems. One motor-operated booster pump is supplied on the intake structure of the cooling tower with a diesel engine backup pump installed on the water inlet line.

The cycle makeup water system provides high-quality demineralized water for makeup to the GFB cycle and for steam injection ahead of the WGS reactors.

The cycle makeup system consists of two 100 percent trains, each with a full-capacity activated carbon filter, primary cation exchanger, primary anion exchanger, mixed bed exchanger, recycle pump, and regeneration equipment. The equipment is skid-mounted and includes a control panel and associated piping, valves, and instrumentation.

#### **4.4.14 Process Water Systems**

##### **4.4.14.1 Process Water Sources**

This section provides brief technology descriptions of equipment that produces process wastewater from gasification plants, including the syngas scrubber, LTHR, sour water stripper (SWS), NH<sub>3</sub> wash, and process water drum.


##### **4.4.14.1.1 Syngas Scrubber**

The majority of PM is removed from the syngas by upstream equipment, leaving only the finest particulates remaining prior to the syngas scrubber. Most of the remaining particulate is removed in the scrubber, although the primary concern of the syngas scrubber is to facilitate high-efficiency gas cleaning by maximizing the contact surface area between liquid and gas, as gases such as HCl are eliminated through absorption into the scrubbing liquid, which in this case is an alkali solution of water and NaOH.

A HP ejector venturi scrubber is particularly suitable for high-efficiency gas cleaning in HP operations and is frequently selected to facilitate this process, with expected HCl removal efficiencies in excess of 95 percent. [72] [73]

Exhibit 4-5 provides a diagram of an ejector type venturi scrubber. The gas enters the top section of the system where it comes into contact with a spray of fine water droplets, the spray is directed into a chamber that is shaped to conduct the gas through the atomized droplets, [74] where the HCl and other soluble gases are absorbed. The majority of the remaining particulates are removed from the gas stream by impingement against the high-velocity droplets. The liquid is collected in a reservoir, and the gas exits the side of the reservoir opposite the entrance. The liquid is pumped from the reservoir through a settling tank for particulate removal before being recycled.

**Exhibit 4-5. Example diagram of an ejector type venturi scrubber**



Source: EPA [75]


The ejector type venturi scrubbers are typically constructed of 316L stainless steel, operate with a relatively low pressure drop (approximately 2–3 percent of the inlet pressure) [76], have a liquid injection pressure of around 0.83 MPa (120 psi) above that of the inlet gas stream [74], and require between 30 and 100 gallons per 1,000 ft<sup>3</sup> of inlet gas. [72]

While 316L stainless steel has a very high tolerance to alkali solutions without concern for corrosion (concentrations of NaOH of up to 50 wt% can be used with negligible corrosion rates [77]), it can only withstand up to 2,000 ppmw of chloride ions. Considering the cost of the downstream ZLD equipment, priority was given to maximizing the chloride concentration and minimizing the process water discharge flowrate. Because 317L stainless steel can withstand up to 5,000 ppmw Cl<sup>-</sup>, it was selected as the material of choice for the scrubber system. [78] The blowdown from the syngas scrubber is adjusted to maintain a Cl<sup>-</sup> concentration of 5,000 ppmw, or lower.

While the tolerance of both 316L and 317L to alkali solutions is very high, the pitting rate of both steels rapidly increases with decreasing pH. At a pH of 5, severe pitting occurs with chloride concentrations as low as 500 ppmw. [79] In order to prevent excessive pitting, it is recommended that sufficient NaOH be added in the makeup water to maintain an alkali solution in the effluent. [72] [80]

Exhibit 4-6 provides a simplified block flow diagram (BFD) of the syngas scrubber system, including the alkali injection, makeup water, blowdown, and recycle. The alkali solution is assumed to be 50 wt% NaOH in water. The final cooling water HX cools the injection water to 21.1 °C (70 °F). The two process HXs are integrated with the syngas preheating system prior to the GFB and the WGS FW preheating system. The makeup water to the syngas scrubber is sourced from either ZLD condensate or process wastewater, depending on the selection of technologies utilized in each case.

*Exhibit 4-6. Simplified syngas scrubber block flow diagram*




#### 4.4.14.1.2 Low Temperature Heat Recovery

The gas exiting the WGS reactors enters the LTHR system before entering the NH<sub>3</sub> wash. The purpose of the LTHR system is to cool the syngas to the required operating temperature of the mercury control system, the NH<sub>3</sub> wash, and the AGR system, while recovering low grade heat.

As shown in Exhibit 4-7, LTHR consists of a series of shell-and-tube HXs; [81] depending on the inlet temperature, the LTHR system consists of one to three process integrated HXs, followed by a final heat exchange with cooling water. [82]

**Exhibit 4-7. Simplified low temperature heat recovery system**



During cooling, a significant amount of water is condensed, along with 55 percent of the  $\text{NH}_3$  present at the inlet and nearly all the remaining  $\text{HCl}$ , leaving only trace amounts. Small amounts of  $\text{CO}_2$ ,  $\text{H}_2$ , and  $\text{H}_2\text{S}$  are also removed. Knockout drums are located after each HX to remove condensed water.

The effluent from the LTHR system is combined with that of the  $\text{NH}_3$  wash and is flashed to 0.5 MPa (65 psia). The vapor product is combined with the compressed sour gas from the SWS and sent to the Claus plant for incineration. The effluent from the flash drum is sent to the process water collection drum for use as process water recycle.

The first of the LTHR HXs is used to produce low pressure steam, which is used in the steam cycle, and the second of the LTHR HXs is used for fuel gas preheat prior and/or steam cycle FW preheat, depending on the plant configuration. The third LTHR HX is used to preheat steam cycle FW.

To withstand the  $\text{NH}_3$  concentration in the effluent, which can approach 60,000 ppmw, 316L stainless steel was selected as the material of construction for its high tolerance to  $\text{NH}_3$ , as discussed in Section 4.4.14.1.5.

#### 4.4.14.1.3 Primary Sour Water Stripper

As  $\text{NH}_3$  is a highly soluble gas, it has a tendency to build-up in the plant process water. The solution is to utilize a combination of technologies that result in the presence of excess water from the process water collection drum that necessitates the utilization of a SWS to remove  $\text{NH}_3$ ,  $\text{H}_2\text{S}$ , and other dissolved gases, so that the process water can be utilized as makeup water to downstream systems such as the  $\text{NH}_3$  wash.

The presence of acids, chlorides, sulfates, and formates suppress  $\text{NH}_3$  stripping. [83] Since small quantities of  $\text{HCl}$  are present in the sour water as a result of the LTHR effluent (discussed in

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Section 4.4.14.1.2), which reacts with NH<sub>3</sub> to form ammonium chloride (NH<sub>4</sub>Cl), small amounts of NaOH may be added to react with the NH<sub>4</sub>Cl, releasing the NH<sub>3</sub> and producing the heat stable salt (HSS) sodium chloride (NaCl). [83] The caustic would be fed onto a tray far enough down the column that most of the H<sub>2</sub>S has already been stripped out (tray 35 of 40). No more NaOH should be injected than is necessary to maintain pH, as it will chemically bind H<sub>2</sub>S into the solution. [83] Other alkaline contaminants that can trap H<sub>2</sub>S include sodium, potassium, and magnesium; however, they were assumed to be present in negligible quantities in this report.

HSS can cause the protonation of NH<sub>3</sub> and, therefore, cause a residual amount of NH<sub>3</sub> that cannot be removed (as little as 300 ppmw of HSS can prevent the treated water from reaching NH<sub>3</sub> concentrations of below 100 ppmw), which limits the usefulness of the effluent as recycle water. However, HSS can significantly improve H<sub>2</sub>S removal rates, as they are weak acids. [83]

Despite the reasons presented above for adding caustic to the SWS, there are also potential adverse consequences, including a negative impact on the removal of H<sub>2</sub>S, the fact that NaOH reacts with HCl to form NaCl, and the beneficial role that the presence of HCl can have on H<sub>2</sub>S removal. Based on the net impacts, it was determined that the addition of NaOH would not be necessary and would not be utilized in this report.


A selection of typical values for key operating parameters for a SWS are provided in Exhibit 4-8.

**Exhibit 4-8. Typical operating parameters for sour water strippers**

Parameter	Typical
Column Stages [83]	35-45
NH <sub>3</sub> in Effluent, ppmw [83]	30-80
H <sub>2</sub> S in Effluent, ppmw [84]	<<1
Steam/Sour Water Feed, kg/m <sup>3</sup> (lb/ft <sup>3</sup> ) [84]	60-300 (3.7-18.7)
Column Operating Pressure, MPa (psia) [84]	0.1-0.5 (16-65)
pH of Sour Water Feed [83]	~9

Exhibit 4-9 provides a diagram of an SWS column. The excess water from the process water collection drum (described in Section 4.4.14.1.6) constitutes the sour water feed stream to the SWS. The sour water feed is preheated against the treated water product effluent prior to being injected at the top of the column. The sour water flows downward through the column packing [84] against an up-flow of sour gases and steam. A portion of the bottom water is recycled through the reboiler back to the column to increase the rate of recovery of the sour gases. The vapor product is passed through a partial-vapor condenser with the sour gases being separated from the condensate in the reflux drum. The condensate is returned to the column to increase the retention rate of water in the column.

**Exhibit 4-9. Simplified sour water stripper diagram**



To withstand the  $\text{NH}_3$  concentration in the sour water feed stream, which can exceed 20,000 ppmw, 316L stainless steel was selected as the material of construction for its high tolerance to  $\text{NH}_3$ , as discussed in Section 4.4.14.1.5.

The sour water is fed to the SWS above the first stage at 0.4 MPa (65 psia), with the sour gas produced at 0.11 MPa (16 psia) and the effluent produced at stage 40 at 0.15 MPa (22 psia). The SWS utilizes an external kettle-type reboiler with 0.4 MPa (65 psia) process steam used as its heat source. [83] The partial-vapor condenser receives cold water from the cooling tower at 16 °C (60 °F) and the water is returned to the cooling tower at 27 °C (80 °F).

The SWS is designed to recover 99.5 percent by mole (mol%) of  $\text{NH}_3$  while retaining 99.6 mol% of water. Only trace amounts of other dissolved gases remain, including  $\text{H}_2\text{S}$ . The sour gas is sent to the Claus plant for incineration, and the clean effluent is used as wash water in the  $\text{NH}_3$  wash system.

#### 4.4.14.1.4 Secondary Sour Water Stripper

In each gasification case, the selected combination of plant technologies resulted in excess process wastewater that required disposal. However, to qualify for ZLD, this wastewater needed to be utilized as process makeup water. Since the Shell gasifier requires steam addition at elevated pressure (~5.1 MPa [~740 psia]), it was determined that the production of mid-grade steam from process water would be beneficial, rather than extracting high-grade steam and letting it down to the required pressure.

The use of raw process water presents multiple design and operation issues, as these streams contain appreciable quantities of dissolved solids, which would cause fouling on the surface of the boiler tubes. Of particular concern is the presence of NaCl, which is typically limited to 10 ppmw in the boiler water feed. [85] In order to avoid this, the feed to the secondary SWS was sourced from the condensate of the ZLD processes (discussed in Section 4.4.14.2). This effluent is free from suspended solids, and contains less than 20 ppm of dissolved solids, consisting primarily of sodium- and calcium-based constituents. It is assumed that the sodium-based constituents comprise less than half of the total dissolved solids. Therefore, the only contaminant of concern is NH<sub>3</sub>, which is limited to 200 ppmw at the desired operating pressure. [85]

The design of the secondary SWS is nearly identical to that of the primary SWS. The only two differences being that the secondary SWS operates with a feed pressure of 0.13 MPa (19.3 psia) and the column is designed to achieve an effluent with an NH<sub>3</sub> concentration of 200 ppmw. The sour gas from the secondary SWS is compressed and sent to the Claus plant for incineration.

#### 4.4.14.1.5 NH<sub>3</sub> Wash

The operation of solvent-based AGR systems is sensitive to the presence of NH<sub>3</sub>, which has a tendency to concentrate in the CO<sub>2</sub> reflux loop. [86] NH<sub>3</sub> forms ammonium sulfide with H<sub>2</sub>S that is a contaminant in the product CO<sub>2</sub> and the off gas, and it can form ammonium carbamate with CO<sub>2</sub> that can cause plugging of equipment. [87] If concentrations are allowed to build-up to the point that performance starts to be impacted, the conventional recovery measure would consist of blowing down a portion of the reflux stream, which would then be disposed. [86]

In order to minimize the loss of solvent and to maximize performance of the AGR, a pre-scrubber for NH<sub>3</sub> control is typically utilized to maintain NH<sub>3</sub> concentrations at or below 10 ppmv in the syngas. [86] [88] [89] A spray tower absorption column is often the scrubber of choice for highly soluble gases, such as NH<sub>3</sub>, in systems that operate at low temperatures. [90] [86] [82]


NH<sub>3</sub>, like HCl, is eliminated through absorption into the scrubbing liquid, [73] and as such, the efficiency of scrubbers increases with decreasing temperature; typical scrubber operating temperatures are around 26.7–29.4 °C (80–85 °F). [91] In order to achieve this, a cooling stage is included in the low temperature HX design (discussed in Section 4.4.14.1.2) that lowers the temperature to 29.4 °C (85 °F) and the wash water is cooled to 21.1 °C (70 °F) in a HX prior to injection.

A single-stage system can expect to achieve between 70 [86] and 85 [91] percent NH<sub>3</sub> reduction, with a typical configuration consisting of approximately 5 stages, [91] which can achieve total NH<sub>3</sub> reduction of over 99 percent. [91] To achieve the target concentration of NH<sub>3</sub> in the clean syngas of 10 ppm, 4 stages were required.

Exhibit 4-10 provides a diagram of an example spray tower absorption column. The spray tower operates by having a counter-current raw gas flow upward against a downward fine-mist spray of water. The water functions to both cool the syngas and absorb the NH<sub>3</sub>, along with other soluble gases. The cleaned gas exits the top of the column and the water exits the bottom. To

maximize  $\text{NH}_3$  removal, the water is not recycled but is instead sent to a process water collection drum (discussed in Section 4.4.14.1.6) to be utilized as process water makeup. The water demand for the spray tower is primarily sourced from the effluent of the SWS, [92] [91] with raw water making up the balance, as necessary.

**Exhibit 4-10. Example diagram of a spray tower absorption column**



Source: EPA [75]


The  $\text{NH}_3$  water wash column has the same relative pressure drop and water to gas ratio as the syngas scrubber, described in Section 4.4.14.1.1.

While spray scrubbers are generally constructed of carbon steel, [92] 316L stainless steel is required for high  $\text{NH}_3$  concentration applications. [93] Considering the concentration of  $\text{NH}_3$  can exceed 20,000 ppmw in the scrubber effluent and dissolved  $\text{CO}_2$  is present in the system, 316L stainless steel was the material of choice for this study since no significant deterioration occurs in the presence of  $\text{NH}_3$  at concentrations as high as 6 percent [60,000 ppmw]. [94]

#### **4.4.14.1.6 Process Water Drum**

The process water drum, depicted in Exhibit 4-11, is a collection tank and distribution point for process wastewater. The process water from various sources such as the Claus plant, ZLD process water treatment system, and  $\text{NH}_3$  wash are collected together before being distributed to processes with a water demand, such as the syngas scrubber and gasifier.

**Exhibit 4-11. Example diagram of a process water drum**



As is the case with the process wastewater sources, the process water drum would be subjected to a high concentration of  $\text{NH}_3$  in the process water (greater than 20,000 ppmw). Therefore, 316L stainless steel is utilized as the material of construction, due to its high tolerance for  $\text{NH}_3$  and  $\text{CO}_2$ , as discussed in Section 4.4.14.1.5.

#### 4.4.14.1.7 Gasification Wastewater Quality

Gasification wastewater quality, summarized in Exhibit 4-12, represents the assumed quality of the water exiting the syngas scrubber that must be treated under the ELG rule, as stated earlier in Section 2.7.2. The gasification water quality is based on internal information from Black & Veatch IGCC projects utilizing a GE gasifier and discussions with GEP regarding their experience with gasification wastewater. The water quality is assumed to not be significantly different with a Shell gasifier. Exhibit 4-12 includes a range of values, an average, and the final selected gasification wastewater quality.

The wastewater composition reported in the following table is based on water qualities from actual operations and adjusted to account for chloride. The design concentration of each constituent is individually representative of a plant configuration comparable to those in this study. However, due to the interaction and interdependencies of each constituent and the multitude of potential species, the wastewater quality cannot be considered representative as a whole. The wastewater quality is intended to inform users of the contaminants likely present, and at what concentrations they may be expected at, to facilitate appropriate equipment selection and design.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 4-12. Gasification wastewater quality**

Parameter	Gasification Wastewater (Range)	Gasification Wastewater (Average)	Gasification Wastewater (Final)
pH	5.5–7.0		7.0
Chemical O <sub>2</sub> demand, ppm		1,500	1,500
Biological O <sub>2</sub> demand, ppm		1,000	1,000
Specific Conductance, μS/cm			14,000
Ammonia as N, ppm		<80	<80
Suspended Solids, ppm		<50	5
Total Dissolved Solids, ppm			14,995
Chloride as Cl, ppm		5,000	5,000
Sodium as Na, ppm		3,250	3,250
Formate, ppm		3,200	5,333
M-Alkalinity as CaCO <sub>3</sub> , ppm <sup>A</sup>	600–2,000		700
Calcium as Ca, ppm	20–270		270
Sulfate as SO <sub>4</sub> , ppm	25–100		100
Silica as SiO <sub>2</sub> , ppm	25–50		50
Barium (total), ppm	0.20–40	20	40
Magnesium as Mg, ppm	4–20		20
Aluminum, ppm			20
Boron (total), ppm	2.5–10	5	10
Iron (total), ppm	2.5–10	5	10
Selenium (total), ppm	2.5–10	5	10
Sulfide, ppm		<10	<10
Cyanide, ppm		<5	<5
Chromium (total), ppm	0.5–2.0	1	2
Phosphorus, ppm	0.5–2.0	1	2
Potassium, ppm			2
Fluorine, ppm			2
Nickel (total), ppm	0.1–1.0	0.5	1
Molybdenum (total), ppm	0.2–0.8	0.4	0.8
Titanium (total), ppm	0.2–0.8	0.4	0.8
Lithium, ppm			0.3
Antimony (total), ppm	0.005–0.200	0.1	0.2
Arsenic (total), ppm	0.005–0.200	0.1	0.2
Lead (total), ppm	0.05–0.2	0.1	0.2
Thallium (total), ppm	0.05–0.2	0.1	0.2

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Parameter	Gasification Wastewater (Range)	Gasification Wastewater (Average)	Gasification Wastewater (Final)
Vanadium (total), ppm	0.025–0.1	0.05	0.1
Uranium, ppm			0.1
Cobalt, ppm			0.1
Manganese (total), ppm	0.015–0.06	0.03	0.06
Beryllium (total), ppm	0.01–0.04	0.02	0.04
Copper (total), ppm	0.01–0.04	0.02	0.04
Zinc (total), ppm	0.01–0.04	0.02	0.04
Thorium, ppm			0.04
Cadmium (total), ppm	0.005–0.02	0.01	0.02
Tin, ppm			0.02
Mercury (total), ppm	0.002–0.008	0	0.01

<sup>a</sup>Alkalinity is reported as CaCO<sub>3</sub> equivalent, rather than the concentration of HCO<sub>3</sub>. The concentration of HCO<sub>3</sub> can be obtained by dividing the alkalinity by 0.82

The gasification wastewater composition will be dependent on several factors, including composition of the coal, makeup water quality, syngas treatment systems that recycle water to the syngas scrubber, and other factors. The wastewater quality defined above will form the basis for discussion of the process water treatment systems, discussed in the following section.

#### 4.4.14.2 Process Water Treatment

The updated ELG rule established gasification wastewater as a new category, with discharge limits that must be met. The gasification wastewater from the balance of plant is recycled within the gasification and syngas cleanup process, ultimately being utilized as makeup to the syngas scrubber. Therefore, all streams detailed in the updated ELG rule are included in the syngas scrubber blowdown (primary sources are described in Section 4.4.14.1) and can be treated by a single system with a composition described in Section 4.4.14.1.7.

It was a goal of this study to eliminate process water discharge in all the gasification cases presented in this report. Process water discharge is defined as any water discharged from systems that provide direct contact with contaminants foreign to the source-water (syngas scrubber, NH<sub>3</sub> wash, LTHR) to local waterways. Under these boundaries, blowdown from both the steam cycle and cooling tower are exempt from ZLD classification, provided that no process wastewater is utilized as makeup to either of these systems.

The equipment utilized to achieve ZLD is varied and dependent on several factors, such as contaminants being treated (e.g., selenium or chlorine), general water quality (e.g., pH), end use of product (e.g., process makeup or drinking water), land availability (evaporative ponds), geology characteristics (e.g., deep-well injection), and site characteristics (e.g., wetlands).

Wabash River, Kemper County, and Duke Edwardsport were designed with, and use, vapor-compression evaporation systems to treat their gasification wastewater as part of a ZLD operating practice. [39]

While multiple process configurations were assessed for feasibility of complying with the ELG rule, given this study’s intention of maintaining general applicability of the cases presented, and the prevalence of utilizing ZLD operating practices in existing gasification plants, systems that would achieve ZLD were selected in all cases.


The process water treatment system for gasification cases includes a vacuum flash, brine concentrator, and crystallizer.

#### 4.4.14.2.1 Vacuum Flash

The primary purpose of the vacuum flash system is to remove dissolved gases, such as NH<sub>3</sub>, CO, H<sub>2</sub>, and H<sub>2</sub>S. The separation of dissolved gases prior to the brine concentrator aids in maintaining stable operation and avoiding upsets. Considering the desire to utilize the ZLD system condensate as FW to the auxiliary boiler, and the sensitivity of the auxiliary boiler to NH<sub>3</sub> (discussed in 4.4.14.1.3), it is particularly desirable to remove as much NH<sub>3</sub> as possible prior to the brine concentrator.

Exhibit 4-13 provides a diagram of a vacuum flash system. The blowdown from the syngas scrubber enters the LP drum where it is flashed to 0.5 MPa (70 psia). [95] The effluent of the LP drum enters the vacuum drum, where it is flashed to 0.05 MPa (7.5 psia). The effluent from the vacuum drum is then sent to the brine concentrator. The vapor overhead from both the LP and vacuum drums is first cooled to 46 °C (115 °F), by preheating fuel gas prior to the GFB, before being cooled further to 29 °C (85 °F) using cooling water. The vacuum flash is compressed in a vacuum pump before both overhead (OH) streams are sent to the overhead drum, where they are flashed to 0.2 MPa (35 psia). [95] The sour gas is compressed to 0.4 MPa (65 psia) and sent to the Claus plant for incineration and the effluent is sent to the process water drum.

*Exhibit 4-13. Simplified diagram of vacuum flash system*



While the syngas scrubber limits the chloride concentration of the blowdown stream to 5,000 ppmw, a portion of the water present in the blowdown will be lost with the NH<sub>3</sub> in the LP and

vacuum flash drums, resulting in an increased chloride concentration in the effluent of the LP and vacuum flash drums.

The effluent from the LP flash drum exceeds the chloride tolerance of 317L stainless steel (5,000 ppmw). Therefore, a more advanced stainless steel will be required in both the LP and vacuum flash drum, such as 317LM or 317LMN. [96] The OH flash drum is required to be constructed of 316L stainless steel due to the high concentration of  $\text{NH}_3$  (greater than 40,000 ppmw), as discussed in Section 4.4.14.1.2.

#### 4.4.14.2.2 Brine Concentrator

A brine concentrator is a thermal evaporation process that is often selected as a component of a wastewater treatment system and is utilized as the first step in this study. There are two primary categories of evaporators used in the wastewater treatment industry: thin film and forced circulation. Most brine concentrators in operation are thin film evaporators configured to use a mechanical vapor compression vertical tube evaporation process, which partially evaporates water from the incoming waste stream and leaves behind a concentrated salt solution.

As NaOH is used for HCl scrubbing (discussed in Section 4.4.14.1.1), the wastewater contains primarily sodium-based salts, which are easy to crystallize compared to calcium- and magnesium-based salts, which are highly soluble and difficult to evaporate to a solid product. Therefore, the system can achieve full ZLD without a purge from the crystallizer.

Due to the nature of the salts and the low total suspended solids<sup>f</sup> (5 ppmw) in gasification wastewater, pretreatment upstream of the brine concentrator is not required. However, gasification wastewater typically contains constituents that will precipitate from solution within the brine concentrator when heated, adhering to the evaporator surface. While a seeded slurry process can be used to reduce precipitation on tube walls (calcium sulfate is added as a precipitation surface for low solubility salts), scaling cannot be completely eliminated through this method. Therefore, antiscalant addition was selected over seeding, which is fed at multiple points in the system.

To minimize carryover into downstream equipment, an antifoam is added to prevent foaming caused by biological  $\text{O}_2$  demand, chemical  $\text{O}_2$  demand, and other organics.

Lastly, sulfuric acid is added to prevent fouling and corrosion, as well as maintain consistent brine properties.


Exhibit 4-14 provides a depiction of a brine concentrator [97] and consists of a HX, heat transfer tubes, sump, sump pump, and compressor. The process water (depicted as “Wastewater”) from the vacuum flash is pumped (not shown) through a HX, where its temperature is raised to the boiling point by the distillate product of the brine concentrator. While the depiction shows a deaerator following the HX, it is not included in the design utilized in this study as the vacuum flash serves the same purpose of removing dissolved gases. From the HX, the process water

---

<sup>f</sup> The feedwater to the brine concentrator is limited to 50 ppmw TSS to prevent plugging the inlet plate and frame heat exchanger.

enters the brine concentrator and is combined with the brine slurry in the sump. The brine slurry is recirculated from the sump to a floodbox at the top of a bundle of heat transfer tubes. [98] As the brine falls through the heat transfer tubes to the sump, a portion of the water evaporates and passes through a mist eliminator (not shown) before entering the vapor compressor. [98] The compressed vapor is sent to the outside of the heat transfer tubes where it is condensed against the brine falling inside the tubes. The condensed distillate is pumped back through the HX, where it heats the incoming process water. A small amount of waste brine is blown down from the sump to control the total dissolved solids (TDS). [98]

*Exhibit 4-14. Example diagram of a brine concentrator*



*Copyright General Electric Company; used with permission [97]*

The brine concentrator is expected to produce an effluent with up to 500,000 TDS [99], with typical performance achieving between 200,000 and 300,000 TDS. [100] Given the elevated operating temperature and the use of NaOH in the upstream syngas scrubber for salt conversion, along with the high solubility of NaCl, it was assumed that 250,000 TDS would be achievable.


The brine concentrator operates at ambient pressure, and the vapor compressor varies the outlet pressure to ensure that sufficient heat is available to preheat the incoming process wastewater (0.14 MPa [20.6 psia]).

The brine concentrator must be constructed out of exotic materials to withstand the corrosive nature of the highly concentrated product stream. Either Inconel 625 or Hastelloy C276 can be used for piping and equipment construction; however, titanium would be required for the HX tubes.

#### 4.4.14.2.3 Crystallizer

A crystallizer is often selected as a component of a wastewater treatment system and is utilized as the second step in this study. Exhibit 4-15 provides a depiction of a forced-circulation, steam-driven crystallizer [97] and consists of two HXs and a pump.

*Exhibit 4-15. Example diagram of a forced-circulation, steam-driven crystallizer*



*Copyright General Electric Company; used with permission [97]*

The process water (depicted as feed) from the brine concentrator is sent to the crystallizer sump, where the sump pump circulates the brine through a shell and tube HX. Because the tubes are flooded, the brine is under pressure and will not boil, which prevents scaling in the tubes. [97] The brine enters the crystallizer vapor body at an angle, where it swirls in a vortex. [97] As the water in the brine evaporates, crystals begin to form. The majority of the brine is recirculated back to the heater; however, approximately 20 percent [97] is blown down to the centrifuge/filter press for dewatering (depicted as “To Filter Press”, but not shown). The water from the centrifuge and filter press is returned and mixed with the process water feed from the brine concentrator (not shown). The vapor from evaporation passes through a mist eliminator to remove entrained particles. [98] The product vapor is sent to a HX to be condensed against cooling water. The hot cooling water is returned to the cooling tower and the resulting condensate is utilized as process water makeup. An antifoam chemical feed is required to control foaming within the crystallizer.

An alternative configuration is to use a vapor compressor, rather than plant process steam, to provide heat to the system. In this alternative configuration, the compressed vapor heats the recirculating brine as it condenses. [98] The advantages of this process are the elimination of the condensing HX and process steam extraction in exchange for an electrical auxiliary load. Considering the energy penalties of using an electrical compressor versus process steam, along with the concern of sufficient vapor product to provide heat to the system, it was determined that a steam-driven crystallizer was most suitable for the cases in this study.

As with the brine concentrator, the crystallizer operates at ambient pressures and requires exotic materials of construction to withstand the corrosive concentrations of brine. Either Inconel 625 or Hastelloy C276 can be used for piping and equipment construction; however, titanium would be required for HX tubes.

The use of sulfuric acid for pH control in the brine concentrator results in the elimination of NaOH and the production of  $\text{Na}_2\text{SO}_4$ , which is removed as a dissolved solid in the moisture of the salt cake. It is assumed that the impurities present in the gasification wastewater result in a waste product, rather than a salable product, which is transported off-site to a waste-disposal site.

The combined distillate stream from the brine concentrator and crystallizer has a TDS level of less than 20 ppmw, generally consisting primarily of sodium and calcium as carryovers. For the purposes of this study, it is assumed that the combined distillate consists of less than 10 ppmw NaCl.

#### **4.4.15 Accessory Electric Plant**

The accessory electric plant is the same as in the reforming plants, described in Section 3.3.6.

#### **4.4.16 Instrumentation and Control**

An integrated plant-wide DCS is provided. The DCS is a redundant microprocessor-based, functional DCS. The control room houses an array of multiple video monitors and keyboard units. The monitor/keyboard units are the primary interface between the generating process and operations personnel. The DCS incorporates plant monitoring and control functions for all the major plant equipment. The DCS is designed to be operational and accessible 99.5 percent of the time that it is required (99.5 percent availability). Startup and shutdown routines are manually implemented, with operator selection of modular automation routines available. The exception to this, and an important facet of the control system for gasification, is the critical controller system, which is a part of the license package from the gasifier supplier and is a dedicated and distinct hardware segment of the DCS.

This critical controller system is used to control the gasification process. The partial oxidation of the fuel feed and  $\text{O}_2$  feed streams to form a syngas product is a stoichiometric, temperature- and pressure-dependent reaction. The critical controller utilizes a redundant microprocessor executing calculations and dynamic controls at 100- to 200-millisecond intervals. The enhanced execution speeds as well as evolved predictive controls allow the critical controller to mitigate process upsets and maintain the reactor operation within a stable set of operating parameters.

#### **4.4.17 Miscellaneous Systems**

An onsite water treatment facility treats all runoff, cleaning wastes, blowdown, and backwash. It is anticipated that the treated water will be suitable for discharge into existing systems and be within EPA standards for suspended solids, oil and grease, pH, and miscellaneous metals.

The waste treatment system is minimal and consists, primarily, of neutralization and oil/water separators (along with the associated pumps, piping, etc.).

A natural gas supply line has been included in all cases for start-up or emergency fuel.

Miscellaneous systems consisting of natural gas, service air, instrument air, and service water are provided. All truck roadways and unloading stations inside the fence area are provided.

#### **4.4.18 Performance Summary Metrics**

This section details the methodologies of several metrics reported in the performance summaries. The effective thermal efficiency is calculated in the same manner as in the reforming cases, shown in Section 3.3.10.1. Net power is a negative value in Case 4 and Case 5 and is a positive value in Case 6. The cold gas efficiency is also calculated using the equation described in Section 3.3.10.2.

##### **4.4.18.1 Steam Turbine Efficiency**

The steam turbine efficiency is calculated by taking the steam turbine power produced and dividing it by the difference between the thermal input and thermal output. This calculation is represented by the following equation:

$$STE = \frac{STP}{(TI - TO)} * 100\%$$

Where:

**STE** – steam turbine efficiency

**STP** – steam turbine power

**TI** – thermal input

**TO** – thermal output

Depending on the case, the thermal input is considered to include the main steam, makeup water, energy added during reheat, LP steam from the GFB, and/or IP steam from the WGS.

The IP blowdown, HP blowdown, and superheater losses are also credited to the thermal input as they are extracted from the cycle prior to the main steam but after the condensate boiler FW.

The thermal output is considered to be the BFW from the condenser and any extractions, such as the gasifier steam and the 1.7 MPa (250 psia) header.

##### **4.4.18.2 Steam Turbine Heat Rate**

The steam turbine heat rate is calculated by taking the inverse of the steam turbine efficiency. This calculation is represented by the following equation:

$$STHR = \frac{1}{STE} * 3,412 \text{ Btu/kWh}$$

Where:

**STHR** – steam turbine heat rate, Btu/kWh

**STE** – steam turbine efficiency, fraction

## **4.5 CASE 4 – SHELL GASIFICATION PLANT WITHOUT CO<sub>2</sub> CAPTURE PROCESS DESCRIPTION**

This section contains an evaluation of a plant design for Case 4, which is based on a Shell coal gasification plant without CO<sub>2</sub> capture. The system descriptions follow the BFD provided in Exhibit 4-16 with the associated stream tables that show process data provided in Exhibit 4-17.

The balance of this section is organized as follows:

- Process Description – provides an overview of the technology operation as applied to Case 4. The systems that are common to all gasification cases were covered in Section 4.4 and only features that are unique to Case 4 are discussed further in this section
- Performance Results – provides the main modeling results from Case 4, including the performance summary, environmental performance, carbon balance, sulfur balance, water balance, energy balance, mass and energy balance diagrams. Note – some rounding error may be present in results reporting
- Equipment List – provides an itemized list of major equipment for Case 4
- Cost Estimates – provides a summary of capital and operating costs for Case 4



COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 4-17. Case 4 stream table, Shell gasification plant without capture**

	1	2	3	4	5	6	7	8	9	10
V-L Mole Fraction										
Ar	0.0092	0.0343	0.0025	0.0343	0.0000	0.0000	0.0092	0.0062	0.0000	0.0082
CH <sub>4</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0003	0.0000	0.0004
CO	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0105	0.0000	0.5163
CO <sub>2</sub>	0.0003	0.0000	0.0004	0.0000	0.0000	0.0000	0.0003	0.3805	0.0000	0.0170
COS	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0006
H <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.5603	0.0000	0.2637
H <sub>2</sub> O	0.0099	0.0000	0.0091	0.0000	0.0000	0.0000	0.0099	0.0017	0.0000	0.1293
HCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0004
H <sub>2</sub> S	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0073
H <sub>2</sub> SO <sub>4</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.7732	0.0157	0.9844	0.0157	0.9964	0.0000	0.7732	0.0391	0.0000	0.0516
NH <sub>3</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0051
O <sub>2</sub>	0.2074	0.9501	0.0035	0.9501	0.0036	0.0000	0.2074	0.0014	0.0000	0.0000
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaOH	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	1.0000	1.0000	0.0000	1.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	24,168	188	17,942	5,017	945	0	1,089	488	0	26,522
V-L Flowrate (kg/hr)	697,414	6,061	501,902	161,609	26,484	0	31,415	9,560	0	536,840
Solids Flowrate (kg/hr)	0	0	0	0	0	211,967	0	0	21,230	0
Temperature (°C)	15	27	21	27	130	15	15	45	1,427	1,079
Pressure (MPa, abs)	0.10	0.86	0.45	5.10	5.62	0.10	0.10	3.04	4.24	4.24
Steam Table Enthalpy (kJ/kg) <sup>A</sup>	30.23	21.53	28.11	9.82	129.22	---	30.23	64.45	---	2,034.61
AspenPlus Enthalpy (kJ/kg) <sup>B</sup>	-97.58	-0.97	-97.36	-12.68	103.25	-2,119.02	-97.58	-7,702.04	2,165.43	-3,011.85
Density (kg/m <sup>3</sup> )	1.2	11.2	5.2	68.6	46.4	---	1.2	22.9	---	7.6
V-L Molecular Weight	28.857	32.209	27.974	32.209	28.028	---	28.857	19.594	---	20.241
V-L Flowrate (lb <sub>mol</sub> /hr)	53,281	415	39,555	11,062	2,083	0	2,400	1,076	0	58,471
V-L Flowrate (lb/hr)	1,537,535	13,363	1,106,504	356,286	58,388	0	69,258	21,076	0	1,183,529
Solids Flowrate (lb/hr)	0	0	0	0	0	467,308	0	0	46,803	0
Temperature (°F)	59	80	70	80	267	59	59	112	2,600	1,974
Pressure (psia)	14.7	125.0	65.0	740.0	815.0	14.7	14.7	441.1	615.0	615.0
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	13.0	9.3	12.1	4.2	55.6	---	13.0	27.7	---	874.7
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	-42.0	-0.4	-41.9	-5.5	44.4	-911.0	-42.0	-3,311.3	931.0	-1,294.9
Density (lb/ft <sup>3</sup> )	0.076	0.700	0.322	4.283	2.894	---	0.076	1.427	---	0.473

<sup>A</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>B</sup>AspenPlus thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 4-17. Case 4 stream table, Shell gasification plant without capture (continued)**

	11	12	13	14	15	16	17	18	19	20
V-L Mole Fraction										
Ar	0.0000	0.0000	0.0059	0.0000	0.0000	0.0000	0.0000	0.0048	0.0000	0.0000
CH <sub>4</sub>	0.0000	0.0000	0.0003	0.0000	0.0000	0.0000	0.0000	0.0002	0.0000	0.0000
CO	0.0000	0.0000	0.3728	0.0000	0.0000	0.0000	0.0000	0.0083	0.0002	0.0000
CO <sub>2</sub>	0.0000	0.0010	0.0125	0.0000	0.0000	0.0000	0.0007	0.3013	0.0001	0.0000
COS	0.0000	0.0000	0.0005	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub>	0.0000	0.0000	0.1904	0.0000	0.0000	0.0000	0.0000	0.4437	0.0001	0.0000
H <sub>2</sub> O	0.9998	0.9798	0.3658	1.0000	0.6895	0.1000	0.9802	0.1999	0.9932	0.9993
HCl	0.0000	0.0000	0.0003	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub> S	0.0000	0.0001	0.0053	0.0000	0.0000	0.0000	0.0001	0.0046	0.0001	0.0000
H <sub>2</sub> SO <sub>4</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.9000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0373	0.0000	0.0000	0.0000	0.0000	0.0299	0.0000	0.0000
NH <sub>3</sub>	0.0002	0.0190	0.0090	0.0000	0.0000	0.0000	0.0190	0.0073	0.0038	0.0007
O <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0026	0.0000
NaOH	0.0000	0.0000	0.0000	0.0000	0.3105	0.0000	0.0000	0.0000	0.0001	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	1,130	10,213	29,021	8,247	29	0	711	36,155	3,480	1,627
V-L Flowrate (kg/hr)	20,363	184,094	569,529	148,564	731	13	12,810	697,887	63,058	29,312
Solids Flowrate (kg/hr)	0	0	0	0	0	0	0	0	0	0
Temperature (°C)	343	188	232	288	16	15	66	202	190	88
Pressure (MPa, abs)	5.10	4.98	3.98	3.88	4.81	0.13	0.47	3.49	3.88	0.13
Steam Table Enthalpy (kJ/kg) <sup>A</sup>	3,083.36	768.16	1,189.25	2,971.61	-338.78	-8,206.86	237.61	803.97	792.35	368.05
AspenPlus Enthalpy (kJ/kg) <sup>B</sup>	-12,884.30	-14,942.19	-6,580.56	-13,008.68	-13,665.00	-8,526.27	-15,478.76	-8,422.21	-15,049.89	-15,593.15
Density (kg/m <sup>3</sup> )	19.9	836.4	19.0	16.9	1,531.7	1,791.5	965.1	17.2	873.9	965.6
V-L Molecular Weight	18.015	18.025	19.625	18.015	24.842	90.073	18.017	19.303	18.120	18.015
V-L Flowrate (lb <sub>mol</sub> /hr)	2,492	22,516	63,979	18,181	65	0	1,567	79,708	7,672	3,587
V-L Flowrate (lb/hr)	44,893	405,859	1,255,596	327,527	1,612	29	28,241	1,538,578	139,020	64,622
Solids Flowrate (lb/hr)	0	0	0	0	0	0	0	0	0	0
Temperature (°F)	650	371	450	550	61	59	151	395	373	191
Pressure (psia)	740.0	722.7	577.7	562.7	697.7	18.2	67.7	506.1	562.7	19.3
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	1,325.6	330.2	511.3	1,277.6	-145.7	-3,528.3	102.2	345.6	340.7	158.2
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	-5,539.3	-6,424.0	-2,829.1	-5,592.7	-5,874.9	-3,665.6	-6,654.7	-3,620.9	-6,470.3	-6,703.8
Density (lb/ft <sup>3</sup> )	1.240	52.218	1.183	1.055	95.623	111.841	60.248	1.075	54.557	60.280

<sup>A</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>B</sup>AspenPlus thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 4-17. Case 4 stream table, Shell gasification plant without capture (continued)**

	21	22	23	24	25	26	27	28	29	30
V-L Mole Fraction										
Ar	0.0000	0.0000	0.0060	0.0000	0.0000	0.0059	0.0062	0.0000	0.0035	0.0000
CH <sub>4</sub>	0.0000	0.0000	0.0003	0.0000	0.0000	0.0003	0.0003	0.0000	0.0000	0.0000
CO	0.0000	0.0000	0.0105	0.0000	0.0000	0.0099	0.0105	0.0001	0.0000	0.0000
CO <sub>2</sub>	0.0007	0.0010	0.3784	0.0000	0.0002	0.4133	0.3805	0.9074	0.9512	0.0000
COS	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub>	0.0000	0.0000	0.5598	0.0000	0.0000	0.5256	0.5603	0.0042	0.0000	0.0000
H <sub>2</sub> O	0.9802	0.9792	0.0016	0.9999	0.9833	0.0016	0.0017	0.0010	0.0025	0.0000
HCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub> S	0.0001	0.0001	0.0057	0.0000	0.0003	0.0054	0.0000	0.0856	0.0000	0.0000
H <sub>2</sub> SO <sub>4</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0378	0.0000	0.0000	0.0367	0.0391	0.0002	0.0196	0.0000
NH <sub>3</sub>	0.0190	0.0196	0.0000	0.0000	0.0162	0.0000	0.0000	0.0002	0.0000	0.0000
O <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0013	0.0014	0.0000	0.0218	0.0000
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0001	0.0000	0.0014	0.0014	0.0000
NaCl	0.0000	0.0000	0.0000	0.0001	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaOH	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	3,367	13,314	28,649	2,571	684	30,511	28,608	1,903	1,862	0
V-L Flowrate (kg/hr)	60,667	240,009	561,548	46,318	12,326	642,318	560,536	81,782	80,770	0
Solids Flowrate (kg/hr)	0	0	0	0	0	0	0	0	0	5,280
Temperature (°C)	66	69	29	15	30	37	45	45	38	182
Pressure (MPa, abs)	0.47	0.45	3.18	0.10	0.24	3.07	3.04	3.04	3.07	0.29
Steam Table Enthalpy (kJ/kg) <sup>A</sup>	237.61	247.91	39.43	62.75	91.05	45.70	64.45	9.96	5.20	---
AspenPlus Enthalpy (kJ/kg) <sup>B</sup>	-15,478.76	-15,454.40	-7,686.77	-15,905.25	-15,665.35	-7,799.78	-7,702.04	-8,376.94	-8,669.58	145.98
Density (kg/m <sup>3</sup> )	965.1	962.4	25.2	999.4	985.7	25.6	22.9	58.0	60.7	5,270.5
V-L Molecular Weight	18.017	18.026	19.601	18.019	18.008	21.052	19.594	42.976	43.382	---
V-L Flowrate (lb <sub>mol</sub> /hr)	7,423	29,353	63,161	5,667	1,509	67,266	63,070	4,195	4,105	0
V-L Flowrate (lb/hr)	133,748	529,130	1,238,001	102,113	27,175	1,416,069	1,235,771	180,298	178,068	0
Solids Flowrate (lb/hr)	0	0	0	0	0	0	0	0	0	11,640
Temperature (°F)	151	156	84	59	85	98	112	112	100	360
Pressure (psia)	67.7	65.0	460.7	14.7	35.0	445.2	441.1	441.1	445.2	41.7
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	102.2	106.6	17.0	27.0	39.1	19.6	27.7	4.3	2.2	---
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	-6,654.7	-6,644.2	-3,304.7	-6,838.0	-6,734.9	-3,353.3	-3,311.3	-3,601.4	-3,727.2	62.8
Density (lb/ft <sup>3</sup> )	60.248	60.083	1.572	62.391	61.535	1.599	1.427	3.622	3.787	329.025

<sup>A</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>B</sup>AspenPlus thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 4-17. Case 4 stream table, Shell gasification plant without capture (continued)**

	31	32	33	34	35	36	37	38	39
V-L Mole Fraction									
Ar	0.0000	0.0004	0.0062	0.0008	0.0008	0.0112	0.0092	0.0000	0.0074
CH <sub>4</sub>	0.0000	0.0000	0.0003	0.0000	0.0000	0.0005	0.0000	0.0000	0.0000
CO	0.0000	0.0042	0.0105	0.0000	0.0000	0.0201	0.0000	0.0000	0.0000
CO <sub>2</sub>	0.0001	0.3168	0.3805	0.0000	0.0000	0.7271	0.0003	0.0000	0.2330
COS	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub>	0.0000	0.0282	0.5603	0.9990	0.9990	0.1606	0.0000	0.0000	0.0000
H <sub>2</sub> O	0.9999	0.1576	0.0017	0.0000	0.0000	0.0032	0.0099	1.0000	0.0786
HCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub> S	0.0000	0.0123	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub> SO <sub>4</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0014	0.0391	0.0002	0.0002	0.0745	0.7732	0.0000	0.6422
NH <sub>3</sub>	0.0000	0.4791	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
O <sub>2</sub>	0.0000	0.0000	0.0014	0.0000	0.0000	0.0027	0.2074	0.0000	0.0388
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaOH	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	294	137	28,120	13,406	13,406	14,714	14,578	13,684	48,104
V-L Flowrate (kg/hr)	5,303	3,510	550,976	27,498	27,498	523,479	420,681	246,512	1,500,775
Solids Flowrate (kg/hr)	0	0	0	0	0	0	0	0	0
Temperature (°C)	49	160	45	45	30	193	15	482	68
Pressure (MPa, abs)	0.27	0.45	3.04	2.97	6.48	0.50	0.10	11.82	0.11
Steam Table Enthalpy (kJ/kg) <sup>A</sup>	105.73	505.34	64.45	634.68	439.90	204.42	30.23	3,302.61	181.25
AspenPlus Enthalpy (kJ/kg) <sup>B</sup>	-15,863.29	-7,054.88	-7,702.04	284.27	89.50	-7,951.62	-97.58	-12,677.68	-3,504.91
Density (kg/m <sup>3</sup> )	963.8	3.2	22.9	2.3	5.1	4.6	1.2	38.0	1.2
V-L Molecular Weight	18.017	25.588	19.594	2.051	2.051	35.576	28.857	18.015	31.198
V-L Flowrate (lb <sub>mol</sub> /hr)	649	302	61,995	29,555	29,555	32,439	32,139	30,167	106,052
V-L Flowrate (lb/hr)	11,692	7,739	1,214,695	60,622	60,622	1,154,073	927,443	543,466	3,308,642
Solids Flowrate (lb/hr)	0	0	0	0	0	0	0	0	0
Temperature (°F)	120	321	112	112	86	380	59	900	154
Pressure (psia)	39.5	65.0	441.1	431.1	940.0	72.5	14.7	1,714.7	15.4
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	45.5	217.3	27.7	272.9	189.1	87.9	13.0	1,419.9	77.9
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	-6,820.0	-3,033.1	-3,311.3	122.2	38.5	-3,418.6	-42.0	-5,450.4	-1,506.8
Density (lb/ft <sup>3</sup> )	60.168	0.201	1.427	0.142	0.319	0.287	0.076	2.372	0.073


<sup>A</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>B</sup>AspenPlus thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm

### 4.5.1 Acid Gas Removal

H<sub>2</sub>S removal generally consists of absorption by a regenerable solvent. The most commonly used technique is based on counter current contact with the solvent. Acid-gas-rich solution from the absorber is stripped of its acid gas in a regenerator, usually by application of heat. The regenerated lean solution is then cooled and recirculated to the top of the absorber, completing the cycle. Exhibit 4-18 is a simplified diagram of the AGR process. [101]

*Exhibit 4-18. Flow diagram for a conventional single-stage AGR unit*



There are well over 30 AGR processes in common commercial use throughout the oil, chemical, and natural gas industries. However, in a 2002 report by Sfa Pacific, Inc. a list of 42 operating and planned gasifiers shows that only six AGR processes are represented: Rectisol, Sulfinol-M, MDEA, Selexol, aqueous di-isopropanol (ADIP) amine, and FLEXSORB. [102] These processes can be separated into three general types: chemical reagents, physical solvents, and hybrid solvents.

There are numerous commercial AGR processes that could meet the sulfur environmental target of this report. The most frequently used AGR systems (Selexol, Sulfinol-M, MDEA, and Rectisol) have all been used with the Shell gasifiers in various applications.

For the non-capture case, Case 4, the MDEA system is chosen due to its low CO<sub>2</sub> selectivity which is preferred when treating a shifted syngas without the separation of CO<sub>2</sub>. AGR technologies with higher CO<sub>2</sub> selectivities result in a buildup of CO<sub>2</sub> in the acid gas stream and the sulfur recovery unit due to the recycling of Claus tail gas to the AGR. Additionally, refrigerated MDEA is chosen over conventional MDEA because the sulfur emissions environmental target chosen is just below the range of the conventional, higher temperature MDEA system.

Cool, particulate-free syngas (stream 26) enters the absorber unit at approximately 3.1 MPa (445 psia) and 37 °C (98 °F). In the absorber, H<sub>2</sub>S is preferentially removed from the syngas

stream by contact with MDEA. The absorber column is operated at 45 °C (112 °F) by refrigerating the lean MDEA solvent. An outlet H<sub>2</sub>S concentration of less than 40 ppmv in the sweet syngas is achieved. The stripper acid gas stream (stream 28), consisting of 9 vol% H<sub>2</sub>S and 91 vol% CO<sub>2</sub>, is sent to the Claus unit.

#### **4.5.2 Hydrogen Production**

The remaining clean syngas exiting the MDEA unit (stream 27) that is not used for coal drying (stream 33) is sent to a pressure swing adsorption (PSA) unit. The PSA produces a highly pure hydrogen product stream (stream 34) as well as a low pressure and low temperature off-gas stream that is used as fuel gas in the GFB. The PSA unit produces 99.9 vol% purity hydrogen at a H<sub>2</sub> recovery efficiency of 85 percent. The hydrogen stream is compressed using an integrally geared, multi-stage, intercooled centrifugal compressor to a pipeline-ready pressure of 6.48 MPa (925 psig).

#### **4.5.3 Steam Generation**

The steam conditions for the coal gasification plant without capture (Case 4) are 11.7 MPa/482 °C/482 °C (1,700 psig/900 °F/900 °F).

### **4.6 CASE 4 – PERFORMANCE RESULTS**

Overall performance for the entire plant is summarized in Exhibit 4-19. The plant produces 27,498 kg/hr (60,622 lb/hr) of hydrogen at an effective thermal efficiency of 65.0 percent (HHV basis). The steam turbine generates 89 MWe and the total auxiliary load for the plant is 114 MWe, requiring 25 MW of electricity to be sourced from the grid.

Exhibit 4-20 provides a detailed breakdown of the auxiliary power requirements. The ASU accounts for approximately 67 percent of the total auxiliary load distributed between the MAC, booster compressor, N<sub>2</sub> compressor, O<sub>2</sub> pump, and ASU auxiliaries. The hydrogen compressor accounts for about 9 percent of the total auxiliary load. The BFW pumps and cooling water system, including the circulating water pumps and cooling tower fan, accounts for approximately 5 percent of the auxiliary load. All other systems together constitute the remaining 19 percent of the auxiliary load.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 4-19. Case 4 plant performance summary**

Performance Summary	
Steam Turbine Power, MWe	89
<b>Total Gross Power, MWe</b>	<b>89</b>
Air Separation Unit Main Air Compressor, kWe	66,970
Air Separation Unit Booster Compressor, kWe	5,270
N <sub>2</sub> Compressors, kWe	2,390
CO <sub>2</sub> Compression, kWe	0
Acid Gas Removal, kWe	5,610
Balance of Plant, kWe	33,350
<b>Total Auxiliaries, MWe</b>	<b>114</b>
<b>Net Power, MWe</b>	<b>-25</b>
<b>Hydrogen Production, kg/hr (lb/hr)</b>	<b>27,498 (60,622)</b>
<b>CO<sub>2</sub> Capture, %</b>	<b>–</b>
HHV Effective Thermal Efficiency <sup>A</sup> , %	65.0%
HHV Cold Gas Efficiency <sup>B</sup> , %	66.6%
LHV Effective Thermal Efficiency <sup>A</sup> , %	56.8%
LHV Cold Gas Efficiency <sup>B</sup> , %	58.4%
Steam Turbine Cycle Efficiency, %	52.9%
Steam Turbine Heat Rate, kJ/kWh (Btu/kWh)	6,799 (6,445)
Condenser Duty, GJ/hr (MMBtu/hr)	366 (347)
AGR Cooling Duty, GJ/hr (MMBtu/hr)	351 (333)
As-Received Coal Feed, kg/hr (lb/hr)	211,967 (467,308)
HHV Thermal Input, kWt	1,597,711
LHV Thermal Input, kWt	1,541,012
Raw Water Withdrawal, m <sup>3</sup> /min (gpm)	12.1 (3,188)
Raw Water Consumption, m <sup>3</sup> /min (gpm)	9.5 (2,516)

<sup>A</sup>ETE = (Hydrogen Heating Value + Net Power) / Fuel Heating Value

<sup>B</sup>CGE = Hydrogen Heating Value / Fuel Heating Value

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 4-20. Case 4 plant power summary**

Power Summary	
Steam Turbine Power, MWe	89
<b>Total Gross Power, MWe</b>	<b>89</b>
Auxiliary Load Summary	
Acid Gas Removal, kWe	5,610
Air Blower, kWe	1,080
Air Separation Unit Auxiliaries, kWe	1,000
Air Separation Unit Main Air Compressor, kWe	66,970
Air Separation Unit Booster Compressor, kWe	5,270
Ammonia Wash Pumps, kWe	120
Circulating Water Pumps, kWe	2,910
Claus Plant TG Recycle Compressor, kWe	4,230
Claus Plant/TGTU Auxiliaries, kWe	680
CO <sub>2</sub> Compression, kWe	0
Coal Handling, kWe	460
Coal Milling, kWe	2,180
Condensate Pumps, kWe	110
Cooling Tower Fans, kWe	1,500
Dryer Air Compressor, kWe	80
Feedwater Pumps, kWe	1,540
Gasifier Water Pump, kWe	40
Ground Water Pumps, kWe	290
Hydrogen Compressor, kWe	10,430
Miscellaneous Balance of Plant <sup>A</sup> , kWe	1,930
N <sub>2</sub> Compressors, kWe	2,390
O <sub>2</sub> Pump, kWe	330
Quench Water Pump, kWe	330
Shift Steam Pump, kWe	310
Slag Handling, kWe	550
Slag Reclaim Water Recycle Pump, kWe	0
Slurry Water Pump, kWe	0
Sour Gas Compressors, kWe	140
Sour Water Recycle Pumps, kWe	0
Steam Turbine Auxiliaries, kWe	80
Syngas Recycle Compressor, kWe	880
Syngas Scrubber Pumps, kWe	120
Process Water Treatment Auxiliaries, kWe	1,310
Transformer Losses, kWe	720
<b>Total Auxiliaries, MWe</b>	<b>114</b>
<b>Net Power, MWe</b>	<b>-25</b>

<sup>A</sup>Includes plant control systems, lighting, HVAC, and miscellaneous low voltage loads

### 4.6.1 Environmental Performance

The environmental targets for emissions of Hg, HCl, NO<sub>x</sub>, SO<sub>2</sub>, and PM were presented in Section 2.7.1. A summary of the plant air emissions for Case 4 is presented in Exhibit 4-21.

*Exhibit 4-21. Case 4 air emissions*

	kg/GJ (lb/MMBtu)	Tonne/year (ton/year) <sup>A</sup>	lb/lb H <sub>2</sub>
SO <sub>2</sub>	0.011 (0.027)	462 (509)	0.002
NO <sub>x</sub>	0.007 (0.017)	291 (321)	0.002
Particulate	0.003 (0.007)	123 (136)	0.001
Hg	2.46E-7 (5.71E-7)	0.010 (0.011)	5.14E-8
HCl	0.000 (0.000)	0.00 (0.00)	0.000
CO <sub>2</sub> <sup>B</sup>	86 (199)	3,456,164 (3,809,769)	17.9
CO <sub>2</sub> e <sup>C</sup>	95 (222)	3,845,486 (4,238,922)	20.

<sup>A</sup>Calculations based on an 80 percent capacity factor

<sup>B</sup>Plant stack emissions

<sup>C</sup>Life cycle emissions

The low level of SO<sub>2</sub> emissions is achieved by capturing the sulfur in the syngas by the MDEA AGR process. The AGR process removes over 99 percent of the sulfur compounds in the fuel gas down to a level of less than 36 ppmv. The H<sub>2</sub>S-rich regeneration gas from the AGR system is fed to a Claus plant, producing elemental sulfur. The Claus plant tail gas is compressed and recycled back to the AGR to capture most of the remaining sulfur. The SO<sub>2</sub> emissions in Exhibit 4-21 include both the stack emissions and the coal dryer emissions.

NO<sub>x</sub> emissions are limited by the use of low NO<sub>x</sub> burners to 15 ppmvd (as NO at 15 percent O<sub>2</sub>). NH<sub>3</sub> in the syngas is removed with process condensate prior to the low-temperature AGR process and destroyed in the Claus plant burner. This helps lower NO<sub>x</sub> levels as well.

Particulate discharge to the atmosphere is limited to extremely low values by the use of a cyclone and a barrier filter in addition to the syngas scrubber and the gas washing effect of the AGR absorber. The particulate emissions represent filterable particulate only.

Approximately 97 percent of the mercury is captured from the syngas by dual activated carbon beds.

Plant stack CO<sub>2</sub> emissions represent the uncontrolled discharge from the process. Life cycle CO<sub>2</sub> emissions represent the total GWP, in CO<sub>2</sub>e emissions, of the process over the plant life cycle, as detailed in Section 2.8.

The carbon balance for the plant is shown in Exhibit 4-22. The carbon input to the plant consists of carbon in the air in addition to carbon in the coal. Carbon in the air is not neglected here since the Aspen model accounts for air components throughout. Carbon leaves the plant as unburned carbon in the slag, a small portion of the hydrogen product, and the CO<sub>2</sub> in the stack gas, including the coal dryer vent gas and ASU vent gas.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 4-22. Case 4 carbon balance**

Carbon In		Carbon Out	
	kg/hr (lb/hr)		kg/hr (lb/hr)
Coal	135,118 (297,884)	Stack Gas	134,595 (296,732)
Air (CO <sub>2</sub> )	156 (345)	CO <sub>2</sub> Product	–
		Slag	676 (1,489)
		H <sub>2</sub> Product	3 (7)
<b>Total</b>	<b>135,274 (298,229)</b>	<b>Total</b>	<b>135,274 (298,229)</b>

Exhibit 4-23 shows the sulfur balance for the plant. Sulfur input comes solely from the sulfur in the coal. Sulfur output includes the sulfur recovered in the Claus plant as elemental sulfur and sulfur emitted in the stack gas, including the coal drying vent. Sulfur in the slag is considered negligible.

**Exhibit 4-23. Case 4 sulfur balance**

Sulfur In		Sulfur Out	
	kg/hr (lb/hr)		kg/hr (lb/hr)
Coal	5,313 (11,713)	Stack Gas	33 (73)
		CO <sub>2</sub> Product	–
		Elemental Sulfur	5,280 (11,640)
<b>Total</b>	<b>5,313 (11,713)</b>	<b>Total</b>	<b>5,313 (11,713)</b>

Exhibit 4-24 shows the overall water balance for the plant. The primary water demand comes from the cooling tower (11.32 m<sup>3</sup>/min), which makes up about 60 percent of the total water demand (18.94 m<sup>3</sup>/min). The largest contributor to the internal recycle is the quench, making up about 45 percent of the total internal recycle (6.87 m<sup>3</sup>/min). Process water is discharged from the cooling tower at a rate of 2.55 m<sup>3</sup>/min. The raw water consumption, which can be described as the water demand minus the internal recycle and process water discharge, is 9.52 m<sup>3</sup>/min in total for the coal gasification plant without capture (Case 4).

**Exhibit 4-24. Case 4 water balance**

Water Use	Water Demand	Internal Recycle	Raw Water Withdrawal	Process Water Discharge	Raw Water Consumption
	m <sup>3</sup> /min (gpm)				
Slag Handling	0.46 (122)	0.46 (122)	–	–	–
Slurry Water	–	–	–	–	–
Gasifier Water	–	–	–	–	–
Quench	3.07 (812)	3.07 (812)	–	–	–

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Water Use	Water Demand	Internal Recycle	Raw Water Withdrawal	Process Water Discharge	Raw Water Consumption
	m <sup>3</sup> /min (gpm)				
HCl Scrubber	1.88 (496)	1.88 (496)	–	–	–
NH <sub>3</sub> Scrubber	1.76 (465)	0.99 (261)	0.77 (204)	–	0.77 (204)
Gasifier Steam	0.34 (90)	0.34 (90)	–	–	–
<b>Condenser Makeup</b>	<b>0.11 (29)</b>	–	<b>0.11 (29)</b>	–	<b>0.11 (29)</b>
BFW Makeup	0.11 (29)	–	0.11 (29)	–	0.11 (29)
Gasifier Steam	–	–	–	–	–
Shift Steam	–	–	–	–	–
<b>Cooling Tower</b>	<b>11.32 (2,990)</b>	<b>0.13 (35)</b>	<b>11.19 (2,955)</b>	<b>2.55 (672)</b>	<b>8.64 (2,283)</b>
BFW Blowdown	–	0.11 (29)	-0.11 (-29)	–	-0.11 (-29)
ASU Knockout	–	0.02 (6)	-0.02 (-6)	–	-0.02 (-6)
<b>Total</b>	<b>18.94 (5,004)</b>	<b>6.87 (1,815)</b>	<b>12.07 (3,188)</b>	<b>2.55 (672)</b>	<b>9.52 (2,516)</b>

An overall plant energy balance is provided in tabular form in Exhibit 4-25. The power out is the steam turbine power prior to generator losses.

*Exhibit 4-25. Case 4 overall energy balance (0 °C [32 °F] reference)*

	HHV	Sensible + Latent	Power	Total
<b>Heat In, GJ/hr (MMBtu/hr)</b>				
Coal	5,752 (5,452)	4.8 (4.6)	–	5,757 (5,456)
Air	–	34.7 (32.9)	–	34.7 (32.9)
Raw Water Makeup	–	45.4 (43.0)	–	45.4 (43.0)
Auxiliary Power	–	–	408.9 (387.6)	408.9 (387.6)
<b>Total</b>	<b>5,752 (5,452)</b>	<b>84.9 (80.5)</b>	<b>408.9 (387.6)</b>	<b>6,246 (5,920)</b>
<b>Heat Out, GJ/hr (MMBtu/hr)</b>				
Misc. Process Steam	–	5.0 (4.7)	–	5.0 (4.7)
Slag	22.1 (21.0)	35.8 (34.0)	–	58.0 (55.0)
Stack Gas	–	272 (258)	–	272 (258)
Sulfur	48.9 (46.4)	0.6 (0.6)	–	49.5 (47.0)
Motor Losses and Design Allowances	–	–	14.7 (13.9)	14.7 (13.9)
Hydrogen Product	3,828 (3,628)	12.1 (11.5)	–	3,840 (3,640)
Cooling Tower Load <sup>A</sup>	–	1,478 (1,401)	–	1,478 (1,401)
CO <sub>2</sub> Product Stream	–	–	–	–

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

	HHV	Sensible + Latent	Power	Total
Blowdown Streams	–	22.9 (21.7)	–	22.9 (21.7)
<i>Ambient Losses<sup>B</sup></i>	–	89.8 (85.1)	–	89.8 (85.1)
Power	–	–	319 (302)	319 (302)
<b>Total</b>	<b>3,899 (3,696)</b>	<b>1,916 (1,816)</b>	<b>334 (316)</b>	<b>6,149 (5,828)</b>
Unaccounted Energy <sup>C</sup>	–	96.4 (91.4)	–	96.4 (91.4)

<sup>A</sup>Includes condenser, AGR, and miscellaneous cooling loads

<sup>B</sup>Ambient losses include all losses to the environment through radiation, convection, etc. Sources of these losses include the combustor, reheater, superheater, and transformers

<sup>C</sup>By difference

## 4.6.2 Energy and Mass Balance Diagrams

Energy and mass balance diagrams are shown for the following subsystems in Exhibit 4-26 through Exhibit 4-28:

- ASU, gasification, and gas cooling
- Gas cleanup system
- Hydrogen purification and power block

Exhibit 4-26. Case 4 coal gasification and ASU energy and mass balance




Exhibit 4-27. Case 4 syngas cleanup energy and mass balance





Exhibit 4-28. Case 4 hydrogen purification and power block energy and mass balance



This page intentionally left blank

## 4.7 CASE 4 – MAJOR EQUIPMENT LIST

Major equipment items for the Shell gasifier with no CO<sub>2</sub> capture are shown in the following tables. In general, the design conditions include a 10 percent design allowance for flows and heat duties and a 21 percent design allowance for heads on pumps and fans.

### Case 4 – Account 1: Coal Handling

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Bottom Trestle Dumper and Receiving Hoppers	N/A	181 tonne (200 ton)	2	0
2	Feeder	Belt	570 tonne/hr (630 tph)	2	0
3	Conveyor No. 1	Belt	1,130 tonne/hr (1,250 tph)	1	0
4	Conveyor No. 2	Belt	1,130 tonne/hr (1,250 tph)	1	0
5	Stacker/Reclaimer	Traveling, linear	1,130 tonne/hr (1,250 tph)	1	0
6	Reclaim Hopper	N/A	40 tonne (50 ton)	2	1
7	Feeder	Vibratory	170 tonne/hr (190 tph)	2	1
8	Conveyor No. 3	Belt w/ tripper	350 tonne/hr (390 tph)	1	0
9	Coal Surge Bin w/ Vent Filter	Dual outlet	170 tonne (190 ton)	2	0
10	Crusher	Impactor reduction	8 cm x 0 – 3 cm x 0 (3" x 0 - 1-1/4" x 0)	2	0
11	Conveyor No. 4	Belt w/trippper	350 tonne/hr (390 tph)	1	0
12	Conveyor No. 5	Belt w/ tripper	350 tonne/hr (390 tph)	1	0
13	Coal Silo w/ Vent Filter and Slide Gates	Field erected	780 tonne (860 ton)	3	0

### Case 4 – Account 2: Coal Preparation and Feed

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Feeder	Vibratory	80 tonne/hr (90 tph)	3	0
2	Conveyor No. 6	Belt w/trippper	230 tonne/hr (260 tph)	1	0
3	Roller Mill Feed Hopper	Dual Outlet	470 tonne (510 ton)	1	0
4	Weigh Feeder	Belt	120 tonne/hr (130 tph)	2	0
5	Coal Dryer and Pulverizer	Rotary	120 tonne/hr (130 tph)	2	0
6	Coal Dryer Feed Hopper	Vertical Hopper	230 tonne (260 ton)	2	0

### Case 4 – Account 3: Feedwater and Miscellaneous Balance of Plant Systems

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Demineralized Water Storage Tank	Vertical, cylindrical, outdoor	10,288,000 liters (2,718,000 gal)	2	0
2	Condensate Pumps	Vertical canned	3,080 lpm @ 90 m H <sub>2</sub> O (810 gpm @ 300 ft H <sub>2</sub> O)	2	1
3	Deaerator (integral w/ GFB)	Horizontal spray type	198,000 kg/hr (437,000 lb/hr)	2	0
4	Intermediate Pressure Feedwater Pump	Horizontal centrifugal, single stage	980 lpm @ 10 m H <sub>2</sub> O (260 gpm @ 20 ft H <sub>2</sub> O)	2	1
5	High Pressure Feedwater Pump No. 1	Barrel type, multi-stage, centrifugal	HP water: 2,420 lpm @ 1,600 m H <sub>2</sub> O (640 gpm @ 5,300 ft H <sub>2</sub> O)	2	1
6	High Pressure Feedwater Pump No. 2	Barrel type, multi-stage, centrifugal	IP water: 1,920 lpm @ 190 m H <sub>2</sub> O (510 gpm @ 640 ft H <sub>2</sub> O)	2	1
7	Auxiliary Boiler	Shop fabricated, water tube	18,000 kg/hr, 2.8 MPa, 343 °C (40,000 lb/hr, 400 psig, 650 °F)	1	0
8	Service Air Compressors	Flooded Screw	28 m <sup>3</sup> /min @ 0.7 MPa (1,000 scfm @ 100 psig)	2	1

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
9	Instrument Air Dryers	Duplex, regenerative	28 m <sup>3</sup> /min (1,000 scfm)	2	1
10	Closed Cycle Cooling Heat Exchangers	Plate and frame	418 GJ/hr (397 MMBtu/hr) each	2	0
11	Closed Cycle Cooling Water Pumps	Horizontal centrifugal	150,200 lpm @ 20 m H <sub>2</sub> O (39,700 gpm @ 70 ft H <sub>2</sub> O)	2	1
12	Engine-Driven Fire Pump	Vertical turbine, diesel engine	3,785 lpm @ 110 m H <sub>2</sub> O (1,000 gpm @ 350 ft H <sub>2</sub> O)	1	1
13	Fire Service Booster Pump	Two-stage horizontal centrifugal	2,650 lpm @ 80 m H <sub>2</sub> O (700 gpm @ 250 ft H <sub>2</sub> O)	1	1
14	Municipal Water Pumps	Stainless steel, single suction	1,470 lpm @ 20 m H <sub>2</sub> O (390 gpm @ 60 ft H <sub>2</sub> O)	2	1
15	Ground Water Pumps	Stainless steel, single suction	2,930 lpm @ 270 m H <sub>2</sub> O (770 gpm @ 880 ft H <sub>2</sub> O)	1	1
16	Filtered Water Pumps	Stainless steel, single suction	1,850 lpm @ 50 m H <sub>2</sub> O (490 gpm @ 160 ft H <sub>2</sub> O)	2	1
17	Filtered Water Tank	Vertical, cylindrical	890,000 liter (235,000 gal)	2	0
18	Makeup Water Demineralizer	Anion, cation, and mixed bed	1,430 lpm (380 gpm)	2	0
19	Liquid Waste Treatment System	N/A	10 years, 24-hour storm	1	0
20	Process Water Treatment	Vacuum flash, brine concentrator, and crystallizer	Vacuum Flash Inlet: 35,000 kg/hr (76,000 lb/hr) Vacuum Flash Outlet: 6,218 ppmw Cl- Brine Concentrator Inlet: 28,000 kg/hr (61,000 lb/hr) Crystallizer Inlet: 2,000 kg/hr (5,000 lb/hr)	2	0

**Case 4 – Account 4: Gasifier, ASU, and Accessories**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Gasifier	Pressurized dry-feed, entrained bed	2,800 tonne/day, 4.2 MPa (3,100 tpd, 615 psia)	2	0
2	Synthesis Gas Cooler	Convective spiral-wound tube boiler	295,000 kg/hr (651,000 lb/hr)	2	0
3	Synthesis Gas Cyclone	High efficiency	397,000 kg/hr (874,000 lb/hr) Design efficiency 90%	2	0
4	HCl Scrubber	Ejector Venturi	313,000 kg/hr (691,000 lb/hr)	2	0
5	Ammonia Wash	Counter-flow spray tower	311,000 kg/hr (685,000 lb/hr) @ 3.3 MPa (473 psia)	2	0
6	Primary Sour Water Stripper	Counter-flow with external reboiler	33,000 kg/hr (74,000 lb/hr)	2	0
7	Secondary Sour Water Stripper	Counter-flow with external reboiler	11,000 kg/hr (25,000 lb/hr)	2	0
8	Low Temperature Heat Recovery Coolers	Shell and tube with condensate drain	256,000 kg/hr (564,000 lb/hr)	9	0
9	Low Temperature Heat Recovery Knockout Drum	Vertical with mist eliminator	312,000 kg/hr, 59 °C, 3.3 MPa (689,000 lb/hr, 138 °F, 476 psia)	2	0
10	Synthesis Gas Reheaters	Shell and tube	Reheater 1: 0 kg/hr (0 lb/hr) Reheater 2: 54,000 kg/hr (119,000 lb/hr) Reheater 3: 61,000 kg/hr (135,000 lb/hr) Reheater 4: 173,000 kg/hr (382,000 lb/hr) Reheater 5: 288,000 kg/hr (635,000 lb/hr) Reheater 6: 288,000 kg/hr (635,000 lb/hr)	2	0

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
11	Flare Stack	Self-supporting, carbon steel, stainless steel top, pilot ignition	302,000 kg/hr (666,000 lb/hr) syngas	2	0
12	ASU Main Air Compressor	Centrifugal, multi-stage	5,000 m <sup>3</sup> /min @ 1.6 MPa (185,000 scfm @ 236 psia)	2	0
13	Cold Box	Vendor design	2,200 tonne/day (2,400 tpd) of 95% purity oxygen	2	0
14	Gasifier O <sub>2</sub> Pump	Centrifugal, multi-stage	1,000 m <sup>3</sup> /min (38,000 scfm) Suction – 1.0 MPa (130 psia) Discharge – 5.1 MPa (740 psia)	2	0
15	Gasifier Nitrogen Boost Compressor	Centrifugal, single-stage	210 m <sup>3</sup> /min (7,000 scfm) Suction – 0.4 MPa (70 psia) Discharge – 5.6 MPa (820 psia)	2	0

**Case 4 – Account 5: Syngas Cleanup**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Mercury Adsorber 1	Sulfated carbon bed	309,000 kg/hr (681,000 lb/hr) 29 °C (84 °F) 3.2 MPa (461 psia)	2	0
2	Mercury Adsorber 2	Sulfated carbon bed	309,000 kg/hr (681,000 lb/hr) 37 °C (99 °F) 3.1 MPa (448 psia)	2	0
3	Sulfur Plant	Claus type	139 tonne/day (154 tpd)	1	0
4	Water Gas Shift Reactors	Fixed bed, catalytic	256,000 kg/hr (282,000 lb/hr) 216 °C (420 °F) 3.9 MPa (560 psia)	6	0
5	Shift Reactor Heat Recovery Exchangers	Shell and Tube	Exchanger 1: 223 GJ/hr (211 MMBtu/hr) Exchanger 2: 91 GJ/hr (86 MMBtu/hr) Exchanger 3: 66 GJ/hr (63 MMBtu/hr) Exchanger 4: 83 GJ/hr (78 MMBtu/hr)	8	0
6	Acid Gas Removal Plant	MDEA	353,000 kg/hr (779,000 lb/hr) 37 °C (98 °F) 3.1 MPa (445 psia)	2	0
7	Hydrogenation Reactor	Fixed bed, catalytic	95,000 kg/hr (209,000 lb/hr) 219 °C (427 °F) 0.3 MPa (40.8 psia)	1	0
8	Tail Gas Recycle Compressor	Centrifugal	89,000 kg/hr (196,000 lb/hr) each	1	0
9	Candle Filter	Pressurized filter with pulse-jet cleaning	metallic filters	2	0

**Case 4 – Account 6: Hydrogen Production**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Pressure Swing Adsorber	Polybed Proprietary	Syngas: 550,976 kg/hr (1,214,695 lb/hr) 45 °C (112 °F) 3.0 MPa (441.1 psia) Hydrogen: 27,498 kg/hr (60,622 lb/hr) 45 °C (112 °F) 3.0 MPa (431.1 psia)	1	0

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
			Off Gas: 523,479 kg/hr (1,154,073 lb/hr) -7 °C (20 °F) 0.5 MPa (77.0 psia)		
2	Hydrogen Compressor	Integrally geared, multi-stage centrifugal	99 m <sup>3</sup> /min @ 6.5 MPa (3,482 acfm @ 940 psia)	1	1

**Case 4 – Account 7: Stack, Ducting, & Off-Gas Fired Boiler**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Stack	CS plate, type 409SS liner	76 m (250 ft) high x 4.5 m (15 ft) diameter	1	0
2	Field-Erected Gas-Fired Boiler	Drum, multi-pressure with economizer section and integral deaerator Air-Fired	Off Gas: 523,479 kg/hr (1,154,073 lb/hr) 0.5 MPa (72.5 psia) 193 °C (380 °F) Air: 420,681 kg/hr (927,443 lb/hr) 0.1 MPa (16.0 psia) 24 °C (75 °F) 645 GJ/hr (611 MMBtu/hr)	1	0
3	Air Blower	Centrifugal	462,749 kg/hr, 6,315 m <sup>3</sup> /min @ 111 cm WG (1,020,187 lb/hr, 223,000 acfm @ 44 in. WG)	2	1

**Case 4 – Account 8: Steam Turbine and Accessories**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Steam Turbine	Commercially available advanced steam turbine	93 MW 11.7 MPa/482 °C/482 °C (1,700 psig/ 900 °F/900 °F)	1	0
2	Steam Turbine Generator	Hydrogen cooled, static excitation	100 MVA @ 0.9 p.f., 24 kV, 60 Hz, 3-phase	1	0
3	Surface Condenser	Single pass, divided waterbox including vacuum pumps	400GJ/hr (380 MMBtu/hr), Inlet water temperature 16 °C (60 °F), Water temperature rise 11 °C (20 °F)	1	0
4	Steam Bypass	One per boiler	50% steam flow @ design steam conditions	1	0

**Case 4 – Account 9: Cooling Water System**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Circulating Water Pumps	Vertical, wet pit	292,000 lpm @ 30 m (77,000 gpm @ 100 ft)	2	1
2	Cooling Tower	Evaporative, mechanical draft, multi-cell	11 °C (52 °F) wet bulb/ 16 °C (60 °F) CWT/27 °C (80 °F) HWT/ 1,630 GJ/hr (1,540 MMBtu/hr) heat duty	1	0

**Case 4 – Account 10: Slag Recovery and Handling**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Slag Quench Tank	Water bath	223,000 liters (59,000 gal)	2	0
2	Slag Crusher	Roll	12 tonne/hr (13 tph)	2	0
3	Slag Depressurizer	Lock Hopper	12 tonne/hr (13 tph)	2	0
4	Slag Receiving Tank	Horizontal, weir	134,000 liters (35,000 gal)	2	0
5	Black Water Overflow Tank	Shop fabricated	60,000 liters (16,000 gal)	2	0
6	Slag Conveyor	Drag chain	12 tonne/hr (13 tph)	2	0
7	Slag Separation Screen	Vibrating	12 tonne/hr (13 tph)	2	0

## COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
8	Coarse Slag Conveyor	Belt/bucket	12 tonne/hr (13 tph)	2	0
9	Fine Ash Settling Tank	Vertical, gravity	190,000 liters (50,000 gal)	2	0
10	Fine Ash Recycle Pumps	Horizontal centrifugal	50 lpm @ 14 m H <sub>2</sub> O (10 gpm @ 46 ft H <sub>2</sub> O)	2	2
11	Grey Water Storage Tank	Field erected	61,000 liters (16,000 gal)	2	0
12	Grey Water Pumps	Centrifugal	210 lpm @ 430 m H <sub>2</sub> O (60 gpm @ 1,420 ft H <sub>2</sub> O)	2	2
13	Slag Storage Bin	Vertical, field erected	800 tonne (900 tons)	2	0
14	Unloading Equipment	Telescoping chute	100 tonne/hr (110 tph)	1	0

### Case 4 – Account 11: Accessory Electric Plant

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	STG Transformer	Oil-filled	24 kV/345 kV, 60 MVA, 3-ph, 60 Hz	1	0
2	High Voltage Auxiliary Transformer	Oil-filled	345 kV/13.8 kV, 41 MVA, 3-ph, 60 Hz	2	0
3	Medium Voltage Transformer	Oil-filled	24 kV/4.16 kV, 42 MVA, 3-ph, 60 Hz	1	1
4	Low Voltage Transformer	Dry ventilated	4.16 kV/480 V, 6 MVA, 3-ph, 60 Hz	1	1
5	STG Isolated Phase Bus Duct and Tap Bus	Aluminum, self-cooled	24 kV, 3-ph, 60 Hz	1	0
6	Medium Voltage Switchgear	Metal clad	4.16 kV, 3-ph, 60 Hz	1	1
7	Low Voltage Switchgear	Metal enclosed	480 V, 3-ph, 60 Hz	1	1
8	Emergency Diesel Generator	Sized for emergency shutdown	750 kW, 480 V, 3-ph, 60 Hz	1	0

### Case 4 – Account 12: Instrumentation and Control

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	DCS – Main Control	Monitor/keyboard; Operator printer (laser color); Engineering printer (laser B&W)	Operator stations/printers and engineering stations/printers	1	0
2	DCS – Processor	Microprocessor with redundant input/output	N/A	1	0
3	DCS – Data Highway	Fiber optic	Fully redundant, 25% spare	1	0

## 4.8 CASE 4 – COST ESTIMATING

The cost estimating methodology was described previously in Section 2.11. Exhibit 4-29 shows a detailed breakdown of the capital costs; Exhibit 4-30 shows the owner's costs, TOC, and TASC; Exhibit 4-31 shows the initial and annual O&M costs; and Exhibit 4-32 shows the LCOH breakdown.

The estimated TOC of the Shell gasification plant without CO<sub>2</sub> capture is \$5,243/[kg H<sub>2</sub>/day]. Process contingency represents 4.4 percent of the TOC and project contingency represents 12.0 percent. The LCOH is \$2.58/kg H<sub>2</sub>.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Exhibit 4-29. Case 4 total plant cost details

Case:		4		– Coal Gasification w/o CCS				Estimate Type:			Conceptual	
Plant Size (kg H <sub>2</sub> /day):		659,947						Cost Base:			Dec 2018	
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost		
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]	
<b>1</b>												
Coal Handling												
1.1	Coal Receive & Unload	\$971	\$0	\$468	\$0	\$1,438	\$216	\$0	\$331	\$1,985	\$3	
1.2	Coal Stackout & Reclaim	\$3,173	\$0	\$758	\$0	\$3,931	\$590	\$0	\$904	\$5,425	\$8	
1.3	Coal Conveyors & Yard Crush	\$30,270	\$0	\$7,704	\$0	\$37,974	\$5,696	\$0	\$8,734	\$52,404	\$79	
1.4	Other Coal Handling	\$4,715	\$0	\$1,061	\$0	\$5,776	\$866	\$0	\$1,328	\$7,970	\$12	
1.5	Biomass Receive & Unload	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
1.6	Biomass Handling	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
1.7	Biomass Conveyors	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
1.8	Biomass Hnd. Foundations	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
1.9	Coal & Sorbent Handling Foundations	\$0	\$85	\$222	\$0	\$307	\$46	\$0	\$71	\$424	\$1	
	<b>Subtotal</b>	<b>\$39,128</b>	<b>\$85</b>	<b>\$10,213</b>	<b>\$0</b>	<b>\$49,426</b>	<b>\$7,414</b>	<b>\$0</b>	<b>\$11,368</b>	<b>\$68,208</b>	<b>\$103</b>	
<b>2</b>												
Coal Preparation & Feed												
2.1	Coal Crushing & Drying	\$2,349	\$142	\$338	\$0	\$2,829	\$424	\$0	\$651	\$3,904	\$6	
2.2	Prepared Coal Storage & Feed	\$7,217	\$1,734	\$1,115	\$0	\$10,066	\$1,510	\$0	\$2,315	\$13,891	\$21	
2.3	Dry Coal Injection System	\$9,212	\$106	\$844	\$0	\$10,162	\$1,524	\$0	\$2,337	\$14,023	\$21	
2.4	Miscellaneous Coal Preparation & Feed	\$713	\$521	\$1,534	\$0	\$2,768	\$415	\$0	\$637	\$3,819	\$6	
2.5	Biomass Shredding & Drying	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
2.6	Prepared Biomass Storage & Feed	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
2.7	Dry Biomass Injection System	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
2.9	Coal, Biomass & Sorbent Feed Foundation	\$0	\$1,734	\$1,488	\$0	\$3,221	\$483	\$0	\$741	\$4,446	\$7	
	<b>Subtotal</b>	<b>\$19,491</b>	<b>\$4,237</b>	<b>\$5,318</b>	<b>\$0</b>	<b>\$29,045</b>	<b>\$4,357</b>	<b>\$0</b>	<b>\$6,680</b>	<b>\$40,083</b>	<b>\$61</b>	
<b>3</b>												
Feedwater & Miscellaneous BOP Systems												
3.1	Feedwater System	\$1,051	\$1,802	\$901	\$0	\$3,754	\$563	\$0	\$864	\$5,181	\$8	
3.2	Water Makeup & Pretreating	\$3,738	\$374	\$2,118	\$0	\$6,230	\$935	\$0	\$2,149	\$9,314	\$14	
3.3	Other Feedwater Subsystems	\$543	\$178	\$169	\$0	\$891	\$134	\$0	\$205	\$1,229	\$2	
3.4	Service Water Systems	\$1,117	\$2,133	\$6,905	\$0	\$10,155	\$1,523	\$0	\$3,503	\$15,181	\$23	
3.5	Other Boiler Plant Systems	\$138	\$50	\$126	\$0	\$314	\$47	\$0	\$72	\$433	\$1	
3.6	Natural Gas Pipeline and Start-Up System	\$7,197	\$310	\$232	\$0	\$7,739	\$1,161	\$0	\$1,780	\$10,679	\$16	
3.7	Wastewater Treatment Equipment	\$5,256	\$0	\$3,222	\$0	\$8,478	\$1,272	\$0	\$2,925	\$12,674	\$19	
3.8	Vacuum Flash, Brine Concentrator, & Crystallizer	\$25,027	\$0	\$15,504	\$0	\$40,532	\$6,080	\$0	\$13,983	\$60,595	\$92	
3.9	Miscellaneous Plant Equipment	\$15,325	\$2,010	\$7,788	\$0	\$25,124	\$3,769	\$0	\$8,668	\$37,560	\$57	
	<b>Subtotal</b>	<b>\$59,393</b>	<b>\$6,856</b>	<b>\$36,966</b>	<b>\$0</b>	<b>\$103,216</b>	<b>\$15,482</b>	<b>\$0</b>	<b>\$34,149</b>	<b>\$152,847</b>	<b>\$232</b>	

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case:		4		– Coal Gasification w/o CCS				Estimate Type:			Conceptual	
Plant Size (kg H <sub>2</sub> /day):		659,947						Cost Base:			Dec 2018	
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost		
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]	
<b>4 Gasifier, ASU, &amp; Accessories</b>												
4.1	Gasifier & Auxiliaries (Shell)	\$604,151	\$0	\$259,074	\$0	\$863,224	\$129,484	\$120,851	\$167,034	\$1,280,593	\$1,940	
4.2	Syngas Cooler	\$61,105	\$0	\$26,203	\$0	\$87,308	\$13,096	\$12,223	\$16,894	\$129,521	\$196	
4.3	Air Separation Unit/Oxidant Compression	\$126,735	\$29,005	\$30,163	\$0	\$185,903	\$37,181	\$18,590	\$36,251	\$277,925	\$421	
4.5	Miscellaneous Gasification Equipment	\$4,180	\$0	\$1,792	\$0	\$5,972	\$896	\$0	\$1,030	\$7,898	\$12	
4.6	Low Temperature Heat Recovery & Fuel Gas Saturation	\$44,687	\$0	\$16,977	\$0	\$61,664	\$9,250	\$0	\$14,183	\$85,096	\$129	
4.7	Flare Stack System	\$1,901	\$0	\$335	\$0	\$2,236	\$335	\$0	\$514	\$3,086	\$5	
4.15	Major Component Rigging	\$233	\$0	\$100	\$0	\$332	\$50	\$0	\$57	\$439	\$1	
4.16	Gasification Foundations	\$0	\$470	\$280	\$0	\$751	\$113	\$0	\$216	\$1,079	\$2	
	<b>Subtotal</b>	<b>\$842,990</b>	<b>\$29,476</b>	<b>\$334,925</b>	<b>\$0</b>	<b>\$1,207,390</b>	<b>\$190,404</b>	<b>\$151,665</b>	<b>\$236,179</b>	<b>\$1,785,638</b>	<b>\$2,706</b>	
<b>5 Syngas Cleanup</b>												
5.2	Methyl Diethanolamine (MDEA) – Low Temperature Acid Gas Removal	\$10,598	\$0	\$8,932	\$0	\$19,530	\$2,929	\$0	\$4,492	\$26,951	\$41	
5.3	Elemental Sulfur Plant	\$47,453	\$9,250	\$60,802	\$0	\$117,505	\$17,626	\$0	\$27,026	\$162,157	\$246	
5.4	Carbon Dioxide (CO <sub>2</sub> ) Compression & Drying	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
5.5	Carbon Dioxide (CO <sub>2</sub> ) Compressor Aftercooler	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
5.6	Mercury Removal (Carbon Bed)	\$480	\$0	\$363	\$0	\$843	\$126	\$42	\$202	\$1,214	\$2	
5.7	Water Gas Shift (WGS) Reactors	\$133,061	\$0	\$53,194	\$0	\$186,255	\$27,938	\$0	\$42,839	\$257,032	\$389	
5.9	Particulate Removal	\$1,841	\$0	\$790	\$0	\$2,631	\$395	\$0	\$454	\$3,480	\$5	
5.10	Blowback Gas Systems	\$838	\$471	\$263	\$0	\$1,571	\$236	\$0	\$361	\$2,168	\$3	
5.11	Fuel Gas Piping	\$0	\$3,802	\$2,490	\$0	\$6,292	\$944	\$0	\$1,447	\$8,683	\$13	
5.12	Gas Cleanup Foundations	\$0	\$220	\$148	\$0	\$369	\$55	\$0	\$127	\$551	\$1	
	<b>Subtotal</b>	<b>\$194,272</b>	<b>\$13,743</b>	<b>\$126,980</b>	<b>\$0</b>	<b>\$334,996</b>	<b>\$50,249</b>	<b>\$42</b>	<b>\$76,949</b>	<b>\$462,236</b>	<b>\$700</b>	
<b>6 Hydrogen Production</b>												
6.1	Pressure Swing Adsorber	\$32,224	\$23	\$1,403	\$1,095	\$34,745	\$5,212	\$0	\$7,991	\$47,948	\$73	
6.2	Hydrogen Compressor	\$9,097	\$147	\$526	\$410	\$10,179	\$1,527	\$0	\$2,341	\$14,048	\$21	
	<b>Subtotal</b>	<b>\$41,321</b>	<b>\$170</b>	<b>\$1,929</b>	<b>\$1,505</b>	<b>\$44,925</b>	<b>\$6,739</b>	<b>\$0</b>	<b>\$10,333</b>	<b>\$61,996</b>	<b>\$94</b>	
<b>7 Off Gas Fired Boiler, Ductwork, &amp; Stack</b>												
7.1	Off Gas Fired Boiler	\$3,727	\$367	\$416	\$324	\$4,833	\$725	\$0	\$1,112	\$6,670	\$10	
7.2	Off Gas Fired Boiler Accessories	\$523	\$465	\$741	\$578	\$2,307	\$346	\$0	\$531	\$3,184	\$5	
7.3	Ductwork	w/7.1	w/7.1	w/7.1	w/7.1	\$0	\$0	\$0	\$0	\$0	\$0	
7.4	Stack	\$1,157	\$77	\$211	\$164	\$1,610	\$242	\$0	\$463	\$2,314	\$4	
7.5	Off Gas Fired Boiler, Ductwork & Stack Foundations	w/7.1	w/7.1	w/7.1	w/7.1	\$0	\$0	\$0	\$0	\$0	\$0	
	<b>Subtotal</b>	<b>\$5,407</b>	<b>\$910</b>	<b>\$1,368</b>	<b>\$1,067</b>	<b>\$8,751</b>	<b>\$1,313</b>	<b>\$0</b>	<b>\$2,105</b>	<b>\$12,169</b>	<b>\$18</b>	

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case:		4		– Coal Gasification w/o CCS				Estimate Type:		Conceptual	
Plant Size (kg H <sub>2</sub> /day):		659,947						Cost Base:		Dec 2018	
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost	
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]
<b>8 Steam Turbine &amp; Accessories</b>											
8.1	Steam Turbine Generator & Accessories	\$28,196	\$1,952	\$3,109	\$2,425	\$35,682	\$5,352	\$0	\$8,207	\$49,242	\$75
8.2	Steam Turbine Plant Auxiliaries	w/8.1	w/8.1	w/8.1	w/8.1	\$0	\$0	\$0	\$0	\$0	\$0
8.3	Condenser & Auxiliaries	\$761	\$620	\$504	\$393	\$2,278	\$342	\$0	\$524	\$3,143	\$5
8.4	Steam Piping	w/8.1	w/8.1	w/8.1	w/8.1	\$0	\$0	\$0	\$0	\$0	\$0
8.5	Turbine Generator Foundations	w/8.1	w/8.1	w/8.1	w/8.1	\$0	\$0	\$0	\$0	\$0	\$0
	<b>Subtotal</b>	<b>\$28,957</b>	<b>\$2,572</b>	<b>\$3,613</b>	<b>\$2,818</b>	<b>\$37,960</b>	<b>\$5,694</b>	<b>\$0</b>	<b>\$8,731</b>	<b>\$52,385</b>	<b>\$79</b>
<b>9 Cooling Water System</b>											
9.1	Cooling Towers	\$8,329	\$0	\$2,520	\$0	\$10,849	\$1,627	\$0	\$1,872	\$14,348	\$22
9.2	Circulating Water Pumps	\$1,084	\$0	\$80	\$0	\$1,164	\$175	\$0	\$201	\$1,539	\$2
9.3	Circulating Water System Auxiliaries	\$7,666	\$0	\$1,089	\$0	\$8,755	\$1,313	\$0	\$1,510	\$11,578	\$18
9.4	Circulating Water Piping	\$0	\$4,417	\$4,000	\$0	\$8,418	\$1,263	\$0	\$1,936	\$11,616	\$18
9.5	Make-up Water System	\$464	\$0	\$638	\$0	\$1,102	\$165	\$0	\$253	\$1,520	\$2
9.6	Component Cooling Water System	\$158	\$189	\$130	\$0	\$476	\$71	\$0	\$110	\$657	\$1
9.7	Circulating Water System Foundations	\$0	\$368	\$654	\$0	\$1,022	\$153	\$0	\$353	\$1,529	\$2
	<b>Subtotal</b>	<b>\$17,701</b>	<b>\$4,974</b>	<b>\$9,111</b>	<b>\$0</b>	<b>\$31,786</b>	<b>\$4,768</b>	<b>\$0</b>	<b>\$6,234</b>	<b>\$42,788</b>	<b>\$65</b>
<b>10 Slag Recovery &amp; Handling</b>											
10.1	Slag Dewatering & Cooling	\$1,934	\$0	\$947	\$0	\$2,881	\$432	\$0	\$497	\$3,810	\$6
10.2	Gasifier Ash Depressurization	\$1,096	\$0	\$537	\$0	\$1,632	\$245	\$0	\$282	\$2,158	\$3
10.3	Cleanup Ash Depressurization	\$492	\$0	\$241	\$0	\$734	\$110	\$0	\$127	\$970	\$1
10.6	Ash Storage Silos	\$1,104	\$0	\$1,193	\$0	\$2,297	\$345	\$0	\$396	\$3,038	\$5
10.7	Ash Transport & Feed Equipment	\$425	\$0	\$99	\$0	\$524	\$79	\$0	\$90	\$693	\$1
10.8	Miscellaneous Ash Handling Equipment	\$61	\$75	\$22	\$0	\$158	\$24	\$0	\$27	\$209	\$0
10.9	Ash/Spent Sorbent Foundation	\$0	\$431	\$573	\$0	\$1,004	\$151	\$0	\$346	\$1,501	\$2
	<b>Subtotal</b>	<b>\$5,112</b>	<b>\$506</b>	<b>\$3,612</b>	<b>\$0</b>	<b>\$9,230</b>	<b>\$1,384</b>	<b>\$0</b>	<b>\$1,765</b>	<b>\$12,380</b>	<b>\$19</b>
<b>11 Accessory Electric Plant</b>											
11.1	Generator Equipment	\$1,468	\$0	\$1,108	\$0	\$2,576	\$386	\$0	\$444	\$3,406	\$5
11.2	Station Service Equipment	\$3,409	\$0	\$292	\$0	\$3,702	\$555	\$0	\$639	\$4,896	\$7
11.3	Switchgear & Motor Control	\$20,574	\$0	\$3,569	\$0	\$24,143	\$3,621	\$0	\$4,165	\$31,929	\$48
11.4	Conduit & Cable Tray	\$0	\$91	\$263	\$0	\$354	\$53	\$0	\$102	\$509	\$1
11.5	Wire & Cable	\$0	\$1,248	\$2,231	\$0	\$3,479	\$522	\$0	\$1,000	\$5,002	\$8
11.6	Protective Equipment	\$241	\$0	\$837	\$0	\$1,078	\$162	\$0	\$186	\$1,426	\$2
11.7	Standby Equipment	\$307	\$0	\$284	\$0	\$591	\$89	\$0	\$102	\$781	\$1
11.8	Main Power Transformers	\$1,421	\$0	\$29	\$0	\$1,450	\$218	\$0	\$250	\$1,918	\$3
11.9	Electrical Foundations	\$0	\$17	\$43	\$0	\$59	\$9	\$0	\$20	\$89	\$0

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case:		4		– Coal Gasification w/o CCS				Estimate Type:		Conceptual	
Plant Size (kg H <sub>2</sub> /day):		659,947						Cost Base:		Dec 2018	
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost	
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]
	<b>Subtotal</b>	<b>\$27,421</b>	<b>\$1,356</b>	<b>\$8,656</b>	<b>\$0</b>	<b>\$37,433</b>	<b>\$5,615</b>	<b>\$0</b>	<b>\$6,908</b>	<b>\$49,956</b>	<b>\$76</b>
<b>12</b>		<b>Instrumentation &amp; Control</b>									
12.1	Gasification Control Equipment	\$654	\$0	\$280	\$0	\$934	\$140	\$0	\$161	\$1,235	\$2
12.3	Steam Turbine Control Equipment	\$604	\$0	\$82	\$0	\$686	\$103	\$0	\$118	\$907	\$1
12.4	Other Major Component Control Equipment	\$1,150	\$0	\$783	\$0	\$1,933	\$290	\$97	\$348	\$2,667	\$4
12.5	Signal Processing Equipment	\$892	\$0	\$29	\$0	\$921	\$138	\$0	\$159	\$1,219	\$2
12.6	Control Boards, Panels & Racks	\$259	\$0	\$170	\$0	\$428	\$64	\$21	\$103	\$617	\$1
12.7	Distributed Control System Equipment	\$9,364	\$0	\$306	\$0	\$9,669	\$1,450	\$483	\$1,740	\$13,344	\$20
12.8	Instrument Wiring & Tubing	\$466	\$373	\$1,491	\$0	\$2,329	\$349	\$116	\$699	\$3,494	\$5
12.9	Other Instrumentation & Controls Equipment	\$1,045	\$0	\$518	\$0	\$1,563	\$234	\$78	\$281	\$2,157	\$3
	<b>Subtotal</b>	<b>\$14,433</b>	<b>\$373</b>	<b>\$3,659</b>	<b>\$0</b>	<b>\$18,464</b>	<b>\$2,770</b>	<b>\$796</b>	<b>\$3,610</b>	<b>\$25,639</b>	<b>\$39</b>
<b>13</b>		<b>Improvements to Site</b>									
13.1	Site Preparation	\$0	\$422	\$9,603	\$0	\$10,025	\$1,504	\$0	\$3,459	\$14,987	\$23
13.2	Site Improvements	\$0	\$1,908	\$2,697	\$0	\$4,604	\$691	\$0	\$1,589	\$6,884	\$10
13.3	Site Facilities	\$2,978	\$0	\$3,344	\$0	\$6,322	\$948	\$0	\$2,181	\$9,451	\$14
	<b>Subtotal</b>	<b>\$2,978</b>	<b>\$2,330</b>	<b>\$15,643</b>	<b>\$0</b>	<b>\$20,951</b>	<b>\$3,143</b>	<b>\$0</b>	<b>\$7,228</b>	<b>\$31,322</b>	<b>\$47</b>
<b>14</b>		<b>Buildings &amp; Structures</b>									
14.3	Steam Turbine Building	\$0	\$2,585	\$3,681	\$0	\$6,266	\$940	\$0	\$1,081	\$8,287	\$13
14.4	Administration Building	\$0	\$844	\$613	\$0	\$1,457	\$219	\$0	\$251	\$1,927	\$3
14.5	Circulation Water Pumphouse	\$0	\$116	\$61	\$0	\$178	\$27	\$0	\$31	\$235	\$0
14.6	Water Treatment Buildings	\$0	\$250	\$244	\$0	\$493	\$74	\$0	\$85	\$653	\$1
14.7	Machine Shop	\$0	\$477	\$326	\$0	\$803	\$120	\$0	\$138	\$1,062	\$2
14.8	Warehouse	\$0	\$371	\$240	\$0	\$611	\$92	\$0	\$105	\$808	\$1
14.9	Other Buildings & Structures	\$0	\$272	\$212	\$0	\$484	\$73	\$0	\$83	\$640	\$1
14.10	Waste Treating Building & Structures	\$0	\$730	\$1,393	\$0	\$2,123	\$318	\$0	\$366	\$2,808	\$4
	<b>Subtotal</b>	<b>\$0</b>	<b>\$5,645</b>	<b>\$6,769</b>	<b>\$0</b>	<b>\$12,415</b>	<b>\$1,862</b>	<b>\$0</b>	<b>\$2,142</b>	<b>\$16,418</b>	<b>\$25</b>
	<b>Total</b>	<b>\$1,298,603</b>	<b>\$73,232</b>	<b>\$568,762</b>	<b>\$5,389</b>	<b>\$1,945,987</b>	<b>\$301,193</b>	<b>\$152,503</b>	<b>\$414,381</b>	<b>\$2,814,065</b>	<b>\$4,264</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 4-30. Case 4 owner's costs**

Description	\$/1,000	\$/[kg H <sub>2</sub> /day]
<b>Pre-Production Costs</b>		
6 Months All Labor	\$22,852	\$35
1 Month Maintenance Materials	\$5,716	\$9
1 Month Non-Fuel Consumables	\$2,275	\$3
1 Month Waste Disposal	\$695	\$1
25% of 1 Months Fuel Cost at 100% CF	\$2,216	\$3
2% of TPC	\$56,281	\$85
<b>Total</b>	<b>\$90,034</b>	<b>\$136</b>
<b>Inventory Capital</b>		
60-day supply of fuel and consumables at 100% CF	\$19,393	\$29
0.5% of TPC (spare parts)	\$14,070	\$21
<b>Total</b>	<b>\$33,463</b>	<b>\$51</b>
<b>Other Costs</b>		
Initial Cost for Catalyst and Chemicals	\$23,857	\$36
Land	\$900	\$1
Other Owner's Costs	\$422,110	\$640
Financing Costs	\$75,980	\$115
<b>Total Overnight Costs (TOC)</b>	<b>\$3,460,409</b>	<b>\$5,243</b>
TASC Multiplier (IOU, 35 year)	1.116	
<b>Total As-Spent Cost (TASC)</b>	<b>\$3,862,980</b>	<b>\$5,853</b>

**Exhibit 4-31. Case 4 initial and annual operating and maintenance costs**

Case:	4	– Coal Gasification w/o CCS		Cost Base:	Dec 2018
Plant Size (kg H <sub>2</sub> /day):	659,947			Capacity Factor (%):	80
<b>Operating &amp; Maintenance Labor</b>					
<b>Operating Labor</b>			<b>Operating Labor Requirements per Shift</b>		
Operating Labor Rate (base):	38.50	\$/hour	Skilled Operator:	2.0	
Operating Labor Burden:	30.00	% of base	Operator:	10.0	
Labor O-H Charge Rate:	25.00	% of labor	Foreman:	1.0	
			Lab Techs, etc.:	3.0	
			<b>Total:</b>	<b>16.0</b>	
<b>Fixed Operating Costs</b>					
				<b>Annual Cost</b>	
				(\$)	(\$/[kg H <sub>2</sub> /day])
Annual Operating Labor:				\$7,015,008	\$10.63

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Case:	4 – Coal Gasification w/o CCS				Cost Base:	Dec 2018
Plant Size (kg H <sub>2</sub> /day):	659,947				Capacity Factor (%):	80
Maintenance Labor:					\$29,547,681	\$44.77
Administrative & Support Labor:					\$9,140,672	\$13.85
Property Taxes and Insurance:					\$56,281,297	\$85.28
<b>Total:</b>					<b>\$101,984,658</b>	<b>\$154.53</b>
<b>Variable Operating Costs</b>						
					<b>(\$)</b>	<b>(\$/kg H<sub>2</sub>)</b>
Maintenance Material:					\$54,874,264	\$0.28
<b>Consumables</b>						
	<b>Initial Fill</b>	<b>Per Day</b>	<b>Per Unit</b>	<b>Initial Fill</b>		
Water (gal/1000):	0	2,296	\$1.90	\$0	\$1,273,566	\$0.00661
Makeup and Wastewater Treatment Chemicals (ton):	0	6.8	\$550.00	\$0	\$1,098,198	\$0.00570
Sulfur-Impregnated Activated Carbon (ton):	107	0.146	\$12,000.00	\$1,282,315	\$512,926	\$0.00266
Water Gas Shift Catalyst (ft <sup>3</sup> ):	25,993	17.8	\$480.00	\$12,476,654	\$2,495,331	\$0.01295
Methyl Diethanolamine Solution (gal):	231,310	107.3	\$2.80	\$647,667	\$87,750	\$0.00046
Sodium Hydroxide (50 wt%, ton):	0	19.3	\$600.00	\$0	\$3,388,268	\$0.01758
Sulfuric Acid (98 wt%, ton):	0	0.342	\$210.00	\$0	\$20,992	\$0.00011
Claus Catalyst (ft <sup>3</sup> ):	w/equip.	1.93	\$48.00	\$0	\$27,085	\$0.00014
PSA Unit Adsorbent (ft <sup>3</sup> ):	63,000	8.6	\$150.00	\$9,450,000	\$378,000	\$0.00196
Triethylene Glycol (gal):	w/equip.	0	\$6.80	\$0	\$0	\$0.00000
Electricity (MWh):	0	600	\$71.70	\$0	\$12,556,815	\$0.06516
<b>Subtotal:</b>				<b>\$23,856,637</b>	<b>\$21,838,931</b>	<b>\$0.11333</b>
<b>Waste Disposal</b>						
Sulfur-Impregnated Activated Carbon (ton):	0	0.146	\$80.00	\$0	\$3,420	\$0.00002
Water Gas Shift Catalyst (ft <sup>3</sup> ):	0	17.8	\$2.50	\$0	\$12,997	\$0.00007
Methyl Diethanolamine Solution (gal):	0	107.3	\$0.35	\$0	\$10,969	\$0.00006
Claus Catalyst (ft <sup>3</sup> ):	0	1.93	\$2.50	\$0	\$1,411	\$0.00001
Crystallizer Solids (ton):	0	36.4	\$38.00	\$0	\$404,177	\$0.00210
Slag (ton):	0	562	\$38.00	\$0	\$6,231,964	\$0.03234
PSA Unit Adsorbent (ft <sup>3</sup> ):	0	8.6	\$1.50	\$0	\$3,780	\$0.00002
Triethylene Glycol (gal):	0	0	\$0.35	\$0	\$0	\$0.00000
<b>Subtotal:</b>				<b>\$0</b>	<b>\$6,668,716</b>	<b>\$0.03461</b>
<b>By-Products</b>						
Sulfur (tons):	0	140	\$0.00	\$0	\$0	\$0.00000
Electricity (MWh):	0	0	\$71.70	\$0	\$0	\$0.00000
<b>Subtotal:</b>				<b>\$0</b>	<b>\$0</b>	<b>\$0.00000</b>
<b>Variable Operating Costs Total:</b>				<b>\$23,856,637</b>	<b>\$83,381,911</b>	<b>\$0.43269</b>
<b>Fuel Cost</b>						
Illinois Number 6 (ton):	0	5,608	\$51.96	\$0	\$85,078,534	\$0.44150
Woody Torrefied Biomass (ton):	0	0	\$105.84	\$0	\$0	\$0.00000
<b>Total:</b>				<b>\$0</b>	<b>\$85,078,534</b>	<b>\$0.44150</b>

**Exhibit 4-32. Case 4 LCOH breakdown**


Component	Value, \$/kg H <sub>2</sub>	Percentage
Capital	1.17	46%
Fixed	0.53	21%
Variable	0.43	17%
Fuel	0.44	17%
<b>Total (Excluding T&amp;S)</b>	<b>2.58</b>	<b>N/A</b>
CO <sub>2</sub> T&S	0.00	0%
<b>Total (Including T&amp;S)</b>	<b>2.58</b>	<b>N/A</b>

## 4.9 CASE 5 – SHELL GASIFICATION PLANT WITH CO<sub>2</sub> CAPTURE PROCESS DESCRIPTION

This section contains an evaluation of a plant design for Case 5, which is based on a Shell coal gasification plant with CO<sub>2</sub> capture. The plant configuration is nearly identical to that of Case 4, with the exception that this case is configured to produce hydrogen with CO<sub>2</sub> capture. The hydrogen production rate of Case 5 is equal to the Case 4 capacity. The system descriptions follow the BFD provided in Exhibit 4-33 with the associated stream tables that show process data provided in Exhibit 4-34. Rather than repeating the entire process description, only differences from Case 4 are reported here.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Exhibit 4-33. Case 5 block flow diagram, Shell gasification plant with CO<sub>2</sub> capture



COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 4-34. Case 5 stream table, Shell gasification plant with capture**

	1	2	3	4	5	6	7	8	9	10	11	12
V-L Mole Fraction												
Ar	0.0092	0.0343	0.0025	0.0343	0.0000	0.0000	0.0092	0.0096	0.0000	0.0082	0.0000	0.0000
CH <sub>4</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0004	0.0000	0.0004	0.0000	0.0000
CO	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0167	0.0000	0.5163	0.0000	0.0000
CO <sub>2</sub>	0.0003	0.0000	0.0004	0.0000	0.0000	0.0000	0.0003	0.0286	0.0000	0.0170	0.0000	0.0010
COS	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0006	0.0000	0.0000
H <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.8832	0.0000	0.2637	0.0000	0.0000
H <sub>2</sub> O	0.0099	0.0000	0.0091	0.0000	0.0000	0.0000	0.0099	0.0001	0.0000	0.1293	0.9998	0.9796
HCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0004	0.0000	0.0000
H <sub>2</sub> S	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0073	0.0000	0.0001
H <sub>2</sub> SO <sub>4</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.7732	0.0157	0.9844	0.0157	0.9964	0.0000	0.7732	0.0614	0.0000	0.0516	0.0000	0.0000
NH <sub>3</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0051	0.0002	0.0193
O <sub>2</sub>	0.2074	0.9501	0.0035	0.9501	0.0036	0.0000	0.2074	0.0000	0.0000	0.0000	0.0000	0.0000
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaOH	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	1.0000	1.0000	0.0000	1.0000	1.0000	1.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	23,745	97	17,612	5,017	945	0	1,003	305	0	26,522	1,130	10,214
V-L Flowrate (kg/hr)	685,216	3,129	492,660	161,608	26,484	0	28,929	1,716	0	536,844	20,363	184,111
Solids Flowrate (kg/hr)	0	0	0	0	0	211,967	0	0	21,230	0	0	0
Temperature (°C)	15	27	21	27	130	15	15	18	1,427	1,079	343	188
Pressure (MPa, abs)	0.10	0.86	0.45	5.10	5.62	0.10	0.10	2.89	4.24	4.24	5.10	4.98
Steam Table Enthalpy (kJ/kg) <sup>A</sup>	30.23	21.53	28.11	9.82	129.22	---	30.23	94.16	---	2,034.56	3,083.36	767.78
AspenPlus Enthalpy (kJ/kg) <sup>B</sup>	-97.58	-0.97	-97.45	-12.68	103.25	-2,119.02	-97.58	-2,374.94	2,165.43	-3,011.70	12,884.30	14,939.49
Density (kg/m <sup>3</sup> )	1.2	11.2	5.2	68.6	46.4	---	1.2	6.6	---	7.6	19.9	835.9
V-L Molecular Weight	28.857	32.209	27.974	32.209	28.028	---	28.857	5.617	---	20.241	18.015	18.025
V-L Flowrate (lb <sub>mol</sub> /hr)	52,349	214	38,827	11,062	2,083	0	2,210	673	0	58,472	2,492	22,518
V-L Flowrate (lb/hr)	1,510,643	6,897	1,086,129	356,286	58,388	0	63,778	3,783	0	1,183,539	44,892	405,896
Solids Flowrate (lb/hr)	0	0	0	0	0	467,308	0	0	46,803	0	0	0
Temperature (°F)	59	80	70	80	267	59	59	65	2,600	1,974	650	371
Pressure (psia)	14.7	125.0	65.0	740.0	815.0	14.7	14.7	418.7	615.0	615.0	740.0	722.7
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	13.0	9.3	12.1	4.2	55.6	---	13.0	40.5	---	874.7	1,325.6	330.1
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	-42.0	-0.4	-41.9	-5.5	44.4	-911.0	-42.0	-1,021.0	931.0	-1,294.8	-5,539.3	-6,422.8
Density (lb/ft <sup>3</sup> )	0.076	0.700	0.322	4.283	2.894	---	0.076	0.412	---	0.473	1.240	52.186

<sup>A</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>B</sup>Aspen thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 4-34. Case 5 stream table, Shell gasification plant with capture (continued)**

	13	14	15	16	17	18	19	20	21	22	23
V-L Mole Fraction											
Ar	0.0059	0.0000	0.0000	0.0000	0.0000	0.0048	0.0000	0.0000	0.0000	0.0000	0.0060
CH <sub>4</sub>	0.0003	0.0000	0.0000	0.0000	0.0000	0.0002	0.0000	0.0000	0.0000	0.0000	0.0003
CO	0.3728	0.0000	0.0000	0.0000	0.0000	0.0084	0.0002	0.0000	0.0000	0.0000	0.0106
CO <sub>2</sub>	0.0125	0.0000	0.0000	0.0000	0.0007	0.3010	0.0001	0.0000	0.0007	0.0010	0.3783
COS	0.0005	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub>	0.1904	0.0000	0.0000	0.0000	0.0000	0.4433	0.0001	0.0000	0.0000	0.0000	0.5597
H <sub>2</sub> O	0.3657	1.0000	0.6895	0.1000	0.9799	0.2004	0.9931	0.9993	0.9799	0.9791	0.0016
HCl	0.0003	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub> S	0.0053	0.0000	0.0000	0.0000	0.0001	0.0046	0.0001	0.0000	0.0001	0.0001	0.0057
H <sub>2</sub> SO <sub>4</sub>	0.0000	0.0000	0.0000	0.9000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0373	0.0000	0.0000	0.0000	0.0000	0.0299	0.0000	0.0000	0.0000	0.0000	0.0378
NH <sub>3</sub>	0.0091	0.0000	0.0000	0.0000	0.0192	0.0073	0.0038	0.0007	0.0192	0.0197	0.0000
O <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0026	0.0000	0.0000	0.0000	0.0000
NaOH	0.0000	0.0000	0.3105	0.0000	0.0000	0.0000	0.0001	0.0000	0.0000	0.0000	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	29,022	8,265	29	0	709	36,173	3,480	1,627	3,331	13,357	28,645
V-L Flowrate (kg/hr)	569,546	148,903	731	13	12,771	698,204	63,063	29,316	60,014	240,775	561,467
Solids Flowrate (kg/hr)	0	0	0	0	0	0	0	0	0	0	0
Temperature (°C)	232	288	16	15	67	202	190	88	67	69	29
Pressure (MPa, abs)	3.98	3.88	4.81	0.13	0.47	3.49	3.88	0.13	0.47	0.45	3.18
Steam Table Enthalpy (kJ/kg) <sup>A</sup>	1,189.11	2,971.61	-338.78	-8,206.86	238.31	804.50	792.23	368.02	238.31	247.89	39.45
AspenPlus Enthalpy (kJ/kg) <sup>B</sup>	-6,579.94	-13,008.68	-13,665.00	-8,526.27	-15,475.10	-8,423.95	-15,049.56	-15,593.09	-15,475.10	-15,452.90	-7,685.67
Density (kg/m <sup>3</sup> )	19.0	16.9	1,531.7	1,791.5	964.7	17.2	873.9	965.6	964.7	962.3	25.2
V-L Molecular Weight	19.625	18.015	24.842	90.073	18.017	19.302	18.120	18.015	18.017	18.026	19.601
V-L Flowrate (lb <sub>mol</sub> /hr)	63,982	18,222	65	0	1,563	79,747	7,673	3,588	7,343	29,447	63,152
V-L Flowrate (lb/hr)	1,255,634	328,274	1,612	29	28,156	1,539,277	139,029	64,631	132,308	530,818	1,237,823
Solids Flowrate (lb/hr)	0	0	0	0	0	0	0	0	0	0	0
Temperature (°F)	450	550	61	59	152	395	373	191	152	157	84
Pressure (psia)	577.7	562.7	697.7	18.2	67.7	506.1	562.7	19.3	67.7	65.0	460.7
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	511.2	1,277.6	-145.7	-3,528.3	102.5	345.9	340.6	158.2	102.5	106.6	17.0
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	-2,828.9	-5,592.7	-5,874.9	-3,665.6	-6,653.1	-3,621.6	-6,470.1	-6,703.8	-6,653.1	-6,643.6	-3,304.2
Density (lb/ft <sup>3</sup> )	1.183	1.055	95.623	111.841	60.225	1.075	54.553	60.280	60.225	60.075	1.572

<sup>A</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>B</sup>Aspen thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 4-34. Case 5 stream table, Shell gasification plant with capture (continued)**

	24	25	26	27	28	29	30	31	32	33	34
V-L Mole Fraction											
Ar	0.0000	0.0000	0.0060	0.0096	0.0000	0.0093	0.0000	0.0000	0.0004	0.0096	0.0008
CH <sub>4</sub>	0.0000	0.0000	0.0003	0.0004	0.0000	0.0000	0.0000	0.0000	0.0000	0.0004	0.0000
CO	0.0000	0.0000	0.0106	0.0167	0.0004	0.0053	0.0000	0.0000	0.0042	0.0167	0.0000
CO <sub>2</sub>	0.0000	0.0002	0.3816	0.0286	0.5187	0.6440	0.0000	0.0000	0.3172	0.0286	0.0000
COS	0.0000	0.0000	0.0000	0.0000	0.0009	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub>	0.0000	0.0000	0.5557	0.8832	0.0122	0.2388	0.0000	0.0000	0.0283	0.8832	0.9990
H <sub>2</sub> O	0.9999	0.9832	0.0016	0.0001	0.0226	0.0024	0.0000	1.0000	0.1566	0.0001	0.0000
HCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub> S	0.0000	0.0003	0.0057	0.0000	0.4441	0.0050	0.0000	0.0000	0.0123	0.0000	0.0000
H <sub>2</sub> SO <sub>4</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0385	0.0614	0.0003	0.0952	0.0000	0.0000	0.0015	0.0614	0.0002
NH <sub>3</sub>	0.0000	0.0164	0.0000	0.0000	0.0007	0.0000	0.0000	0.0000	0.4796	0.0000	0.0000
O <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaCl	0.0001	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaOH	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	1.0000	1.0000	1.0000	1.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	2,627	685	29,011	18,152	373	366	0	214	137	17,847	13,412
V-L Flowrate (kg/hr)	47,343	12,327	573,275	101,962	14,340	11,808	0	3,864	3,515	100,246	27,500
Solids Flowrate (kg/hr)	0	0	0	0	0	0	5,312	0	0	0	0
Temperature (°C)	15	30	37	18	27	38	184	50	160	18	18
Pressure (MPa, abs)	0.10	0.24	3.07	2.89	0.18	3.07	0.12	0.11	0.45	2.89	2.82
Steam Table Enthalpy (kJ/kg) <sup>A</sup>	62.75	90.75	50.96	94.16	40.84	23.14	---	109.79	503.09	94.16	263.41
AspenPlus Enthalpy (kJ/kg) <sup>B</sup>	-15,905.25	-15,663.68	-7,678.43	-2,374.94	-5,697.83	-7,909.59	147.51	-15,860.13	-7,050.59	-2,374.94	-86.91
Density (kg/m <sup>3</sup> )	999.4	985.6	23.9	6.6	2.9	41.0	5,266.6	968.5	3.2	6.6	2.4
V-L Molecular Weight	18.019	18.008	19.760	5.617	38.486	32.224	---	18.016	25.597	5.617	2.050
V-L Flowrate (lb <sub>mol</sub> /hr)	5,793	1,509	63,959	40,019	821	808	0	473	303	39,345	29,568
V-L Flowrate (lb/hr)	104,373	27,175	1,263,856	224,788	31,615	26,032	0	8,518	7,749	221,005	60,627
Solids Flowrate (lb/hr)	0	0	0	0	0	0	11,711	0	0	0	0
Temperature (°F)	59	85	99	65	80	100	364	121	320	65	65
Pressure (psia)	14.7	35.0	445.2	418.7	26.7	445.2	16.8	15.9	65.0	418.7	408.7
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	27.0	39.0	21.9	40.5	17.6	9.9	---	47.2	216.3	40.5	113.2
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	-6,838.0	-6,734.2	-3,301.1	-1,021.0	-2,449.6	-3,400.5	63.4	-6,818.6	-3,031.2	-1,021.0	-37.4
Density (lb/ft <sup>3</sup> )	62.391	61.529	1.491	0.412	0.181	2.561	328.780	60.459	0.201	0.412	0.147

<sup>A</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>B</sup>Aspen thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 4-34. Case 5 stream table, Shell gasification plant with capture (continued)**

	35	36	37	38	39	40	41	42	43	44	45
V-L Mole Fraction											
Ar	0.0008	0.0364	0.0092	0.0000	0.0095	0.0001	0.0000	0.0000	0.0000	0.0000	0.0000
CH <sub>4</sub>	0.0000	0.0016	0.0000	0.0000	0.0000	0.0001	0.0000	0.0000	0.0000	0.0000	0.0000
CO	0.0000	0.0671	0.0000	0.0000	0.0000	0.0005	0.0001	0.0004	0.0004	0.0000	0.0004
CO <sub>2</sub>	0.0000	0.1150	0.0003	0.0000	0.0254	0.9841	0.9984	0.9879	0.9908	0.0500	0.9908
COS	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub>	0.9990	0.5331	0.0000	0.0000	0.0000	0.0106	0.0008	0.0080	0.0080	0.0000	0.0080
H <sub>2</sub> O	0.0000	0.0005	0.0099	1.0000	0.1124	0.0043	0.0007	0.0034	0.0005	0.9500	0.0005
HCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub> S	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub> SO <sub>4</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0002	0.2464	0.7732	0.0000	0.8242	0.0004	0.0000	0.0003	0.0003	0.0000	0.0003
NH <sub>3</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
O <sub>2</sub>	0.0000	0.0000	0.2074	0.0000	0.0285	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaOH	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	13,412	4,435	10,388	13,270	33,068	7,648	2,839	10,487	10,455	32	10,455
V-L Flowrate (kg/hr)	27,500	72,746	299,768	239,062	910,167	332,195	124,778	456,973	456,364	609	456,364
Solids Flowrate (kg/hr)	0	0	0	0	0	0	0	0	0	0	0
Temperature (°C)	30	193	15	510	50	-3	-11	29	29	29	30
Pressure (MPa, abs)	6.48	0.50	0.10	12.51	0.11	0.55	0.12	2.50	2.39	2.50	15.27
Steam Table Enthalpy (kJ/kg) <sup>A</sup>	440.05	356.19	30.23	3,369.21	216.61	-8.36	-9.60	2.30	0.54	138.13	-226.95
AspenPlus Enthalpy (kJ/kg) <sup>B</sup>	89.72	-2,913.87	-97.58	-12,611.09	-1,345.41	-8,974.80	-8,972.84	-8,963.44	-8,956.66	-15,225.03	-9,184.16
Density (kg/m <sup>3</sup> )	5.1	2.1	1.2	38.4	1.1	11.2	2.3	49.8	47.2	319.0	838.1
V-L Molecular Weight	2.050	16.403	28.857	18.015	27.524	43.435	43.956	43.576	43.650	19.315	43.650
V-L Flowrate (lb <sub>mol</sub> /hr)	29,568	9,777	22,902	29,255	72,903	16,861	6,258	23,119	23,050	70	23,050
V-L Flowrate (lb/hr)	60,627	160,378	660,875	527,042	2,006,574	732,364	275,089	1,007,453	1,006,110	1,343	1,006,110
Solids Flowrate (lb/hr)	0	0	0	0	0	0	0	0	0	0	0
Temperature (°F)	86	380	59	950	122	26	12	85	85	85	86
Pressure (psia)	939.7	72.5	14.7	1,814.7	15.4	80.0	16.7	363.0	346.5	363.0	2,214.7
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	189.2	153.1	13.0	1,448.5	93.1	-3.6	-4.1	1.0	0.2	59.4	-97.6
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	38.6	-1,252.7	-42.0	-5,421.8	-578.4	-3,858.5	-3,857.6	-3,853.6	-3,850.7	-6,545.6	-3,948.5
Density (lb/ft <sup>3</sup> )	0.319	0.132	0.076	2.395	0.069	0.698	0.146	3.108	2.947	19.917	52.320

<sup>A</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>B</sup>Aspen thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm

### 4.9.1 Acid Gas Removal


The AGR process in Case 5 is a two-stage Selexol process where H<sub>2</sub>S is removed in the first stage and CO<sub>2</sub> in the second stage of absorption. The process results in four product streams, the clean syngas (stream 27), two CO<sub>2</sub>-rich streams (streams 40 and 41), and an acid gas feed to the Claus plant (stream 28). The acid gas contains 44 vol% H<sub>2</sub>S and 52 vol% CO<sub>2</sub> with the balance primarily water and H<sub>2</sub>. The raw CO<sub>2</sub> stream from the Selexol process contains over 98 vol% CO<sub>2</sub>.

The two-stage Selexol process is used in the two gasification cases that require CO<sub>2</sub> capture, Case 5 and Case 6. According to the previously referenced Sfa Pacific, Inc. report, “For future IGCC with CO<sub>2</sub> removal for storage, a two-stage Selexol process presently appears to be the preferred AGR process – as indicated by ongoing engineering studies at EPRI and by various engineering firms with IGCC interests.” [70]

As several vendors have indicated that Selexol is sensitive to NH<sub>3</sub> and have specified that NH<sub>3</sub> should be reduced to a concentration below 10 ppmv in the syngas feed, a water wash column is included upstream of the AGR for NH<sub>3</sub> control, as detailed in Section 4.4.14.1.5.

As shown in Exhibit 4-35, syngas enters the bottom of the first of two absorbers and flows upward through packed beds where it contacts chilled solvent—loaded with CO<sub>2</sub>—entering at the top of the column, which preferentially removes H<sub>2</sub>S from the gas phase.

**Exhibit 4-35. Flow diagram for a conventional two-stage AGR unit**



The gas from the H<sub>2</sub>S absorber flows upward through the packed beds of the second absorber. CO<sub>2</sub> is removed from the gas phase first by semi-lean, flash-regenerated solvent entering near the middle of the tower, followed by chilled, lean solvent entering at the top of the tower. The treated gas passes through de-entrainment devices at the top of the tower before exiting the absorber and being sent directly to the PSA. A portion of the gas can also be used for coal drying, when required.

The CO<sub>2</sub> loaded solvent exits the CO<sub>2</sub> absorber. A portion is sent to the H<sub>2</sub>S absorber, which is pumped up to pressure and then chilled prior to reaching the H<sub>2</sub>S absorber, and the remainder is sent to a series of flash drums for regeneration.

The portion sent to the flash regeneration is expanded in the HP CO<sub>2</sub> recycle flash drum at 2.0 MPa (289.7 psia) where H<sub>2</sub>, CH<sub>4</sub>, CO<sub>2</sub>, and other dissolved gases are transferred to the gas phase. The flashed off gas is compressed and returned to the CO<sub>2</sub> absorber, minimizing product losses to the CO<sub>2</sub> stream.

The amount of H<sub>2</sub> recovered from the syngas stream is dependent on the Selexol process design conditions. In this report, H<sub>2</sub> recovery is 99.5 percent per pass. The minimal H<sub>2</sub> slip to the CO<sub>2</sub> storage stream maximizes the overall plant efficiency.

The semi-rich solvent from the HP CO<sub>2</sub> recycle flash drum is routed to two sequential CO<sub>2</sub> flash drums. The HP CO<sub>2</sub> stream is flashed at 0.55 MPa (80 psia) and the LP CO<sub>2</sub> stream is flashed at 0.1 MPa (16.7 psia). The flashed CO<sub>2</sub> gas is sent to the CO<sub>2</sub> compressors and the semi-lean solvent is pumped back to the CO<sub>2</sub> absorber.

The rich solvent exiting the H<sub>2</sub>S absorber is heated using the lean solvent from the stripper. The hot, rich solvent enters the H<sub>2</sub>S concentrator and partially flashes. The gas exiting the concentrator is compressed and recycled back to the H<sub>2</sub>S absorber. The H<sub>2</sub>S-rich solvent from the concentrator is sent to the regenerator for thermal regeneration.

The regenerator is composed of a lower section containing packed beds and an upper section containing several reflux trays used to contact the overhead vapor with the reflux water. The solvent from the concentrator enters the regenerator above the packed bed and flows downward, releasing H<sub>2</sub>S, CO<sub>2</sub>, and other components as it passes an upflow of hot vapor generated in the reboiler.

The combined gases and hot vapor flow upward through a demister and the trayed section, where it is contacted with downflowing reflux water, which cools and condenses the hot vapor and reduces solvent entrainment. The overhead stream passes through a de-entrainment device and exits the top of the column. The overhead gas then passes through the reflux condenser in order to recover the overhead liquid. The cooled liquid and vapor phases are separated in the reflux drum. The reflux liquid is pumped to the trayed section of the regenerator and the acid gas stream is sent to the Claus plant for further processing, as discussed in Section 4.4.11. The lean solvent exiting the stripper is first cooled by providing heat to the rich solvent, then further cooled by exchange with the product gas and finally chilled in the lean chiller before returning to the top of the CO<sub>2</sub> absorber.

The Selexol process unit can be constructed primarily out of killed carbon steel, which is a deoxidized steel that provides limited or no aging, and a harder material. High severity areas of the Selexol process require stainless steel.

High severity areas are defined as:

- High temperature
- CO<sub>2</sub>/H<sub>2</sub>S evolution
- High turbulence
- Areas not normally wetted by Selexol solvent

The reboiler, absorber, and regenerator packing and internals, regenerator column and reflux circuit, water wash section, and reflux pump impellers and casings are considered high severity areas.

### 4.9.2 CO<sub>2</sub> Compression and Drying System

The CO<sub>2</sub> discharge pressures from the AGR for each capture case are identical, as are the suction pressures at the CO<sub>2</sub> compressor inlets. Therefore, the CO<sub>2</sub> compressor specifications, stage pressure ratios and outlet stage pressures are identical for each of the CO<sub>2</sub> capture cases with the major differentiator being the inlet CO<sub>2</sub> flowrates.

The compression system was modeled based on vendor supplied data and using elements of the compressor design presented in the Carbon Capture Simulation Initiative’s paper “Centrifugal Compressor Simulation User Manual.” [58] The design was assumed to be an eight-stage front-loaded integrally geared centrifugal compressor with feed streams at stage one and stage three. The stage discharge pressures are presented in Exhibit 4-36.

*Exhibit 4-36. CO<sub>2</sub> compressor interstage pressures*


Stage	Outlet Pressure, MPa (psia)	Stage Pressure Ratio
1	0.26 (38)	2.28
2	0.59 (85)	2.28
3	1.22 (177)	2.21
4	2.51 (364)	2.07
5	3.97 (576)	1.66
6	6.34 (920)	1.60
7	9.88 (1,433)	1.56
8	15.28 (2,217)	1.55

The AGR produces CO<sub>2</sub> at two pressure levels and contains approximately 99 percent CO<sub>2</sub>. The LP CO<sub>2</sub> stream enters the first stage of the CO<sub>2</sub> compressor at 0.1 MPa (16.7 psia) and is compressed to 0.59 MPa (85 psia) in the first two compression stages with intercooling. The LP CO<sub>2</sub> stream exiting stage two of compression is flashed to 0.55 MPa (80 psia) and is combined

with the MP CO<sub>2</sub> stream prior to stage three of compression. The combined stream is compressed in the following two stages to 2.51 MPa (364 psia) with intercooling, after which the combined stream is dehydrated using a triethylene glycol (TEG) dryer. The dried CO<sub>2</sub> stream is then further compressed in the final four stages, with intercooling, to the target product pressure of 15.27 MPa (2,215 psia).

Due to the temperature rise with compression, intercooling is included for each stage with the first three stages including water knockout. The first five intercoolers cool the CO<sub>2</sub> to 29 °C (85 °F), the sixth intercooler cools the CO<sub>2</sub> to 40 °C (104 °F), and the final intercooler cools the CO<sub>2</sub> to 55 °C (131 °F). The increased temperature is utilized in the final two stages of intercooling to provide a suitable buffer between the compressor operating profile and SC CO<sub>2</sub> dome. A CO<sub>2</sub> product aftercooler is also included to cool the CO<sub>2</sub> 30 °C (86 °F). CO<sub>2</sub> transportation and storage costs assume that the CO<sub>2</sub> enters the transport pipeline as a dense phase liquid; thus, a pipeline inlet temperature of 30 °C (86 °F) is considered. Exhibit 4-37 shows the enthalpy versus pressure plot for the CO<sub>2</sub> compressor modeled in Case 5. Reference conditions for the data are 0.01 °C (32.02 °F) and 0.0006 MPa (0.089 psia), the same as those used for stream table results. Data points representing compression stage discharge pressures are labeled with the compression stage number (e.g., C1). Given that the two gasification cases with CO<sub>2</sub> capture utilize the same AGR, and thus, have the same CO<sub>2</sub> discharge pressures, the operating profile is identical across the two gasification cases with CO<sub>2</sub> capture. The CO<sub>2</sub> aftercooler is not represented in the compressor operating profile plot.

**Exhibit 4-37. Case 5 CO<sub>2</sub> compressor enthalpy versus pressure operating profile**



A TEG dehydration unit is included between stages 4 and 5, operating at 2.39 MPa (346 psia), to reduce the moisture concentration of the CO<sub>2</sub> stream to 500 ppmv. The dryer was designed based on a paper published by the Norwegian University of Science and Technology. [60]

In an absorption process, such as in a TEG dehydration unit, the gas containing water flows up through a column while the TEG flows downward. The solvent preferentially binds the water by physical absorption. The dried gas exits at the top of the column, while the solvent rich in water exits at the bottom. After depressurization to around atmospheric pressure, the solvent is regenerated by heating it and passing it through a regeneration column where the water is boiled off. A TEG unit is capable of reducing water concentrations to meet the QGESS design point of 500 ppmv. [59]

### 4.9.3 Hydrogen Production

No differences from Case 4.

### 4.9.4 Steam Generation

The steam conditions for the coal gasification plant with capture (Case 5) are 12.4 MPa/510 °C/510 °C (1,800 psig/950 °F/950 °F).

## 4.10 CASE 5 – PERFORMANCE RESULTS

Overall performance for the plant is summarized in Exhibit 4-38. The plant produces 27,500 kg/hr (60,627 lb/hr) of hydrogen at an effective thermal efficiency of 64.1 percent (HHV basis). The removal of CO<sub>2</sub> from the syngas results in a higher quality PSA off-gas than in Case 4 and leads to higher grade heat available for steam generation. The steam turbine generates 109 MWe and the total auxiliary load for the plant is 148 MWe, requiring 39 MW of electricity to be sourced from the grid.

Exhibit 4-39 provides a detailed breakdown of the auxiliary power requirements. The ASU accounts for approximately 50 percent of the auxiliary load between the MAC, booster compressor, N<sub>2</sub> compressors, O<sub>2</sub> pump, and ASU auxiliaries. The two-stage Selexol process and CO<sub>2</sub> compression account for an additional 29 percent of the auxiliary power load. The hydrogen compressor accounts for about 7 percent. The BFW and circulating water system, including the circulating water pumps and cooling tower fan, composes approximately 5 percent of the load, with all other systems together constituting the remaining 9 percent of the auxiliary load.

*Exhibit 4-38. Case 5 plant performance summary*

Performance Summary	
Steam Turbine Power, MWe	109
<b>Total Gross Power, MWe</b>	<b>109</b>
Air Separation Unit Main Air Compressor, kWe	65,800
Air Separation Unit Booster Compressor, kWe	5,170

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Performance Summary	
N <sub>2</sub> Compressors, kWe	2,390
CO <sub>2</sub> Compression, kWe	31,880
Acid Gas Removal, kWe	11,640
Balance of Plant, kWe	31,550
<b>Total Auxiliaries, MWe</b>	<b>148</b>
<b>Net Power, MWe</b>	<b>-39</b>
<b>Hydrogen Production, kg/hr (lb/hr)</b>	<b>27,500 (60,627)</b>
<b>CO<sub>2</sub> Capture, %</b>	<b>92.5%</b>
HHV Effective Thermal Efficiency <sup>A</sup> , %	64.1%
HHV Cold Gas Efficiency <sup>B</sup> , %	66.6%
LHV Effective Thermal Efficiency <sup>A</sup> , %	55.9%
LHV Cold Gas Efficiency <sup>B</sup> , %	58.4%
Steam Turbine Cycle Efficiency, %	42.7%
Steam Turbine Heat Rate, kJ/kWh (Btu/kWh)	8,430 (7,991)
Condenser Duty, GJ/hr (MMBtu/hr)	615 (583)
AGR Cooling Duty, GJ/hr (MMBtu/hr)	148 (141)
As-Received Coal Feed, kg/hr (lb/hr)	211,967 (467,308)
HHV Thermal Input, kWt	1,597,711
LHV Thermal Input, kWt	1,541,012
Raw Water Withdrawal, m <sup>3</sup> /min (gpm)	13.8 (3,638)
Raw Water Consumption, m <sup>3</sup> /min (gpm)	10.8 (2,866)

<sup>A</sup>ETE = (Hydrogen Heating Value + Net Power) / Fuel Heating Value

<sup>B</sup>CGE = Hydrogen Heating Value / Fuel Heating Value

**Exhibit 4-39. Case 5 plant power summary**

Power Summary	
Steam Turbine Power, MWe	109
<b>Total Gross Power, MWe</b>	<b>109</b>
Auxiliary Load Summary	
Acid Gas Removal, kWe	11,640
Air Blower, kWe	780
Air Separation Unit Auxiliaries, kWe	1,000
Air Separation Unit Main Air Compressor, kWe	65,800
Air Separation Unit Booster Compressor, kWe	5,170
Ammonia Wash Pumps, kWe	120
Circulating Water Pumps, kWe	3,340

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Power Summary	
Claus Plant TG Recycle Compressor, kWe	1,240
Claus Plant/TGTU Auxiliaries, kWe	250
CO <sub>2</sub> Compression, kWe	31,880
Coal Handling, kWe	460
Coal Milling, kWe	2,180
Condensate Pumps, kWe	150
Cooling Tower Fans, kWe	1,730
Dryer Air Compressor, kWe	80
Feedwater Pumps, kWe	1,600
Gasifier Water Pump, kWe	40
Ground Water Pumps, kWe	330
Hydrogen Compressor, kWe	10,720
Miscellaneous Balance of Plant <sup>A</sup> , kWe	2,520
N <sub>2</sub> Compressors, kWe	2,390
O <sub>2</sub> Pump, kWe	330
Quench Water Pump, kWe	330
Shift Steam Pump, kWe	310
Slag Handling, kWe	550
Slag Reclaim Water Recycle Pump, kWe	0
Slurry Water Pump, kWe	0
Sour Gas Compressors, kWe	140
Sour Water Recycle Pumps, kWe	0
Steam Turbine Auxiliaries, kWe	90
Syngas Recycle Compressor, kWe	880
Syngas Scrubber Pumps, kWe	120
Process Water Treatment Auxiliaries, kWe	1,310
Transformer Losses, kWe	950
<b>Total Auxiliaries, MWe</b>	<b>148</b>
<b>Net Power, MWe</b>	<b>-39</b>

<sup>A</sup>Includes plant control systems, lighting, HVAC, and miscellaneous low voltage loads

### 4.10.1 Environmental Performance

The environmental targets for emissions of Hg, HCl, NO<sub>x</sub>, SO<sub>2</sub>, CO<sub>2</sub>, and PM were presented in Section 2.7.1. A summary of the plant air emissions for Case 5 is presented in Exhibit 4-40.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 4-40. Case 5 air emissions**

	kg/GJ (lb/MMBtu)	Tonne/year (ton/year) <sup>A</sup>	lb/lb H <sub>2</sub>
SO <sub>2</sub>	0.000 (0.000)	0 (0)	0.000
NO <sub>x</sub>	0.003 (0.007)	121 (133)	0.001
Particulate	0.003 (0.007)	123 (136)	0.001
Hg	2.46E-7 (5.71E-7)	0.010 (0.011)	5.14E-8
HCl	0.000 (0.000)	0.00 (0.00)	0.000
CO <sub>2</sub> <sup>B</sup>	6 (15)	259,485 (286,033)	1.3
CO <sub>2</sub> e <sup>C</sup>	19 (44)	757,406 (834,897)	4.1

<sup>A</sup>Calculations based on an 80 percent capacity factor

<sup>B</sup>Plant stack emissions

<sup>C</sup>Life cycle emissions

The low level of SO<sub>2</sub> emissions is achieved by capturing the sulfur in the gas by the two-stage Selexol AGR process. The CO<sub>2</sub> capture target results in more sulfur compounds being removed than required in the environmental targets of Section 2.7.1. The clean syngas exiting the AGR process has a sulfur concentration of approximately 0 ppmv. The H<sub>2</sub>S-rich regeneration gas from the AGR system is fed to a Claus plant, producing elemental sulfur. The Claus plant tail gas is compressed and recycled back to the AGR where most of the remaining sulfur is removed.

NO<sub>x</sub>, PM, and Hg emissions are the same as described in Case 4.

Ninety five percent of the CO<sub>2</sub> from the syngas is captured in the AGR system and compressed for storage. Because not all CO is converted to CO<sub>2</sub> in the shift reactors, the overall carbon removal is 92.5 percent. Additionally, an LCA was conducted to determine the total GWP of the plant.

The carbon balance for the plant is shown in Exhibit 4-41. The carbon input to the plant consists of carbon in the air in addition to carbon in the coal. Carbon leaves the plant as unburned carbon in the slag, a small portion of the hydrogen product, the captured CO<sub>2</sub> product, and the CO<sub>2</sub> in the stack gas, including the coal dryer vent gas and ASU vent gas. The carbon capture efficiency is defined as one minus the mass of carbon in the stack gas relative to the total carbon in less carbon contained in the slag, represented by the following equation:

$$\text{Carbon Capture Efficiency (\%)} = \left( 1 - \left( \frac{\text{Carbon in Stack}}{(\text{Total Carbon In}) - (\text{Carbon in Slag})} \right) \right) * 100\%$$

**Exhibit 4-41. Case 5 carbon balance**

Carbon In		Carbon Out	
	kg/hr (lb/hr)		kg/hr (lb/hr)
Coal	135,118 (297,884)	Stack Gas	10,105 (22,278)
Air (CO <sub>2</sub> )	138 (304)	CO <sub>2</sub> Product	124,472 (274,414)
		Slag	676 (1,489)
		H <sub>2</sub> Product	3 (6)
<b>Total</b>	<b>135,256 (298,188)</b>	<b>Total</b>	<b>135,256 (298,188)</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Exhibit 4-42 shows the sulfur balance for the plant. Sulfur input comes solely from the sulfur in the coal. Sulfur output includes the sulfur recovered in the Claus plant and sulfur in the CO<sub>2</sub> product. Sulfur in the slag is considered negligible.

**Exhibit 4-42. Case 5 sulfur balance**

Sulfur In		Sulfur Out	
	kg/hr (lb/hr)		kg/hr (lb/hr)
Coal	5,313 (11,713)	Stack Gas	–
		CO <sub>2</sub> Product	1 (2)
		Elemental Sulfur	5,312 (11,711)
<b>Total</b>	<b>5,313 (11,713)</b>	<b>Total</b>	<b>5,313 (11,713)</b>

Exhibit 4-43 shows the overall water balance for the plant. The exhibit is presented in an identical manner as for Case 4.

**Exhibit 4-43. Case 5 water balance**

Water Use	Water Demand	Internal Recycle	Raw Water Withdrawal	Process Water Discharge	Raw Water Consumption
	m <sup>3</sup> /min (gpm)				
Slag Handling	0.46 (122)	0.46 (122)	–	–	–
Slurry Water	–	–	–	–	–
Gasifier Water	–	–	–	–	–
Quench	3.07 (812)	3.07 (812)	–	–	–
HCl Scrubber	1.88 (497)	1.88 (497)	–	–	–
NH <sub>3</sub> Scrubber	1.77 (467)	0.98 (258)	0.79 (209)	–	0.79 (209)
Gasifier Steam	0.34 (90)	0.34 (90)	–	–	–
<b>Condenser Makeup</b>	<b>0.10 (26)</b>	–	<b>0.10 (26)</b>	–	<b>0.10 (26)</b>
BFW Makeup	0.10 (26)	–	0.10 (26)	–	0.10 (26)
Gasifier Steam	–	–	–	–	–
Shift Steam	–	–	–	–	–
<b>Cooling Tower</b>	<b>13.00 (3,435)</b>	<b>0.12 (32)</b>	<b>12.88 (3,403)</b>	<b>2.92 (773)</b>	<b>9.96 (2,630)</b>
BFW Blowdown	–	0.10 (26)	-0.10 (-26)	–	-0.10 (-26)
ASU Knockout	–	0.02 (6)	-0.02 (-6)	–	-0.02 (-6)
<b>Total</b>	<b>20.63 (5,449)</b>	<b>6.86 (1,811)</b>	<b>13.77 (3,638)</b>	<b>2.92 (773)</b>	<b>10.85 (2,866)</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

An overall plant energy balance is provided in tabular form in Exhibit 4-44. The power out is the steam turbine power prior to generator losses.

**Exhibit 4-44. Case 5 overall energy balance (0 °C [32 °F] reference)**

	HHV	Sensible + Latent	Power	Total
<b>Heat In, GJ/hr (MMBtu/hr)</b>				
Coal	5,752 (5,452)	4.8 (4.6)	–	5,757 (5,456)
Air	–	30.6 (29.0)	–	30.6 (29.0)
Raw Water Makeup	–	51.8 (49.1)	–	51.8 (49.1)
Auxiliary Power	–	–	534.3 (506.5)	534.3 (506.5)
<b>Total</b>	<b>5,752 (5,452)</b>	<b>87.2 (82.7)</b>	<b>534.3 (506.5)</b>	<b>6,373 (6,041)</b>
<b>Heat Out, GJ/hr (MMBtu/hr)</b>				
Misc. Process Steam	–	4.8 (4.6)	–	4.8 (4.6)
Slag	22.1 (21.0)	35.8 (34.0)	–	58.0 (55.0)
Stack Gas	–	197 (187)	–	197 (187)
Sulfur	49.2 (46.7)	0.6 (0.6)	–	49.9 (47.3)
Motor Losses and Design Allowances	–	–	18.8 (17.8)	18.8 (17.8)
Hydrogen Product	3,830 (3,630)	12.1 (11.5)	–	3,842 (3,641)
Cooling Tower Load <sup>A</sup>	–	1,698 (1,609)	–	1,698 (1,609)
CO <sub>2</sub> Product Stream	–	-103.6 (-98.2)	–	-103.6 (-98.2)
Blowdown Streams	–	25.3 (24.0)	–	25.3 (24.0)
Ambient Losses <sup>B</sup>	–	88.9 (84.3)	–	88.9 (84.3)
Power	–	–	393 (373)	393 (373)
<b>Total</b>	<b>3,901 (3,698)</b>	<b>1,959 (1,857)</b>	<b>412 (391)</b>	<b>6,272 (5,945)</b>
Unaccounted Energy <sup>C</sup>	–	101.1 (95.8)	–	101.1 (95.8)

<sup>A</sup>Includes condenser, AGR, and miscellaneous cooling loads

<sup>B</sup>Ambient losses include all losses to the environment through radiation, convection, etc. Sources of these losses include the combustor, reheater, superheater, and transformers

<sup>C</sup>By difference

## 4.10.2 Energy and Mass Balance Diagrams

Energy and mass balance diagrams are shown for the following subsystems in Exhibit 4-45 through Exhibit 4-47:

- ASU, gasification, and gas cooling
- Gas cleanup system
- Hydrogen purification and power block

This page intentionally left blank

Exhibit 4-45. Case 5 coal gasification and ASU energy and mass balance




Exhibit 4-46. Case 5 syngas cleanup energy and mass balance





Exhibit 4-47. Case 5 hydrogen purification and power block energy and mass balance



This page intentionally left blank

## 4.11 CASE 5 – MAJOR EQUIPMENT LIST

Major equipment items for the Shell gasifier with CO<sub>2</sub> capture are shown in the following tables. In general, the design conditions include a 10 percent design allowance for flows and heat duties and a 21 percent design allowance for heads on pumps and fans.

### Case 5 – Account 1: Coal Handling

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Bottom Trestle Dumper and Receiving Hoppers	N/A	181 tonne (200 ton)	2	0
2	Feeder	Belt	570 tonne/hr (630 tph)	2	0
3	Conveyor No. 1	Belt	1,130 tonne/hr (1,250 tph)	1	0
4	Conveyor No. 2	Belt	1,130 tonne/hr (1,250 tph)	1	0
5	Stacker/Reclaimer	Traveling, linear	1,130 tonne/hr (1,250 tph)	1	0
6	Reclaim Hopper	N/A	40 tonne (50 ton)	2	1
7	Feeder	Vibratory	170 tonne/hr (190 tph)	2	1
8	Conveyor No. 3	Belt w/ tripper	350 tonne/hr (390 tph)	1	0
9	Coal Surge Bin w/ Vent Filter	Dual outlet	170 tonne (190 ton)	2	0
10	Crusher	Impactor reduction	8 cm x 0 – 3 cm x 0 (3" x 0 – 1-1/4" x 0)	2	0
11	Conveyor No. 4	Belt w/tripper	350 tonne/hr (390 tph)	1	0
12	Conveyor No. 5	Belt w/ tripper	350 tonne/hr (390 tph)	1	0
13	Coal Silo w/ Vent Filter and Slide Gates	Field erected	780 tonne (860 ton)	3	0

### Case 5 – Account 2: Coal Preparation and Feed

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Feeder	Vibratory	80 tonne/hr (90 tph)	3	0
2	Conveyor No. 6	Belt w/tripper	230 tonne/hr (260 tph)	1	0
3	Roller Mill Feed Hopper	Dual Outlet	470 tonne (510 ton)	1	0
4	Weigh Feeder	Belt	120 tonne/hr (130 tph)	2	0
5	Coal Dryer and Pulverizer	Rotary	120 tonne/hr (130 tph)	2	0
6	Coal Dryer Feed Hopper	Vertical Hopper	230 tonne (260 ton)	2	0

### Case 5 – Account 3: Feedwater and Miscellaneous Balance of Plant Systems

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Demineralized Water Storage Tank	Vertical, cylindrical, outdoor	10,277,000 liters (2,715,000 gal)	2	0
2	Condensate Pumps	Vertical canned	4,120 lpm @ 90 m H <sub>2</sub> O (1,090 gpm @ 300 ft H <sub>2</sub> O)	2	1
3	Deaerator (integral w/ GFB)	Horizontal spray type	194,000 kg/hr (428,000 lb/hr)	2	0
4	Intermediate Pressure Feedwater Pump	Horizontal centrifugal, single stage	980 lpm @ 20 m H <sub>2</sub> O (260 gpm @ 70 ft H <sub>2</sub> O)	2	1
5	High Pressure Feedwater Pump No. 1	Barrel type, multi-stage, centrifugal	HP water: 2,340 lpm @ 1,700 m H <sub>2</sub> O (620 gpm @ 5,700 ft H <sub>2</sub> O)	2	1
6	High Pressure Feedwater Pump No. 2	Barrel type, multi-stage, centrifugal	IP water: 1,590 lpm @ 210 m H <sub>2</sub> O (420 gpm @ 670 ft H <sub>2</sub> O)	2	1

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
7	Auxiliary Boiler	Shop fabricated, water tube	18,000 kg/hr, 2.8 MPa, 343 °C (40,000 lb/hr, 400 psig, 650 °F)	1	0
8	Service Air Compressors	Flooded Screw	28 m <sup>3</sup> /min @ 0.7 MPa (1,000 scfm @ 100 psig)	2	1
9	Instrument Air Dryers	Duplex, regenerative	28 m <sup>3</sup> /min (1,000 scfm)	2	1
10	Closed Cycle Cooling Heat Exchangers	Plate and frame	514 GJ/hr (487 MMBtu/hr) each	2	0
11	Closed Cycle Cooling Water Pumps	Horizontal centrifugal	184,400 lpm @ 20 m H <sub>2</sub> O (48,700 gpm @ 70 ft H <sub>2</sub> O)	2	1
12	Engine-Driven Fire Pump	Vertical turbine, diesel engine	3,785 lpm @ 110 m H <sub>2</sub> O (1,000 gpm @ 350 ft H <sub>2</sub> O)	1	1
13	Fire Service Booster Pump	Two-stage horizontal centrifugal	2,650 lpm @ 80 m H <sub>2</sub> O (700 gpm @ 250 ft H <sub>2</sub> O)	1	1
14	Municipal Water Pumps	Stainless steel, single suction	1,940 lpm @ 20 m H <sub>2</sub> O (510 gpm @ 60 ft H <sub>2</sub> O)	2	1
15	Ground Water Pumps	Stainless steel, single suction	3,870 lpm @ 270 m H <sub>2</sub> O (1,020 gpm @ 880 ft H <sub>2</sub> O)	1	1
16	Filtered Water Pumps	Stainless steel, single suction	1,860 lpm @ 50 m H <sub>2</sub> O (490 gpm @ 160 ft H <sub>2</sub> O)	2	1
17	Filtered Water Tank	Vertical, cylindrical	893,000 liter (236,000 gal)	2	0
18	Makeup Water Demineralizer	Anion, cation, and mixed bed	1,430 lpm (380 gpm)	2	0
19	Liquid Waste Treatment System	N/A	10 years, 24-hour storm	1	0
20	Process Water Treatment	Vacuum flash, brine concentrator, and crystallizer	Vacuum Flash Inlet: 35,000 kg/hr (76,000 lb/hr) Vacuum Flash Outlet: 6,218 ppmw Cl- Brine Concentrator Inlet: 28,000 kg/hr (61,000 lb/hr) Crystallizer Inlet: 2,000 kg/hr (5,000 lb/hr)	2	0

**Case 5 – Account 4: Gasifier, ASU, and Accessories**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Gasifier	Pressurized dry-feed, entrained bed	2,800 tonne/day, 4.2 MPa (3,100 tpd, 615 psia)	2	0
2	Synthesis Gas Cooler	Convective spiral-wound tube boiler	295,000 kg/hr (651,000 lb/hr)	2	0
3	Synthesis Gas Cyclone	High efficiency	397,000 kg/hr (874,000 lb/hr) Design efficiency 90%	2	0
4	HCl Scrubber	Ejector Venturi	313,000 kg/hr (691,000 lb/hr)	2	0
5	Ammonia Wash	Counter-flow spray tower	311,000 kg/hr (685,000 lb/hr) @ 3.3 MPa (473 psia)	2	0
6	Primary Sour Water Stripper	Counter-flow with external reboiler	33,000 kg/hr (73,000 lb/hr)	2	0
7	Secondary Sour Water Stripper	Counter-flow with external reboiler	11,000 kg/hr (25,000 lb/hr)	2	0
8	Low Temperature Heat Recovery Coolers	Shell and tube with condensate drain	256,000 kg/hr (564,000 lb/hr)	9	0
9	Low Temperature Heat Recovery Knockout Drum	Vertical with mist eliminator	312,000 kg/hr, 59 °C, 3.3 MPa (689,000 lb/hr, 138 °F, 476 psia)	2	0

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
10	Synthesis Gas Reheaters	Shell and tube	Reheater 1: N/A Reheater 2: 31,000 kg/hr (69,000 lb/hr) Reheater 3: 9,000 kg/hr (20,000 lb/hr) Reheater 4: N/A Reheater 5: 40,000 kg/hr (88,000 lb/hr) Reheater 6: 40,000 kg/hr (88,000 lb/hr)	2	0
11	Flare Stack	Self-supporting, carbon steel, stainless steel top, pilot ignition	302,000 kg/hr (666,000 lb/hr) syngas	2	0
12	ASU Main Air Compressor	Centrifugal, multi-stage	5,000 m <sup>3</sup> /min @ 1.6 MPa (182,000 scfm @ 236 psia)	2	0
13	Cold Box	Vendor design	2,200 tonne/day (2,400 tpd) of 95% purity oxygen	2	0
14	Gasifier O <sub>2</sub> Pump	Centrifugal, multi-stage	1,000 m <sup>3</sup> /min (38,000 scfm) Suction – 1.0 MPa (130 psia) Discharge – 5.1 MPa (740 psia)	2	0
15	Gasifier Nitrogen Boost Compressor	Centrifugal, single-stage	210 m <sup>3</sup> /min (7,000 scfm) Suction – 0.4 MPa (70 psia) Discharge – 5.6 MPa (820 psia)	2	0

**Case 5 – Account 5: Syngas Cleanup**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Mercury Adsorber 1	Sulfated carbon bed	309,000 kg/hr (681,000 lb/hr) 29 °C (84 °F) 3.2 MPa (461 psia)	2	0
2	Mercury Adsorber 2	Sulfated carbon bed	309,000 kg/hr (681,000 lb/hr) 37 °C (99 °F) 3.1 MPa (448 psia)	2	0
3	Sulfur Plant	Claus type	140 tonne/day (155 tpd)	1	0
4	Water Gas Shift Reactors	Fixed bed, catalytic	128,000 kg/hr (282,000 lb/hr) 216 °C (420 °F) 3.9 MPa (560 psia)	6	0
5	Shift Reactor Heat Recovery Exchangers	Shell and Tube	Exchanger 1: 223 GJ/hr (211 MMBtu/hr) Exchanger 2: 91 GJ/hr (86 MMBtu/hr) Exchanger 3: 66 GJ/hr (63 MMBtu/hr) Exchanger 4: 83 GJ/hr (78 MMBtu/hr)	8	0
6	Acid Gas Removal Plant	Two-stage Selexol	631,000 kg/hr (1,390,000 lb/hr) 37 °C (99 °F) 3.1 MPa (445 psia)	1	0
7	Hydrogenation Reactor	Fixed bed, catalytic	17,000 kg/hr (38,000 lb/hr) 219 °C (427 °F) 0.1 MPa (16.4 psia)	1	0
8	Tail Gas Recycle Compressor	Centrifugal	13,000 kg/hr (29,000 lb/hr) each	1	0
9	Candle Filter	Pressurized filter with pulse-jet cleaning	metallic filters	2	0
10	CO <sub>2</sub> Dryer	Triethylene glycol	Inlet: 153 m <sup>3</sup> /min @ 2.5 MPa (5,403 acfm @ 363 psia) Outlet: 2.4 MPa (346 psia)	1	0

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
			Water Recovered: 609 kg/hr (1,343 lb/hr)		
11	CO <sub>2</sub> Compressor	Integrally geared, multi-stage centrifugal	10 m <sup>3</sup> /min @ 15.3 MPa (353 acfm @ 2,217 psia)	1	0
12	CO <sub>2</sub> Aftercooler	Shell and tube heat exchanger	Outlet: 15.3 MPa, 30 °C (2,215 psia, 86 °F) Duty: 78 GJ/hr (74 MMBtu/hr)	1	0

**Case 5 – Account 6: Hydrogen Production**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Pressure Swing Adsorber	Polybed Proprietary	Syngas: 100,246 kg/hr (221,005 lb/hr) 18 °C (65 °F) 2.9 MPa (418.7 psia) Hydrogen: 27,500 kg/hr (60,627 lb/hr) 18 °C (65 °F) 2.8 MPa (408.7 psia) Off Gas: 72,746 kg/hr (160,378 lb/hr) -7 °C (20 °F) 0.5 MPa (77.0 psia)	1	0
2	Hydrogen Compressor	Integrally geared, multi-stage centrifugal	99 m <sup>3</sup> /min @ 6.5 MPa (3,484 acfm @ 940 psia)	1	1

**Case 5 – Account 7: Stack, Ducting, & Off-Gas Fired Boiler**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Stack	CS plate, type 409SS liner	76 m (250 ft) high x 3.6 m (12 ft) diameter	1	0
2	Field-Erected Gas-Fired Boiler	Drum, multi-pressure with economizer section and integral deaerator Air-Fired	Off Gas: 72,746 kg/hr (160,378 lb/hr) 0.5 MPa (72.5 psia) 193 °C (380 °F) Air: 299,768 kg/hr (660,875 lb/hr) 0.1 MPa (16.0 psia) 24 °C (75 °F) 632 GJ/hr (599 MMBtu/hr)	1	0
3	Air Blower	Centrifugal	329,744 kg/hr, 4,500 m <sup>3</sup> /min @ 111 cm WG (726,962 lb/hr, 158,905 acfm @ 44 in. WG)	2	1

**Case 5 – Account 8: Steam Turbine and Accessories**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Steam Turbine	Commercially available advanced steam turbine	115 MW 12.4 MPa/510 °C/510 °C (1,800 psig/ 950 °F/950 °F)	1	0
2	Steam Turbine Generator	Hydrogen cooled, static excitation	130 MVA @ 0.9 p.f., 24 kV, 60 Hz, 3-phase	1	0
3	Surface Condenser	Single pass, divided waterbox including vacuum pumps	680 GJ/hr (640 MMBtu/hr), Inlet water temperature 16 °C (60 °F), Water temperature rise 11 °C (20 °F)	1	0
4	Steam Bypass	One per boiler	50% steam flow @ design steam conditions	1	0

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Case 5 – Account 9: Cooling Water System**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Circulating Water Pumps	Vertical, wet pit	335,000 lpm @ 30 m (89,000 gpm @ 100 ft)	2	1
2	Cooling Tower	Evaporative, mechanical draft, multi-cell	11 °C (52 °F) wet bulb/ 16 °C (60 °F) CWT/27 °C (80 °F) HWT/ 1,870 GJ/hr (1,770 MMBtu/hr) heat duty	1	0

**Case 5 – Account 10: Slag Recovery and Handling**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Slag Quench Tank	Water bath	223,000 liters (59,000 gal)	2	0
2	Slag Crusher	Roll	12 tonne/hr (13 tph)	2	0
3	Slag Depressurizer	Lock Hopper	12 tonne/hr (13 tph)	2	0
4	Slag Receiving Tank	Horizontal, weir	134,000 liters (35,000 gal)	2	0
5	Black Water Overflow Tank	Shop fabricated	60,000 liters (16,000 gal)	2	0
6	Slag Conveyor	Drag chain	12 tonne/hr (13 tph)	2	0
7	Slag Separation Screen	Vibrating	12 tonne/hr (13 tph)	2	0
8	Coarse Slag Conveyor	Belt/bucket	12 tonne/hr (13 tph)	2	0
9	Fine Ash Settling Tank	Vertical, gravity	190,000 liters (50,000 gal)	2	0
10	Fine Ash Recycle Pumps	Horizontal centrifugal	50 lpm @ 14 m H <sub>2</sub> O (10 gpm @ 46 ft H <sub>2</sub> O)	2	2
11	Grey Water Storage Tank	Field erected	61,000 liters (16,000 gal)	2	0
12	Grey Water Pumps	Centrifugal	210 lpm @ 430 m H <sub>2</sub> O (60 gpm @ 1,420 ft H <sub>2</sub> O)	2	2
13	Slag Storage Bin	Vertical, field erected	800 tonne (900 tons)	2	0
14	Unloading Equipment	Telescoping chute	100 tonne/hr (110 tph)	1	0

**Case 5 – Account 11: Accessory Electric Plant**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	STG Transformer	Oil-filled	24 kV/345 kV, 80 MVA, 3-ph, 60 Hz	1	0
2	High Voltage Auxiliary Transformer	Oil-filled	345 kV/13.8 kV, 58 MVA, 3-ph, 60 Hz	2	0
3	Medium Voltage Transformer	Oil-filled	24 kV/4.16 kV, 47 MVA, 3-ph, 60 Hz	1	1
4	Low Voltage Transformer	Dry ventilated	4.16 kV/480 V, 7 MVA, 3-ph, 60 Hz	1	1
5	STG Isolated Phase Bus Duct and Tap Bus	Aluminum, self-cooled	24 kV, 3-ph, 60 Hz	1	0
6	Medium Voltage Switchgear	Metal clad	4.16 kV, 3-ph, 60 Hz	1	1
7	Low Voltage Switchgear	Metal enclosed	480 V, 3-ph, 60 Hz	1	1
8	Emergency Diesel Generator	Sized for emergency shutdown	750 kW, 480 V, 3-ph, 60 Hz	1	0

**Case 5 – Account 12: Instrumentation and Control**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	DCS – Main Control	Monitor/keyboard; Operator printer (laser color); Engineering printer (laser B&W)	Operator stations/printers and engineering stations/printers	1	0
2	DCS – Processor	Microprocessor with redundant input/output	N/A	1	0
3	DCS – Data Highway	Fiber optic	Fully redundant, 25% spare	1	0

**4.12 CASE 5 – COST ESTIMATING**

The cost estimating methodology was described previously in Section 2.11. Exhibit 4-48 shows a detailed breakdown of the capital costs; Exhibit 4-49 shows the owner’s costs, TOC, and TASC; Exhibit 4-50 shows the initial and annual O&M costs; and Exhibit 4-51 shows the LCOH breakdown.

The estimated TOC of the Shell gasification plant with CO<sub>2</sub> capture is \$6,044/[kg H<sub>2</sub>/day]. Process contingency represents 5.0 percent of the TOC and project contingency represents 12.2 percent. The LCOH is \$3.09/kg H<sub>2</sub> with CO<sub>2</sub> T&S.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Exhibit 4-48. Case 5 total plant cost details

Case: 5		– Coal Gasification w/ CCS					Estimate Type: Conceptual			Dec 2018	
Plant Size (kg H <sub>2</sub> /day): 660,004		Cost Base:									
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost	
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]
<b>1 Coal Handling</b>											
1.1	Coal Receive & Unload	\$971	\$0	\$468	\$0	\$1,438	\$216	\$0	\$331	\$1,985	\$3
1.2	Coal Stackout & Reclaim	\$3,173	\$0	\$758	\$0	\$3,931	\$590	\$0	\$904	\$5,425	\$8
1.3	Coal Conveyors & Yard Crush	\$30,270	\$0	\$7,704	\$0	\$37,974	\$5,696	\$0	\$8,734	\$52,404	\$79
1.4	Other Coal Handling	\$4,715	\$0	\$1,061	\$0	\$5,776	\$866	\$0	\$1,328	\$7,970	\$12
1.5	Biomass Receive & Unload	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
1.6	Biomass Handling	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
1.7	Biomass Conveyors	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
1.8	Biomass Hnd. Foundations	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
1.9	Coal & Sorbent Handling Foundations	\$0	\$85	\$222	\$0	\$307	\$46	\$0	\$71	\$424	\$1
	<b>Subtotal</b>	<b>\$39,128</b>	<b>\$85</b>	<b>\$10,213</b>	<b>\$0</b>	<b>\$49,426</b>	<b>\$7,414</b>	<b>\$0</b>	<b>\$11,368</b>	<b>\$68,208</b>	<b>\$103</b>
<b>2 Coal Preparation &amp; Feed</b>											
2.1	Coal Crushing & Drying	\$2,349	\$142	\$338	\$0	\$2,829	\$424	\$0	\$651	\$3,904	\$6
2.2	Prepared Coal Storage & Feed	\$7,217	\$1,734	\$1,115	\$0	\$10,066	\$1,510	\$0	\$2,315	\$13,891	\$21
2.3	Dry Coal Injection System	\$9,212	\$106	\$844	\$0	\$10,162	\$1,524	\$0	\$2,337	\$14,023	\$21
2.4	Miscellaneous Coal Preparation & Feed	\$713	\$521	\$1,534	\$0	\$2,768	\$415	\$0	\$637	\$3,819	\$6
2.5	Biomass Shredding & Drying	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
2.6	Prepared Biomass Storage & Feed	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
2.7	Dry Biomass Injection System	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
2.8	Open	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
2.9	Coal, Biomass & Sorbent Feed Foundation	\$0	\$1,734	\$1,488	\$0	\$3,221	\$483	\$0	\$741	\$4,446	\$7
	<b>Subtotal</b>	<b>\$19,491</b>	<b>\$4,237</b>	<b>\$5,318</b>	<b>\$0</b>	<b>\$29,045</b>	<b>\$4,357</b>	<b>\$0</b>	<b>\$6,680</b>	<b>\$40,083</b>	<b>\$61</b>
<b>3 Feedwater &amp; Miscellaneous BOP Systems</b>											
3.1	Feedwater System	\$1,027	\$1,761	\$880	\$0	\$3,669	\$550	\$0	\$844	\$5,063	\$8
3.2	Water Makeup & Pretreating	\$4,105	\$411	\$2,326	\$0	\$6,842	\$1,026	\$0	\$2,361	\$10,229	\$15
3.3	Other Feedwater Subsystems	\$531	\$174	\$165	\$0	\$870	\$131	\$0	\$200	\$1,201	\$2
3.4	Service Water Systems	\$1,227	\$2,342	\$7,584	\$0	\$11,153	\$1,673	\$0	\$3,848	\$16,674	\$25
3.5	Other Boiler Plant Systems	\$135	\$49	\$123	\$0	\$307	\$46	\$0	\$71	\$423	\$1
3.6	Natural Gas Pipeline and Start-Up System	\$7,197	\$310	\$232	\$0	\$7,739	\$1,161	\$0	\$1,780	\$10,679	\$16
3.7	Wastewater Treatment Equipment	\$5,801	\$0	\$3,555	\$0	\$9,356	\$1,403	\$0	\$3,228	\$13,987	\$21
3.8	Vacuum Flash, Brine Concentrator, & Crystallizer	\$25,030	\$0	\$15,506	\$0	\$40,536	\$6,080	\$0	\$13,985	\$60,602	\$92
3.9	Miscellaneous Plant Equipment	\$15,325	\$2,010	\$7,788	\$0	\$25,124	\$3,769	\$0	\$8,668	\$37,560	\$57
	<b>Subtotal</b>	<b>\$60,378</b>	<b>\$7,056</b>	<b>\$38,161</b>	<b>\$0</b>	<b>\$105,595</b>	<b>\$15,839</b>	<b>\$0</b>	<b>\$34,983</b>	<b>\$156,417</b>	<b>\$237</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case:		5		– Coal Gasification w/ CCS				Estimate Type:			Conceptual	
Plant Size (kg H <sub>2</sub> /day):		660,004						Cost Base:			Dec 2018	
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost		
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]	
<b>4</b>												
Gasifier, ASU, & Accessories												
4.1	Gasifier & Auxiliaries (Shell)	\$604,151	\$0	\$259,074	\$0	\$863,224	\$129,484	\$120,851	\$167,034	\$1,280,593	\$1,940	
4.2	Syngas Cooler	\$61,106	\$0	\$26,204	\$0	\$87,310	\$13,096	\$12,223	\$16,894	\$129,524	\$196	
4.3	Air Separation Unit/Oxidant Compression	\$125,401	\$28,700	\$29,845	\$0	\$183,946	\$36,789	\$18,395	\$35,870	\$275,000	\$417	
4.5	Miscellaneous Gasification Equipment	\$4,180	\$0	\$1,792	\$0	\$5,972	\$896	\$0	\$1,030	\$7,898	\$12	
4.6	Low Temperature Heat Recovery & Fuel Gas Saturation	\$44,687	\$0	\$16,977	\$0	\$61,664	\$9,250	\$0	\$14,183	\$85,096	\$129	
4.7	Flare Stack System	\$1,901	\$0	\$335	\$0	\$2,236	\$335	\$0	\$514	\$3,086	\$5	
4.15	Major Component Rigging	\$233	\$0	\$100	\$0	\$332	\$50	\$0	\$57	\$439	\$1	
4.16	Gasification Foundations	\$0	\$470	\$280	\$0	\$751	\$113	\$0	\$216	\$1,079	\$2	
	<b>Subtotal</b>	<b>\$841,657</b>	<b>\$29,170</b>	<b>\$334,608</b>	<b>\$0</b>	<b>\$1,205,435</b>	<b>\$190,013</b>	<b>\$151,469</b>	<b>\$235,798</b>	<b>\$1,782,715</b>	<b>\$2,701</b>	
<b>5</b>												
Syngas Cleanup												
5.1	Double Stage Selexol	\$170,726	\$0	\$69,733	\$0	\$240,459	\$36,069	\$48,092	\$64,924	\$389,544	\$590	
5.2	Sulfur Removal	w/5.1	w/5.1	w/5.1	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
5.3	Elemental Sulfur Plant	\$47,647	\$9,288	\$61,050	\$0	\$117,985	\$17,698	\$0	\$27,137	\$162,819	\$247	
5.4	Carbon Dioxide (CO <sub>2</sub> ) Compression & Drying	\$32,713	\$4,907	\$13,735	\$0	\$51,354	\$7,703	\$0	\$11,812	\$70,869	\$107	
5.5	Carbon Dioxide (CO <sub>2</sub> ) Compressor Aftercooler	\$483	\$77	\$207	\$0	\$767	\$115	\$0	\$176	\$1,058	\$2	
5.6	Mercury Removal (Carbon Bed)	\$480	\$0	\$363	\$0	\$843	\$126	\$42	\$202	\$1,214	\$2	
5.7	Water Gas Shift (WGS) Reactors	\$131,699	\$0	\$52,649	\$0	\$184,348	\$27,652	\$0	\$42,400	\$254,401	\$385	
5.9	Particulate Removal	\$1,841	\$0	\$790	\$0	\$2,631	\$395	\$0	\$454	\$3,480	\$5	
5.10	Blowback Gas Systems	\$838	\$471	\$263	\$0	\$1,571	\$236	\$0	\$361	\$2,168	\$3	
5.11	Fuel Gas Piping	\$0	\$1,115	\$730	\$0	\$1,844	\$277	\$0	\$424	\$2,545	\$4	
5.12	Gas Cleanup Foundations	\$0	\$221	\$149	\$0	\$371	\$56	\$0	\$128	\$554	\$1	
	<b>Subtotal</b>	<b>\$386,428</b>	<b>\$16,078</b>	<b>\$199,668</b>	<b>\$0</b>	<b>\$602,174</b>	<b>\$90,326</b>	<b>\$48,134</b>	<b>\$148,018</b>	<b>\$888,653</b>	<b>\$1,346</b>	
<b>6</b>												
Hydrogen Production												
6.1	Pressure Swing Adsorber	\$20,140	\$23	\$932	\$727	\$21,822	\$3,273	\$0	\$5,019	\$30,114	\$46	
6.2	Hydrogen Compressor	\$5,166	\$273	\$524	\$408	\$6,371	\$956	\$0	\$1,465	\$8,792	\$13	
	<b>Subtotal</b>	<b>\$25,306</b>	<b>\$296</b>	<b>\$1,455</b>	<b>\$1,135</b>	<b>\$28,193</b>	<b>\$4,229</b>	<b>\$0</b>	<b>\$6,484</b>	<b>\$38,906</b>	<b>\$59</b>	
<b>7</b>												
Off Gas Fired Boiler, Ductwork, & Stack												
7.1	Off Gas Fired Boiler	\$3,880	\$375	\$426	\$332	\$5,013	\$752	\$0	\$1,153	\$6,918	\$10	
7.2	Off Gas Fired Boiler Accessories	\$398	\$320	\$496	\$387	\$1,601	\$240	\$0	\$368	\$2,210	\$3	
7.3	Ductwork	w/7.1	w/7.1	w/7.1	w/7.1	\$0	\$0	\$0	\$0	\$0	\$0	
7.4	Stack	\$579	\$77	\$211	\$164	\$1,032	\$155	\$0	\$297	\$1,483	\$2	
7.5	Off Gas Fired Boiler, Ductwork & Stack Foundations	w/7.1	w/7.1	w/7.1	w/7.1	\$0	\$0	\$0	\$0	\$0	\$0	
	<b>Subtotal</b>	<b>\$4,857</b>	<b>\$773</b>	<b>\$1,133</b>	<b>\$883</b>	<b>\$7,646</b>	<b>\$1,147</b>	<b>\$0</b>	<b>\$1,818</b>	<b>\$10,611</b>	<b>\$16</b>	

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case:		5	– Coal Gasification w/ CCS				Estimate Type:				Conceptual		
Plant Size (kg H <sub>2</sub> /day):		660,004					Cost Base:				Dec 2018		
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost			
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]		
<b>8</b>												<b>Steam Turbine &amp; Accessories</b>	
8.1	Steam Turbine Generator & Accessories	\$32,224	\$1,952	\$3,109	\$2,425	\$39,710	\$5,957	\$0	\$9,133	\$54,800	\$83		
8.2	Steam Turbine Plant Auxiliaries	w/8.1	w/8.1	w/8.1	w/8.1	\$0	\$0	\$0	\$0	\$0	\$0		
8.3	Condenser & Auxiliaries	\$1,216	\$647	\$609	\$475	\$2,948	\$442	\$0	\$848	\$4,238	\$6		
8.4	Steam Piping	w/8.1	w/8.1	w/8.1	w/8.1	\$0	\$0	\$0	\$0	\$0	\$0		
8.5	Turbine Generator Foundations	w/8.1	w/8.1	w/8.1	w/8.1	\$0	\$0	\$0	\$0	\$0	\$0		
	<b>Subtotal</b>	<b>\$33,440</b>	<b>\$2,599</b>	<b>\$3,719</b>	<b>\$2,900</b>	<b>\$42,658</b>	<b>\$6,399</b>	<b>\$0</b>	<b>\$9,981</b>	<b>\$59,038</b>	<b>\$89</b>		
<b>9</b>												<b>Cooling Water System</b>	
9.1	Cooling Towers	\$9,205	\$0	\$2,785	\$0	\$11,990	\$1,799	\$0	\$2,068	\$15,857	\$24		
9.2	Circulating Water Pumps	\$1,198	\$0	\$88	\$0	\$1,286	\$193	\$0	\$222	\$1,701	\$3		
9.3	Circulating Water System Auxiliaries	\$8,413	\$0	\$1,195	\$0	\$9,608	\$1,441	\$0	\$1,657	\$12,707	\$19		
9.4	Circulating Water Piping	\$0	\$4,808	\$4,354	\$0	\$9,162	\$1,374	\$0	\$2,107	\$12,643	\$19		
9.5	Make-up Water System	\$504	\$0	\$693	\$0	\$1,197	\$180	\$0	\$275	\$1,652	\$3		
9.6	Component Cooling Water System	\$173	\$206	\$142	\$0	\$520	\$78	\$0	\$120	\$718	\$1		
9.7	Circulating Water System Foundations	\$0	\$400	\$710	\$0	\$1,110	\$166	\$0	\$383	\$1,659	\$3		
	<b>Subtotal</b>	<b>\$19,493</b>	<b>\$5,414</b>	<b>\$9,967</b>	<b>\$0</b>	<b>\$34,874</b>	<b>\$5,231</b>	<b>\$0</b>	<b>\$6,833</b>	<b>\$46,938</b>	<b>\$71</b>		
<b>10</b>												<b>Slag Recovery &amp; Handling</b>	
10.1	Slag Dewatering & Cooling	\$1,934	\$0	\$947	\$0	\$2,881	\$432	\$0	\$497	\$3,810	\$6		
10.2	Gasifier Ash Depressurization	\$1,096	\$0	\$537	\$0	\$1,632	\$245	\$0	\$282	\$2,158	\$3		
10.3	Cleanup Ash Depressurization	\$492	\$0	\$241	\$0	\$734	\$110	\$0	\$127	\$970	\$1		
10.6	Ash Storage Silos	\$1,104	\$0	\$1,193	\$0	\$2,297	\$345	\$0	\$396	\$3,038	\$5		
10.7	Ash Transport & Feed Equipment	\$425	\$0	\$99	\$0	\$524	\$79	\$0	\$90	\$693	\$1		
10.8	Miscellaneous Ash Handling Equipment	\$61	\$75	\$22	\$0	\$158	\$24	\$0	\$27	\$209	\$0		
10.9	Ash/Spent Sorbent Foundation	\$0	\$431	\$573	\$0	\$1,004	\$151	\$0	\$346	\$1,501	\$2		
	<b>Subtotal</b>	<b>\$5,112</b>	<b>\$506</b>	<b>\$3,612</b>	<b>\$0</b>	<b>\$9,230</b>	<b>\$1,384</b>	<b>\$0</b>	<b>\$1,765</b>	<b>\$12,380</b>	<b>\$19</b>		
<b>11</b>												<b>Accessory Electric Plant</b>	
11.1	Generator Equipment	\$1,644	\$0	\$1,241	\$0	\$2,885	\$433	\$0	\$498	\$3,815	\$6		
11.2	Station Service Equipment	\$3,846	\$0	\$330	\$0	\$4,176	\$626	\$0	\$720	\$5,522	\$8		
11.3	Switchgear & Motor Control	\$23,206	\$0	\$4,026	\$0	\$27,232	\$4,085	\$0	\$4,697	\$36,014	\$55		
11.4	Conduit & Cable Tray	\$0	\$103	\$296	\$0	\$399	\$60	\$0	\$115	\$574	\$1		
11.5	Wire & Cable	\$0	\$1,408	\$2,517	\$0	\$3,925	\$589	\$0	\$1,128	\$5,642	\$9		
11.6	Protective Equipment	\$241	\$0	\$837	\$0	\$1,078	\$162	\$0	\$186	\$1,426	\$2		
11.7	Standby Equipment	\$340	\$0	\$314	\$0	\$653	\$98	\$0	\$113	\$864	\$1		
11.8	Main Power Transformers	\$1,650	\$0	\$34	\$0	\$1,684	\$253	\$0	\$290	\$2,227	\$3		
11.9	Electrical Foundations	\$0	\$19	\$49	\$0	\$69	\$10	\$0	\$24	\$103	\$0		
	<b>Subtotal</b>	<b>\$30,926</b>	<b>\$1,530</b>	<b>\$9,643</b>	<b>\$0</b>	<b>\$42,100</b>	<b>\$6,315</b>	<b>\$0</b>	<b>\$7,771</b>	<b>\$56,186</b>	<b>\$85</b>		

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case:		5	– Coal Gasification w/ CCS				Estimate Type:				Conceptual
Plant Size (kg H <sub>2</sub> /day):		660,004					Cost Base:				Dec 2018
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost	
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]
<b>12</b>											
Instrumentation & Control											
12.1	Gasification Control Equipment	\$677	\$0	\$290	\$0	\$967	\$145	\$0	\$167	\$1,279	\$2
12.3	Steam Turbine Control Equipment	\$625	\$0	\$85	\$0	\$710	\$107	\$0	\$123	\$939	\$1
12.4	Other Major Component Control Equipment	\$1,190	\$0	\$811	\$0	\$2,001	\$300	\$100	\$360	\$2,762	\$4
12.5	Signal Processing Equipment	\$924	\$0	\$30	\$0	\$954	\$143	\$0	\$165	\$1,262	\$2
12.6	Control Boards, Panels & Racks	\$268	\$0	\$176	\$0	\$443	\$67	\$22	\$106	\$638	\$1
12.7	Distributed Control System Equipment	\$9,695	\$0	\$317	\$0	\$10,011	\$1,502	\$501	\$1,802	\$13,816	\$21
12.8	Instrument Wiring & Tubing	\$482	\$386	\$1,544	\$0	\$2,412	\$362	\$121	\$724	\$3,618	\$5
12.9	Other Instrumentation & Controls Equipment	\$1,082	\$0	\$536	\$0	\$1,618	\$243	\$81	\$291	\$2,233	\$3
	<b>Subtotal</b>	<b>\$14,943</b>	<b>\$386</b>	<b>\$3,788</b>	<b>\$0</b>	<b>\$19,117</b>	<b>\$2,868</b>	<b>\$824</b>	<b>\$3,737</b>	<b>\$26,547</b>	<b>\$40</b>
<b>13</b>											
Improvements to Site											
13.1	Site Preparation	\$0	\$426	\$9,702	\$0	\$10,129	\$1,519	\$0	\$3,494	\$15,142	\$23
13.2	Site Improvements	\$0	\$1,927	\$2,725	\$0	\$4,652	\$698	\$0	\$1,605	\$6,955	\$11
13.3	Site Facilities	\$3,009	\$0	\$3,378	\$0	\$6,388	\$958	\$0	\$2,204	\$9,549	\$14
	<b>Subtotal</b>	<b>\$3,009</b>	<b>\$2,354</b>	<b>\$15,805</b>	<b>\$0</b>	<b>\$21,168</b>	<b>\$3,175</b>	<b>\$0</b>	<b>\$7,303</b>	<b>\$31,647</b>	<b>\$48</b>
<b>14</b>											
Buildings & Structures											
14.3	Steam Turbine Building	\$0	\$2,618	\$3,727	\$0	\$6,346	\$952	\$0	\$1,095	\$8,392	\$13
14.4	Administration Building	\$0	\$852	\$618	\$0	\$1,469	\$220	\$0	\$253	\$1,943	\$3
14.5	Circulation Water Pumphouse	\$0	\$124	\$66	\$0	\$189	\$28	\$0	\$33	\$251	\$0
14.6	Water Treatment Buildings	\$0	\$274	\$267	\$0	\$542	\$81	\$0	\$93	\$717	\$1
14.7	Machine Shop	\$0	\$479	\$328	\$0	\$806	\$121	\$0	\$139	\$1,066	\$2
14.8	Warehouse	\$0	\$373	\$241	\$0	\$613	\$92	\$0	\$106	\$811	\$1
14.9	Other Buildings & Structures	\$0	\$273	\$213	\$0	\$486	\$73	\$0	\$84	\$642	\$1
14.10	Waste Treating Building & Structures	\$0	\$739	\$1,410	\$0	\$2,149	\$322	\$0	\$371	\$2,842	\$4
	<b>Subtotal</b>	<b>\$0</b>	<b>\$5,731</b>	<b>\$6,869</b>	<b>\$0</b>	<b>\$12,600</b>	<b>\$1,890</b>	<b>\$0</b>	<b>\$2,174</b>	<b>\$16,664</b>	<b>\$25</b>
	<b>Total</b>	<b>\$1,484,168</b>	<b>\$76,215</b>	<b>\$643,960</b>	<b>\$4,919</b>	<b>\$2,209,263</b>	<b>\$340,587</b>	<b>\$200,428</b>	<b>\$484,715</b>	<b>\$3,234,992</b>	<b>\$4,901</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 4-49. Case 5 owner's costs**

Description	\$/1,000	\$/[kg H <sub>2</sub> /day]
<b>Pre-Production Costs</b>		
6 Months All Labor	\$25,888	\$39
1 Month Maintenance Materials	\$6,571	\$10
1 Month Non-Fuel Consumables	\$3,229	\$5
1 Month Waste Disposal	\$701	\$1
25% of 1 Months Fuel Cost at 100% CF	\$2,216	\$3
2% of TPC	\$64,700	\$98
<b>Total</b>	<b>\$103,305</b>	<b>\$157</b>
<b>Inventory Capital</b>		
60-day supply of fuel and consumables at 100% CF	\$19,784	\$30
0.5% of TPC (spare parts)	\$16,175	\$25
<b>Total</b>	<b>\$35,959</b>	<b>\$54</b>
<b>Other Costs</b>		
Initial Cost for Catalyst and Chemicals	\$41,169	\$62
Land	\$900	\$1
Other Owner's Costs	\$485,249	\$735
Financing Costs	\$87,345	\$132
<b>Total Overnight Costs (TOC)</b>	<b>\$3,988,919</b>	<b>\$6,044</b>
TASC Multiplier (IOU, 35 year)	1.116	
<b>Total As-Spent Cost (TASC)</b>	<b>\$4,452,975</b>	<b>\$6,747</b>

**Exhibit 4-50. Case 5 initial and annual operating and maintenance costs**

Case:	5	– Coal Gasification w/ CCS		Cost Base:	Dec 2018
Plant Size (kg H <sub>2</sub> /day):	660,004			Capacity Factor (%):	80
<b>Operating &amp; Maintenance Labor</b>					
<b>Operating Labor</b>			<b>Operating Labor Requirements per Shift</b>		
Operating Labor Rate (base):	38.50	\$/hour	Skilled Operator:	2.0	
Operating Labor Burden:	30.00	% of base	Operator:	11.0	
Labor O-H Charge Rate:	25.00	% of labor	Foreman:	1.0	
			Lab Techs, etc.:	3.0	
			<b>Total:</b>	<b>17.0</b>	
<b>Fixed Operating Costs</b>					
				<b>Annual Cost</b>	
				(\$)	(\$/[kg H <sub>2</sub> /day])
Annual Operating Labor:				\$7,453,446	\$11.29
Maintenance Labor:				\$33,967,412	\$51.47

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Case:	5 – Coal Gasification w/ CCS				Cost Base:	Dec 2018
Plant Size (kg H <sub>2</sub> /day):	660,004				Capacity Factor (%):	80
Administrative & Support Labor:					\$10,355,215	\$15.69
Property Taxes and Insurance:					\$64,699,832	\$98.03
<b>Total:</b>					<b>\$116,475,905</b>	<b>\$176.48</b>
<b>Variable Operating Costs</b>						
					(\$)	(\$/kg H <sub>2</sub> )
Maintenance Material:					\$63,082,337	\$0.33
<b>Consumables</b>						
	<b>Initial Fill</b>	<b>Per Day</b>	<b>Per Unit</b>	<b>Initial Fill</b>		
Water (gal/1000):	0	2,620	\$1.90	\$0	\$1,453,327	\$0.00754
Makeup and Wastewater Treatment Chemicals (ton):	0	7.8	\$550.00	\$0	\$1,253,206	\$0.00650
Sulfur-Impregnated Activated Carbon (ton):	107	0.146	\$12,000.00	\$1,282,161	\$512,864	\$0.00266
Water Gas Shift Catalyst (ft <sup>3</sup> ):	25,661	17.6	\$480.00	\$12,317,212	\$2,463,442	\$0.01278
Selexol Solution (gal):	555,790	55.1	\$38.00	\$21,120,035	\$611,538	\$0.00317
Sodium Hydroxide (50 wt%, ton):	0	19.3	\$600.00	\$0	\$3,388,165	\$0.01758
Sulfuric Acid (98 wt%, ton):	0	0.342	\$210.00	\$0	\$20,983	\$0.00011
Claus Catalyst (ft <sup>3</sup> ):	w/equip.	1.94	\$48.00	\$0	\$27,237	\$0.00014
PSA Unit Adsorbent (ft <sup>3</sup> ):	43,000	5.9	\$150.00	\$6,450,000	\$258,000	\$0.00134
Triethylene Glycol (gal):	w/equip.	680	\$6.80	\$0	\$1,350,417	\$0.00701
Electricity (MWh):	0	939	\$71.70	\$0	\$19,661,792	\$0.10202
<b>Subtotal:</b>				<b>\$41,169,408</b>	<b>\$31,000,972</b>	<b>\$0.16086</b>
<b>Waste Disposal</b>						
Sulfur-Impregnated Activated Carbon (ton):	0	0.146	\$80.00	\$0	\$3,419	\$0.00002
Water Gas Shift Catalyst (ft <sup>3</sup> ):	0	17.6	\$2.50	\$0	\$12,830	\$0.00007
Selexol Solution (gal):	0	55.1	\$0.35	\$0	\$5,633	\$0.00003
Claus Catalyst (ft <sup>3</sup> ):	0	1.94	\$2.50	\$0	\$1,419	\$0.00001
Crystallizer Solids (ton):	0	36.4	\$38.00	\$0	\$404,178	\$0.00210
Slag (ton):	0	562	\$38.00	\$0	\$6,231,964	\$0.03234
PSA Unit Adsorbent (ft <sup>3</sup> ):	0	5.9	\$1.50	\$0	\$2,580	\$0.00001
Triethylene Glycol (gal):	0	680	\$0.35	\$0	\$69,507	\$0.00036
<b>Subtotal:</b>				<b>\$0</b>	<b>\$6,731,529</b>	<b>\$0.03493</b>
<b>By-Products</b>						
Sulfur (tons):	0	141	\$0.00	\$0	\$0	\$0.00000
Electricity (MWh):	0	0	\$71.70	\$0	\$0	\$0.00000
<b>Subtotal:</b>				<b>\$0</b>	<b>\$0</b>	<b>\$0.00000</b>
<b>Variable Operating Costs Total:</b>				<b>\$41,169,408</b>	<b>\$100,814,837</b>	<b>\$0.03493</b>
<b>Fuel Cost</b>						
Illinois Number 6 (ton):	0	5,608	\$51.96	\$0	\$85,078,534	\$0.44146
Woody Torrefied Biomass (ton):	0	0	\$105.84	\$0	\$0	\$0.00000
<b>Total:</b>				<b>\$0</b>	<b>\$85,078,534</b>	<b>\$0.44146</b>

**Exhibit 4-51. Case 5 LCOH breakdown**

Component	Value, \$/kg H <sub>2</sub>	Percentage
Capital	1.35	44%
Fixed	0.60	20%
Variable	0.52	17%
Fuel	0.44	14%
<b>Total (Excluding T&amp;S)</b>	<b>2.92</b>	<b>N/A</b>
CO <sub>2</sub> T&S	0.17	5%
<b>Total (Including T&amp;S)</b>	<b>3.09</b>	<b>N/A</b>

### 4.13 CASE 6 – SHELL CO-GASIFICATION PLANT WITH CO<sub>2</sub> CAPTURE PROCESS DESCRIPTION

In this section, the Shell gasification process for Case 6 is described. The plant configuration is nearly identical to that of Case 5, with the exception that this case is configured to co-feed biomass and is at a reduced capacity. Furthermore, some adjustments have been made to the PSA to ensure the plant auxiliary loads can be met entirely by the steam turbine output. The capacity for Case 6 has been scaled to match the Buggenum power plant as-received total gasifier input, as discussed in Section 4, while the percentage of biomass fed to the system was adjusted to achieve net-zero life cycle emissions. As shown in Exhibit 2-7 the alkali content of the torrefied, woody biomass was not modeled.

The process descriptions for Case 6 are similar to Case 5 with several notable exceptions to accommodate the biomass co-feed. The system descriptions follow the BFD provided in Exhibit 4-52 with the associated stream tables that show process data provided in Exhibit 4-53. Rather than repeating the entire process description, only differences from Case 5 are reported here.



COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 4-53. Case 6 stream table, Shell co-gasification plant with capture**

	1	2	3	4	5	6	7	8	9	10	11	12
V-L Mole Fraction												
Ar	0.0092	0.0343	0.0025	0.0343	0.0000	0.0000	0.0000	0.0092	0.0104	0.0000	0.0082	0.0000
CH <sub>4</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0001	0.0000	0.0001	0.0000
CO	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0168	0.0000	0.4738	0.0000
CO <sub>2</sub>	0.0003	0.0000	0.0004	0.0000	0.0000	0.0000	0.0000	0.0003	0.0304	0.0000	0.0444	0.0000
COS	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0004	0.0000
H <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.8770	0.0000	0.2361	0.0000
H <sub>2</sub> O	0.0099	0.0000	0.0091	0.0000	0.0000	0.0000	0.0000	0.0099	0.0001	0.0000	0.1776	0.9998
HCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0002	0.0000
H <sub>2</sub> S	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0041	0.0000
H <sub>2</sub> SO <sub>4</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.7732	0.0157	0.9844	0.0157	0.9964	0.0000	0.0000	0.7732	0.0652	0.0000	0.0504	0.0000
NH <sub>3</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0047	0.0002
O <sub>2</sub>	0.2074	0.9501	0.0035	0.9501	0.0036	0.0000	0.0000	0.2074	0.0000	0.0000	0.0000	0.0000
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaOH	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	1.0000	1.0000	0.0000	1.0000	1.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	5,890	16	4,367	1,252	236	0	0	210	64	0	6,642	282
V-L Flowrate (kg/hr)	169,965	526	122,159	40,337	6,612	0	0	6,048	374	0	138,770	5,084
Solids Flowrate (kg/hr)	0	0	0	0	0	29,899	23,020	0	0	3,181	0	0
Temperature (°C)	15	27	21	27	130	15	15	15	18	1,427	1,080	343
Pressure (MPa, abs)	0.10	0.86	0.45	5.10	5.62	0.10	0.10	0.10	2.89	4.24	4.24	5.10
Steam Table Enthalpy (kJ/kg) <sup>A</sup>	30.23	21.53	28.12	9.82	129.22	---	---	30.23	90.68	---	2,120.07	3,083.36
AspenPlus Enthalpy (kJ/kg) <sup>B</sup>	-97.58	-0.97	-97.48	-12.68	103.25	-2,119.02	-5,119.15	-97.58	-2,412.27	1,526.12	-3,716.57	12,884.30
Density (kg/m <sup>3</sup> )	1.2	11.2	5.2	68.6	46.4	---	---	1.2	6.8	---	7.8	19.9
V-L Molecular Weight	28.857	32.209	27.974	32.209	28.028	---	---	28.857	5.821	---	20.892	18.015
V-L Flowrate (lb <sub>mol</sub> /hr)	12,985	36	9,627	2,761	520	0	0	462	142	0	14,644	622
V-L Flowrate (lb/hr)	374,708	1,159	269,315	88,927	14,577	0	0	13,334	825	0	305,936	11,207
Solids Flowrate (lb/hr)	0	0	0	0	0	65,917	50,750	0	0	7,012	0	0
Temperature (°F)	59	80	70	80	267	59	59	59	65	2,600	1,975	650
Pressure (psia)	14.7	125.0	65.0	740.0	815.0	14.7	14.7	14.7	418.7	615.0	615.0	740.0
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	13.0	9.3	12.1	4.2	55.6	---	---	13.0	39.0	---	911.5	1,325.6
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	-42.0	-0.4	-41.9	-5.5	44.4	-911.0	-2,200.8	-42.0	-1,037.1	656.1	-1,597.8	-5,539.3
Density (lb/ft <sup>3</sup> )	0.076	0.700	0.322	4.283	2.894	---	---	0.076	0.427	---	0.488	1.240

<sup>A</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>B</sup>Aspen thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 4-53. Case 6 stream table, Shell co-gasification plant with capture (continued)**

	13	14	15	16	17	18	19	20	21	22	23	24
V-L Mole Fraction												
Ar	0.0000	0.0059	0.0000	0.0000	0.0000	0.0000	0.0051	0.0000	0.0000	0.0000	0.0000	0.0064
CH <sub>4</sub>	0.0000	0.0001	0.0000	0.0000	0.0000	0.0000	0.0001	0.0000	0.0000	0.0000	0.0000	0.0001
CO	0.0000	0.3391	0.0000	0.0000	0.0000	0.0000	0.0083	0.0001	0.0000	0.0000	0.0000	0.0105
CO <sub>2</sub>	0.0010	0.0321	0.0000	0.0000	0.0000	0.0007	0.3134	0.0002	0.0000	0.0007	0.0010	0.3936
COS	0.0000	0.0003	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub>	0.0000	0.1690	0.0000	0.0000	0.0000	0.0000	0.4317	0.0001	0.0000	0.0000	0.0000	0.5449
H <sub>2</sub> O	0.9794	0.4055	1.0000	0.6895	0.1000	0.9797	0.1999	0.9932	0.9993	0.9797	0.9786	0.0016
HCl	0.0000	0.0002	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub> S	0.0001	0.0029	0.0000	0.0000	0.0000	0.0000	0.0028	0.0000	0.0000	0.0000	0.0001	0.0034
H <sub>2</sub> SO <sub>4</sub>	0.0000	0.0000	0.0000	0.0000	0.9000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0361	0.0000	0.0000	0.0000	0.0000	0.0312	0.0000	0.0000	0.0000	0.0000	0.0394
NH <sub>3</sub>	0.0195	0.0089	0.0000	0.0000	0.0000	0.0195	0.0075	0.0036	0.0007	0.0195	0.0203	0.0000
O <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0026	0.0000	0.0000	0.0000	0.0000
NaOH	0.0000	0.0000	0.0000	0.3105	0.0000	0.0000	0.0000	0.0001	0.0000	0.0000	0.0000	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	2,637	7,331	1,575	4	0	0	8,465	490	44	688	3,130	6,705
V-L Flowrate (kg/hr)	47,534	147,178	28,382	103	2	0	167,579	8,882	799	12,388	56,411	135,607
Solids Flowrate (kg/hr)	0	0	0	0	0	0	0	0	0	0	0	0
Temperature (°C)	188	232	288	16	15	67	203	193	88	67	69	29
Pressure (MPa, abs)	4.98	3.98	3.88	4.81	0.13	0.47	3.49	3.88	0.13	0.47	0.45	3.18
Steam Table Enthalpy (kJ/kg) <sup>A</sup>	767.69	1,252.51	2,971.61	-338.78	-8,206.86	241.60	787.57	806.98	368.22	241.60	246.32	37.86
AspenPlus Enthalpy (kJ/kg) <sup>B</sup>	14,938.00	-7,102.42	13,008.68	13,665.00	-8,526.27	15,469.43	-8,445.47	15,036.25	15,593.65	15,469.43	15,449.42	-7,743.98
Density (kg/m <sup>3</sup> )	835.5	19.5	16.9	1,531.7	1,791.5	964.0	17.6	870.5	965.6	964.0	962.1	26.0
V-L Molecular Weight	18.024	20.077	18.015	24.842	90.073	18.017	19.798	18.122	18.015	18.017	18.025	20.225
V-L Flowrate (lb <sub>mol</sub> /hr)	5,814	16,161	3,473	9	0	0	18,661	1,081	98	1,516	6,900	14,782
V-L Flowrate (lb/hr)	104,795	324,471	62,572	227	4	0	369,448	19,582	1,761	27,310	124,365	298,962
Solids Flowrate (lb/hr)	0	0	0	0	0	0	0	0	0	0	0	0
Temperature (°F)	371	450	550	61	59	153	398	379	191	153	156	84
Pressure (psia)	722.7	577.7	562.7	697.7	18.2	67.7	506.1	562.7	19.3	67.7	65.0	460.7
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	330.0	538.5	1,277.6	-145.7	-3,528.3	103.9	338.6	346.9	158.3	103.9	105.9	16.3
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	-6,422.2	-3,053.5	-5,592.7	-5,874.9	-3,665.6	-6,650.7	-3,630.9	-6,464.4	-6,704.1	-6,650.7	-6,642.1	-3,329.3
Density (lb/ft <sup>3</sup> )	52.157	1.218	1.055	95.623	111.841	60.178	1.099	54.347	60.283	60.178	60.060	1.625

<sup>A</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>B</sup>Aspen thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 4-53. Case 6 stream table, Shell co-gasification plant with capture (continued)**

	25	26	27	28	29	30	31	32	33	34	35
V-L Mole Fraction											
Ar	0.0000	0.0000	0.0064	0.0104	0.0001	0.0071	0.0000	0.0000	0.0004	0.0104	0.0008
CH <sub>4</sub>	0.0000	0.0000	0.0001	0.0001	0.0000	0.0000	0.0000	0.0000	0.0000	0.0001	0.0000
CO	0.0000	0.0000	0.0104	0.0168	0.0005	0.0056	0.0000	0.0000	0.0027	0.0168	0.0000
CO <sub>2</sub>	0.0000	0.0004	0.3974	0.0304	0.6390	0.7092	0.0000	0.0000	0.3482	0.0304	0.0000
COS	0.0000	0.0000	0.0000	0.0000	0.0007	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub>	0.0000	0.0000	0.5406	0.8770	0.0140	0.1820	0.0000	0.0000	0.0280	0.8770	0.9990
H <sub>2</sub> O	0.9999	0.9842	0.0016	0.0001	0.0269	0.0024	0.0000	1.0000	0.1558	0.0001	0.0000
HCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub> S	0.0000	0.0002	0.0035	0.0000	0.3177	0.0039	0.0000	0.0000	0.0074	0.0000	0.0000
H <sub>2</sub> SO <sub>4</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0400	0.0652	0.0004	0.0898	0.0000	0.0000	0.0015	0.0652	0.0002
NH <sub>3</sub>	0.0000	0.0152	0.0000	0.0000	0.0008	0.0000	0.0000	0.0000	0.4560	0.0000	0.0000
O <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaCl	0.0001	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaOH	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	1.0000	1.0000	1.0000	1.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	711	99	6,786	4,160	74	81	0	38	30	4,095	2,697
V-L Flowrate (kg/hr)	12,809	1,789	138,414	24,212	2,913	2,807	0	681	798	23,838	5,531
Solids Flowrate (kg/hr)	0	0	0	0	0	0	749	0	0	0	0
Temperature (°C)	15	30	37	18	27	38	183	49	156	18	18
Pressure (MPa, abs)	0.10	0.24	3.07	2.89	0.18	3.07	0.12	0.11	0.45	2.89	2.82
Steam Table Enthalpy (kJ/kg) <sup>A</sup>	62.75	92.90	48.94	90.68	39.82	18.89	---	107.20	481.26	90.68	263.32
AspenPlus Enthalpy (kJ/kg) <sup>B</sup>	-15,905.25	-15,675.87	-7,739.44	-2,412.27	-6,706.91	-8,085.18	146.79	-15,862.69	-7,262.49	-2,412.27	-86.95
Density (kg/m <sup>3</sup> )	999.4	986.4	24.7	6.8	3.0	44.9	5,268.4	967.0	3.4	6.8	2.4
V-L Molecular Weight	18.019	18.013	20.398	5.821	39.543	34.712	---	18.016	26.339	5.821	2.051
V-L Flowrate (lb <sub>mol</sub> /hr)	1,567	219	14,960	9,171	162	178	0	83	67	9,029	5,945
V-L Flowrate (lb/hr)	28,239	3,943	305,150	53,379	6,423	6,188	0	1,501	1,759	52,554	12,194
Solids Flowrate (lb/hr)	0	0	0	0	0	0	1,652	0	0	0	0
Temperature (°F)	59	85	99	65	80	100	362	120	312	65	65
Pressure (psia)	14.7	35.0	445.2	418.7	26.7	445.2	17.1	16.2	65.0	418.7	408.7
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	27.0	39.9	21.0	39.0	17.1	8.1	---	46.1	206.9	39.0	113.2
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	-6,838.0	-6,739.4	-3,327.4	-1,037.1	-2,883.5	-3,476.0	63.1	-6,819.7	-3,122.3	-1,037.1	-37.4
Density (lb/ft <sup>3</sup> )	62.391	61.576	1.542	0.427	0.186	2.803	328.893	60.369	0.209	0.427	0.147

<sup>A</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>B</sup>Aspen thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 4-53. Case 6 stream table, Shell co-gasification plant with capture (continued)**

	36	37	38	39	40	41	42	43	44	45	46
V-L Mole Fraction											
Ar	0.0008	0.0290	0.0092	0.0000	0.0094	0.0001	0.0000	0.0000	0.0000	0.0000	0.0000
CH <sub>4</sub>	0.0000	0.0003	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
CO	0.0000	0.0492	0.0000	0.0000	0.0000	0.0005	0.0001	0.0004	0.0004	0.0000	0.0004
CO <sub>2</sub>	0.0000	0.0889	0.0003	0.0000	0.0215	0.9850	0.9985	0.9886	0.9913	0.0500	0.9913
COS	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub>	0.9990	0.6419	0.0000	0.0000	0.0000	0.0099	0.0007	0.0074	0.0075	0.0000	0.0075
H <sub>2</sub> O	0.0000	0.0004	0.0099	1.0000	0.1244	0.0042	0.0007	0.0032	0.0005	0.9500	0.0005
HCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub> S	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
H <sub>2</sub> SO <sub>4</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0002	0.1904	0.7732	0.0000	0.8119	0.0004	0.0000	0.0003	0.0003	0.0000	0.0003
NH <sub>3</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
O <sub>2</sub>	0.0000	0.0000	0.2074	0.0000	0.0327	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
SO <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaCl	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
NaOH	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Total	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
V-L Flowrate (kg <sub>mol</sub> /hr)	2,697	1,399	3,658	4,270	9,310	1,861	691	2,552	2,545	7	2,545
V-L Flowrate (kg/hr)	5,531	18,307	105,547	76,932	254,701	80,898	30,390	111,288	111,145	143	111,145
Solids Flowrate (kg/hr)	0	0	0	0	0	0	0	0	0	0	0
Temperature (°C)	30	193	15	532	56	-3	-11	29	29	29	30
Pressure (MPa, abs)	6.48	0.51	0.10	12.51	0.11	0.55	0.12	2.50	2.39	2.50	15.27
Steam Table Enthalpy (kJ/kg) <sup>A</sup>	439.89	442.46	30.23	3,428.46	265.12	-8.36	-9.63	2.14	0.50	138.13	-227.22
AspenPlus Enthalpy (kJ/kg) <sup>B</sup>	89.62	-2,710.88	-97.58	-12,551.84	-1,376.14	-8,974.80	-8,972.87	-8,963.60	-8,957.03	-15,225.03	-9,184.75
Density (kg/m <sup>3</sup> )	5.1	1.7	1.2	36.8	1.1	11.2	2.3	49.8	47.2	319.0	839.2
V-L Molecular Weight	2.051	13.087	28.857	18.015	27.356	43.470	43.959	43.602	43.673	19.315	43.673
V-L Flowrate (lb <sub>mol</sub> /hr)	5,945	3,084	8,064	9,415	20,526	4,103	1,524	5,627	5,611	16	5,611
V-L Flowrate (lb/hr)	12,194	40,360	232,692	169,606	561,519	178,350	66,998	245,347	245,033	315	245,033
Solids Flowrate (lb/hr)	0	0	0	0	0	0	0	0	0	0	0
Temperature (°F)	86	380	59	990	132	26	12	85	85	85	86
Pressure (psia)	939.7	74.0	14.7	1,814.7	15.4	80.0	16.7	363.0	346.5	363.0	2,214.7
Steam Table Enthalpy (Btu/lb) <sup>A</sup>	189.1	190.2	13.0	1,474.0	114.0	-3.6	-4.1	0.9	0.2	59.4	-97.7
AspenPlus Enthalpy (Btu/lb) <sup>B</sup>	38.5	-1,165.5	-42.0	-5,396.3	-591.6	-3,858.5	-3,857.6	-3,853.7	-3,850.8	-6,545.6	-3,948.7
Density (lb/ft <sup>3</sup> )	0.319	0.107	0.076	2.300	0.066	0.698	0.146	3.110	2.949	19.917	52.393

<sup>A</sup>Steam table reference conditions are 32.02 °F & 0.089 psia

<sup>B</sup>Aspen thermodynamic reference state is the component's constituent elements in an ideal gas state at 25 °C and 1 atm

### **4.13.1 Biomass Receiving and Storage**

Torrefied, woody biomass has similar physical characteristics as coal. As such, the biomass receiving and storage systems mimic but are separate from the coal preparation and feed systems. The system is comprised of a biomass bottom trestle dumper and receiving hoppers, belt feeder, conveyers, stacker/reclaimer, reclaim hopper, vibratory feeder, surge bin with vent filter, crusher, and silo with vent filter and slide gates. Details on the coal receiving and storage systems can be found in Section 4.4.1.

### **4.13.2 Biomass Preparation and Feed Systems**

The biomass preparation and feed systems mimic but are separate from the coal preparation and feed systems. The system is comprised of a biomass feeder, conveyor, roller mill feed hopper, weigh feeder, dryer and pulverizer, and dryer feed hopper. Although the as-received moisture content of the biomass is near the dried coal moisture content of 5 percent by weight, a biomass dryer is included in the plant configuration to match the dried coal specification. Additionally, although fluctuations in feedstock moisture content are not considered, the dryer is assumed to be necessary to handle expected fluctuations.

### **4.13.3 Acid Gas Removal**

The dual-stage Selexol system is employed for acid gas removal in this case. The process is the same as in Case 5 except the acid gas contains 32 vol% H<sub>2</sub>S and 64 vol% CO<sub>2</sub> with the balance primarily water and H<sub>2</sub>.

### **4.13.4 CO<sub>2</sub> Compression and Drying System**

No differences from Case 5.

### **4.13.5 Hydrogen Production**

There are no differences from Case 5, except the PSA operates with a hydrogen recovery rate of 75 percent. The recovery efficiency was lowered from the 85 percent assumed for the other cases in this study in order to produce a PSA off-gas having sufficient heating value to generate enough power in the steam turbine to fully offset the auxiliary loads in the plant. As a result, life cycle GHG emissions associated with grid electricity are avoided and the required quantity of biomass feed is minimized.

### **4.13.6 Steam Generation**

The steam conditions for the biomass/coal co-gasification plant with capture (Case 6) are 12.4 MPa/532 °C/532 °C (1,800 psig/990 °F/990 °F).

## **4.14 CASE 6 – PERFORMANCE RESULTS**

Overall performance for the plant is summarized in Exhibit 4-54. The plant produces 5,531 kg/hr (12,194 lb/hr) of hydrogen at an effective thermal efficiency of 57.9 percent (HHV basis). The

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

steam turbine generates 37 MWe and the total auxiliary load for the plant is about 37 MWe, allowing about 1 MW of electricity to be sold back to the grid.

Exhibit 4-55 provides a detailed breakdown of the auxiliary power requirements. The ASU accounts for approximately 51 percent of the auxiliary load between the MAC, booster compressor, N<sub>2</sub> compressors, O<sub>2</sub> pump, and ASU auxiliaries. The two-stage Selexol process and CO<sub>2</sub> compression account for an additional 29 percent of the auxiliary power load. The hydrogen compressor accounts for about 6 percent. The BFW and circulating water system, including the circulating water pumps and cooling tower fan, composes approximately 5 percent of the load, with all other systems together constituting the remaining 9 percent of the auxiliary load.

**Exhibit 4-54. Case 6 plant performance summary**

Performance Summary	
Steam Turbine Power, MWe	37
<b>Total Gross Power, MWe</b>	<b>37</b>
Air Separation Unit Main Air Compressor, kWe	16,320
Air Separation Unit Booster Compressor, kWe	1,280
N <sub>2</sub> Compressors, kWe	610
CO <sub>2</sub> Compression, kWe	7,800
Acid Gas Removal, kWe	2,820
Balance of Plant, kWe	7,770
<b>Total Auxiliaries, MWe</b>	<b>37</b>
<b>Net Power, MWe</b>	<b>1</b>
<b>Hydrogen Production, kg/hr (lb/hr)</b>	<b>5,531 (12,194)</b>
<b>CO<sub>2</sub> Capture, %</b>	<b>92.7%</b>
HHV Effective Thermal Efficiency <sup>A</sup> , %	57.9%
HHV Cold Gas Efficiency <sup>B</sup> , %	57.7%
LHV Effective Thermal Efficiency <sup>A</sup> , %	51.2%
LHV Cold Gas Efficiency <sup>B</sup> , %	51.1%
Steam Turbine Cycle Efficiency, %	42.9%
Steam Turbine Heat Rate, kJ/kWh (Btu/kWh)	8,393 (7,955)
Condenser Duty, GJ/hr (MMBtu/hr)	211 (200)
AGR Cooling Duty, GJ/hr (MMBtu/hr)	36 (34)
As-Received Coal Feed, kg/hr (lb/hr)	29,899 (65,917)
As-Received Biomass Feed, kg/hr (lb/hr)	23,020 (50,750)
HHV Thermal Input, kWt	370,367
LHV Thermal Input, kWt	354,249
Raw Water Withdrawal, m <sup>3</sup> /min (gpm)	3.9 (1,035)
Raw Water Consumption, m <sup>3</sup> /min (gpm)	3.1 (814)

<sup>A</sup>ETE = (Hydrogen Heating Value + Net Power) / Fuel Heating Value

<sup>B</sup>CGE = Hydrogen Heating Value / Fuel Heating Value

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 4-55. Case 6 plant power summary**

Power Summary	
Steam Turbine Power, MWe	37
<b>Total Gross Power, MWe</b>	<b>37</b>
Auxiliary Load Summary	
Acid Gas Removal, kWe	2,820
Air Blower, kWe	280
Air Separation Unit Auxiliaries, kWe	250
Air Separation Unit Main Air Compressor, kWe	16,320
Air Separation Unit Booster Compressor, kWe	1,280
Ammonia Wash Pumps, kWe	30
Biomass Handling, kWe	90
Biomass Milling, kWe	240
Circulating Water Pumps, kWe	970
Claus Plant TG Recycle Compressor, kWe	280
Claus Plant/TGTU Auxiliaries, kWe	50
CO <sub>2</sub> Compression, kWe	7,800
Coal Handling, kWe	270
Coal Milling, kWe	310
Condensate Pumps, kWe	40
Cooling Tower Fans, kWe	500
Dryer Air Compressor, kWe	20
Feedwater Pumps, kWe	510
Gasifier Water Pump, kWe	10
Ground Water Pumps, kWe	90
Hydrogen Compressor, kWe	2,170
Miscellaneous Balance of Plant <sup>A</sup> , kWe	620
N <sub>2</sub> Compressors, kWe	610
O <sub>2</sub> Pump, kWe	80
Quench Water Pump, kWe	90
Shift Steam Pump, kWe	70
Slag Handling, kWe	80
Slag Reclaim Water Recycle Pump, kWe	0
Slurry Water Pump, kWe	0
Sour Gas Compressors, kWe	30
Sour Water Recycle Pumps, kWe	0

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Power Summary	
Steam Turbine Auxiliaries, kWe	30
Syngas Recycle Compressor, kWe	220
Syngas Scrubber Pumps, kWe	20
Process Water Treatment Auxiliaries, kWe	180
Transformer Losses, kWe	240
<b>Total Auxiliaries, MWe</b>	<b>37</b>
<b>Net Power, MWe</b>	<b>1</b>

<sup>A</sup>Includes plant control systems, lighting, HVAC, and miscellaneous low voltage loads

### 4.14.1 Environmental Performance

The environmental targets for emissions of Hg, HCl, NO<sub>x</sub>, SO<sub>2</sub>, CO<sub>2</sub>, and PM were presented in Section 2.5. A summary of the plant air emissions for Case 6 is presented in Exhibit 4-56.

**Exhibit 4-56. Case 6 air emissions**

	kg/GJ (lb/MMBtu)	Tonne/year (ton/year) <sup>A</sup>	lb/lb H <sub>2</sub>
SO <sub>2</sub>	0.000 (0.000)	0 (0)	0.000
NO <sub>x</sub>	0.004 (0.010)	39 (43)	0.001
Particulate	0.003 (0.007)	29 (31)	0.001
Hg	1.49E-7 (3.48E-7)	0.001 (0.002)	3.60E-8
HCl	0.000 (0.000)	0.00 (0.00)	0.000
CO <sub>2</sub> <sup>B</sup>	7 (15)	61,731 (68,047)	1.6
CO <sub>2</sub> e <sup>C</sup>	0 (0)	-1,352 (-1,490)	-1.0

<sup>A</sup>Calculations based on an 80 percent capacity factor

<sup>B</sup>Plant stack emissions

<sup>C</sup>Life cycle emissions

SO<sub>2</sub>, NO<sub>x</sub>, PM, and Hg emissions are the same as described in Case 4 and Case 5.

Ninety five percent of the CO<sub>2</sub> from the syngas is captured in the AGR system and compressed for storage. Because not all CO is converted to CO<sub>2</sub> in the shift reactors, the overall carbon removal is 92.7 percent. Additionally, an LCA was conducted to determine the total GWP of the plant.

The carbon balance for the plant is shown in Exhibit 4-57. The carbon input to the plant consists of carbon in the air in addition to carbon in the coal and biomass. Carbon leaves the plant as unburned carbon in the slag, a small portion of the hydrogen product, the captured CO<sub>2</sub> product, and the CO<sub>2</sub> in the stack gas, including the coal dryer vent gas and ASU vent gas. The carbon capture efficiency is defined as one minus the amount of carbon in the stack gas relative to the total carbon in less carbon contained in the slag, represented by the following fraction:

$$\text{Carbon Capture Efficiency (\%)} = \left( 1 - \left( \frac{\text{Carbon in Stack}}{(\text{Total Carbon In}) - (\text{Carbon in Slag})} \right) \right) * 100\%$$

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 4-57. Case 6 carbon balance**

Carbon In		Carbon Out	
	kg/hr (lb/hr)		kg/hr (lb/hr)
Coal	19,059 (42,018)	Stack Gas	2,404 (5,300)
Biomass	13,786 (30,392)	CO <sub>2</sub> Product	30,314 (66,832)
Air (CO <sub>2</sub> )	38 (84)	Slag	164 (362)
		H <sub>2</sub> Product	1 (1)
<b>Total</b>	<b>32,883 (72,495)</b>	<b>Total</b>	<b>32,883 (72,495)</b>

Exhibit 4-58 shows the sulfur balance for the plant. Sulfur input comes solely from the sulfur in the coal. Sulfur output includes the sulfur recovered in the Claus plant and sulfur in the CO<sub>2</sub> product. Sulfur in the slag is considered negligible.

**Exhibit 4-58. Case 6 sulfur balance**

Sulfur In		Sulfur Out	
	kg/hr (lb/hr)		kg/hr (lb/hr)
Coal	749 (1,652)	Stack Gas	–
Biomass	0 (0)	CO <sub>2</sub> Product	0 (0)
		Elemental Sulfur	749 (1,652)
<b>Total</b>	<b>749 (1,652)</b>	<b>Total</b>	<b>749 (1,652)</b>

Exhibit 4-59 shows the overall water balance for the plant. The exhibit is presented in an identical manner as for Case 5.

**Exhibit 4-59. Case 6 water balance**

Water Use	Water Demand	Internal Recycle	Raw Water Withdrawal	Process Water Discharge	Raw Water Consumption
	m <sup>3</sup> /min (gpm)				
Slag Handling	0.07 (18)	0.07 (18)	–	–	–
Slurry Water	–	–	–	–	–
Gasifier Water	–	–	–	–	–
Quench	0.79 (210)	0.79 (210)	–	–	–
HCl Scrubber	0.58 (153)	0.58 (153)	–	–	–
NH <sub>3</sub> Scrubber	0.42 (110)	0.20 (53)	0.21 (56)	–	0.21 (56)
Gasifier Steam	0.08 (22)	0.08 (22)	–	–	–
<b>Condenser Makeup</b>	<b>0.03 (8)</b>	–	<b>0.03 (8)</b>	–	<b>0.03 (8)</b>
BFW Makeup	0.03 (8)	–	0.03 (8)	–	0.03 (8)
Gasifier Steam	–	–	–	–	–
Shift Steam	–	–	–	–	–

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Water Use	Water Demand	Internal Recycle	Raw Water Withdrawal	Process Water Discharge	Raw Water Consumption
	m <sup>3</sup> /min (gpm)				
<b>Cooling Tower</b>	<b>3.71 (980)</b>	<b>0.04 (9)</b>	<b>3.67 (970)</b>	<b>0.83 (220)</b>	<b>2.84 (750)</b>
BFW Blowdown	–	0.03 (8)	-0.03 (-8)	–	-0.03 (-8)
ASU Knockout	–	0.01 (1)	-0.01 (-1)	–	-0.01 (-1)
<b>Total</b>	<b>5.68 (1,500)</b>	<b>1.76 (465)</b>	<b>3.92 (1,035)</b>	<b>0.83 (220)</b>	<b>3.08 (814)</b>

An overall plant energy balance is provided in tabular form in Exhibit 4-60. The power out is the steam turbine power prior to generator losses. The power at the generator is calculated by multiplying the power out by a combined generator efficiency of 98.5 percent.

**Exhibit 4-60. Case 6 overall energy balance (0 °C [32 °F] reference)**

	HHV	Sensible + Latent	Power	Total
<b>Heat In, GJ/hr (MMBtu/hr)</b>				
Coal	811 (769)	0.7 (0.6)	–	812 (770)
Biomass	522 (495)	0.5 (0.5)	–	523 (495)
Air	–	8.5 (8.1)	–	8.5 (8.1)
Raw Water Makeup	–	14.7 (14.0)	–	14.7 (14.0)
Auxiliary Power	–	–	131.8 (124.9)	131.8 (124.9)
<b>Total</b>	<b>1,333 (1,264)</b>	<b>24.4 (23.2)</b>	<b>131.8 (124.9)</b>	<b>1,490 (1,412)</b>
<b>Heat Out, GJ/hr (MMBtu/hr)</b>				
Misc. Process Steam	–	4.8 (4.6)	–	4.8 (4.6)
Slag	5.4 (5.1)	5.4 (5.1)	–	10.8 (10.2)
Stack Gas	–	68 (64)	–	68 (64)
Sulfur	6.9 (6.6)	0.1 (0.1)	–	7.0 (6.7)
Motor Losses and Design Allowances	–	–	5.5 (5.2)	5.5 (5.2)
Hydrogen Product	770 (730)	2.4 (2.3)	–	772 (732)
Cooling Tower Load <sup>A</sup>	–	484 (459)	–	484 (459)
CO <sub>2</sub> Product Stream	–	-25.3 (-23.9)	–	-25.3 (-23.9)
Blowdown Streams	–	7.3 (6.9)	–	7.3 (6.9)
<i>Ambient Losses<sup>B</sup></i>	–	21.8 (20.7)	–	21.8 (20.7)
Power	–	–	134 (127)	134 (127)
<b>Total</b>	<b>782 (741)</b>	<b>568 (538)</b>	<b>139 (132)</b>	<b>1,490 (1,412)</b>
Unaccounted Energy <sup>C</sup>	–	0.0 (0.0)	–	0.0 (0.0)

<sup>A</sup>Includes condenser, AGR, and miscellaneous cooling loads

<sup>B</sup>Ambient losses include all losses to the environment through radiation, convection, etc. Sources of these losses include the combustor, reheater, superheater, and transformers

<sup>C</sup>By difference

#### **4.14.2 Energy and Mass Balance Diagrams**

Energy and mass balance diagrams are shown for the following subsystems in Exhibit 4-61 through Exhibit 4-63:

- ASU, gasification, and gas cooling
- Gas cleanup system
- Hydrogen purification and power block

This page intentionally left blank

Exhibit 4-61. Case 6 coal gasification and ASU energy and mass balance




Exhibit 4-62. Case 6 syngas cleanup energy and mass balance





Exhibit 4-63. Case 6 hydrogen purification and power block energy and mass balance



This page intentionally left blank

## 4.15 CASE 6 – MAJOR EQUIPMENT LIST

Major equipment items for the Shell gasifier with CO<sub>2</sub> capture are shown in the following tables. In general, the design conditions include a 10 percent design allowance for flows and heat duties and a 21 percent design allowance for heads on pumps and fans.

### Case 6 – Account 1: Coal & Biomass Handling

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Coal Bottom Trestle Dumper and Receiving Hoppers	N/A	181 tonne (200 ton)	2	0
2	Coal Feeder	Belt	570 tonne/hr (630 tph)	2	0
3	Coal Conveyor No. 1	Belt	1,130 tonne/hr (1,250 tph)	1	0
4	Coal Conveyor No. 2	Belt	1,130 tonne/hr (1,250 tph)	1	0
5	Coal Stacker/Reclaimer	Traveling, linear	1,130 tonne/hr (1,250 tph)	1	0
6	Coal Reclaim Hopper	N/A	10 tonne (10 ton)	2	0
7	Coal Feeder	Vibratory	20 tonne/hr (30 tph)	2	0
8	Coal Conveyor No. 3	Belt w/ tripper	50 tonne/hr (50 tph)	1	0
9	Coal Surge Bin w/ Vent Filter	Dual outlet	20 tonne (30 ton)	2	0
10	Coal Crusher	Impactor reduction	8 cm x 0 – 3 cm x 0 (3" x 0 – 1-1/4" x 0)	2	0
11	Coal Conveyor No. 4	Belt w/tripper	50 tonne/hr (50 tph)	1	0
12	Coal Conveyor No. 5	Belt w/ tripper	50 tonne/hr (50 tph)	1	0
13	Coal Silo w/ Vent Filter and Slide Gates	Field erected	110 tonne (120 ton)	3	0
14	Biomass Bottom Trestle Dumper and Receiving Hoppers	N/A	32 tonne (35 ton)	2	0
15	Biomass Feeder	Belt	80 tonne/hr (90 tph)	2	0
16	Biomass Conveyor No. 1	Belt	160 tonne/hr (180 tph)	1	0
17	Biomass Conveyor No. 2	Belt	160 tonne/hr (180 tph)	1	0
18	Biomass Stacker/Reclaimer	Traveling, linear	160 tonne/hr (180 tph)	1	0
19	Biomass Reclaim Hopper	N/A	5 tonne (10 ton)	2	0
20	Biomass Feeder	Vibratory	20 tonne/hr (20 tph)	2	0
21	Biomass Conveyor No. 3	Belt w/ tripper	40 tonne/hr (40 tph)	1	0
22	Biomass Surge Bin w/ Vent Filter	Dual outlet	20 tonne (20 ton)	2	0
23	Biomass Crusher	Impactor reduction	8 cm x 0 – 3 cm x 0 (3" x 0 – 1-1/4" x 0)	2	0
24	Biomass Conveyor No. 4	Belt w/tripper	40 tonne/hr (40 tph)	1	0
25	Biomass Conveyor No. 5	Belt w/ tripper	40 tonne/hr (40 tph)	1	0
26	Biomass Silo w/ Vent Filter and Slide Gates	Field erected	80 tonne (90 ton)	3	0

### Case 6 – Account 2: Coal & Biomass Preparation and Feed

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Coal Feeder	Vibratory	10 tonne/hr (10 tph)	3	0
2	Coal Conveyor No. 6	Belt w/tripper	30 tonne/hr (40 tph)	1	0
3	Coal Roller Mill Feed Hopper	Dual Outlet	70 tonne (70 ton)	1	0
4	Coal Weigh Feeder	Belt	20 tonne/hr (20 tph)	2	0
5	Coal Dryer and Pulverizer	Rotary	20 tonne/hr (20 tph)	2	0
6	Coal Dryer Feed Hopper	Vertical Hopper	30 tonne (40 ton)	2	0
7	Biomass Feeder	Vibratory	10 tonne/hr (10 tph)	3	0
8	Biomass Conveyor No. 6	Belt w/tripper	30 tonne/hr (30 tph)	1	0
9	Biomass Roller Mill Feed Hopper	Dual Outlet	50 tonne (60 ton)	1	0

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
10	Biomass Weigh Feeder	Belt	10 tonne/hr (10 tph)	2	0
11	Biomass Dryer and Pulverizer	Rotary	10 tonne/hr (10 tph)	2	0
12	Biomass Dryer Feed Hopper	Vertical Hopper	30 tonne (30 ton)	2	0

**Case 6 – Account 3: Feedwater and Miscellaneous Balance of Plant Systems**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Demineralized Water Storage Tank	Vertical, cylindrical, outdoor	2,005,000 liters (530,000 gal)	2	0
2	Condensate Pumps	Vertical canned	1,180 lpm @ 90 m H <sub>2</sub> O (310 gpm @ 300 ft H <sub>2</sub> O)	2	1
3	Deaerator (integral w/ GFB)	Horizontal spray type	58,000 kg/hr (129,000 lb/hr)	2	0
4	Intermediate Pressure Feedwater Pump	Horizontal centrifugal, single stage	250 lpm @ 20 m H <sub>2</sub> O (70 gpm @ 70 ft H <sub>2</sub> O)	2	1
5	High Pressure Feedwater Pump No. 1	Barrel type, multi-stage, centrifugal	HP water: 750 lpm @ 1,700 m H <sub>2</sub> O (200 gpm @ 5,700 ft H <sub>2</sub> O)	2	1
6	High Pressure Feedwater Pump No. 2	Barrel type, multi-stage, centrifugal	IP water: 390 lpm @ 210 m H <sub>2</sub> O (100 gpm @ 670 ft H <sub>2</sub> O)	2	1
7	Auxiliary Boiler	Shop fabricated, water tube	18,000 kg/hr, 2.8 MPa, 343 °C (40,000 lb/hr, 400 psig, 650 °F)	1	0
8	Service Air Compressors	Flooded Screw	28 m <sup>3</sup> /min @ 0.7 MPa (1,000 scfm @ 100 psig)	2	1
9	Instrument Air Dryers	Duplex, regenerative	28 m <sup>3</sup> /min (1,000 scfm)	2	1
10	Closed Cycle Cooling Heat Exchangers	Plate and frame	131 GJ/hr (124 MMBtu/hr) each	2	0
11	Closed Cycle Cooling Water Pumps	Horizontal centrifugal	46,900 lpm @ 20 m H <sub>2</sub> O (12,400 gpm @ 70 ft H <sub>2</sub> O)	2	1
12	Engine-Driven Fire Pump	Vertical turbine, diesel engine	3,785 lpm @ 110 m H <sub>2</sub> O (1,000 gpm @ 350 ft H <sub>2</sub> O)	1	1
13	Fire Service Booster Pump	Two-stage horizontal centrifugal	2,650 lpm @ 80 m H <sub>2</sub> O (700 gpm @ 250 ft H <sub>2</sub> O)	1	1
14	Municipal Water Pumps	Stainless steel, single suction	600 lpm @ 20 m H <sub>2</sub> O (160 gpm @ 60 ft H <sub>2</sub> O)	2	1
15	Ground Water Pumps	Stainless steel, single suction	1,200 lpm @ 270 m H <sub>2</sub> O (320 gpm @ 880 ft H <sub>2</sub> O)	1	1
16	Filtered Water Pumps	Stainless steel, single suction	400 lpm @ 50 m H <sub>2</sub> O (100 gpm @ 160 ft H <sub>2</sub> O)	2	1
17	Filtered Water Tank	Vertical, cylindrical	190,000 liter (50,000 gal)	2	0
18	Makeup Water Demineralizer	Anion, cation, and mixed bed	280 lpm (70 gpm)	2	0
19	Liquid Waste Treatment System	N/A	10 years, 24-hour storm	1	0
20	Process Water Treatment	Vacuum flash, brine concentrator, and crystallizer	Vacuum Flash Inlet: 5,000 kg/hr (11,000 lb/hr) Vacuum Flash Outlet: 6,264 ppmw Cl- Brine Concentrator Inlet: 4,000 kg/hr (9,000 lb/hr) Crystallizer Inlet: 300 kg/hr (1,000 lb/hr)	2	0

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Case 6 – Account 4: Gasifier, ASU, and Accessories**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Gasifier	Pressurized dry-feed, entrained bed	400 tonne/day, 4.2 MPa (400 tpd, 615 psia)	2	0
2	Synthesis Gas Cooler	Convective spiral-wound tube boiler	76,000 kg/hr (168,000 lb/hr)	2	0
3	Synthesis Gas Cyclone	High efficiency	102,000 kg/hr (226,000 lb/hr) Design efficiency 90%	2	0
4	HCl Scrubber	Ejector Venturi	81,000 kg/hr (178,000 lb/hr)	2	0
5	Ammonia Wash	Counter-flow spray tower	75,000 kg/hr (165,000 lb/hr) @ 3.3 MPa (473 psia)	2	0
6	Primary Sour Water Stripper	Counter-flow with external reboiler	7,000 kg/hr (15,000 lb/hr)	2	0
7	Secondary Sour Water Stripper	Counter-flow with external reboiler	3,000 kg/hr (6,000 lb/hr)	2	0
8	Low Temperature Heat Recovery Coolers	Shell and tube with condensate drain	92,000 kg/hr (203,000 lb/hr)	6	0
9	Low Temperature Heat Recovery Knockout Drum	Vertical with mist eliminator	75,000 kg/hr, 59 °C, 3.3 MPa (166,000 lb/hr, 138 °F, 476 psia)	2	0
10	Synthesis Gas Reheaters	Shell and tube	Reheater 1: 9,000 kg/hr (19,000 lb/hr) Reheater 2: 1,200 kg/hr (3,000 lb/hr) Reheater 3: N/A Reheater 4: N/A Reheater 5: 10,000 kg/hr (22,000 lb/hr) Reheater 6: 10,000 kg/hr (22,000 lb/hr)	2	0
11	Flare Stack	Self-supporting, carbon steel, stainless steel top, pilot ignition	77,000 kg/hr (169,000 lb/hr) syngas	2	0
12	ASU Main Air Compressor	Centrifugal, multi-stage	1,000 m <sup>3</sup> /min @ 1.6 MPa (45,000 scfm @ 236 psia)	1	0
13	Cold Box	Vendor design	500 tonne/day (600 tpd) of 95% purity oxygen	1	0
14	Gasifier Oxygen Pump	Centrifugal, multi-stage	300 m <sup>3</sup> /min (10,000 scfm) Suction – 1.0 MPa (130 psia) Discharge – 5.1 MPa (740 psia)	1	0
15	AGR Nitrogen Boost Compressor	Centrifugal, multi-stage	N/A	1	0
16	Gasifier Nitrogen Boost Compressor	Centrifugal, single-stage	50 m <sup>3</sup> /min (2,000 scfm) Suction – 0.4 MPa (70 psia) Discharge – 5.6 MPa (820 psia)	1	0

**Case 6 – Account 5: Syngas Cleanup**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Mercury Adsorber 1	Sulfated carbon bed	75,000 kg/hr (164,000 lb/hr) 29 °C (84 °F) 3.2 MPa (461 psia)	2	0
2	Mercury Adsorber 2	Sulfated carbon bed	75,000 kg/hr (164,000 lb/hr) 38 °C (100 °F) 3.1 MPa (448 psia)	2	0
3	Sulfur Plant	Claus type	20 tonne/day (22 tpd)	1	0

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
4	Water Gas Shift Reactors	Fixed bed, catalytic	31,000 kg/hr (68,000 lb/hr) 210 °C (410 °F) 3.9 MPa (560 psia)	6	0
5	Shift Reactor Heat Recovery Exchangers	Shell and Tube	Exchanger 1: 50 GJ/hr (47 MMBtu/hr) Exchanger 2: 21 GJ/hr (20 MMBtu/hr) Exchanger 3: 15 GJ/hr (14 MMBtu/hr) Exchanger 4: 19 GJ/hr (18 MMBtu/hr)	8	0
6	Acid Gas Removal Plant	Two-stage Selexol	152,000 kg/hr (336,000 lb/hr) 37 °C (99 °F) 3.1 MPa (445 psia)	1	0
7	Hydrogenation Reactor	Fixed bed, catalytic	4,000 kg/hr (8,000 lb/hr) 219 °C (427 °F) 0.1 MPa (17 psia)	1	0
8	Tail Gas Recycle Compressor	Centrifugal	3,000 kg/hr (7,000 lb/hr) each	1	0
9	Candle Filter	Pressurized filter with pulse-jet cleaning	metallic filters	2	0
10	CO <sub>2</sub> Dryer	Triethylene glycol	Inlet: 37 m <sup>3</sup> /min @ 2.5 MPa (1,315 acfm @ 363 psia) Outlet: 2.4 MPa (346 psia) Water Recovered: 143 kg/hr (315 lb/hr)	1	0
11	CO <sub>2</sub> Compressor	Integrally geared, multi-stage centrifugal	2 m <sup>3</sup> /min @ 15.3 MPa (86 acfm @ 2,217 psia)	1	0
12	CO <sub>2</sub> Aftercooler	Shell and tube heat exchanger	Outlet: 15.3 MPa, 30 °C (2,215 psia, 86 °F) Duty: 19 GJ/hr (18 MMBtu/hr)	1	0

**Case 6 – Account 6: Hydrogen Production**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Pressure Swing Adsorber	Polybed Proprietary	Syngas 23,838 kg/hr (52,554 lb/hr) 18 °C (65 °F) 2.9 MPa (418.7 psia) Hydrogen 5,531 kg/hr (12,194 lb/hr) 18 °C (65 °F) 2.8 MPa (408.7 psia) Off Gas 18,307 kg/hr (40,360 lb/hr) -7 °C (20 °F) 0.5 MPa (77.0 psia)	1	0
2	Hydrogen Compressor	Integrally geared, multi-stage centrifugal	20 m <sup>3</sup> /min @ 6.5 MPa (701 acfm @ 940 psia)	1	1

**Case 6 – Account 7: Stack, Ducting, & Off-Gas Fired Boiler**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Stack	CS plate, type 409SS liner	76 m (250 ft) high x 2.0 m (6 ft) diameter	1	0
2	Field-Erected Gas-Fired Boiler	Drum, multi-pressure with economizer section and integral deaerator Air-Fired	Off Gas: 18,307 kg/hr (40,360 lb/hr) 0.5 MPa (74.0 psia) 193 °C (380 °F) Air: 105,547 kg/hr (232,692 lb/hr) 0.1 MPa (16.0 psia) 24 °C (75 °F) 226 GJ/hr (214 MMBtu/hr)	1	0
3	Air Blower	Centrifugal	116,102 kg/hr, 1,584 m <sup>3</sup> /min @ 111 cm WG (255,961 lb/hr, 55,950 acfm @ 44 in. WG)	2	1

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Case 6 – Account 8: Steam Turbine and Accessories**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Steam Turbine	Commercially available advanced steam turbine	39 MW 12.4 MPa/532 °C/532 °C (1,800 psig/ 990 °F/990 °F)	1	0
2	Steam Turbine Generator	Hydrogen cooled, static excitation	40 MVA @ 0.9 p.f., 24 kV, 60 Hz, 3-phase	1	0
3	Surface Condenser	Single pass, divided waterbox including vacuum pumps	230 GJ/hr (220 MMBtu/hr), Inlet water temperature 16 °C (60 °F), Water temperature rise 11 °C (20 °F)	1	0
4	Steam Bypass	One per boiler	50% steam flow @ design steam conditions	1	0

**Case 6 – Account 9: Cooling Water System**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Circulating Water Pumps	Vertical, wet pit	96,000 lpm @ 30 m (25,000 gpm @ 100 ft)	2	1
2	Cooling Tower	Evaporative, mechanical draft, multi-cell	11 °C (52 °F) wet bulb/ 16 °C (60 °F) CWT/27 °C (80 °F) HWT/ 530 GJ/hr (500 MMBtu/hr) heat duty	1	0

**Case 6 – Account 10: Slag Recovery and Handling**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	Slag Quench Tank	Water bath	33,000 liters (9,000 gal)	2	0
2	Slag Crusher	Roll	2 tonne/hr (2 tph)	2	0
3	Slag Depressurizer	Lock Hopper	2 tonne/hr (2 tph)	2	0
4	Slag Receiving Tank	Horizontal, weir	20,000 liters (5,000 gal)	2	0
5	Black Water Overflow Tank	Shop fabricated	9,000 liters (2,000 gal)	2	0
6	Slag Conveyor	Drag chain	2 tonne/hr (2 tph)	2	0
7	Slag Separation Screen	Vibrating	2 tonne/hr (2 tph)	2	0
8	Coarse Slag Conveyor	Belt/bucket	2 tonne/hr (2 tph)	2	0
9	Fine Ash Settling Tank	Vertical, gravity	29,000 liters (8,000 gal)	2	0
10	Fine Ash Recycle Pumps	Horizontal centrifugal	10 lpm @ 14 m H <sub>2</sub> O (2 gpm @ 46 ft H <sub>2</sub> O)	2	2
11	Grey Water Storage Tank	Field erected	9,000 liters (2,000 gal)	2	0
12	Grey Water Pumps	Centrifugal	30 lpm @ 430 m H <sub>2</sub> O (10 gpm @ 1,420 ft H <sub>2</sub> O)	2	2
13	Slag Storage Bin	Vertical, field erected	100 tonne (100 tons)	2	0
14	Unloading Equipment	Telescoping chute	10 tonne/hr (20 tph)	1	0

**Case 6 – Account 11: Accessory Electric Plant**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	STG Transformer	Oil-filled	24 kV/345 kV, 30 MVA, 3-ph, 60 Hz	1	0
2	High Voltage Auxiliary Transformer	Oil-filled	345 kV/13.8 kV, 14 MVA, 3-ph, 60 Hz	2	0
3	Medium Voltage Transformer	Oil-filled	24 kV/4.16 kV, 12 MVA, 3-ph, 60 Hz	1	1
4	Low Voltage Transformer	Dry ventilated	4.16 kV/480 V, 2 MVA, 3-ph, 60 Hz	1	1

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
5	STG Isolated Phase Bus Duct and Tap Bus	Aluminum, self-cooled	24 kV, 3-ph, 60 Hz	1	0
6	Medium Voltage Switchgear	Metal clad	4.16 kV, 3-ph, 60 Hz	1	1
7	Low Voltage Switchgear	Metal enclosed	480 V, 3-ph, 60 Hz	1	1
8	Emergency Diesel Generator	Sized for emergency shutdown	750 kW, 480 V, 3-ph, 60 Hz	1	0

**Case 6 – Account 12: Instrumentation and Control**

Equipment No.	Description	Type	Design Condition	Operating Qty.	Spares
1	DCS – Main Control	Monitor/keyboard; Operator printer (laser color); Engineering printer (laser B&W)	Operator stations/printers and engineering stations/printers	1	0
2	DCS – Processor	Microprocessor with redundant input/output	N/A	1	0
3	DCS – Data Highway	Fiber optic	Fully redundant, 25% spare	1	0

## 4.16 CASE 6 – COST ESTIMATING

The cost estimating methodology was described previously in Section 2.11. Exhibit 4-64 shows a detailed breakdown of the capital costs; Exhibit 4-65 shows the owner’s costs, TOC, and TASC; Exhibit 4-66 shows the initial and annual O&M costs; and Exhibit 4-67 shows the LCOH breakdown.

The estimated TOC of the Shell co-gasification plant with CO<sub>2</sub> capture is \$6,515/[kg H<sub>2</sub>/day]. Process contingency represents 3.2 percent of the TOC and project contingency represents 11.7 percent. The LCOH is \$3.64/kg H<sub>2</sub> with CO<sub>2</sub> T&S.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Exhibit 4-64. Case 6 total plant cost details

Case: 6		– Coal + Bio Gasification w/ CCS					Estimate Type: Conceptual			Dec 2018	
Plant Size (kg H <sub>2</sub> /day): 132,746		Cost Base:									
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O. & Fee	Contingencies		Total Plant Cost	
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]
<b>1 Coal Handling</b>											
1.1	Coal Receive & Unload	\$288	\$0	\$139	\$0	\$427	\$64	\$0	\$98	\$589	\$4
1.2	Coal Stackout & Reclaim	\$942	\$0	\$225	\$0	\$1,167	\$175	\$0	\$268	\$1,611	\$12
1.3	Coal Conveyors & Yard Crush	\$8,987	\$0	\$2,287	\$0	\$11,275	\$1,691	\$0	\$2,593	\$15,559	\$117
1.4	Other Coal Handling	\$1,400	\$0	\$315	\$0	\$1,715	\$257	\$0	\$394	\$2,367	\$18
1.5	Biomass Receive & Unload	\$245	\$0	\$118	\$0	\$363	\$0	\$0	\$0	\$363	\$3
1.6	Biomass Handling	\$801	\$0	\$191	\$0	\$993	\$0	\$0	\$0	\$993	\$7
1.7	Biomass Conveyors	\$7,642	\$0	\$1,945	\$0	\$9,587	\$0	\$0	\$0	\$9,587	\$72
1.8	Biomass Hnd. Foundations	\$1,190	\$0	\$268	\$0	\$1,458	\$0	\$0	\$0	\$1,458	\$11
1.9	Coal & Sorbent Handling Foundations	\$0	\$25	\$66	\$0	\$91	\$14	\$0	\$21	\$126	\$1
	<b>Subtotal</b>	<b>\$21,496</b>	<b>\$25</b>	<b>\$5,555</b>	<b>\$0</b>	<b>\$27,076</b>	<b>\$2,201</b>	<b>\$0</b>	<b>\$3,375</b>	<b>\$32,653</b>	<b>\$246</b>
<b>2 Coal &amp; Biomass Preparation &amp; Feed</b>											
2.1	Coal Crushing & Drying	\$645	\$39	\$93	\$0	\$777	\$116	\$0	\$179	\$1,072	\$8
2.2	Prepared Coal Storage & Feed	\$1,981	\$476	\$306	\$0	\$2,763	\$415	\$0	\$636	\$3,814	\$29
2.3	Dry Coal Injection System	\$2,529	\$29	\$232	\$0	\$2,790	\$418	\$0	\$642	\$3,850	\$29
2.4	Miscellaneous Coal Preparation & Feed	\$196	\$143	\$421	\$0	\$760	\$114	\$0	\$175	\$1,049	\$8
2.5	Biomass Crushing & Drying	\$543	\$33	\$78	\$0	\$654	\$0	\$0	\$0	\$654	\$5
2.6	Prepared Biomass Storage & Feed	\$1,667	\$401	\$258	\$0	\$2,325	\$0	\$0	\$0	\$2,325	\$18
2.7	Dry Biomass Injection System	\$2,128	\$25	\$195	\$0	\$2,348	\$0	\$0	\$0	\$2,348	\$18
2.8	Miscellaneous Biomass Preparation & Feed	\$165	\$120	\$354	\$0	\$639	\$0	\$0	\$0	\$639	\$5
2.9	Coal, Biomass & Sorbent Feed Foundation	\$0	\$37	\$32	\$0	\$70	\$10	\$0	\$16	\$96	\$1
	<b>Subtotal</b>	<b>\$9,854</b>	<b>\$1,303</b>	<b>\$1,969</b>	<b>\$0</b>	<b>\$13,125</b>	<b>\$1,074</b>	<b>\$0</b>	<b>\$1,647</b>	<b>\$15,845</b>	<b>\$119</b>
<b>3 Feedwater &amp; Miscellaneous BOP Systems</b>											
3.1	Feedwater System	\$458	\$786	\$393	\$0	\$1,637	\$246	\$0	\$377	\$2,259	\$17
3.2	Water Makeup & Pretreating	\$1,681	\$168	\$953	\$0	\$2,802	\$420	\$0	\$967	\$4,189	\$32
3.3	Other Feedwater Subsystems	\$237	\$78	\$74	\$0	\$388	\$58	\$0	\$89	\$536	\$4
3.4	Service Water Systems	\$502	\$959	\$3,105	\$0	\$4,567	\$685	\$0	\$1,576	\$6,827	\$51
3.5	Other Boiler Plant Systems	\$61	\$22	\$56	\$0	\$139	\$21	\$0	\$32	\$192	\$1
3.6	Natural Gas Pipeline and Start-Up System	\$4,498	\$193	\$145	\$0	\$4,836	\$725	\$0	\$1,112	\$6,674	\$50
3.7	Wastewater Treatment Equipment	\$2,380	\$0	\$1,459	\$0	\$3,839	\$576	\$0	\$1,324	\$5,739	\$43
3.8	Vacuum Flash, Brine Concentrator, & Crystallizer	\$5,659	\$0	\$3,506	\$0	\$9,165	\$1,375	\$0	\$3,162	\$13,702	\$103
3.9	Miscellaneous Plant Equipment	\$10,984	\$1,441	\$5,582	\$0	\$18,007	\$2,701	\$0	\$6,212	\$26,921	\$203
	<b>Subtotal</b>	<b>\$26,461</b>	<b>\$3,647</b>	<b>\$15,272</b>	<b>\$0</b>	<b>\$45,380</b>	<b>\$6,807</b>	<b>\$0</b>	<b>\$14,851</b>	<b>\$67,039</b>	<b>\$505</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case:		6				Estimate Type:		Conceptual			
Plant Size (kg H <sub>2</sub> /day):		132,746				– Coal + Bio Gasification w/ CCS		Cost Base:		Dec 2018	
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost	
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]
4		Gasifier, ASU, & Accessories									
4.1	Gasifier & Auxiliaries (Shell)	\$171,150	\$489	\$809	\$631	\$173,079	\$25,962	\$24,231	\$33,491	\$256,763	\$1,934
4.2	Syngas Cooler	\$5,438	\$390	\$403	\$314	\$6,545	\$982	\$916	\$1,267	\$9,710	\$73
4.3	Air Separation Unit/Oxidant Compression	\$52,364	\$108	\$13,983	\$10,906	\$77,362	\$11,604	\$0	\$13,345	\$102,311	\$771
4.5	Miscellaneous Gasification Equipment	\$2,234	\$59	\$182	\$142	\$2,617	\$393	\$0	\$451	\$3,461	\$26
4.6	Low Temperature Heat Recovery & Fuel Gas Saturation	\$670	\$1,017	\$1,476	\$1,151	\$4,314	\$647	\$0	\$992	\$5,953	\$45
4.7	Flare Stack System	\$202	\$48	\$128	\$99	\$477	\$72	\$0	\$110	\$658	\$5
4.15	Major Component Rigging	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
4.16	Gasification Foundations	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
<b>Subtotal</b>		<b>\$232,057</b>	<b>\$2,113</b>	<b>\$16,981</b>	<b>\$13,244</b>	<b>\$264,394</b>	<b>\$39,659</b>	<b>\$25,147</b>	<b>\$49,656</b>	<b>\$378,856</b>	<b>\$2,854</b>
5		Syngas Cleanup									
5.1	Double Stage Selexol	\$9,669	\$81	\$469	\$365	\$10,584	\$1,588	\$2,117	\$2,858	\$17,146	\$129
5.2	Sulfur Removal	w/5.1	w/5.1	w/5.1	w/5.1	\$0	\$0	\$0	\$0	\$0	\$0
5.3	Elemental Sulfur Plant	\$1,007	\$18	\$111	\$87	\$1,223	\$183	\$0	\$281	\$1,688	\$13
5.4	Carbon Dioxide (CO <sub>2</sub> ) Compression & Drying	\$4,683	\$395	\$1,021	\$797	\$6,897	\$1,035	\$0	\$1,586	\$9,517	\$72
5.5	Carbon Dioxide (CO <sub>2</sub> ) Compressor Aftercooler	\$201	\$175	\$177	\$138	\$692	\$104	\$0	\$159	\$955	\$7
5.6	Mercury Removal (Carbon Bed)	\$201	\$209	\$439	\$342	\$1,191	\$179	\$60	\$286	\$1,716	\$13
5.7	Water Gas Shift (WGS) Reactors	\$1,357	\$1,750	\$2,630	\$2,051	\$7,788	\$1,168	\$0	\$1,791	\$10,747	\$81
5.8	Hydrogen Chloride Scrubber	\$904	\$529	\$1,027	\$801	\$3,261	\$489	\$0	\$750	\$4,500	\$34
5.9	Particulate Removal	\$162	\$42	\$65	\$51	\$320	\$48	\$0	\$55	\$423	\$3
5.10	Blowback Gas Systems	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
5.11	Fuel Gas Piping	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
5.12	Gas Cleanup Foundations	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
<b>Subtotal</b>		<b>\$18,184</b>	<b>\$3,200</b>	<b>\$5,940</b>	<b>\$4,633</b>	<b>\$31,956</b>	<b>\$4,793</b>	<b>\$2,176</b>	<b>\$7,767</b>	<b>\$46,693</b>	<b>\$352</b>
6		Hydrogen Production									
6.1	Pressure Swing Adsorber	\$7,553	\$23	\$359	\$280	\$8,215	\$1,232	\$0	\$1,889	\$11,336	\$85
6.2	Hydrogen Compressor	\$3,978	\$98	\$314	\$245	\$4,636	\$695	\$0	\$1,066	\$6,397	\$48
<b>Subtotal</b>		<b>\$11,531</b>	<b>\$122</b>	<b>\$673</b>	<b>\$525</b>	<b>\$12,850</b>	<b>\$1,928</b>	<b>\$0</b>	<b>\$2,956</b>	<b>\$17,734</b>	<b>\$134</b>
7		Off Gas Fired Boiler, Ductwork, & Stack									
7.1	Off Gas Fired Boiler	\$391	\$135	\$239	\$187	\$952	\$143	\$0	\$219	\$1,313	\$10
7.2	Off Gas Fired Boiler Accessories	\$108	\$95	\$133	\$104	\$440	\$66	\$0	\$101	\$608	\$5
7.3	Ductwork	w/7.1	w/7.1	w/7.1	w/7.1	\$0	\$0	\$0	\$0	\$0	\$0
7.4	Stack	\$458	\$70	\$194	\$151	\$874	\$131	\$0	\$251	\$1,256	\$9
7.5	Off Gas Fired Boiler, Ductwork & Stack Foundations	w/7.1	w/7.1	w/7.1	w/7.1	\$0	\$0	\$0	\$0	\$0	\$0
<b>Subtotal</b>		<b>\$957</b>	<b>\$300</b>	<b>\$567</b>	<b>\$442</b>	<b>\$2,266</b>	<b>\$340</b>	<b>\$0</b>	<b>\$571</b>	<b>\$3,177</b>	<b>\$24</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case:		6				Estimate Type:		Conceptual			
Plant Size (kg H <sub>2</sub> /day):		132,746				– Coal + Bio Gasification w/ CCS		Cost Base:		Dec 2018	
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost	
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]
<b>8 Steam Turbine &amp; Accessories</b>											
8.1	Steam Turbine Generator & Accessories	\$13,091	\$1,159	\$1,861	\$1,452	\$17,563	\$2,634	\$0	\$4,040	\$24,237	\$183
8.2	Steam Turbine Plant Auxiliaries	w/8.1	w/8.1	w/8.1	w/8.1	\$0	\$0	\$0	\$0	\$0	\$0
8.3	Condenser & Auxiliaries	\$510	\$333	\$336	\$262	\$1,442	\$216	\$0	\$332	\$1,990	\$15
8.4	Steam Piping	w/8.1	w/8.1	w/8.1	w/8.1	\$0	\$0	\$0	\$0	\$0	\$0
8.5	Turbine Generator Foundations	w/8.1	w/8.1	w/8.1	w/8.1	\$0	\$0	\$0	\$0	\$0	\$0
	<b>Subtotal</b>	<b>\$13,601</b>	<b>\$1,492</b>	<b>\$2,198</b>	<b>\$1,714</b>	<b>\$19,005</b>	<b>\$2,851</b>	<b>\$0</b>	<b>\$4,371</b>	<b>\$26,227</b>	<b>\$198</b>
<b>9 Cooling Water System</b>											
9.1	Cooling Towers	\$3,730	\$0	\$1,128	\$0	\$4,858	\$729	\$0	\$838	\$6,425	\$48
9.2	Circulating Water Pumps	\$485	\$0	\$36	\$0	\$521	\$78	\$0	\$90	\$689	\$5
9.3	Circulating Water System Auxiliaries	\$3,629	\$0	\$516	\$0	\$4,145	\$622	\$0	\$715	\$5,482	\$41
9.4	Circulating Water Piping	\$0	\$2,236	\$2,025	\$0	\$4,261	\$639	\$0	\$980	\$5,881	\$44
9.5	Make-up Water System	\$228	\$0	\$314	\$0	\$542	\$81	\$0	\$125	\$748	\$6
9.6	Component Cooling Water System	\$77	\$92	\$63	\$0	\$233	\$35	\$0	\$54	\$322	\$2
9.7	Circulating Water System Foundations	\$0	\$191	\$339	\$0	\$529	\$79	\$0	\$183	\$791	\$6
	<b>Subtotal</b>	<b>\$8,150</b>	<b>\$2,519</b>	<b>\$4,421</b>	<b>\$0</b>	<b>\$15,090</b>	<b>\$2,263</b>	<b>\$0</b>	<b>\$2,984</b>	<b>\$20,337</b>	<b>\$153</b>
<b>10 Slag Recovery &amp; Handling</b>											
10.1	Slag Dewatering & Cooling	\$574	\$0	\$281	\$0	\$855	\$128	\$0	\$147	\$1,131	\$9
10.2	Gasifier Ash Depressurization	\$325	\$0	\$159	\$0	\$484	\$73	\$0	\$84	\$640	\$5
10.3	Cleanup Ash Depressurization	\$146	\$0	\$72	\$0	\$218	\$33	\$0	\$38	\$288	\$2
10.6	Ash Storage Silos	\$389	\$0	\$420	\$0	\$809	\$121	\$0	\$139	\$1,069	\$8
10.7	Ash Transport & Feed Equipment	\$150	\$0	\$35	\$0	\$184	\$28	\$0	\$32	\$244	\$2
10.8	Miscellaneous Ash Handling Equipment	\$21	\$26	\$8	\$0	\$56	\$8	\$0	\$10	\$73	\$1
10.9	Ash/Spent Sorbent Foundation	\$0	\$152	\$202	\$0	\$353	\$53	\$0	\$122	\$528	\$4
	<b>Subtotal</b>	<b>\$1,605</b>	<b>\$178</b>	<b>\$1,176</b>	<b>\$0</b>	<b>\$2,959</b>	<b>\$444</b>	<b>\$0</b>	<b>\$571</b>	<b>\$3,974</b>	<b>\$30</b>
<b>11 Accessory Electric Plant</b>											
11.1	Generator Equipment	\$918	\$0	\$692	\$0	\$1,610	\$241	\$0	\$278	\$2,129	\$16
11.2	Station Service Equipment	\$2,048	\$0	\$176	\$0	\$2,224	\$334	\$0	\$384	\$2,941	\$22
11.3	Switchgear & Motor Control	\$12,359	\$0	\$2,144	\$0	\$14,503	\$2,175	\$0	\$2,502	\$19,180	\$144
11.4	Conduit & Cable Tray	\$0	\$55	\$158	\$0	\$213	\$32	\$0	\$61	\$306	\$2
11.5	Wire & Cable	\$0	\$750	\$1,340	\$0	\$2,090	\$314	\$0	\$601	\$3,005	\$23
11.6	Protective Equipment	\$241	\$0	\$837	\$0	\$1,078	\$162	\$0	\$186	\$1,426	\$11
11.7	Standby Equipment	\$202	\$0	\$187	\$0	\$389	\$58	\$0	\$67	\$514	\$4
11.8	Main Power Transformers	\$766	\$0	\$16	\$0	\$782	\$117	\$0	\$135	\$1,034	\$8
11.9	Electrical Foundations	\$0	\$9	\$23	\$0	\$32	\$5	\$0	\$11	\$48	\$0
	<b>Subtotal</b>	<b>\$16,534</b>	<b>\$814</b>	<b>\$5,573</b>	<b>\$0</b>	<b>\$22,920</b>	<b>\$3,438</b>	<b>\$0</b>	<b>\$4,224</b>	<b>\$30,583</b>	<b>\$230</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case:		6				Estimate Type:		Conceptual			
Plant Size (kg H <sub>2</sub> /day):		132,746				Cost Base:		Dec 2018			
Item No.	Description	Equipment Cost	Material Cost	Labor		Bare Erected Cost	Eng'g CM H.O.& Fee	Contingencies		Total Plant Cost	
				Direct	Indirect			Process	Project	\$/1,000	\$/[kg H <sub>2</sub> /day]
<b>12 Instrumentation &amp; Control</b>											
12.1	Gasification Control Equipment	\$564	\$0	\$242	\$0	\$806	\$121	\$0	\$139	\$1,066	\$8
12.3	Steam Turbine Control Equipment	\$521	\$0	\$71	\$0	\$592	\$89	\$0	\$102	\$783	\$6
12.4	Other Major Component Control Equipment	\$992	\$0	\$676	\$0	\$1,668	\$250	\$83	\$300	\$2,302	\$17
12.5	Signal Processing Equipment	\$770	\$0	\$25	\$0	\$795	\$119	\$0	\$137	\$1,052	\$8
12.6	Control Boards, Panels & Racks	\$223	\$0	\$146	\$0	\$370	\$55	\$18	\$89	\$532	\$4
12.7	Distributed Control System Equipment	\$8,082	\$0	\$264	\$0	\$8,346	\$1,252	\$417	\$1,502	\$11,517	\$87
12.8	Instrument Wiring & Tubing	\$402	\$322	\$1,287	\$0	\$2,011	\$302	\$101	\$603	\$3,016	\$23
12.9	Other Instrumentation & Controls Equipment	\$902	\$0	\$447	\$0	\$1,349	\$202	\$67	\$243	\$1,861	\$14
	<b>Subtotal</b>	<b>\$12,457</b>	<b>\$322</b>	<b>\$3,158</b>	<b>\$0</b>	<b>\$15,936</b>	<b>\$2,390</b>	<b>\$687</b>	<b>\$3,115</b>	<b>\$22,129</b>	<b>\$167</b>
<b>13 Improvements to Site</b>											
13.1	Site Preparation	\$0	\$377	\$8,587	\$0	\$8,965	\$1,345	\$0	\$3,093	\$13,402	\$101
13.2	Site Improvements	\$0	\$369	\$521	\$0	\$890	\$134	\$0	\$307	\$1,331	\$10
13.3	Site Facilities	\$125	\$0	\$140	\$0	\$264	\$40	\$0	\$91	\$395	\$3
	<b>Subtotal</b>	<b>\$125</b>	<b>\$746</b>	<b>\$9,249</b>	<b>\$0</b>	<b>\$10,119</b>	<b>\$1,518</b>	<b>\$0</b>	<b>\$3,491</b>	<b>\$15,128</b>	<b>\$114</b>
<b>14 Buildings &amp; Structures</b>											
14.3	Steam Turbine Building	\$0	\$2,454	\$3,493	\$0	\$5,947	\$892	\$0	\$1,026	\$7,865	\$59
14.4	Administration Building	\$0	\$816	\$592	\$0	\$1,407	\$211	\$0	\$243	\$1,861	\$14
14.5	Circulation Water Pumphouse	\$0	\$70	\$37	\$0	\$106	\$16	\$0	\$18	\$141	\$1
14.6	Water Treatment Buildings	\$0	\$167	\$163	\$0	\$330	\$50	\$0	\$57	\$437	\$3
14.7	Machine Shop	\$0	\$468	\$321	\$0	\$789	\$118	\$0	\$136	\$1,043	\$8
14.8	Warehouse	\$0	\$365	\$235	\$0	\$600	\$90	\$0	\$104	\$794	\$6
14.9	Other Buildings & Structures	\$0	\$267	\$208	\$0	\$475	\$71	\$0	\$82	\$629	\$5
14.10	Waste Treating Building & Structures	\$0	\$659	\$1,259	\$0	\$1,919	\$288	\$0	\$331	\$2,538	\$19
	<b>Subtotal</b>	<b>\$0</b>	<b>\$5,266</b>	<b>\$6,308</b>	<b>\$0</b>	<b>\$11,574</b>	<b>\$1,736</b>	<b>\$0</b>	<b>\$1,997</b>	<b>\$15,307</b>	<b>\$115</b>
	<b>Total</b>	<b>\$373,010</b>	<b>\$22,046</b>	<b>\$79,038</b>	<b>\$20,557</b>	<b>\$494,652</b>	<b>\$71,443</b>	<b>\$28,011</b>	<b>\$101,576</b>	<b>\$695,682</b>	<b>\$5,241</b>

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 4-65. Case 6 owner's costs**

Description	\$/1,000	\$/[kg H <sub>2</sub> /day]
<b>Pre-Production Costs</b>		
6 Months All Labor	\$7,580	\$57
1 Month Maintenance Materials	\$1,413	\$11
1 Month Non-Fuel Consumables	\$262	\$2
1 Month Waste Disposal	\$106	\$1
25% of 1 Months Fuel Cost at 100% CF	\$803	\$6
2% of TPC	\$13,914	\$105
<b>Total</b>	<b>\$24,077</b>	<b>\$181</b>
<b>Inventory Capital</b>		
60-day supply of fuel and consumables at 100% CF	\$6,859	\$52
0.5% of TPC (spare parts)	\$3,478	\$26
<b>Total</b>	<b>\$10,338</b>	<b>\$78</b>
<b>Other Costs</b>		
Initial Cost for Catalyst and Chemicals	\$10,726	\$81
Land	\$900	\$7
Other Owner's Costs	\$104,352	\$786
Financing Costs	\$18,783	\$141
<b>Total Overnight Costs (TOC)</b>	<b>\$864,858</b>	<b>\$6,515</b>
TASC Multiplier (IOU, 35 year)	1.116	
<b>Total As-Spent Cost (TASC)</b>	<b>\$965,472</b>	<b>\$7,273</b>

**Exhibit 4-66. Case 6 initial and annual operating and maintenance costs**

Case:	6	– Coal + Bio Gasification w/ CCS		Cost Base:	Dec 2018
Plant Size (kg H <sub>2</sub> /day):	132,746			Capacity Factor (%):	80
<b>Operating &amp; Maintenance Labor</b>					
<b>Operating Labor</b>			<b>Operating Labor Requirements per Shift</b>		
Operating Labor Rate (base):		38.50	\$/hour	Skilled Operator:	2.0
Operating Labor Burden:		30.00	% of base	Operator:	6.0
Labor O-H Charge Rate:		25.00	% of labor	Foreman:	1.0
				Lab Techs, etc.:	2.0
				<b>Total:</b>	<b>11.0</b>
<b>Fixed Operating Costs</b>					
				<b>Annual Cost</b>	
				(\$)	\$/[kg H <sub>2</sub> /day]
Annual Operating Labor:				\$4,822,818	\$36.331
Maintenance Labor:				\$7,304,660	\$55.027
Administrative & Support Labor:				\$3,031,869	\$22.840
Property Taxes and Insurance:				\$13,913,637	\$104.814

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Case:	6 – Coal + Bio Gasification w/ CCS				Cost Base:	Dec 2018
Plant Size (kg H <sub>2</sub> /day):	132,746				Capacity Factor (%):	80
Total:					\$29,072,984	\$219.012
<b>Variable Operating Costs</b>						
					(\$)	(\$/kg H <sub>2</sub> )
Maintenance Material:					\$13,565,796	\$0.35
<b>Consumables</b>						
	Initial Fill	Per Day	Per Unit	Initial Fill		
Water (gal/1000):	0	745	\$1.90	\$0	\$413,249	\$0.01066
Makeup and Wastewater Treatment Chemicals (ton):	0	2.2	\$550.00	\$0	\$356,345	\$0.00919
Sulfur-Impregnated Activated Carbon (ton):	25	0.034	\$12,000.00	\$299,608	\$119,843	\$0.00309
Water Gas Shift Catalyst (ft <sup>3</sup> ):	6,012	4.1	\$480.00	\$2,885,997	\$577,199	\$0.01489
Selexol Solution (gal):	134,490	13.3	\$38.00	\$5,110,603	\$147,979	\$0.00382
Sodium Hydroxide (50 wt%, ton):	0	2.7	\$600.00	\$0	\$477,915	\$0.01233
Sulfuric Acid (98 wt%, ton):	0	0.048	\$210.00	\$0	\$2,957	\$0.00008
Claus Catalyst (ft <sup>3</sup> ):	w/equip.	0.41	\$48.00	\$0	\$5,777	\$0.00015
PSA Unit Adsorbent (ft <sup>3</sup> ):	16,200	2.2	\$150.00	\$2,430,000	\$97,200	\$0.00251
Triethylene Glycol (gal):	w/equip.	159	\$6.80	\$0	\$316,438	\$0.00816
Electricity (MWh):	0	0	\$71.70	\$0	\$0	\$0.00000
<b>Subtotal:</b>				<b>\$10,726,209</b>	<b>\$2,514,904</b>	<b>\$0.06488</b>
<b>Waste Disposal</b>						
Sulfur-Impregnated Activated Carbon (ton):	0	0.034	\$80.00	\$0	\$799	\$0.00002
Water Gas Shift Catalyst (ft <sup>3</sup> ):	0	4.1	\$2.50	\$0	\$3,006	\$0.00008
Selexol Solution (gal):	0	13.3	\$0.35	\$0	\$1,363	\$0.00004
Claus Catalyst (ft <sup>3</sup> ):	0	0.41	\$2.50	\$0	\$301	\$0.00001
Crystallizer Solids (ton):	0	5.1	\$38.00	\$0	\$56,926	\$0.00147
Slag (ton):	0	84	\$38.00	\$0	\$933,694	\$0.02409
PSA Unit Adsorbent (ft <sup>3</sup> ):	0	2.2	\$1.50	\$0	\$972	\$0.00003
Triethylene Glycol (gal):	0	159	\$0.35	\$0	\$16,287	\$0.00042
<b>Subtotal:</b>				<b>\$0</b>	<b>\$1,013,348</b>	<b>\$0.02614</b>
<b>By-Products</b>						
Sulfur (tons):	0	20	\$0.00	\$0	\$0	\$0.00000
Electricity (MWh):	0	12	\$71.70	\$0	\$251,237	\$0.00648
<b>Subtotal:</b>				<b>\$0</b>	<b>\$251,237</b>	<b>\$0.00648</b>
<b>Variable Operating Costs Total:</b>				<b>\$10,726,209</b>	<b>\$16,842,812</b>	<b>\$0.43452</b>
<b>Fuel Cost</b>						
Illinois Number 6 (ton):	0	791	\$51.96	\$0	\$12,000,850	\$0.30960
Woody Torrefied Biomass (ton):	0	609	\$105.84	\$0	\$18,821,492	\$0.48557
<b>Total:</b>				<b>\$0</b>	<b>\$30,822,342</b>	<b>\$0.79517</b>

**Exhibit 4-67. Case 6 LCOH breakdown**

Component	Value, \$/kg H <sub>2</sub>	Percentage
Capital	1.46	40%
Fixed	0.75	21%
Variable	0.43	12%
Fuel	0.80	22%
<b>Total (Excluding T&amp;S)</b>	<b>3.44</b>	<b>N/A</b>
CO <sub>2</sub> T&S	0.20	6%
<b>Total (Including T&amp;S)</b>	<b>3.64</b>	<b>N/A</b>

## 4.17 GASIFICATION CASE SUMMARY

The performance and cost results of the three gasification plant configurations modeled in this report are summarized in Exhibit 4-68. The following section provides a discussion on the gasification performance, environmental, and cost results.

*Exhibit 4-68. Estimated performance results for all gasification cases*

Case Name	Gasification		
	Shell		
	4	5	6
<b>PERFORMANCE</b>			
Nominal CO <sub>2</sub> Capture	0%	92.5%	92.7%
Capacity Factor	80%	80%	80%
Hydrogen Production Rate (lb/hr)	60,622	60,627	12,194
Gross Power Output (MWe)	89	109	37
Auxiliary Power Requirement (MWe)	114	148	37
Net Power Output (MWe)	-25	-39	1
Coal Flowrate (lb/hr)	467,308	467,308	65,917
Biomass Flowrate (lb/hr)	N/A	N/A	50,750
Natural Gas Flowrate (lb/hr)	N/A	N/A	N/A
HHV Thermal Input (kW <sub>t</sub> )	1,597,711	1,597,711	370,367
HHV Effective Thermal Efficiency (%)	65.0%	64.1%	57.9%
HHV Cold Gas Efficiency (%)	66.6%	66.6%	57.7%
Raw Water Withdrawal (gpm)	3,188	3,638	1,035
Process Water Discharge (gpm)	672	773	220
Raw Water Consumption (gpm)	2,516	2,866	814
CO <sub>2</sub> Emissions (lb/MMBtu)	199	15	15
SO <sub>2</sub> Emissions <sup>A</sup> (lb/MMBtu)	0.027	0.000	0.000
NO <sub>x</sub> Emissions (lb/MMBtu)	0.017	0.007	0.010
PM Emissions (lb/MMBtu)	0.007	0.007	0.007
Hg Emissions (lb/TBtu)	0.571	0.571	0.348
<b>COST</b>			
Total Plant Cost (2018\$/[kg H <sub>2</sub> /day])	4,264	4,901	5,241
Total Overnight Cost (2018\$/[kg H <sub>2</sub> /day])	5,243	6,044	6,515
<i>Owner's Costs</i>	979	1,142	1,274
<i>Process Contingency</i>	231	304	211
<i>Project Contingency</i>	628	734	765
<i>Home Office Expenses</i>	456	516	538
<i>Bare Erected Cost</i>	2,949	3,347	3,726
Total As-Spent Cost (2018\$/[kg H <sub>2</sub> /day])	5,853	6,747	7,273
LCOH (\$/kg H <sub>2</sub> ) (excluding T&S)	2.58	2.92	3.44
<i>Capital Costs</i>	1.17	1.35	1.46
<i>Fixed Costs</i>	0.53	0.60	0.75
<i>Variable Costs</i>	0.43	0.52	0.43
<i>Fuel Costs</i>	0.44	0.44	0.80
LCOH (\$/kg H <sub>2</sub> ) (including T&S)	2.58	3.09	3.64
<i>CO<sub>2</sub> T&amp;S Costs</i>	0.00	0.17	0.20

<sup>A</sup>Trace amounts of sulfur emissions may exist in the flue gas stream to the stack in capture cases


### 4.17.1 Performance Results Summary

A graph of the net plant efficiency (HHV basis) is provided in Exhibit 4-69.

The following observations can be made regarding plant performance:

- In terms of net hydrogen cold gas efficiency, the gasification plant without capture (Case 4) and with capture (Case 5) performed approximately the same (66.6% HHV-basis) indicating the addition of CO<sub>2</sub> capture does not decrease the yield of H<sub>2</sub> per pound of coal basis. This is a consequence of the two cases having the same configuration and performance for the syngas generation and hydrogen purification systems.
- The gasification plant without capture (Case 4) had the highest effective thermal efficiency (65.0% HHV-basis) compared to the other two cases due to being coal-fed only and having a lower net power demand than Case 5. The biomass co-gasification plant with capture (Case 6) performed the worst overall with respect to efficiency due to the lower heating value of the biomass and reduced H<sub>2</sub> recovery in the PSA.
- Despite performing the same as Case 4 on a cold gas efficiency basis, Case 5 performed slightly worse on an effective thermal efficiency basis. This is due to the energy penalty associated with adding CO<sub>2</sub> capture as additional energy is needed for steam extraction for use in the WGS reaction and the auxiliary load for the CO<sub>2</sub> separation and compression equipment. The reduction in effective thermal efficiency is about 0.9 percentage points (about 1.3 percent relative to non-capture).
- Consequently, the configuration with the highest auxiliary power requirement, normalized on the hydrogen production rate, (0.28 kWe/[kg H<sub>2</sub>/day]) MWe) is the biomass/coal co-gasification plant with capture (Case 6) due to the carbon capture and smaller scale energy penalty. The coal gasification plant without capture (Case 4) has the lowest auxiliary power requirement (0.17 kWe/[kg H<sub>2</sub>/day]).
- Case 6 is also the only case that has a positive net power output of 1 MWe compared to -25 MWe for Case 4 and -39 MWe for Case 5. This is due to intentional differences in the PSA design for Case 6, which has a lower hydrogen recovery that produces an off-gas that is more energetic and therefore generates more electricity in the steam cycle. The positive net power becomes important for the life cycle equivalent CO<sub>2</sub>e emissions as sourcing electricity from the grid is a contributor to total CO<sub>2</sub>e emissions.

**Exhibit 4-69. Net plant efficiency (HHV basis) for all gasification cases**




#### 4.17.2 Environmental Results Summary

A graph of the life cycle equivalent CO<sub>2</sub> emissions breakdown is shown in Exhibit 4-70. The results for each case are generated from a Monte Carlo simulation with 5,000 iterations done in openLCA. The bar height is the median value, and the “error bars” represent the 5<sup>th</sup> and 95<sup>th</sup> percentile values. The relative variability of results of these cases is generally similar to that of Cases 1-3. Further discussion of sources of variability is provided in Section 5.1.2.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Exhibit 4-70. CO<sub>2</sub>e life cycle emissions for all gasification cases



- The highest total equivalent CO<sub>2</sub> life cycle emissions (20 lb CO<sub>2</sub>e/lb H<sub>2</sub>) comes from the coal gasification plant without capture (Case 4), which is expected. Eighty nine percent of total CO<sub>2</sub>e emissions comes from CO<sub>2</sub> released via the plant stack (18 lb CO<sub>2</sub>e/lb H<sub>2</sub>). 8 percent is from coal (1.6 lb CO<sub>2</sub>e/lb H<sub>2</sub>) and 2 percent is from grid electricity (0.53 lb CO<sub>2</sub>e/lb H<sub>2</sub>).
- The coal gasification plant with capture produces over two-thirds of its CO<sub>2</sub>e emissions outside the plant boundary, as only 32 percent of the total life cycle emissions are from the plant stack (1.3 lb CO<sub>2</sub>e/lb H<sub>2</sub>). Forty percent is sourced from the coal life cycle emissions (1.6 lb CO<sub>2</sub>e/lb H<sub>2</sub>), 20 percent is from grid electricity (0.83 lb CO<sub>2</sub>e/lb H<sub>2</sub>), and 8 percent is from CO<sub>2</sub> management after it has been captured (0.26 lb CO<sub>2</sub>e/lb H<sub>2</sub>).
- Although overall CO<sub>2</sub>e emissions are down 80 percent when CO<sub>2</sub> capture is employed, the coal gasification plant with capture (Case 5) has a higher life cycle emissions contribution from grid electricity due to the higher power demand of this case and additional life cycle emissions from management of the captured carbon.


## COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

- The coal and biomass co-gasification plant with capture has a net life cycle emission value of -1.0 lb CO<sub>2</sub>e/lb H<sub>2</sub>. The 3.0 lb CO<sub>2</sub>e/lb H<sub>2</sub> emitted from the stack, coal life cycle, and CO<sub>2</sub> management is more than counteracted by the 4.0 lb CO<sub>2</sub>e/lb H<sub>2</sub> life cycle emissions that are offset by using biomass as a feedstock. If this plant configuration needed to source electricity from the grid, like in the other two cases, a feedstock with more than 50 percent biomass would be needed to account for the life cycle emissions of the grid electricity. Instead, this plant produces excess electricity which results in a credit, assuming that this electricity will displace average electricity production. This explains the motivation for reducing the H<sub>2</sub> recovery in the PSA in order to increase internal power production, as explained previously in Section 4.13.5.

Furthermore, all of the cases satisfy the appropriate hydrogen production facility air emissions targets for SO<sub>2</sub>, NO<sub>x</sub>, particulate matter, and Hg. The coal gasification plant without carbon capture has the highest SO<sub>2</sub> (0.027) and NO<sub>x</sub> (0.017) emissions, on a lb of pollutant per MMBtu thermal input basis while the gasification plant with capture has the lowest, 0.000 and 0.007 respectively. Each case has approximately the same PM emissions (0.007 lb/MMBtu). The coal-only plants have the highest Hg emissions (0.571 lb/TBtu) on a thermal input basis while the coal/biomass co-gasification plant with capture has the lowest (0.348 lb/TBtu).

Finally, water use for the three gasification cases has been summarized in Exhibit 4-71.

**Exhibit 4-71. Water use for all gasification cases**




- The results are as expected for the three gasification cases. The coal gasification plant without capture (Case 4) has the lowest water demands of all three cases, with a raw water consumption of 2.5 gal/lb H<sub>2</sub>. The coal and biomass co-gasification plant with carbon capture has the highest, with a raw water consumption of 4.0 gal/lb H<sub>2</sub>.
- The coal gasification plant with capture (Case 5) has a higher raw water withdrawal rate (3.6 gal/lb H<sub>2</sub>) with an approximately equivalent process discharge to the non-capture plant (Case 4). As a result, there is about a 14 percent increase in raw water consumption demand for Case 5 compared to Case 4. This is due to the increased cooling demand required by the CO<sub>2</sub> capture system.
- The coal and biomass gasification plant with capture (Case 6) has a slightly higher process discharge rate (1.1 gal/lb H<sub>2</sub>) and approximately a 50 percent higher raw water withdrawal (5.1 gal/lb H<sub>2</sub>) than Case 4 and Case 5. This is due to the combined effects of the lower PSA H<sub>2</sub> recovery and additional chemical energy made available in the PSA offgas, which increases evaporative cooling of the steam cycle condenser in Case 6.

### 4.17.3 Cost Results Summary

The components of TOC and the overall TASC of the three gasification cases are shown in Exhibit 4-72. The error bars included represent the potential TOC range relative to the maximum and minimum of the capital cost uncertainty range, which is -25 percent/+50 percent for gasification cases.

**Exhibit 4-72. Plant capital cost for all gasification cases**




The following TOC observations are made:

- The coal gasification plant without capture (Case 4) has the lowest TOC (\$5,243/[kg H<sub>2</sub>/day]) and TASC (\$5,853/[kg H<sub>2</sub>/day]) values of all gasification cases. The coal/biomass co-gasification plant with CCS (Case 6) has the highest TOC (\$6,515/[kg H<sub>2</sub>/day]) and TASC (\$7,273/[kg H<sub>2</sub>/day]) values of all gasification cases.
- The primary contributor to the TOC is the bare erected cost, accounting for 55 to 57 percent of the TOC for all cases. The smallest contributor to the TOC is the process contingency, accounting for only three to five percent.

The LCOH is shown for the three gasification cases in Exhibit 4-73. The error bars included represent the potential LCOH range relative to the maximum and minimum capital cost uncertainty ranges. The LCOH ranges presented are not reflective of other changes, such as variation in fuel price, labor price, CF, or other factors.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Exhibit 4-73. LCOH for all gasification cases



The following observations can be made:

- The lowest LCOH is from the coal gasification plant without capture (Case 4, \$2.58/kg H<sub>2</sub>) and the highest LCOH is from the coal/biomass co-gasification plant with capture (Case 6, \$3.64/kg H<sub>2</sub>). The coal gasification plant with capture (Case 5) has a LCOH in between the other two plants, about \$3.09/kg H<sub>2</sub>.
- The largest contributor to the LCOH is the capital cost, making up between about 40 and 46 percent of the LCOH for the gasification cases.
- The capital cost portion of the LCOH is the largest in the coal/biomass co-gasification plant with capture (Case 6), accounting for \$1.46/kg H<sub>2</sub> and the lowest in the coal gasification plant without capture (Case 4, \$1.17/kg H<sub>2</sub>).
- The fuel cost portion of the LCOH in the coal/biomass co-gasification plant (Case 6) is about double that of the coal-only plants due to the higher cost of biomass compared to coal. Fuel is \$0.80/kg H<sub>2</sub> for Case 6 and is only \$0.44/kg H<sub>2</sub> for Case 4 and Case 5.
- Variable costs are highest in the coal gasification plant with capture (Case 5, \$0.52/kg H<sub>2</sub>) and lowest in the coal gasification plant without capture (Case 4, \$0.43/kg H<sub>2</sub>). This is

primarily due to the higher amount of electricity needed to be purchased in Case 5 and lower maintenance material costs in Case 4.

As presented in Section 2.11.4, the breakeven CO<sub>2</sub> sales price and emissions penalty were calculated by using the coal gasification plant with capture (Case 5) and the biomass/coal co-gasification plant with capture (Case 6). The breakeven CO<sub>2</sub> sales price represents the minimum CO<sub>2</sub> plant gate sales price that will incentivize carbon capture. The breakeven CO<sub>2</sub> emissions penalty represents the minimum CO<sub>2</sub> emissions price, when applied to both the capture and non-capture plant that will incentivize carbon capture in lieu of a defined reference non-capture plant. Both the breakeven CO<sub>2</sub> sales price and emissions penalty were calculated using the gasification plant without capture (Case 4) as a non-capture reference.

The breakeven CO<sub>2</sub> sales price (excluding T&S) for the gasification cases with capture are \$20.8/tonne (\$18.8/ton) for the gasification plant with capture (Case 5) and \$42.9/tonne (\$38.9/ton) for the co-gasification plant with capture (Case 6). The breakeven CO<sub>2</sub> emissions penalty for the gasification cases with capture are \$30.8/tonne (\$27.9/ton) for the gasification plant with capture (Case 5) and \$65.0/tonne (\$59.0/ton) for the co-gasification plant with capture (Case 6). A carbon penalty amount about 111 percent more than the penalty needed for the coal-only case with capture is needed to encourage the use of the biomass/coal co-gasification plant.

## 5 RESULTS ANALYSIS

Summaries of the individual technologies were provided in Section 3 and Section 4. This section provides the results of all technologies for cross-comparison.

### 5.1 PERFORMANCE

Exhibit 5-1 provides a summary of the performance and environmental profile for all cases.

*Exhibit 5-1. Estimated performance results for all cases*

Case Name	Reforming			Gasification		
	SMR		ATR	Shell Gasifier		
	1	2	3	4	5	6
CO <sub>2</sub> Capture	0%	96.2%	94.5%	0%	92.5%	92.7%
Capacity Factor	90%	90%	90%	80%	80%	80%
Hydrogen Production Rate (lb/hr)	44,369	44,369	60,627	60,622	60,627	12,194
Gross Power Output (MWe)	0	0	0	89	109	37
Auxiliary Power Requirement (MWe)	13	41	110	114	148	37
Net Power Output (MWe)	-13	-41	-110	-25	-39	1
Coal Flowrate (lb/hr)	N/A	N/A	N/A	467,308	467,308	65,917
Biomass Flowrate (lb/hr)	N/A	N/A	N/A	N/A	N/A	50,750
Natural Gas Flowrate (lb/hr)	156,482	166,387	213,694	N/A	N/A	N/A
HHV Thermal Input (kW <sub>t</sub> )	1,031,068	1,096,328	1,408,040	1,597,711	1,597,711	370,367
HHV Effective Thermal Efficiency (%)	75.4%	68.4%	67.9%	65.0%	64.1%	57.9%
HHV Cold Gas Efficiency (%)	76.7%	72.1%	75.7%	66.6%	66.6%	57.7%
Raw Water Withdrawal (gpm)	1,457	2,727	3,720	3,188	3,638	1,035
Process Water Discharge (gpm)	63	586	775	672	773	220
Raw Water Consumption (gpm)	1,395	2,140	2,945	2,516	2,866	814
CO <sub>2</sub> Emissions (lb/MMBtu)	118	5	7	199	15	15
SO <sub>2</sub> Emissions <sup>A</sup> (lb/MMBtu)	0.000	0.000	0.000	0.027	0.000	0.000
NO <sub>x</sub> Emissions (lb/MMBtu)	0.003	0.002	0.000	0.017	0.007	0.010
PM Emissions (lb/MMBtu)	0.000	0.000	0.000	0.007	0.007	0.007
Hg Emissions (lb/TBtu)	0.000	0.000	0.000	0.571	0.571	0.348

<sup>A</sup>Trace amounts of sulfur emissions may exist in the flue gas stream to the stack in capture cases

#### 5.1.1 Energy Efficiency


A graph of the net plant efficiency (HHV basis) is provided in Exhibit 5-2. The primary conclusions that can be drawn are:

- In general, the reforming cases have higher efficiencies than the gasification cases, on average about 10 percentage points higher. The highest effective thermal efficiency (75.4%) is from the SMR plant without capture (Case 1) and the lowest effective thermal efficiency (57.9%) is from the coal/biomass co-gasification case with capture (Case 6).

## COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

- Adding capture to the SMR plant decreases the ETE by about seven percentage points due to a greater percentage of the NG feedstock being combusted to satisfy the thermal demands of the CO<sub>2</sub> removal processes; while adding capture to the coal gasification plant decreases the CGE by less than one percentage point since additional feedstock is not required to support CO<sub>2</sub> removal.
- The coal/biomass co-gasification plant with CCS (Case 6) is the only case in which the ETE is higher than the cold gas efficiency, due to the positive net power production of the system. This reflects the design assumption made for this case to eliminate power imports so life cycle GHG emissions associated with power imports are eliminated.

**Exhibit 5-2. Plant efficiencies for all cases (HHV basis)**



### 5.1.2 Environmental Emissions

Estimated emissions of Hg, HCl, PM, NO<sub>x</sub>, and SO<sub>2</sub> are all at or below the applicable regulatory limits for all cases. The SO<sub>2</sub>, NO<sub>x</sub>, and PM emissions for each case are shown in Exhibit 5-3, reported in units of pounds of pollutant emitted per 1,000 pounds of H<sub>2</sub> produced. The Hg emissions for each case are shown in Exhibit 5-4.


Natural gas does not contain Hg, PM, or HCl, which makes its environmental profile more attractive compared to the gasification cases. In this report, it was assumed that the only sulfur

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

present in natural gas is from the addition of the odorant, mercaptan. The addition of a sulfur polishing system for the purpose of preventing catalyst poisoning results in an SO<sub>2</sub> emission rate well below the regulatory limits.


The following systems for the gasification plants are required to bring the cases considered into compliance with the ELG rule: vacuum flash, brine concentrator, and crystallizer. These are applied to the syngas scrubber blowdown to ensure that ZLD is satisfied.

**Exhibit 5-3. SO<sub>2</sub>, NO<sub>x</sub>, and PM emissions for all cases**



COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

**Exhibit 5-4. Hg emissions for all cases**



The following observations can be made about the SO<sub>2</sub>, NO<sub>x</sub>, PM, and Hg emissions:


- The coal gasification plant without CCS (Case 4) releases the most SO<sub>2</sub> pollutant (2.4 lb SO<sub>2</sub>/1,000 lb H<sub>2</sub>) on a normalized basis. All other cases release a negligible amount of SO<sub>2</sub>. This is due to the minimal amount of sulfur present in the natural gas feedstock and the extra AGR systems present in the gasification cases with CO<sub>2</sub> capture.
- The largest emitter of NO<sub>x</sub> on a normalized basis is the coal gasification plant without capture (Case 4), emitting 1.5 lb NO<sub>x</sub>/1,000 lb H<sub>2</sub> and the smallest emitter is the ATR plant with capture (Case 3). The emission of NO<sub>x</sub> is kept to a minimum by the use of low-NO<sub>x</sub> burners in the reforming and gasification plants.
- Each of the gasification cases emits approximately the same normalized amount of PM, about 0.6 – 0.7 lb PM/1,000 lb H<sub>2</sub>. The PM emitted is limited by the use of the direct contact water quench, cyclone collector, candle filter, and syngas scrubber. The reforming cases emit a negligible quantity of PM.
- The largest normalized mercury emissions are released in the coal-only gasification cases (Case 4 and Case 5, 5.14x10<sup>-5</sup> lb Hg/1,000 lb H<sub>2</sub>), which is about 43 percent more than the emissions of the coal/biomass co-gasification plant with CCS (Case 6). This is due to

## COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

the large proportion of woody biomass in Case 6 which does not contain mercury. None of the reforming cases emit any mercury.

Of particular interest in this study is the global warming potential of each plant, throughout the life cycle of the system. This analysis has been discussed previously in Section 2.8. To summarize, the global warming potential, on a CO<sub>2</sub>e unit-basis, is estimated over the life cycle of the plant by considering the GHG emissions from the following sources: grid electricity usage, coal, natural gas, and biomass feedstock curation, CO<sub>2</sub> management, and CO<sub>2</sub> stack emissions. Exhibit 5-5 shows the life cycle global warming potential, in units of lb CO<sub>2</sub>e per lb H<sub>2</sub>, of each of the cases.

**Exhibit 5-5. CO<sub>2</sub>e life cycle emissions for all cases**



The “error bars” represent results of the 5<sup>th</sup> and 95<sup>th</sup> percentile after running a Monte Carlo simulation with 5,000 iterations for each technology. Heights of bars represent median values. Simulations were performed in openLCA, and the results distribution relies on underlying parameterized data in upstream models. The upstream natural gas model has many stochastically defined parameters, such as the triangular distribution for the number of natural gas transmission stations [9]. For upstream natural gas, regional variability is also accounted for in the error bars. The median value represents the U.S. average, while the low case assumes

Alaskan Offshore gas and the high case assumes San Juan Conventional gas. The addition of regional variability to the natural gas error was included to represent the variability in GWP values in the domestic natural gas sector, which is obscured when applying a Monte Carlo simulation to the U.S. average value. The upstream electricity model includes a lognormal uncertainty distribution for select emission flows, such as ammonia and carbon dioxide [11, 103]. This derives from variation in emissions factors measured and reported in facility data. The upstream biomass model includes triangular distributions for key parameters, like biomass yield and fertilization rates [13], and uncertainty in the upstream coal model is driven by the coal mine methane parameter [14]. Both the coal and the biomass cases exhibit wider emissions bands because of known variability in the sourcing and physical properties. For example, coal is modeled using a median value for coal mine methane emissions for all the underground bituminous coal mines in the Illinois basin. There is a wide variability in coal mine methane emissions within that region, as shown by the uncertainty bars. This is appropriate because it is unknown which coal producer might be providing coal to these notional gasification facilities. In contrast, natural gas and electricity exhibit much tighter uncertainty because they are commoditized products with gas or electricity coming from many producers in known amounts.

The following observations can be made about the life cycle emissions:


- The configuration with the highest global warming potential on a life cycle basis is the coal gasification plant without CCS (Case 4, 20 lb CO<sub>2</sub>e/lb H<sub>2</sub>). The configuration with the lowest GWP is the coal/biomass co-gasification plant with CCS (Case 6, -1.0 lb CO<sub>2</sub>e/lb H<sub>2</sub>). The life cycle emissions of Case 6 include a small credit (-0.053 lb CO<sub>2</sub>e/lb H<sub>2</sub>) for electricity sold back to the grid.
- The average life cycle GHG emissions of the reforming cases with capture (Case 2, 4.6 lb CO<sub>2</sub>e/lb H<sub>2</sub> and Case 3, 5.7 lb CO<sub>2</sub>e/lb H<sub>2</sub>) is approximately 10 to 40 percent higher than life cycle GHG emissions of the coal gasification case with capture (Case 5, 4.1 lb CO<sub>2</sub>e/lb H<sub>2</sub>). This is primarily due to the life cycle GHG emissions of the grid electricity and natural gas feedstock procurement, which make up approximately 90 percent of the life cycle emissions of the reforming cases with capture.
- The smallest contributor to the life cycle emissions is the CO<sub>2</sub> management emissions, accounting from between zero, for non-capture cases, and two and eight, for capture cases, percent of the life cycle GHG emissions.
- Monte Carlo simulation results show a strong positive skew for gasification cases. For Case 6, this variation pushes the GWP results to positive 2.6 lb CO<sub>2</sub>e/lb H<sub>2</sub>. This would be the result of a plant getting coal from a mine with high coal mine methane emissions and its biomass from a site with a low yield rate.

Appendix B shows results with additional detail, as well as from using GWP factors other than the IPCC AR5 100-year time horizon to provide additional perspective on the results from the various cases.

### 5.1.3 Water Use

Three water values are presented for each technology in Exhibit 5-6: raw water withdrawal, process discharge, and raw water consumption. Each value is normalized by the hydrogen production rate.

*Exhibit 5-6. Water use for all cases*



The following observations can be made:

- The SMR plant without capture (Case 1) has the lowest water demand of all cases (1.9 gal/lb H<sub>2</sub> raw water consumption). The coal/biomass co-gasification plant with capture (Case 6) has the highest water demands of all cases (4.0 gal/lb H<sub>2</sub> raw water consumption), about two times more than Case 1.
- CO<sub>2</sub> capture imposes a significant water demand on all technologies. The capture technologies have significant cooling water demands that result in increased raw water consumption because of increased cooling tower blowdown and cooling tower evaporative losses. Raw water consumption increases by 53 percent for both SMR and ATR cases with capture, 12 percent for the coal-only gasification plant with capture, and 60 percent for the coal/biomass co-gasification plant with capture.

## 5.2 COST RESULTS

Exhibit 5-7 provides a summary of the costs for all cases.

*Exhibit 5-7. Cost summary for all cases*

Case Name	Reforming <sup>A</sup>			Gasification <sup>A</sup>		
	SMR		ATR	Shell Gasifier		
	1	2	3	4	5	6
Total Plant Cost (2018\$/[kg H <sub>2</sub> /day])	554	1,394	1,092	4,264	4,901	5,241
Total Overnight Cost (2018\$/[kg H <sub>2</sub> /day])	713	1,735	1,372	5,243	6,044	6,515
<i>Owner's Costs</i>	159	341	280	979	1,142	1,274
<i>Process Contingency</i>	0	52	1	231	304	211
<i>Project Contingency</i>	94	252	114	628	734	765
<i>Home Office Expenses</i>	77	182	163	456	516	538
<i>Bare Erected Cost</i>	384	908	814	2,949	3,347	3,726
Total As-Spent Cost (2018\$/[kg H <sub>2</sub> /day])	763	1,856	1,467	5,853	6,747	7,273
LCOH (\$/kg H <sub>2</sub> ) (excluding T&S)	1.06	1.54	1.51	2.58	2.92	3.44
<i>Capital Costs</i>	0.14	0.33	0.26	1.17	1.35	1.46
<i>Fixed Costs</i>	0.07	0.15	0.11	0.53	0.60	0.75
<i>Variable Costs</i>	0.09	0.24	0.36	0.43	0.52	0.43
<i>Fuel Costs</i>	0.77	0.82	0.77	0.44	0.44	0.80
LCOH (\$/kg H <sub>2</sub> ) (including T&S)	1.06	1.64	1.59	2.58	3.09	3.64
<i>CO<sub>2</sub> T&amp;S Costs</i>	0.00	0.10	0.09	0.00	0.17	0.20
Breakeven CO <sub>2</sub> Sales Price (ex. T&S), \$/tonne <sup>B</sup>	N/A	50.1	50.4	N/A	20.8	42.9
Breakeven CO <sub>2</sub> Emissions Penalty (incl. T&S), \$/tonne <sup>B</sup>	N/A	64.1	60.3	N/A	30.8	65.0

<sup>A</sup>Financing structures are presented in NETL's "QGESS: Cost Estimation Methodology for NETL Assessments of Power Plant Performance" [6]

<sup>B</sup>Both the breakeven CO<sub>2</sub> sales price and emissions penalty were calculated based on the respective non-capture cases within the reforming cases (Case 1) and gasification cases (Case 4)

### 5.2.1 TOC and TASC

In Exhibit 5-8, the normalized components of TOC and overall TASC are shown for each technology. The error bars included represent the potential TOC range relative to the maximum and minimum of the capital cost uncertainty range, as described previously in the technology summary sections. This range is -25 percent/+50 percent for gasification cases and -15 percent/+25 percent for reforming cases.

The following observations can be made:


- The configuration with the lowest TOC is the SMR plant without capture (Case 1, \$713/[kg H<sub>2</sub>/day]) and the configuration with the highest TOC is the coal/biomass co-gasification plant with capture (Case 6, \$6,515/[kg H<sub>2</sub>/day]). There is almost an order of magnitude difference between the low and high TOC values.
- The average TOC for the gasification cases is more than four times greater than the average TOC for the reforming cases.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

- The addition of CO<sub>2</sub> capture technology impacts all technologies in different magnitudes. The TOC increase for the addition of CO<sub>2</sub> capture technology in reforming cases is 143 percent for the SMR plant (Case 2). The TOC increases by 15 percent for the coal gasification plant (Case 5).

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Exhibit 5-8. Plant capital costs




## 5.2.2 LCOH

A graph of the LCOH by cost component is provided in Exhibit 5-9. The error bars included represent the potential LCOH range relative to the maximum and minimum capital cost uncertainty ranges. The LCOH ranges presented are not reflective of other changes, such as variation in fuel price, labor price, CF, or other factors. The primary observations that can be made are:

- The lowest LCOH is \$1.06/kg H<sub>2</sub> from the SMR plant without capture (Case 1). The highest LCOH is \$3.64/kg H<sub>2</sub> from the coal/biomass co-gasification case with capture (Case 6).
- The average LCOH for the gasification cases is about two times greater than the average LCOH for the reforming cases. This is mainly due to the higher capital and fixed costs needed in the gasification cases compared to the reforming cases.
- The largest contributor to the LCOH for the reforming cases is the fuel cost, accounting for between 48 and 73 percent of the total LCOH. The largest contributor for the gasification cases is the capital cost, accounting for between 40 and 46 percent of the total LCOH. The cost of the feedstock, on a per thermal content unit, is about double for natural gas compared to coal. On the other hand, the greater complexity of the gasification plants explains the large contribution of capital costs to the LCOH.
- Fixed O&M costs account for 20 percent of the gasification case's average LCOH, which is 13 percentage points higher than the reforming cases. This is attributed to the relatively higher operating, maintenance, and administrative labor burden in the gasification cases as well as higher property taxes and insurance.
- The addition of CO<sub>2</sub> capture technology impacts the reforming plant's LCOH more than the gasification plant's LCOH. Adding CCS to the reforming cases increases the LCOH by 54 percent for the SMR plant (Case 2). Adding capture to the coal gasification plant (Case 5) increases the LCOH by 20 percent.
- The CO<sub>2</sub> T&S LCOH component represents about 5 or 6 percent of the total LCOH across the cases with CO<sub>2</sub> capture considered in this study.

Exhibit 5-9. LCOH by cost component




### 5.2.3 Stack CO<sub>2</sub> Emissions Penalty/Sales Price

If future legislation assigns a cost to carbon emissions, all the technologies examined in this report will become more expensive. The technologies without carbon capture will be impacted to a larger extent than those with carbon capture, and coal-based technologies will be impacted more than natural gas-based technologies. The breakeven CO<sub>2</sub> emissions penalty is described in Section 2.11.4 as the carbon tax on stack CO<sub>2</sub> emissions necessary to increase the LCOH of the non-capture cases, Case 1 and Case 4, to match the LCOH of the comparable capture cases.

Another valuable analysis considers the sale of the captured CO<sub>2</sub> for utilization and storage in CO<sub>2</sub> enhanced oil recovery (EOR), which has the potential to provide a revenue stream for capture plant configurations. The plant gate CO<sub>2</sub> sales price will ultimately depend on a number of factors, including plant location and crude oil prices. The breakeven CO<sub>2</sub> sales price represents the minimum CO<sub>2</sub> plant gate sales price that will incentivize carbon capture relative to a defined reference non-capture plant.

Exhibit 5-10 shows a comparison of the breakeven CO<sub>2</sub> sales price and emissions penalty using the equivalent non-capture cases for the reforming (Case 1) and gasification (Case 4) cases.

**Exhibit 5-10. Breakeven stack CO<sub>2</sub> emissions penalty/sales price using equivalent non-capture cases**



The following observations can be made about the CO<sub>2</sub> emissions penalty and sales price:

- The lowest CO<sub>2</sub> sales price that would create parity in the LCOH is in the coal gasification plant with capture (Case 5, \$20.8/tonne CO<sub>2</sub>). The lowest CO<sub>2</sub> emissions penalty that would create this parity is also in the coal gasification plant with capture (Case 5, \$30.8/tonne).
- The reforming plants require a higher cost of CO<sub>2</sub> for their LCOH to reach parity with the non-capture case. This is primarily due to the smaller percentage difference between the non-capture and capture LCOH in gasification plants as well as the larger amount of CO<sub>2</sub> that is present in the gasification systems.

### 5.3 SENSITIVITY ANALYSIS

Sensitivity analysis is a valuable tool for determining how much the results of the study will change when there are significant variations in key process variable assumptions. One of the most volatile of these process assumptions is the price of the feedstocks. In the following three plots, the LCOH is shown as a function of changes to the price of one of the feedstocks. In each sensitivity analysis, only a single feedstock price is varied with the others held constant. While it

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

is recognized that isolated variations in these prices is unlikely, the single variable sensitivities (slopes) provide a simple approximation to estimate the impact of multi-variable changes.

Exhibit 5-11 shows the LCOH sensitivity to coal fuel costs for all cases, even though the coal fuel cost has no effect on the reforming cases. The coal price has been varied from \$1 to \$10/MMBtu for the sensitivity, with the study coal price being \$2.23/MMBtu. This graph highlights that even at coal prices that approach zero, the gasification cases never become economically favorable compared to the reforming cases unless CO<sub>2</sub> is monetized. Furthermore, outside of the range of this graph, the coal/biomass co-gasification plant (Case 6) becomes more favorable than the coal only gasification plant with capture (Case 5). This occurs at high coal prices above \$11.5/MMBtu.

Exhibit 5-11. LCOH sensitivity to coal fuel costs




Exhibit 5-12 shows the LCOH sensitivity to the biomass fuel costs, which only affects Case 6. The biomass price has been varied from \$1 to \$17/MMBtu. The baseline biomass price assumed in this study was \$5.43/MMBtu. The sensitivity plot shows that the coal/biomass co-gasification case (Case 6) will only become more favorable than the coal only gasification case with capture (Case 5) at a negative biomass fuel cost.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Exhibit 5-12. LCOH sensitivity to biomass fuel costs




Exhibit 5-13 shows the sensitivity plot in which only the natural gas fuel costs are varied and the LCOH is examined; therefore, the gasification cases have no change. The natural gas price was varied from \$1 to \$11/MMBtu, with the study price being \$4.42/MMBtu. The results show that at a low natural gas price of \$1/MMBtu, the reforming cases with capture (Case 2 and Case 3), become equivalent, economically, at a LCOH of about \$1/kg H<sub>2</sub>. Furthermore, at high natural gas prices above \$13/MMBtu, the gasification case with capture becomes more favorable than the reforming cases with capture.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Exhibit 5-13. LCOH sensitivity to natural gas fuel costs





Exhibit 5-14 shows the LCOH sensitivity to the grid electricity price over a range of prices from \$10 to \$190/MWh. The price point used in this study is \$71.70/MWh. The LCOH is relatively insensitive to changes in grid electricity price, with Case 3 and Case 5 being the most sensitive due to their large grid power demand. At grid electricity prices approaching \$100/MWh, the LCOH of the ATR plant with capture (Case 3) becomes approximately equal to that of the SMR plant with capture (Case 2). This is due to the higher net power and therefore higher grid electricity demands of Case 3.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Exhibit 5-14. LCOH sensitivity to grid electricity price



In Exhibit 5-15, the sensitivity of LCOH to CF is shown for all technologies. The curves are relatively grouped by technology and whether CO<sub>2</sub> capture is included or not. The CF is plotted from 30 to 95 percent. The baseline CF is 90 percent for reforming cases and 80 percent for gasification cases. The curves plotted in Exhibit 5-15 assume that the CF could be extended to 95 percent with no additional capital equipment, and that lower capacity factors do not result in capital cost savings. An analysis examining the LCOH sensitivity to additional capital expenditures needed to achieve a capacity factor greater than the 80 percent baseline assumption in the gasification cases is presented in Section 5.4.3.

Technologies with high capital cost, such as all the gasification cases, show a greater increase in LCOH with decreased CF. Conversely, the SMR plant with no CO<sub>2</sub> capture is relatively flat because the LCOH is dominated by fuel charges, which decrease as the CF decreases.


Conclusions that can be drawn from Exhibit 5-15 include:

- In general, the gasification cases are more sensitive to changes in the CF than the reforming cases. The cases employing CO<sub>2</sub> capture are slightly more sensitive to changes in the CF than cases without CO<sub>2</sub> capture.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

- At high capacity factors, the LCOH difference between the SMR and ATR plants with capture (Case 2 and Case 3, respectively) become negligible. None of the cases obtain a LCOH below \$1/kg H<sub>2</sub>, even at high capacity factors.


*Exhibit 5-15. LCOH sensitivity to capacity factor*



The final sensitivity examines how the LCOH is impacted by a range of stack CO<sub>2</sub> emissions penalties, from \$0, which is used as a baseline assumption in this study, to \$120/tonne CO<sub>2</sub>. All of the lines have a positive slope due to greater-than-zero CO<sub>2</sub> stack emissions; however, the slopes of the non-capture lines are steeper due to the larger amount of CO<sub>2</sub> released. The intersection points between the non-capture and capture cases' lines are the breakeven CO<sub>2</sub> emission prices, previously discussed in Section 5.2.3. At high CO<sub>2</sub> emission penalties, above \$100/tonne CO<sub>2</sub>, the non-capture reforming case produces hydrogen that costs more than \$2.00/kg H<sub>2</sub> and the non-capture gasification case produces hydrogen that costs more than \$4.00/kg H<sub>2</sub>.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Exhibit 5-16. LCOH sensitivity to stack CO<sub>2</sub> emissions price




In addition to LCOH, a sensitivity analysis was performed on the life cycle greenhouse gas emissions results, reported as global warming potential (GWP). The inputs assessed for this sensitivity analysis include the effects of electricity source, natural gas source, and methane leakage rates.

Exhibit 5-17 shows the effects of electricity source on GWP for each baseline technology (where Case 1 represents Case 1A). The low-emissions electricity source is 100% wind energy, modeled based on the U.S. average, and the high-emissions electricity source is modeled as the Ohio Valley Electric Cooperation grid mix. [103] [11] [12] Indirect emissions changes in the other upstream supply chains caused by varying electricity sources are not modeled.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES


Exhibit 5-17. GWP sensitivity to electricity source



Case 3 imports the most electricity per unit of H<sub>2</sub> produced and therefore is the most sensitive to the electricity source. As a net electricity exporter, Case 6 receives credit for displacing emissions that would have been caused from electricity generation, and thus shows a lower GWP for the high-emissions case. No matter the electricity source, Case 4 shows the highest GWP and Case 6 shows the lowest GWP. Overall, electricity source is not a large contributor to the overall GHG emissions but is generally much more significant in the cases with CCS than those without.

Exhibit 5-18 shows the sensitivity of total GWP results to levels of methane emissions in the upstream gas supply chain. Methane emissions contribute nearly 40% of the GWP in the natural gas supply chain and are currently a focus of EPA and DOE GHG identification and mitigation efforts. [9] [104] Similar to the regional natural gas sensitivity analysis, indirect emission reductions in the electricity supply chain caused by lower methane leakage are not modeled. The natural gas supply chain is modeled for U.S. average natural gas production through transmission, resulting in a GWP of 0.76 kg CO<sub>2</sub>e per kg natural gas. [9]

**Exhibit 5-18. GWP sensitivity to natural gas supply chain methane emissions**



As the upstream methane emissions are reduced, there is a linear reduction in GWP for Cases 1-3. At 100% reduction in natural gas supply chain methane emissions, Case 1A has a 9.6% reduction in GWP, Case 1B has a 12% reduction in GWP, Case 2 has a 26% reduction in GWP, and Case 3 has a 21% reduction in GWP. This suggests that methane reduction has a higher impact on technologies with CCS. Also, at 100% reduction, Case 2 reaches a lower GWP value than Case 5. At all methane emissions reduction rates, Case 4 shows the highest GWP and Case 6 shows the lowest GWP.

The following statements are a few high-level takeaways from the sensitivity analysis. First, no scenarios resulted in a noticeable reduction in GWP for Case 4, which had a GWP 1.5 times greater than the second highest-emitting technology in all scenarios. Next, Case 6 continued to have the lowest GWP in all scenarios. Meanwhile, Cases 2, 3, and 5 were relatively close in GWP and their ranking changed with each scenario. This suggests that geographic region will have a meaningful impact on GHG emissions for these cases in real-world implementation.

## 5.4 OTHER ANALYSES

### 5.4.1 Hydrogen Compression Credit

The DOE Hydrogen and Fuel Cells Program develops and maintains a suite of Hydrogen Analysis Production Models (H2A) to allow users to estimate the cost of hydrogen production through various fossil and non-fossil routes. [105] Case studies for the production routes are publicly available with documentation detailing underlying assumptions. Hydrogen production costs from projected current (2019) and projected future (2035) distributed Polymer Electrolyte

Membrane (PEM) Electrolysis are available for production capacities representative of distributed (1,500 kg H<sub>2</sub>/day) and centralized (50,000 kg H<sub>2</sub>/day) facilities. [106]

Within the H2A models, a compression credit is applied to the projected future PEM electrolysis cases that inherently produce a hydrogen product above the 300 psig comparative standard. The credit is calculated by estimating the capital and operating cost of a notional hydrogen compressor, since there is no hydrogen compressor within the projected future PEM electrolysis configuration. After being normalized to a \$/kg H<sub>2</sub> basis, the credit is subtracted from the LCOH. The calculated credits were \$0.09/kg H<sub>2</sub> and \$0.05/kg H<sub>2</sub> for the projected future distributed and centralized cases, respectively. [106]

The following analysis was conducted to determine a compression credit for the six study cases in a similar manner to the H2A models. Each of the study cases has an inherent hydrogen pressure greater than the NREL comparative standard of 300 psig and includes additional compression to a final pipeline-ready pressure of 925 psig by a hydrogen compressor. Crediting the LCOH of each study case makes the results comparable to lower-pressure hydrogen production routes and analyses, like in the H2A model.

The hydrogen compressor in each study case, which has known capital and operating costs, is used to determine the appropriate compression credit. A compression credit factor is applied to the known cost of compression to account for any pressurization greater than 300 psig that is accomplished before the hydrogen compressor. This factor, as calculated by the following equation, is greater than one for the six study cases because each case's inherent hydrogen pressure prior to the compressor is greater than the NREL comparative standard of 300 psig:

$$\text{Compression Credit Factor} = \frac{(P_{\text{final}} - P_{\text{ref,NREL}})}{(P_{\text{final}} - P_{\text{initial}})}$$

Where:

**P<sub>final</sub>** – compressed H<sub>2</sub> product pressure, psig

**P<sub>ref,NREL</sub>** – NREL H2A H<sub>2</sub> product reference pressure, 300 psig

**P<sub>initial</sub>** – uncompressed inherent H<sub>2</sub> pressure, psig

The hydrogen compression credit is the factored cost of compression that is normalized on an annual H<sub>2</sub> production basis. The credit is subtracted from the baseline LCOH to produce an adjusted LCOH which approximates a 300 psig H<sub>2</sub> delivery price. The adjusted LCOH is shown for all cases in Exhibit 5-19. The result of the analysis is that the LCOH for each case is reduced by about \$0.04/kg H<sub>2</sub>.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

**Exhibit 5-19. Hydrogen compression credit applied to LCOH for all cases**

Case Name	Reforming			Gasification		
	SMR		ATR	Shell Gasifier		
	1	2	3	4	5	6
Inherent H <sub>2</sub> Pressure, psig (uncompressed)	331	316	316	416	394	394
H <sub>2</sub> Product Pressure, psig (compressed)	925					
Compression Credit Factor	1.053	1.027	1.027	1.229	1.177	1.177
Cost of Compression (MM\$)	6.37	6.61	8.75	6.16	5.96	1.51
Baseline LCOH (\$/kg H <sub>2</sub> ) (including T&S)	1.06	1.64	1.59	2.58	3.09	3.64
<i>Hydrogen Compression Credit</i>	-0.042	-0.043	-0.041	-0.039	-0.036	-0.046
Adjusted LCOH (\$/kg H <sub>2</sub> ) (including T&S)	1.02	1.59	1.55	2.54	3.05	3.59

### 5.4.2 Export Steam Sales Price

Superheated steam at 399 °C (750 °F) and 3.1 MPa (450 psia) is produced in the SMR plant without CO<sub>2</sub> capture (Case 1) at quantities that exceed the internal process demand for the steam. The plant water balance is presented in Exhibit 3-10 and shows that of the steam generated within the plant 53 percent is consumed in the SMR reactor for hydrogen production while the balance is exported from the plant. This is a common occurrence in operating SMR facilities without the additional thermal demands of solvent regeneration from CO<sub>2</sub> removal processes.

Effectively, export steam generation serves as a process cooling mechanism resulting in a potentially saleable by-product. However, challenges exist to produce steam at conditions and at purity levels meeting potential customer requirements in situations where potential customers are co-located. Flowsheet solutions also exist to eliminate the generation of export steam in situations where a customer is not co-located. [107]

It was not an objective of the SMR without CO<sub>2</sub> capture plant (Case 1) in this study to produce a saleable export steam byproduct or eliminate the production of export steam. It was assumed that export steam would be exported off-site as a zero-revenue byproduct. However, a simple sensitivity to steam price was performed in which a value of the steam was \$6/ton. The steam value was calculated by using a simplified approach to estimate the amount of process heat available for steam generation and the cost of the natural gas consumed to provide only the sensible heating of the superheated steam. Applying the \$6/ton value as a variable O&M revenue stream reduced the LCOH from \$1.06 to \$1.01/kg H<sub>2</sub>.

### 5.4.3 Gasifier Capacity Factor and Sparring

Section 2.9.3 describes the 80 percent capacity factor assumption used for the gasification cases. This assumption differs from that of the reforming cases which are assumed to have a capacity factor of 90 percent. A sensitivity analysis was performed to quantify the impact to LCOH by adding a spare gasifier train and associated auxiliary capital equipment in order to achieve a 90 percent capacity factor. Exhibit 5-20 shows the results of the analysis.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

In each of the three gasification study cases the LCOH is increased by adding the spare gasifier and increasing the capacity factor to 90 percent. This indicates that the additional revenue produced from operating at a higher capacity factor throughout the year is not enough to offset the additional capital required to achieve the higher capacity factor.

Adding a spare gasifier had the most impact on the coal gasification case without CO<sub>2</sub> capture, increasing the LCOH by 9 percent. The gasification cases with CO<sub>2</sub> capture were impacted to lesser extent by 7 and 4 percent for coal (Case 5) and coal/biomass (Case 6), respectively. This is primarily due to the additional costs associated with the dual stage Selexol and biomass co-feedstock diluting the overall impact of adding the spare gasifier costs.

**Exhibit 5-20. LCOH impact from gasifier train sparing**

Cost	Case (*=gasifier sparing)					
	4	4*	5	5*	6	6*
LCOH (\$/kg H <sub>2</sub> ) (excluding T&S)	2.58	2.82	2.92	3.13	3.44	3.58
<i>Capital Costs</i>	1.17	1.32	1.35	1.48	1.46	1.55
<i>Fixed Costs</i>	0.53	0.58	0.6	0.66	0.75	0.77
<i>Variable Costs</i>	0.43	0.44	0.52	0.55	0.43	0.46
<i>Fuel Costs</i>	0.44	0.44	0.44	0.44	0.80	0.80
LCOH (\$/kg H <sub>2</sub> ) (including T&S)	<b>2.58</b>	<b>2.82</b>	<b>3.09</b>	<b>3.30</b>	<b>3.64</b>	<b>3.78</b>
<i>CO<sub>2</sub> T&amp;S Costs</i>	0.00	0.00	0.17	0.17	0.20	0.20

## 6 FUTURE WORK

---

This report has presented the results of an independent assessment of the cost and performance of select hydrogen production plants utilizing fossil fuel resources as the primary feedstocks. As stated previously, the cost and performance results presented are important inputs to assessments and determinations of technology combinations to be utilized to meet the projected demands of the nascent hydrogen economy. Future iterations of this report may leverage the included cases to assess R&D goals and metrics, expand the number of commercially representative case configurations included, modify the existing representations, or modify design basis assumptions. As such, this section identifies several potential areas of interest for future work.

### 6.1 REDUCING LIFE CYCLE GHG EMISSIONS

While these hydrogen baseline technologies were modeled with the best available data, there are GHG emissions that were not accounted for. Technologies with water as a feedstock must meet specific water quality requirements to be used in the process. In many cases, this requires upstream water treatment. However, feedstock water treatment was not modeled for these baseline technologies due to an assumed negligible impact. ISO 14040 specifies that all inputs with impacts greater than 1% of the total should be included in the model [1] [2]; thus, this exclusion is insignificant to the results. Construction of plants and components for hydrogen production technologies were also not modeled. Previous LCA models of energy-related technologies show that construction impacts rarely surpass the 1% threshold [43] [14], which was the basis for excluding them from the scope.

As explained in Section 2.7.3, this study examined plant arrangements capable of achieving capture rates in excess of 90 percent of the feedstock carbon entering the facility. The resulting life cycle GHG emission intensities for gasification were -1.1 and 4.1 lb CO<sub>2</sub>e/lb H<sub>2</sub> for coal/biomass and coal with CCS, respectively. The reforming cases were 5.5 and 6.6 lb CO<sub>2</sub>e/lb H<sub>2</sub> for SMR with CCS and ATR with CCS, respectively. Future study to reduce life cycle GHG emissions are identified in the sections following.

#### 6.1.1 Renewable Natural Gas Blending

RNG is a NG pipeline quality gas that has been processed from a renewable, methane-containing source gas. RNG can be blended into an existing NG transmission or distribution network to reduce the GHG intensity of the pipeline gas. Typical source gases for RNG production are biogases from landfills, dairies, and municipal wastewater treatment plants. Impurities such as CO<sub>2</sub>, water vapor, H<sub>2</sub>S, and dioxins are removed from the source gas to upgrade the heat content and composition to meet NG pipeline specifications.

By feeding a blended NG/RNG feedstock to a reforming plant, the life cycle GHG intensity of the plant is reduced. Further study into establishing the magnitude of life cycle GHG reductions and whether RNG-blending is a viable pathway to achieving net-zero, or net-negative, life cycle GHG emissions is needed.

### **6.1.2 Direct Air Capture Pairing**

Direct air capture (DAC) technology is the use of forced draft circulation to adsorb atmospheric CO<sub>2</sub> using solvents or fixed-bed sorbents. As a standalone technology DAC provides an atmospheric CO<sub>2</sub> sink much like photosynthesis during the growth cycle of biomass. However, the sorbent (or sorbent) must be regenerated, and separated CO<sub>2</sub> must be compressed and pipelined for storage or utilization.

Integrated system concepts where DAC technology is paired with a hydrogen production facility may offer a pathway to further reduce uncaptured CO<sub>2</sub> emissions emitted directly from the plant stack and/or through atmospheric CO<sub>2</sub> removal offsets. If sufficient atmospheric CO<sub>2</sub>, or a combination of both CO<sub>2</sub> sources is treated, net-negative life cycle GHG emissions attributable to the facility is possible. Potential synergies exist where the CO<sub>2</sub> compression train of the host hydrogen production plant can be leveraged by an on-site DAC facility.

### **6.1.3 Low Carbon Auxiliary Power**

GHG emissions associated with imported grid electricity are a significant contributor to the life cycle GHG profile of the reforming cases. Importing or co-producing no- or low-carbon electricity from low-carbon syngas, fossil-based sources with carbon capture, hydrogen, or renewables can provide a pathway to reducing the overall GHG profile of the hydrogen production facility. Analyses examining the LCOH impacts of several alternative auxiliary powering options under various grid power cost and emission profile assumptions would be beneficial in assessing the most cost competitive strategies for lowering this portion of the GHG profile.

### **6.1.4 Higher CO<sub>2</sub> Capture Rates**

As described in Section 2.7.3, the capture cases in this report maximized CO<sub>2</sub> capture using a defined approach. No adjustments were made to the vendor-provided CO<sub>2</sub> separation efficiencies of the AGR technologies modeled. Obtaining cost and performance information from technology vendors for AGR systems designed for greater CO<sub>2</sub> separation efficiency would enable quantification of the magnitude of plant stack CO<sub>2</sub> emission reduction, as well as the LCOH impact, from incorporating such designs.

## **6.2 ADVANCED TECHNOLOGY ASSESSMENTS**

Plant configurations containing advanced technologies may offer potential cost and performance improvements to the systems examined in this study after overcoming fundamental R&D barriers before market adoption. Part of the utility of this study is as a performance and cost benchmark against which advanced hydrogen production plant configurations can be measured. The following are brief descriptions of advanced technology concepts that may be compared in future analyses.

### 6.2.1 Advanced Reforming Concepts

Chemical looping reforming (CLR), gas switching reforming (GSR), and membrane-assisted ATR (MA-ATR) are emerging advanced reforming concepts that potentially offer improvements to current NG reforming technologies by eliminating the need for certain conventional processes. [108]

Like the approach in other chemical looping concepts, CLR uses a circulating oxygen carrier to provide oxidant to partially oxidize a NG feed to generate a syngas product. R&D is ongoing to develop oxygen carriers also capable of catalyzing the reforming reaction to generate additional H<sub>2</sub> in the syngas product.

GSR aims to avoid the fundamental issues associated with circulating the solid oxygen carrier at the pressures and temperatures required for CLR. This concept involves a series of fixed reactor beds containing the oxygen carrier material. The fixed beds are periodically exposed to air and NG/steam streams by switching between streams, thereby allowing these reactants to flow over the fixed beds without the need for solids circulation. Demonstrating chemical and mechanical stability and durability of a suitable oxygen carrier as well as high-temperature switching valves is a challenge for this concept. [108]

The MA-ATR concept utilizes a fluidized, catalytic reactor which is fed with NG and oxygen from a conventional ASU. Hydrogen-selective membranes continuously separate hydrogen from the reactor reforming zone while a CO<sub>2</sub>-rich stream is separated at the opposite end of the reactor. The in-situ hydrogen separation is a process intensification concept that is aimed at eliminating the WGS and PSA steps needed in conventional reforming systems. Challenges with this concept include significant electricity consumption, membrane scale-up difficulties, and low hydrogen permeate pressure. [108]

### 6.2.2 NG Pyrolysis

The pyrolysis of natural gas is an endothermic process that occurs in the absence of oxygen to form hydrogen and a solid carbon product. Although currently thought of as a production route for carbon black, the technology has potential as a form of hydrogen production with low CO<sub>2</sub> emissions. Future work is needed to better understand the current market applications and limitations for commercial, state-of-the-art NG pyrolysis. Additionally, integrated process system concepts may be developed to begin to understand the relative performance and cost when compared to conventional NG reforming processes.

### 6.2.3 Supercritical Water Gasification

Supercritical water gasification (SCWG) is an alternative gasification approach to conventional thermal gasification which reacts coal, biomass, or a mixture with water above its supercritical point (374 °C and 22.1 MPa). SCWG differs from thermal gasification by utilizing the enhanced solubility of organics in supercritical water and relying on supercritical water itself as the oxidant. Due to the use of supercritical water as the reaction media, a high-hydrogen syngas results with one study reporting a hydrogen fraction of nearly 73 mol% in the syngas. [109] Potential advantages of this technology include the elimination of the ASU as well as a

reduction in gas cleanup requirements. Challenges include scale-up, reactor materials, and overcoming the large heat demand needed for water to reach supercritical conditions.

Future analysis in this area is needed to understand the potential cost and performance benefits of this technology as an advanced option for co-gasifying biomass with coal as a net-zero hydrogen production technology.

### 6.2.4 Advanced H<sub>2</sub>/CO<sub>2</sub> Separation Concepts

Advanced concepts for H<sub>2</sub> and CO<sub>2</sub> separation continue to be an active area of R&D. Various separation methods including absorption, adsorption, and membranes seek to improve overall system cost and performance beyond current pre-combustion separation methods. Historically having focused on IGCC applications, these technologies can likely be applied to gasification-based hydrogen production plants as well. Exhibit 6-1. provides a summary of current, NETL-funded projects for pre-combustion H<sub>2</sub>/CO<sub>2</sub> separation technologies.

Future work in this area is planned in order to develop a TEA to assess the potential performance and cost benefits of select technologies within a coal and biomass “net-zero” plant arrangement.

*Exhibit 6-1. NETL-funded advanced H<sub>2</sub>/CO<sub>2</sub> R&D projects*

Project Title	Performer	Agreement Number	Date
Technology Gap in Coal FIRST Gasification Based Poly-Generation: Advanced Ceramic Membranes	Media and Process Technology, Inc.	FE0031930	10/1/2020 – 9/30/2023
Bench-Scale Development of a Transformative Membrane Process for Pre-Combustion CO <sub>2</sub> Capture	Membrane Technology and Research, Inc.	FE0031632	10/1/2018 – 9/30/2021
Development and Testing of a High Temperature PBI Hollow-Fiber Membrane Technology for Pre-Combustion CO <sub>2</sub> Capture	SRI International	FE0031633	10/1/2018 – 3/31/2022
Transformational Membranes for Pre-Combustion Carbon Capture	Ohio State University	FE0031635	10/1/2018 – 9/30/2021
Development of Carbon Molecular Sieves Hollow Fiber Membranes Based on Polybenzimidazole Doped with Polyprotic Acids with Superior H <sub>2</sub> /CO <sub>2</sub> Separation Properties	State University of New York	FE0031636	10/1/2018 – 9/30/2021
Bench Scale Testing of a High Efficiency, Ultra-Compact Process for Pre-Combustion CO <sub>2</sub> Capture	University of Southern California	FE0031737	6/1/2019 – 5/31/2022
A High Efficiency, Modular Pre-Combustion Capture System for Coal FIRST Poly-Generation Process	TDA Research, Inc.	FE0031926	10/1/2020 – 9/30/2023
Alkanolamines for Acid Gas Removal in Gasification Processes	Pacific Northwest National Laboratory	FWP-72564	10/1/2018 – 3/31/2021

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Project Title	Performer	Agreement Number	Date
High-Temperature Ceramic-Carbonate Dual-Phase Membrane Reactor for Pre-Combustion Carbon Dioxide Capture	Arizona State University	FE0031634	10/1/2018 – 9/30/2021
Integrated Multichannel Water Gas Shift Catalytic Membrane Reactor for Pre-Combustion Carbon Capture	Bettery Corporation	SC0018853	7/2/2018 – 8/18/2021
Integrated Water-Gas-Shift (WGS) / Pre-Combustion Carbon Capture Process	TDA Research, Inc.	FE0023684	10/1/2014 – 9/30/2021

## 7 REFERENCES

---

- [1] ISO, "ISO 14040 International Standard. In: Environmental Management – Life Cycle Assessment – Principles and Framework," International Organisation for Standardization, Geneva, 2006.
- [2] ISO, "ISO 14044 International Standard. In: Environmental Management – Life cycle assessment — Requirements and guidelines," International Organisation for Standardization, Geneva, 2006.
- [3] NETL, "Quality Guidelines for Energy System Studies: Detailed Coal Specifications," U.S. Department of Energy, Pittsburgh, PA, 2019.
- [4] NETL, "Quality Guidelines for Energy System Studies: Specification for Selected Feedstocks," U.S. Department of Energy, Pittsburgh, PA, 2019.
- [5] NETL, "Quality Guidelines for Energy System Studies: Process Modeling Design Parameters," U.S. Department of Energy, Pittsburgh, PA, 2019.
- [6] NETL, "Quality Guidelines for Energy System Studies: Cost Estimation Methodology for NETL Assessments of Power Plant Performance," U.S. Department of Energy, Pittsburgh, PA, 2019.
- [7] NETL, "Quality Guidelines for Energy System Studies: Capital Cost Scaling Methodology: Revision 4 Report," 2019.
- [8] NETL, "Quality Guidelines for Energy System Studies: Fuel Prices for Selected Feedstocks in NETL Studies," U.S. Department of Energy, Pittsburgh, PA, 2019.
- [9] J. Littlefield, S. Roman-White, D. Augustine, A. Pegallapati, G. G. Zaines, S. Rai, G. Cooney and T. J. Skone, "Life Cycle Analysis of Natural Gas Extraction and Power Generation," NETL, Pittsburgh, 2019.
- [10] National Energy Technology Laboratory, "INDUSTRY PARTNERSHIPS & THEIR ROLE IN REDUCING NATURAL GAS SUPPLY CHAIN GREENHOUSE GAS EMISSIONS - PHASE 2," 2021.
- [11] NETL, *Electricity Life Cycle Inventory (LCI) Code and Model*.
- [12] NETL, *US Electricity Baseline Unit Datasets*, Federal LCA Commons.
- [13] T. J. Skone, R. Eckard, J. Marriott, G. Cooney, J. Littlefield, C. White, D. Gray, J. Plunkett and W. Smith, "Comprehensive Analysis of Coal and Biomass Conversion to Jet Fuel: Oxygen Blown, Transport Reactor Integrated Gasifier (TRIG) and Fischer-Tropsch (F-T) Catalyst Configurations," NETL, Pittsburgh, 2014.
- [14] T. J. Skone, G. Schivley, M. Jamieson, J. Marriott, G. Cooney, J. Littlefield, M. Mutchek, M. Krynock and C. Y. Shih, "Life Cycle Analysis: Supercritical Pulverized Coal (SCPC) Power Plants," NETL, Pittsburgh, 2018.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

- [15] Pacific Northwest National Laboratory, PNNL, "H2 HydrogenTools," [Online]. Available: <https://h2tools.org/hyarc/hydrogen-production>. [Accessed 3 June 2021].
- [16] NETL, "China Gasification Database," [Online]. Available: <https://netl.doe.gov/research/coal/energy-systems/gasification/gasification-plant-databases/china-gasification-database>. [Accessed 3 June 2021].
- [17] IEA, "Task33 Database," [Online]. Available: [http://task33.ieabioenergy.com/content/thermal\\_gasification](http://task33.ieabioenergy.com/content/thermal_gasification). [Accessed 4 June 2021].
- [18] Air Products/Technip, "The Large Hydrogen Plant Challenge," July 2005. [Online]. Available: [https://www.h2alliance.com/pdf/FINAL\\_Large\\_H2\\_Plant\\_Challenge.pdf](https://www.h2alliance.com/pdf/FINAL_Large_H2_Plant_Challenge.pdf). [Accessed 4 June 2021].
- [19] NETL, "Air Products & Chemicals, Inc (APCI) Port Arthur Industrial Carbon Capture and Storage (ICCS) Project," [Online]. Available: <https://www.energy.gov/fe/air-products-chemicals-inc>. [Accessed 4 June 2021].
- [20] Air Liquide, "Technology status of hydrogen production from fossil fuels w/CCS," 2019.
- [21] Shell, "Quest Carbon Capture and Storage (CCS) Project," [Online]. Available: <https://open.alberta.ca/dataset/f74375f3-3c73-4b9c-af2b-ef44e59b7890/resource/c36cf890-3b27-4e7e-b95b-3370cd0d9f7d/download/energy-quest-co2-capture-ratio-performance-2019.pdf>. [Accessed 4 June 2021].
- [22] Shell, "Quest Carbon Capture and Storage (CCS) Project - Hydrogen Manufacturing Unit Material Balance," [Online]. Available: <https://open.alberta.ca/dataset/46ddb1a-7b86-4d7c-b8b6-8fe33a60fada/resource/462e751e-d6ad-454c-bfce-8d80a5c15124/download/hydrogenmanufacturingunitmaterialbalance.pdf>. [Accessed 4 June 2021].
- [23] BEIS Hydrogen Supply Programme, "HyNet Low Carbon Hydrogen Plant: Phase 1 Report for BEIS," [Online]. Available: [https://assets.publishing.service.gov.uk/government/uploads/system/uploads/attachment\\_data/file/866401/HS384\\_-\\_Progressive\\_Energy\\_-\\_HyNet\\_hydrogen.pdf](https://assets.publishing.service.gov.uk/government/uploads/system/uploads/attachment_data/file/866401/HS384_-_Progressive_Energy_-_HyNet_hydrogen.pdf). [Accessed 26 May 2021].
- [24] IEA, "The Future of Hydrogen," IEA, 2019.
- [25] H21 North of England, [Online]. Available: <https://www.h21.green/wp-content/uploads/2019/01/H21-NoE-PRINT-PDF-FINAL-1.pdf>. [Accessed 26 May 2021].
- [26] Pale Blue Dot Energy, "Acorn Hydrogen Feasibility Study," October 2019. [Online]. Available: [https://assets.publishing.service.gov.uk/government/uploads/system/uploads/attachment\\_data/file/866380/Phase\\_1\\_-\\_Pale\\_Blue\\_Dot\\_Energy\\_-\\_Acorn\\_Hydrogen.pdf](https://assets.publishing.service.gov.uk/government/uploads/system/uploads/attachment_data/file/866380/Phase_1_-_Pale_Blue_Dot_Energy_-_Acorn_Hydrogen.pdf). [Accessed 26 May 2021].

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

- [27] BP, "BP plans UK's largest hydrogen project," [Online]. Available: <https://www.bp.com/en/global/corporate/news-and-insights/press-releases/bp-plans-uks-largest-hydrogen-project.html>. [Accessed 4 June 2021].
- [28] Air Products, "Air Products Announces Multi-Billion Dollar Net-Zero Hydrogen Energy Complex in Edmonton, Alberta, Canada," 9 June 2021. [Online]. Available: <https://www.airproducts.com/news-center/2021/06/0609-air-products-net-zero-hydrogen-energy-complex-in-edmonton-alberta-canada>. [Accessed 11 February 2022].
- [29] Air Products, "Louisiana Governor Edwards and Air Products Announce Landmark U.S. \$4.5 Billion Blue Hydrogen Clean Energy Complex in Eastern Louisiana," 14 October 2021. [Online]. Available: <https://www.airproducts.com/news-center/2021/10/1014-air-products-blue-hydrogen-clean-energy-complex-in-louisiana>. [Accessed 11 February 2022].
- [30] IEA Clean Coal Centre, "Recent operating experience and improvement of commercial IGCC," August 2013. [Online]. Available: [https://usea.org/sites/default/files/082013\\_Recent%20operating%20experience%20and%20improvement%20of%20commercial%20IGCC\\_ccc222.pdf](https://usea.org/sites/default/files/082013_Recent%20operating%20experience%20and%20improvement%20of%20commercial%20IGCC_ccc222.pdf). [Accessed 28 May 2021].
- [31] NETL, "Cost and Performance Baseline for Fossil Energy Plants Volume 1: Bituminous Coal and Natural Gas to Electricity," 2019.
- [32] Mining Media, *2004 Keystone Coal Industry Manual*, Prairieville, LA: Mining Media publications, 2004.
- [33] Prairie Research Institute, "Herrin Coal Chlorine," University of Illinois at Urbana-Champaign, [Online]. Available: <https://www.isgs.illinois.edu/content/herrin-coal-chlorine>. [Accessed 24 October 2015].
- [34] NETL, "Major Environmental Aspects of Gasification-Based Power Generation Technologies," U.S. Department of Energy, Pittsburgh, PA, 2002.
- [35] Gas Research Institute, *Variability of Natural Gas Composition in Select Major Metropolitan Areas of the United States*, Springfield: U.S. Department of Commerce, 1992.
- [36] NETL, "Comprehensive Analysis of Coal and Biomass Conversion to Jet Fuel: Oxygen Blown, Transport Reactor Integrated Gasifier (TRIG) and Fischer-Tropsch (F-T) Catalyst Configurations," NETL, 2014.
- [37] Bioenergy Program, Idaho National Laboratory, "Uniform-Feedstock Supply System: A Commodity-Scale Design to Produce an Infrastructure-Compatible Biocrude from Lignocellulosic Biomass - Draft," 2010.
- [38] ISO, "ISO 14687:2019 Hydrogen fuel quality - Product specification," ISO, 2019.
- [39] Environmental Protection Agency, "40 CFR Part 423 Effluent Limitations Guidelines and Standards for the Steam Electric Power," 2015.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

- [40] EPA, "National Pollutant Discharge Elimination System (NPDES)," [Online]. Available: <https://www.epa.gov/npdes>. [Accessed 13 July 2017].
- [41] IPCC, "Climate Change 2014: Synthesis Report. Contribution of Working Groups I, II and III to the Fifth Assessment Report of the Intergovernmental Panel on Climate Change," IPCC, Geneva, 2014.
- [42] W. Chen, Y. Geng, J. Hong, D. Yang and X. Ma, "Life cycle assessment of potash fertilizer production in China," *Resources, Conservation and Recycling*, vol. 138, pp. 238-245, 2018.
- [43] NETL, "Life Cycle Analysis: Natural Gas Combined Cycle (NGCC) Power Plants," NETL, 2018.
- [44] J. Phillips, *IGCC 101*, Tampa, FL, 2011.
- [45] C. Higman, S. DellaVilla and B. Steele, *The Reliability of Integrated Gasification Combined Cycle (IGCC) Power Generation Units*, May 2006.
- [46] P. Amick, *ConocoPhillips Presentation at Gasification Technology Council Workshop for Environmental and Economic Regulators*, June 2010.
- [47] Electric Power Research Institute, *Evaluation of Alternative IGCC Plant Designs for High Availability and Near Zero Emissions: RAM Analysis and Impact of SCR*, Palo Alto, CA, December 2005.
- [48] EPRI, *Integrated Gasification Combined Cycle (IGCC) Design Considerations for High Availability, Volume 1: Lessons from Existing Operations*, Palo Alto, CA, 2005.
- [49] EPRI, *Integrated Gasification Combined Cycle (IGCC) Design Considerations for High Availability, Volume 2: RAM Modeling of Standard Designs*, Palo Alto, CA, 2007.
- [50] Electric Power Research Institute, *Gasification Technology Status*, December 2012.
- [51] The Marley Cooling Tower Company, *Cooling Tower Fundamentals*, vol. 2nd Edition, J. C. Hensley, Ed., Mission, Kansas, 1985.
- [52] AACE International, *Conducting Technical and Economic Evaluations – As Applied for the Process and Utility Industries; TCM Framework: 3.2 – Asset Planning, 3.3 Investment Decision Making*, AACE International, 2003.
- [53] AACE International, *Cost Estimate Classification System – As Applied in Engineering, Procurement, and Construction for the Process Industries; TCM Framework 7.3 – Cost Estimating and Budgeting*, AACE International, 2005.
- [54] Chemical Engineering, *Chemical Engineering Plant Cost Index*, Access Intelligence, LLC, Ed., 2013.
- [55] Federal Reserve Bank of St. Louis, "Gross Domestic Product: Chain-type Price Index (GDPCTPI)," 2013. [Online]. Available:

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

- <http://research.stlouisfed.org/fred2/series/GDPCTPI>. [Accessed 20 November 2013].
- [56] NETL, "Quality Guidelines for Energy System Studies: Carbon Dioxide Transport and Storage Costs in NETL Studies," U.S. Department of Energy, Pittsburgh, PA, 2019.
- [57] U.S. Bureau of Economic Analysis, "Read Gross Domestic Product [GDPC1]," FRED, Federal Reserve Bank of St. Louis, [Online]. Available: <https://fred.stlouisfed.org/series/GDPC1/>. [Accessed 12 June 2019].
- [58] Carbon Capture Simulation Initiative, "Centrifugal Compressor Simulation User Manual," U.S. Department of Energy, 2012.
- [59] NATCO Group Inc, "Glycol Dehydration Systems," 2009. [Online]. Available: <http://www.natcogroup.com>. [Accessed 22 June 2009].
- [60] V. Bilsbak, Conditioning of CO<sub>2</sub> Coming from a CO<sub>2</sub> Capture Process for Transport and Storage Purposes, Norwegian University of Science and Technology, 2009.
- [61] Universal Industrial Gases, "Overview of Cryogenic Air Separation," n.d. [Online]. Available: <http://www.ugi.com/cryodist.html>. [Accessed 29 August 2013].
- [62] R. Drnevich, *Personal communication*, Praxair, Inc., November 2002.
- [63] NETL, "NETL Life Cycle Inventory Data - Unit Process: Combustion of Natural Gas.," U.S. Department of Energy, Pittsburgh, PA, 2015.
- [64] Electric Power Research Institute, "Coal Gasification Guidebook: Status, Applications, and Technologies," EPRI, December 1993.
- [65] E. V. Holthoon, "Shell Coal Gasification – Leading Technology Across Multiple Applications," Gasification Technologies Conference, October 6, 2009.
- [66] D. Denton, *Telephone communication*, Eastman Chemical Co.
- [67] Calgon Carbon Corporation, "Mercury Removal from Flue Gas Streams," 2015. [Online]. Available: <http://www.calgoncarbon.com/flue-gas/>. [Accessed 10 November 2015].
- [68] NETL, "The Cost of Mercury Removal in an IGCC Plant," U.S. Department of Energy, Pittsburgh, PA, 2002.
- [69] Calgon Carbon Corporation, "HGR-P for Mercury Removal: Pelleted Activated Carbon," 2015. [Online]. Available: [https://www.calgoncarbon.com/app/uploads/HGR\\_P.pdf](https://www.calgoncarbon.com/app/uploads/HGR_P.pdf). [Accessed May 2018].
- [70] NETL, "Process Screening Analysis of Alternative Gas Treating and Sulfur Removal for Gasification, Revised Final Report," U.S. Department of Energy, Pittsburgh, PA, December 2002.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

- [71] M. Beychok, "Claus Process," Wikimedia Commons, 2014. [Online]. Available: [http://en.wikipedia.org/wiki/Claus\\_process#mediaviewer/File:Claus\\_Sulfur\\_Recovery.png](http://en.wikipedia.org/wiki/Claus_process#mediaviewer/File:Claus_Sulfur_Recovery.png). [Accessed 11 June 2014].
- [72] R. M. Bethea, *Air Pollution Control Technology*, New York: Van Nostrand Reinhold Company, 1978.
- [73] S. Calvert, "How to Choose a Particulate Scrubber," *Chemical Engineering*, vol. 19, pp. 54-68, August 29, 1977.
- [74] B. Jack D and L. K. Legatski, *Venturi Scrubbers*, Atlanta: FMC Corporation.
- [75] Environmental Protection Agency, "SI:412C Wet Scrubber Plan Review (1998). Lesson 4: Liquid-Phase Contacting Scrubbers," EPA, 1998. [Online]. Available: [http://www.apti-learn.net/lms/content/epa/courses/si\\_412C/index.html?cid=12&userID=43049&bookmarks=](http://www.apti-learn.net/lms/content/epa/courses/si_412C/index.html?cid=12&userID=43049&bookmarks=). [Accessed 27 August 2015].
- [76] Babcock & Wilcox Company, *Steam, Its Generation and Use*, Barberton, OH: J.B. Kitto and S. C. Stultz Eds., 2015.
- [77] The International Nickel Company, Inc., "Corrosion Resistance of the Austenitic Chromium-Nickel Stainless Steels in Chemical Environments," 1963. [Online]. Available: [http://www.parrinst.com/wp-content/uploads/downloads/2011/07/Parr\\_Stainless-Steels-Corrosion-Info.pdf](http://www.parrinst.com/wp-content/uploads/downloads/2011/07/Parr_Stainless-Steels-Corrosion-Info.pdf). [Accessed 30 October 2014].
- [78] STAL, "General Properties," [Online]. Available: <http://www.stal.com.cn/pdf/31631613173171.pdf>. [Accessed 30 October 2014].
- [79] CSI Designs, "Stainless Steel Selection Guide," CSI, [Online]. Available: <http://www.csidesigns.com/PDFs/SSSguide.pdf>. [Accessed 30 October 2014].
- [80] W. J. Gilbert, *Jet Venturi Fume Scrubbing*, Westfield: Croll-Reynolds Company.
- [81] Wabash River Coal Gasification Repowering Project, "Topical Report," U.S. Department of Energy, Morgantown, 1995.
- [82] Polk Tampa Electric, "Final Public Design Report," U.S. Department of Energy, Morgantown, 1996.
- [83] N. A. Hatcher, R. S. Alvis and R. H. Weiland, "Sour Water Stripper Performance in the Presence of Heat Stable Salts," Optimized Gas Treating, Inc.
- [84] L. Addington, C. Fitz, K. Lunsford, L. Lyddon and I. M. Siwek, "Sour Water: Where it comes from and how to handle it," Bryan Research and Engineering, Inc. and Verfahrenstechnik und Automatisierung GmbH.
- [85] The Engineering Toolbox, "Super Boiler Efficiency," [Online]. Available: [http://www.engineeringtoolbox.com/feedwater-chemistry-limits-d\\_1064.html](http://www.engineeringtoolbox.com/feedwater-chemistry-limits-d_1064.html). [Accessed 31 August 2015].
- [86] Cansolv, "Cansolv CO<sub>2</sub> Capture System," Cansolv Technologies Inc., 2012.
- [87] U. Kerestecioğlu and T. Haberle, "Handling of Trace Components for Rectisol® Wash Units," Linde Engineering, [Online]. Available:

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

- <http://www.gasification.org/uploads/eventLibrary/32KEREST.pdf>. [Accessed 28 August 2015].
- [88] Cansolv, *Personal Communication*, Cansolv.
- [89] Honeywell UOP, *Personal Communication*, Honeywell UOP.
- [90] W. Barbour, R. Oommen, G. Sagun Shareef and W. M. Vataavuk, "Wet Scrubbers for Acid Gas," U.S. Environmental Protection Agency, December 1995. [Online]. Available: <http://www.epa.gov/ttn/catc1/dir1/cs5-2ch1.pdf>. [Accessed 1 September 2015].
- [91] A. Kohl and R. Nielsen, *Gas Purification*, Fifth Edition ed., Houston: Gulf Publishing, 1997.
- [92] F. Sowa and M. Wolf, "Investigation of Different Equipment Setups for Ammonia Wash and Desulfurization," DMT GmbH & Co. KG, [Online]. Available: [http://www.dmt.de/fileadmin/PDF/Broschueren/Kokereitechnik/Investigation\\_of\\_different\\_equipment\\_setups\\_for\\_ammonia\\_wash\\_and\\_desulfurization.pdf](http://www.dmt.de/fileadmin/PDF/Broschueren/Kokereitechnik/Investigation_of_different_equipment_setups_for_ammonia_wash_and_desulfurization.pdf). [Accessed 1 September 2015].
- [93] Quick Cut Gasket & Rubber Corporation, "Chemical Resistance Chart," 2014. [Online]. Available: <http://www.quickcutgasket.com/pdf/Chemical-Resistance-Chart.pdf>. [Accessed 1 September 2015].
- [94] Nickel Development Institute, "High-Temperature Characteristics of Stainless Steels," Nickel Development Institute, [Online]. Available: [http://www.nickelinstitute.org/~ / Media/Files/TechnicalLiterature/High\\_TemperatureCharacteristicsofStainlessSteel\\_9004\\_.pdf#page=](http://www.nickelinstitute.org/~ / Media/Files/TechnicalLiterature/High_TemperatureCharacteristicsofStainlessSteel_9004_.pdf#page=). [Accessed 30 October 2014].
- [95] J. Cabe and M. Elliott, "FutureGen Project Report," U.S. Department of Energy, 2013.
- [96] Sandmeyer Steel Company, "Stainless Steel Plate," [Online]. Available: <https://www.sandmeyersteel.com/317LMN.html>. [Accessed 12 December 2017].
- [97] General Electric Energy Power & Water, "Water & Process Technologies," General Electric Energy, [Online]. Available: <http://www.ge.com/in/sites/www.ge.com.in/files/GE-recycle-water-with-zero-liquid-discharge.pdf>. [Accessed 31 August 2015].
- [98] General Electric Energy Power & Water, "Zero Liquid Discharge (ZLD). Brine Concentrators and Evaporators," General Electric Energy, [Online]. Available: [http://www.gewater.com/products/equipment/thermal\\_evaporative/brine\\_concentration.jsp](http://www.gewater.com/products/equipment/thermal_evaporative/brine_concentration.jsp). [Accessed 28 March 2011].
- [99] Dan Sampson, *Personal communication*, Worley Parsons.
- [100] Black & Veatch, "Bituminous Baseline Update for Compliance with Effluent Limitation Guidelines (ELG)," U.S. Department of Energy, Pittsburgh, PA, 2017.

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

- [101] Electric Power Research Institute, "Process Screening Study of Alternative Gas Treating and Sulfur Removal Systems for IGCC Power Plant Applications," December 1987.
- [102] CB&I, "E-Gas™ technology," 2013. [Online]. Available: <http://www.cbi.com/technologies/e-gas-technology-in-action>. [Accessed 1 December 2015].
- [103] NETL, "Grid Mix Explorer Version 4.2," 1 September 2020. [Online]. Available: <https://www.netl.doe.gov/energy-analysis/details?id=f0f94954-3627-4e9b-a5c0-c29cfe419d1c>. [Accessed 19 March 2021].
- [104] The White House Office of Domestic Climate Policy, "U.S. Methane Emissions Reduction Action Plan," The White House, 2021.
- [105] NREL, "H2A: Hydrogen Analysis Production Models," [Online]. Available: <https://www.nrel.gov/hydrogen/h2a-production-models.html>. [Accessed 17 June 2021].
- [106] DOE, "DOE Hydrogen and Fuel Cells Program Record: Hydrogen Production Cost from PEM Electrolysis - 2019," 3 February 2020. [Online]. Available: [https://www.hydrogen.energy.gov/pdfs/19009\\_h2\\_production\\_cost\\_pem\\_electrolysis\\_2019.pdf](https://www.hydrogen.energy.gov/pdfs/19009_h2_production_cost_pem_electrolysis_2019.pdf). [Accessed 17 June 2021].
- [107] Air Liquide, "SMR-X(TM) - Zero Steam Hydrogen Production," Air Liquide, [Online]. Available: <https://www.engineering-airliquide.com/smr-x-zero-steam-hydrogen-production>. [Accessed 15 June 2021].
- [108] S. Cloete, "Two new designs, GSR and MA-ATR, to make "blue" Hydrogen cheaper," 9 March 2020. [Online]. Available: <https://energypost.eu/two-new-designs-gsr-and-ma-atr-to-make-blue-hydrogen-cheaper/>. [Accessed 8 June 2021].
- [109] Y. Li, L. Guo, X. Zhang, H. Jin and Y. Lu, "Hydrogen production from coal gasification in supercritical water with a continuous flowing system," *International Journal of Hydrogen Energy*, vol. 35, pp. 3036 - 3045, 31 July 2010.
- [110] The Engineering ToolBox, "STP - Standard Temperature and Pressure and NTP - Normal Temperature and Pressure," 2004. [Online]. Available: [https://www.engineeringtoolbox.com/stp-standard-ntp-normal-air-d\\_772.html](https://www.engineeringtoolbox.com/stp-standard-ntp-normal-air-d_772.html). [Accessed 15 February 2022].
- [111] IPCC, "Climate Change 2007: Synthesis Report. Contribution of Working Groups I, II and III to the Fourth Assessment Report of the Intergovernmental Panel on Climate Change," IPCC, Geneva, 2007.

## APPENDIX A: HYDROGEN UNIT CONVERSIONS

This appendix provides select hydrogen unit conversions, which may help put the data presented in this report into various contexts.

First, there are multiple ways that hydrogen capacities can be reported, including on mass and volumetric bases. Exhibit A shows various unit conversions of an example capacity of 100 MMSCFD of hydrogen.

*Exhibit A-1. Equivalent hydrogen capacities in various units*

Value	Unit	Notes
100	MMSCFD	"standard conditions" are 60 °F and 14.7 psia [110]
111	kNm <sup>3</sup> /hr	"normal conditions" are 32 °F and 14.7 psia [110]
22,167	lb/hr	
266	ton/day	
87,955	metric ton/year	assumes 100% capacity factor

For turbine firing applications, 100 MMSCFD of H<sub>2</sub> can fuel a 212 MW NGCC plant, assuming a NGCC HHV efficiency of 53.6% as reported in the Fossil Energy Baseline. For ammonia (NH<sub>3</sub>) production applications, 100 MMSCFD of H<sub>2</sub> supports a 1,496 tpd NH<sub>3</sub> plant using the Haber-Bosch process.

Next, the cost of hydrogen, which is typically reported in units of \$/kg H<sub>2</sub>, can be reported on an energy content basis. \$1/kg H<sub>2</sub> is equivalent to \$7.56/MMBtu on a HHV basis and \$8.94/MMBtu on a LHV basis. This assumes a H<sub>2</sub> HHV of 59,970 Btu/lb and a LHV of 50,740 Btu/lb. Finally, the barrel of oil equivalent (BOE), which provides a comparison to the energy content of a barrel of crude oil, of \$1/kg H<sub>2</sub> is \$47/BOE on a LHV basis.

## APPENDIX B: DETAILED LIFE CYCLE RESULTS

### DETAILED RESULTS USING ONLY IPCC AR5 100-YEAR GWP VALUES

The results shown in Exhibit 5-5 are detailed in tabular form in Exhibit B-1. Note that more significant figures are shown in this Appendix than elsewhere in the report in order to help highlight the often small differences in the total, 5<sup>th</sup>, and 95<sup>th</sup> percentile values. Inclusion of these additional digits should not otherwise imply more faith in the underlying results. The 5<sup>th</sup> and 95<sup>th</sup> percentile values were derived from a Monte Carlo simulation with 5,000 iterations, and as stated previously, cases including upstream natural gas also reflect regional variability across natural gas basins. The low case is represented by Alaskan Offshore gas and included in 5<sup>th</sup> percentile results, and the high case is represented by San Juan Conventional gas and included in 95<sup>th</sup> percentile results.

*Exhibit B-1. Life cycle GHG emissions for all hydrogen scenarios (IPCC AR5, 100-yr) (lb CO<sub>2</sub>e/lb H<sub>2</sub>)*

Case Name	Reforming				Gasification		
	SMR			ATR	CG		CG/BG
	1A	1B	2	3	4	5	6
Stack Emissions	9.35	9.35	0.380	0.514	17.9	1.35	1.59
Natural Gas Emissions	2.69	2.69	2.86	2.69	-	-	-
Coal Emissions	-	-	-	-	1.64	1.63	1.15
Biomass Emissions	-	-	-	-	-	-	-4.01
Grid Electricity Emissions	0.368	0.368	1.19	2.39	0.533	0.834	-0.0530
CO <sub>2</sub> Management Emissions	-	-	0.151	0.140	-	0.263	0.318
Steam Generation	-	-2.21	-	-	-	-	-
Total	12.4	10.2	4.57	5.72	20.1	4.08	-1.00
Low (5 <sup>th</sup> percentile)	11.1	8.85	3.13	4.33	19.4	3.40	-1.40
High (95 <sup>th</sup> percentile)	16.4	14.2	8.86	9.79	24.9	8.87	2.51

Given hydrogen's HHV of 59,970 Btu/lb, GWP results can also be presented in terms of energy, as shown in Exhibit B-2 and Exhibit B-3.

*Exhibit B-2. Life cycle GHG emissions for all hydrogen scenarios (IPCC AR5, 100-yr) (lb CO<sub>2</sub>e/MMBtu H<sub>2</sub>)*

Case Name	Reforming				Gasification		
	SMR			ATR	CG		CG/BG
	1A	1B	2	3	4	5	6
Stack Emissions	156	156	6.33	8.57	299	22.5	26.6
Natural Gas Emissions	44.8	44.8	47.6	44.8	-	-	-
Coal Emissions	-	-	-	-	27.7	27.3	19.1
Biomass Emissions	-	-	-	-	-	-	-66.8

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case Name	Reforming				Gasification		
	SMR			ATR	CG		CG/BG
	1A	1B	2	3	4	5	6
Grid Electricity Emissions	6.14	6.14	19.8	39.8	8.88	13.9	-0.884
CO <sub>2</sub> Management Emissions	-	-	2.52	2.33	-	4.38	5.30
Steam Generation	-	-36.9	-	-	-	-	-
Total	207	170	76.3	95.5	335	68.0	-16.4
Low (5 <sup>th</sup> percentile)	184	148	52.2	72.3	324	56.6	-23.3
High (95 <sup>th</sup> percentile)	274	237	148	163	415	148	41.8

**Exhibit B-3. Life cycle GHG emissions for all hydrogen scenarios (IPCC AR5, 100-yr) (kg CO<sub>2</sub>e/MJ H<sub>2</sub>)**

Case Name	Reforming				Gasification		
	SMR			ATR	CG		CG/BG
	1A	1B	2	3	4	5	6
Stack Emissions	0.0670	0.0670	0.00272	0.00368	0.129	0.00966	0.0114
Natural Gas Emissions	0.0192	0.0192	0.0205	0.0192	-	-	-
Coal Emissions	-	-	-	-	0.0117	0.0117	0.00822
Biomass Emissions	-	-	-	-	-	-	-0.0287
Grid Electricity Emissions	0.00264	0.00264	0.00851	0.0171	0.00382	0.00598	-0.000380
CO <sub>2</sub> Management Emissions	-	-	0.00108	0.00100	-	0.00188	0.00228
Steam Generation	-	-0.0159	-	-	-	-	-
Total	0.0889	0.0730	0.0328	0.0410	0.144	0.0292	-0.00720
Low (5 <sup>th</sup> percentile)	0.0793	0.0627	0.0224	0.0311	0.139	0.0243	-0.0100
High (95 <sup>th</sup> percentile)	0.118	0.102	0.0635	0.0702	0.178	0.0636	0.0180

## DETAILED RESULTS USING VARIOUS IPCC GWP VALUES

The results shown in the main study all use the IPCC AR5 100-year GWP values. Impact results for all cases were also calculated with five other GWP methods produced by IPCC to help demonstrate the sensitivity of results to different impact assessment methods. These results are displayed in Exhibit B-4.

**Exhibit B-4. GWP results for all cases by IPCC scenario (lb CO<sub>2</sub>e/lb H<sub>2</sub>)**


Case Name	Reforming				Gasification		
	SMR			ATR	CG		CG/BG
	1A	1B	2	3	4	5	6
AR5, 100-yr time horizon, with climate carbon feedback	12	10	4.6	5.8	20	4.1	-0.94
AR5, 100-yr time horizon, without climate carbon feedback	12	10	4.4	5.5	20	4.0	-1.1

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN PRODUCTION TECHNOLOGIES

Case Name	Reforming				Gasification		
	SMR		ATR		CG	CG/BG	
	1A	1B	2	3	4	5	6
AR5, 20-yr time horizon, with climate carbon feedback	14	12	6.5	7.7	21	5.3	-0.11
AR5, 20-yr time horizon, without climate carbon feedback	14	12	6.5	7.6	21	5.2	-0.14
AR4, 100-yr time horizon	12	9.9	4.2	5.4	20	3.8	-1.1
AR4, 20-yr time horizon	14	11	6.0	7.2	21	5.0	-0.33

These results are also shown graphically in Exhibit B-5, including uncertainty. While not shown explicitly in the graph, the major source of variability in the results are different values used for methane, and to a lesser extent, nitrous oxide. And, as expected, the use of the 20-year GWP values (which are higher than the 100-year values) leads to a boost in GWP results.

Exhibit B-5. GWP results for all cases and across six GWP methods (lb CO<sub>2</sub>e/lb H<sub>2</sub>)



COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

All GWP factors used for the IPCC scenarios in this section of the Appendix are recorded in Exhibit B-6.

**Exhibit B-6. Summary of GWP factors used in all IPCC scenarios [41] [111]**

Common Name	Formula	AR5 100-yr w/ ccf	AR5 100-yr w/o ccf	AR5 20-yr w/ ccf	AR5 20-yr w/o ccf	AR4 100-yr	AR4 20-yr
Carbon dioxide	CO <sub>2</sub>	1	1	1	1	1	1
Methane	CH <sub>4</sub>	36	30	86	84	25	72
Nitrous oxide	N <sub>2</sub> O	298	265	268	264	298	289
CFC-11	CCl <sub>3</sub> F	5,350	4,660	7,020	6,900	4,750	4,750
CFC-12	CCl <sub>2</sub> F <sub>2</sub>	10,200	10,200	10,200	10,200	10,900	10,900
CFC-13	CClF <sub>3</sub>	13,900	13,900	13,900	13,900	14,400	14,400
CFC-113	CCl <sub>2</sub> FCClF <sub>2</sub>	5,820	5,820	5,820	5,820	6,130	6,130
CFC-114	CClF <sub>2</sub> CClF <sub>2</sub>	8,590	8,590	8,590	8,590	10,000	10,000
CFC-115	CClF <sub>2</sub> CF <sub>3</sub>	7,670	7,670	7,670	7,670	7,370	7,370
Halon-1301	CBrF <sub>3</sub>	6,290	6,290	6,290	6,290	7,140	7,140
Halon-1211	CBrClF <sub>2</sub>	1,750	1,750	1,750	1,750	1,890	1,890
Carbon tetrachloride	CCl <sub>4</sub>	1,730	1,730	1,730	1,730	1,400	1,400
Methyl bromide	CH <sub>3</sub> Br	2	2	2	2	5	5
Methyl chloroform	CH <sub>3</sub> CCl <sub>3</sub>	160	160	160	160	146	146
HCFC-21	CHCl <sub>2</sub> F	148	148	148	148	-	-
R-22 (HCFC-22)	CHClF <sub>2</sub>	1,760	1,760	1,760	1,760	1,810	1,810
HCFC-123	CHCl <sub>2</sub> CF <sub>3</sub>	79	79	79	79	77	77
HCFC-124	CHClF <sub>2</sub> CF <sub>3</sub>	527	527	527	527	609	609
HCFC-141b	CH <sub>3</sub> CCl <sub>2</sub> F	782	782	782	782	725	725
HCFC-142b	CH <sub>3</sub> CClF <sub>2</sub>	1,980	1,980	1,980	1,980	2,310	2,310
HCFC-225ca	CHCl <sub>2</sub> CF <sub>2</sub> CF <sub>3</sub>	127	127	127	127	122	122
HCFC-225cb	CHClF <sub>2</sub> CF <sub>2</sub> CF <sub>3</sub>	525	525	525	525	595	595
Methylene chloride	CH <sub>2</sub> Cl <sub>2</sub>	9	9	9	9	9	9
Trichloromethane (Chloroform)	CHCl <sub>3</sub>	16	16	16	16	-	-
Ethane	C <sub>2</sub> H <sub>6</sub>	-	-	-	-	6	6
Propane	C <sub>3</sub> H <sub>8</sub>	-	-	-	-	3	3
Butane	C <sub>4</sub> H <sub>10</sub>	-	-	-	-	4	4
Ethylene	C <sub>2</sub> H <sub>4</sub>	-	-	-	-	4	4

COMPARISON OF COMMERCIAL, STATE-OF-THE-ART, FOSSIL-BASED HYDROGEN  
PRODUCTION TECHNOLOGIES

Common Name	Formula	AR5 100-yr w/ ccf	AR5 100-yr w/o ccf	AR5 20-yr w/ ccf	AR5 20-yr w/o ccf	AR4 100-yr	AR4 20-yr
Propylene	C <sub>3</sub> H <sub>6</sub>	-	-	-	-	2	2
Toluene	C <sub>7</sub> H <sub>8</sub>	-	-	-	-	3	3
Isoprene	C <sub>5</sub> H <sub>8</sub>	-	-	-	-	3	3
Methanol	CH <sub>3</sub> OH	-	-	-	-	3	3
Acetaldehyde	CH <sub>3</sub> CHO	-	-	-	-	1	1
Acetone	CH <sub>3</sub> COCH <sub>3</sub>	-	-	-	-	1	1
HFC-23	CHF <sub>3</sub>	12,400	12,400	12,400	12,400	14,800	12,000
difluoromethane (HFC-32)	CH <sub>2</sub> F <sub>2</sub>	675	675	675	675	675	675
HFC-125	C <sub>2</sub> HF <sub>5</sub>	3,500	3,500	3,500	3,500	3,500	3,500
1,1,1,2- tetrafluoroethane (HFC-134a)	C <sub>2</sub> H <sub>2</sub> F <sub>4</sub> (CH <sub>2</sub> FCF <sub>3</sub> )	1,550	1,300	3,790	3,710	1,430	1,430
HFC-143	C <sub>2</sub> H <sub>3</sub> F <sub>3</sub> (CHF <sub>2</sub> CH <sub>2</sub> F)	353	353	353	353	353	353
1,1,1-Trifluoroethane (HFC-143a)	C <sub>2</sub> H <sub>3</sub> F <sub>3</sub> (CF <sub>3</sub> CH <sub>3</sub> )	4,470	4,470	4,470	4,470	4,470	4,470
HFC-236fa	C <sub>3</sub> H <sub>2</sub> F <sub>6</sub>	9,810	9,810	9,810	9,810	9,810	9,810
HFC-245fa	CHF <sub>2</sub> CH <sub>2</sub> CF <sub>3</sub>	1,030	1,030	1,030	1,030	1,030	1,030
Carbon tetrafluoride (PFC-14)	CF <sub>4</sub>	7,390	6,630	4,950	4,880	7,390	7390
Hexafluoroethane (PFC-116)	C <sub>2</sub> F <sub>6</sub>	12,200	12,200	12,200	12,200	12,200	12,200
Sulphur hexafluoride	SF <sub>6</sub>	23,500	23,500	17,500	17,500	22,800	16,300
Nitrogen trifluoride	NF <sub>3</sub>	17,200	17,200	17,200	17,200	17,200	17,200
Trifluoromethyl sulfur pentafluoride	SF <sub>5</sub> CF <sub>3</sub>	17,400	17,400	17,400	17,400	17,700	17,700

Albany, OR • Anchorage, AK • Morgantown, WV • Pittsburgh, PA • Sugar Land, TX

[www.netl.doe.gov](http://www.netl.doe.gov)

(800) 553-7681

