

the Energy to Lead



Hollow Fiber Membrane Contactors For CCS on Natural Gas Power Systems

WORKSHOP ON TECHNOLOGY PATHWAYS FORWARD FOR
CARBON CAPTURE & STORAGE ON NATURAL GAS POWER SYSTEMS

Howard Meyer, R&D Director

April 22, 2014, Washington, DC

Introduction

- > GTI and PoroGen Inc. have teamed to develop a hollow fiber membrane contactor (HFMC) technology using PoroGen's patented fiber manufacturing technology and knowhow
- > CO₂ removal applications for flue gas and natural gas
- > HFMC for both absorber and regenerator
- > Advantages to be confirmed are lower capital and operating costs, lower weight, smaller size systems, no flooding, high turndown-ratio, modularity, shop fabrication for any capacity, insensitivity to motion for offshore operations

Introduction to GTI and PoroGen



- Not-for-profit research company, providing energy and natural gas solutions to the industry since 1941
- Facilities
 - 18 acre campus near Chicago
 - 250 staff




Energy & Environmental Technology Center



- Materials technology company commercially manufacturing products from high performance plastic PEEK (poly (ether ether ketone))
- Products ranging from membrane separation filters to heat transfer devices

PEEK Fiber + Cartridge + Module = Separation system



Natural Gas Flue Gas has Lower CO₂ and Higher O₂ than Coal

	PC Supercritical Power Plant	NGCC Power Plant
Plant Size, MW _e	550	474
Flue Gas Rate, kgmole/hr	102,548	113,831
CO ₂ , %	13.5	4
H ₂ O, %	15	9
O ₂ , %	2	12
N ₂ , %	68.5	74
CO ₂ Captured, Tonne/hr	550	183

Cost and Performance Baseline for Fossil Energy Plants Volume 1: Bituminous Coal and Natural Gas to Electricity Revision 2a, September 2013, DOE/NETL-2010/1397

Impact of CCS on NGCC


- > Plant capital cost is ~ doubled
- > Cost of electricity increased by ~41-53%
- > Efficiency reduced by 14-16%
- > Plant net output reduced by 14-16%
- > Plant water use increases by 23-86%
- > Cost of CO₂ capture is \$66-99/ton CO₂ avoided
- > Plant land area available at plant is limited

Technical and Regulatory Analysis of Adding CCS to NGCC Power Plants in California, Prepared for Southern California Edison Company by CH2M Hill, Nov. 2010


Basic Principles of HFMC Contactor

Membrane mass transfer principle

- Porous, hollow fiber membrane
- Unique membrane material , PEEK
- Membrane matrix filled with gas
- Mass transfer by diffusion reaction
- Driving force: difference in partial pressures of component to be removed/absorbed ($P_{CO_2(g)} > P_{CO_2(l)}$)
- Liquid on one side, gas on the other side of the membrane
- Pressure difference between shell and tube side can be almost zero
- ($P_l \geq P_g$), i.e. the mass transfer is not pressure driven



HFMC Technology Description



Mass Transfer Performance

Comparison to Other Contacting Technologies

Gas-liquid contactor	Specific surface area, (m ² /m ³)	Volumetric mass transfer coefficient, (sec) ⁻¹
Packed column (Countercurrent)	10 – 350	0.0004 – 0.07
Bubble column (Agitated)	100 – 2,000	0.003 – 0.04
Spray column	10 – 400	0.0007 – 0.075
Membrane contactor	100 – 7,000	0.3 – 4.0

Pilot Test of a Nanoporous, Super-hydrophobic Membrane Contactor Process for Post- combustion CO₂ Capture

DOE Contract No. DE-FE0012829


Bench-scale Technical Goals Achieved

Parameters	Goal	Achievement
CO ₂ removal in one stage	$\geq 90\%$	90%
Gas side ΔP , psi	≤ 2	1.6
Mass transfer coefficient, (sec) ⁻¹	≥ 1	1.7
CO ₂ purity	$\geq 95\%$	97%
Continuous operation time in integrated absorber/desorber	≥ 100 h	104 h with >90% CO ₂ removal
Mass transfer coefficient of the 4" 2,000 GPU module in the field	>1.0 (sec) ⁻¹	1.2 (sec) ⁻¹

Module Scale Up

4-inch diameter
module in 8-
inch shell

2-inch diameter
module for lab
testing



Field Experiment Testing Rig



Flue Gas Composition

Element	Concentration
CO ₂	7.4-9.6 vol%
NO _x	40-60 ppmv
SO ₂	0.4-0.6 ppmv
CO	100-600 ppmv
O ₂	8.5-11 vol%
Balance: N ₂ , water vapor and trace elements	

- > Slipstream removing ~ 100 - 135 lb/day CO₂
- > Modules with ~100 ft² of area
- > Tests of aMDEA and H3-1 (Hitachi solvent)

Integrated Flue Gas Carbon Capture Field Experiment

- > Attained target CO₂ removal (> 90%) with both solvents
- > 200 - 300 hours of operation logged
- > Presence of SO₂ (up to ~500 ppmv) did not affect CO₂ removal
- > Mass transfer coefficients $>1 \text{ s}^{-1}$ obtained (with 2,000 GPU module) [conventional contactors: $0.0004\text{-}0.075 \text{ (sec)}^{-1}$]
- > H3-1 has better mass transfer coefficient by ~17%

Slipstream Project Objectives and Goal


■ Objectives:

- Build a 1 MW_e equivalent pilot-scale CO₂ capture system (20 ton/day) using PEEK hollow fibers in a membrane contactor and conduct tests on flue gas at the NCCC
- Demonstrate a continuous, steady-state operation for a minimum of two months
- Gather data necessary for process scale-up

■ Goal

- Achieve DOE's Carbon Capture performance goal of 90% CO₂ capture rate with 95% CO₂ purity at a cost of \$40/tonne of CO₂ captured by 2025


Timeline and scope




Anticipated Slipstream Feed Conditions at NCCC

Parameter	Condition
Capacity, MW _e	1
CO ₂ Capture, ton/day	20
Pressure	~ atmospheric pressure
Temperature	~ 40 °C (100 °F)
Gas composition	CO ₂ concentration: ~13 vol%
Water vapor in feed stream	Fully saturated
Contaminant levels	SO ₂ level: 20-30 ppm or ~1 ppm

PC Process Flow Diagram




Capture System PFD



Plant Efficiency Summary

Item	Unit	Case 11 (no capture)	Case 12 (Econ-amine™)	GTI HFC - H3-1
HHV Thermal Input	kWh _{th}	1,409,162	1,934,519	1,816,984
Net Plant HHV Effic.	%	39.3	28.4	30.3
Net Plant HHV Heat Rate	Btu/ kWh	8,687	12,002	11,271
COE - Total	mills/ kWh	81	147	130-135
Increase in COE - Total	%	-	82	59-67
Cost of CO ₂ Capture - Total	\$/tonne	-	66	50-57

DOE Cost & Performance Comparison of Fossil Power Plants



DOE/NETL-2007/1281 (2007)

Model Predicts Higher Plant Efficiency and Lower COE for NGCC with HFMC

Basis	DOE		IECM		
	Case 13	Case 14	Base	Capture	Capture
CO ₂ Capture Technology	No	Conv. Column	No	Conv. Column	HFMC
Gross Power Output (kW _e)	570,200	520,900	516,840	516,840	516,840
Auxiliary Power Requirement (kW _e)	9,840	38,200	10,340	84,540	55,000
Net Power Output (kW _e)	560,360	481,890	506,500	432,300	461,900
Natural Gas Flowrate (lb/h)	165,182	165,182	148,740	148,740	148,740
Net Plant HHV Efficiency (%)	50.8	43.7	50.15	42.8	45.73
% Decrease in HHV Efficiency		14.0		14.7	8.8
Net Plant HHV Heat Rate (Btu/kW-h)	6,719	7,813	6,803	7,972	7,461
Total Plant Cost (\$x1000)	310,710	564,628	359,500	500,400	449,800
Total Plant Cost (\$/kW)	554	1,172	554	1,158	974
LCOE (mills/kWh)	68.4	97.4	52.76	77.02	68.22
% Increase in LCOE (mills/kWh)		42.4		46.0	29.3
CO ₂ Emissions (lb/MWh)	783	85.8	809.9	9.49	8.89

DOE/NETL-2007/1281 (2007)

HFMC Reduces Costs of CO₂ Capture

- ✓ Improved membrane material and membrane performance to lower capital costs
- ✓ Improved solvent regeneration using mild heat and higher pressure (even more when combined with a solvent requiring lower regeneration energy).
- ✓ Improved process performance results from increased flexibility in solvent selection
- ✓ Reduced system size and footprint by up to 70% enables retrofit application to many existing power plants
- ✓ Reduced materials of construction costs since membrane modules are constructed from plastic materials and are not subject to corrosion
- ✓ Reduced parasitic fan loads due to lower pressure and pressure drop requirements compared to conventional membranes and columns
- ✓ Reduced solvent degradation

GTI Gratefully Acknowledge Support Provided by:

- > US Department of Energy, National Energy Technology Laboratory, under DOE Contract No. DE-FE0012829
- > Illinois Clean Coal Institute with funds made available by the State of Illinois
- > JIP Sponsors for the natural gas treating part of this work
- > Midwest Generation for hosting the post-combustion field experiment unit