



Advanced Coal Power Systems *Competing in Multiple Market Scenarios*

13th Annual SECA Workshop
July 24, 2012

Kristin Gerdes
Senior Analyst, Office of Program Planning & Analysis

Acknowledgments

- John Wimer
- Charles Zelek
- Larry Rath
- Jose Benitez
- Rodney Geisbrecht
- Morgan Summers
- ESPA Site Support

Overview

- OBJECTIVE

- How can R&D help maintain a balanced energy supply for our nation's energy and economic security through use of its abundant domestic coal resources?
- Determine cost and performance requirements for new coal power plants to deploy in the 2030-2035 timeframe
 - With and without CO₂ utilization for enhanced oil recovery

- METHODOLOGY

- DOE/EIA's National Energy Modeling System (NEMS) Annual Energy Outlook (AEO) 2011 used to examine competitiveness of new power generation capacity under different scenarios
- NEMS competes the full array of power generation options, including coal, NGCC, nuclear and renewables
- Deployment largely driven by levelized cost of electricity (LCOE)

Advanced Coal Power Systems

with and without CO₂ capture

*Today's
IGCC*

*Advanced IGCC
+
Advanced Pre-
combustion
Capture*

*Integrated
Gasification
Fuel Cells
(IGFC)*

*IGFC +
Catalytic
Gasification*

X-Class IGCC

Pulse Combustion

State-of-the-Art

2nd Generation

Transformational

*Today's
Supercritical
PC*

*Advanced Ultra-
supercritical (AUSC) PC
+
Advanced Post-combustion Capture

AUSC Oxycombustion*

*Direct Power
Extraction*

*Coal Chemical
Looping*

*Supercritical
CO₂ Cycles*

Market Uncertainties Impacting Competitiveness of Coal Power Systems

- Natural gas (NG) prices
- Macroeconomic growth and its impact on electricity demand
- Cost and performance of competing baseload technologies
- Enhanced Oil Recovery (EOR) CO₂ prices and opportunities
- Regulations limiting emissions for coal plants
- Regulation-based cost for CO₂ emissions (i.e. CO₂ tax)

AEO 2011 Scenarios Evaluated

| CO ₂ -EOR Revenues Available | No | Yes |
|---|----|-----|
| Reference | X | X |
| Low Shale Gas Recovery (i.e. high NG prices) | X | X |
| High Shale Gas Recovery (i.e. low NG prices) | X | X |
| High Macro-economic Growth (i.e. high electricity demand) | X | X |

- **Reference Case:** Baseline economic growth (2.7 percent per year from 2009 through 2035), world oil price, and technology assumptions
- **Low Shale EUR:** Estimated Ultimate Recovery (EUR) per shale gas well is assumed to be 50 percent lower than in Reference case
- **High Shale EUR:** EUR per shale gas well is assumed to be 50 percent higher than in Reference case
- **High Macroeconomic Growth:** Real GDP grows at an average annual rate of 3.2 percent from 2009 to 2035; other energy market assumptions are the same as in the Reference case
- *In all scenarios without GHG regulations, EIA applies a 3 %-pt increase in the cost of capital for GHG intensive technologies without CCUS (including coal)*

Key Findings

Market Competitiveness of Coal Power Systems in 2030

| | No CO ₂ Capture | | | With CO ₂ Capture | | |
|----------------------------|----------------------------|---------------------|---------|--|---------------------|---|
| Generation | No R&D | 2 nd Gen | Transf. | No R&D | 2 nd Gen | Transf. |
| Higher NG Prices | Competitive | | | Competitive with CO ₂ sales | | CO ₂ sales may not be required |
| Greater Electricity Demand | | | | Higher CO ₂ sales price | | |
| Reference AEO 2011 Case | Not competitive | | | Higher CO ₂ sales price | | With CO ₂ sales |
| Lower NG Prices | | | | Possible | Not competitive | |

ADVANCED POWER SYSTEMS

2nd-Gen Technology Pathways


- Advanced USC PC Pathway
 - Advanced ultra-supercritical steam conditions (5000 psig/1350F/1400F)
 - Advanced post-combustion capture such as CO₂ separation membranes or CO₂ sorbents
 - Advanced CO₂ compression
- Oxycombustion PC Pathway
 - Advanced ultra-supercritical steam conditions
 - Compact oxy-fuel boiler
 - Advanced oxygen separation
 - Advanced CO₂ compression
 - Co-sequestration of CO₂/SO₂
- Advanced IGCC Pathway
 - Advanced hydrogen or syngas turbine (>2600F TIT)
 - Warm gas clean up
 - Advanced H₂-CO₂ separation (i.e. high temperature hydrogen membrane)
 - Ion transport membrane for oxygen separation
 - Dry coal feed pump

IGFC Pathway

| Parameter | Base | Improved |
|---|------|----------|
| SOFC Degradation (%/1000 hrs) | 1.5 | 0.2 |
| Cell Overpotential (mv) | 140 | 70 |
| Gasifier CH ₄ (conventional) | 5.9% | 10.2% |
| Gasifier CH ₄ (catalytic) | 30% | NA |
| SOFC Stack Cost (Atm.) (\$/kW) | 296 | 268 |
| SOFC Stack Cost (Pressure) (\$/kW) | 442 | 414 |
| Inverter Efficiency | 97% | 98% |


IGFC

Catalytic Gasification and Atmospheric SOFC



IGFC with CO₂ Capture


Catalytic Gasification and Atmospheric SOFC



Fossil Energy R&D Program


Driving Down the Cost of Electricity for Coal Power with Capture

First-year cost of electricity (\$/MWh)



Integrated Gasification Combined Cycle (IGCC), Integrated Gasification Fuel Cell (IGFC), Pulverized Coal (PC)

COE is reported in June 2011 dollars on a first-year (non-levelized) basis, and is assumed to escalate at a nominal annual rate of 3%.




MARKET ASSESSMENT IN 2030

Forecasted Gas Price is Key Variable Across Scenarios


Coal Price is Stable Across Scenarios

AEO 2011 Fossil Fuel Prices - Electricity Sector




| 2030 Delivered Fuel Prices (2009 \$/MMBtu) | | | |
|---|------|------|-------|
| | Gas | Coal | Delta |
| High Shale | 4.95 | 2.23 | 2.7 |
| Reference | 6.20 | 2.31 | 3.9 |
| High Macro | 6.92 | 2.37 | 4.6 |
| Low Shale | 7.99 | 2.38 | 5.6 |

Delivered Fuel Costs to U.S. Electric Utilities



LCOE's of New Power Generation Options in 2030


Reference Scenario (No Coal R&D)




Advanced NGCC: 400 MW-net H-Class, 53% HHV

Little or No New Coal Capacity is Deployed In Scenarios without Coal R&D

**New Plant Builds by Technology
Reference Scenario Baseline**




**New Plant Builds by Technology
Low Shale Scenario Baseline**



Competitiveness of Non-Capture Coal Plants in 2030


Impact of Improvements in Capital Cost and/or Efficiency



| AEO 2011 Case | NG Price in 2030 (2009\$/MMBtu) | NGCC LCOE in 2030 (2009\$/MWh) |
|---------------|---------------------------------|--------------------------------|
| High Shale | \$5.0 | \$61 |
| Reference | \$6.2 | \$76 |
| High Macro | \$6.9 | \$81 |
| Low Shale | \$8.0 | \$86 |

How R&D Can Enable Coal Plants to Compete in 2030

Improvements in Capital Cost and/or Efficiency



| AEO 2011 Case | NG Price in 2030 (2009\$/MMBtu) | NGCC LCOE in 2030 (2009\$/MWh) |
|---------------|---------------------------------|--------------------------------|
| High Shale | \$5.0 | \$61 |
| Reference | \$6.2 | \$76 |
| High Macro | \$6.9 | \$81 |
| Low Shale | \$8.0 | \$86 |

Preliminary Deployment Assessment of Non-Capture Advanced Coal (with R&D) in NEMS

- Baseline IGCC parameters in NEMS replaced with select advanced coal cases
 - 2020-2030 transition period with advanced system cost and performance fully met in 2030
- Transformational Coal (i.e. IGFC with Catalytic Gasification)
 - >10 GW deployment 2020-2035 in AEO 2011 Reference case
 - Compare to no deployment without R&D
 - >25 GW deployment 2020-2035 in Low Shale case (i.e. high NG price)
 - Compare to 11 GW without R&D
 - *Target cost and performance not likely fully in place in 2030 timeframe (i.e. 2030 readiness requires completion of R&D, commercial demonstration, and initial deployments, and plants built and ready to produce power)*


CO₂ CAPTURE, UTILIZATION AND STORAGE (CCUS)

Incentivizing CO₂ Capture

- Most coal-based power systems would require some level of CO₂ capture to meet 1,000 lb CO₂/MWh-gross
 - IGFC with atmospheric SOFC and catalytic gasification comes closest with ~1,020 lb CO₂/MWh-gross
 - Adding capture to coal systems further hampers competitiveness
- For advanced coal with capture, objective shifts to assess competitiveness if CO₂ can be sold for EOR
 - Utilization of CO₂ for EOR provides market incentive for coal with CCUS and will speed deployment
- LCOEs of capture systems adjusted to include CO₂ plant gate sales price
 - NEMS currently has limited functionality to sell CO₂ for use in EOR
 - NETL CO₂ Transport, Utilization and Storage (CTUS) model integration into NEMS in final stages of development
- NGCC continues to set LCOE benchmark in 2030
 - NGCC with CCUS not incentivized until CO₂ plant gate sales prices reach ~\$70/tonne

Competitiveness of Coal Plants **with Capture** in 2030

Adding Carbon Capture to Coal Plants




| AEO 2011 Case | NG Price in 2030 (2009\$/MMBtu) | NGCC LCOE in 2030 (2009\$/MWh) |
|---------------|---------------------------------|--------------------------------|
| High Shale | \$5.0 | \$61 |
| Reference | \$6.2 | \$76 |
| High Macro | \$6.9 | \$81 |
| Low Shale | \$8.0 | \$86 |

No CO₂ Sales Revenue

¹Cost reductions calculated on a \$/MWh basis and thus also benefits from efficiency improvements


Competitiveness of Coal Plants **with CCUS** in 2030

Impact of CO₂ Plant Gate Sales



| AEO 2011 Case | NG Price in 2030 (2009\$/MMBtu) | NGCC LCOE in 2030 (2009\$/MWh) |
|---------------|---------------------------------|--------------------------------|
| High Shale | \$5.0 | \$61 |
| Reference | \$6.2 | \$76 |
| High Macro | \$6.9 | \$81 |
| Low Shale | \$8.0 | \$86 |

Future Oil Prices May Support CO₂ Prices for EOR that are Equal to or Above CO₂ Capture Costs



From 2008 to 2011, the market price of CO₂ (expressed in \$/MCF) for EOR, quoted at the Denver City, TX "hub", varied between 1.4% and 3.3% of the WTI Crude oil price (expressed in \$/bbl). Restating this correlation, the market price of CO₂ (expressed in \$ per metric tonne) would be 27% to 63% of the crude oil price (\$/bbl). Source: Chaparral Energy "US CO₂ & CO₂ EOR Developments" Panel Discussion at CO₂ Carbon Management Workshop December 06, 2011

Primary Findings

- Advanced NGCC (H-class; 53% HHV) sets the LCOE benchmark for deployment in all scenarios
 - More advanced turbines could be available by 2030 (J-class and beyond) that enable HHV efficiencies of 56-59% for NGCC
- Scenarios without Coal R&D
 - Little or no new coal capacity is added under any scenario except with the highest natural gas price
 - At high natural gas price, 11 GW is deployed from 2020 to 2035 (~10% of all new capacity)
 - CO₂ plant gate sales price of >\$50/tonne would be required in 2030 for NEMS coal with CCUS to deploy in Reference case

Primary Findings

- Scenarios with Coal R&D
 - “2nd-Gen” non-capture coal systems can compete in all scenarios but lowest natural gas price case
 - “Transformational” non-capture coal systems add potential to compete in scenario with the lowest natural gas price
 - “2nd-Gen” coal systems with CO₂ capture can compete in most scenarios with CO₂ plant gate sales prices of \$20-50/tonne
 - \$20-50/tonne within range of historical CO₂:crude oil price ratio
 - “Transformational” coal systems with CO₂ capture:
 - Compete in the higher natural gas price cases even without CO₂ sales
 - Compete in the lower natural gas price cases with CO₂ plant gate sales prices of \$10-\$40/tonne

Conclusions

- 2nd Gen technologies competitive in all but lowest natural gas price scenario
 - For capture systems, CO₂ sales revenue provides a key market incentive
- Transformational R&D provides promising prospect and is a key next step for future competitiveness of coal-based power
 - Competes in nearly all scenarios
 - High risk-high reward
 - Longer development time period

Future Work & Additional Considerations

- Examine deployment (i.e. total GWs built) for 2nd Gen and Transformational coal power systems
 - Detailed modeling of Enhanced Oil Recovery as a revenue source with new NETL CTUS model
- Assess impact of CO₂ tax
 - Expand beyond CO₂-EOR opportunities
 - Transformational coal plants with capture competitive at lower natural gas prices
- Consider coal program technology impacts on advancement of natural gas-fueled systems
 - Advanced turbines
 - SOFC

Questions?