


Driving Innovation • Delivering Results



Introduction to Performing a Techno-Economic Analysis for Power Generation Systems

James C. Fisher II
Strategic Center for Coal
August 11, 2015



Techno-Economic Analysis (TEA)




- A system performance and cost analysis at commercial scale
 - NFTL's Bituminous Baseline
 - Key subset assessing advanced technology
- Cases in a TEA:
 - Reference case: state-of-the-art power plant should be similar to those found in the Baseline studies
 - Advanced case: Novel technology replaces SOA technology in reference plant
- Comparison between cases can provide:
 - Representation and quantification of the benefits of the novel technology.
 - Identification and potential quantification of performance and cost goals for the novel technology.
 - Identification of critical performance and cost parameters, inform R&D prioritization decisions.
- The common metric derived and compared is Cost of Electricity (COE) and net power plant efficiency (HHV & LHV)

Resources for TEA Development



- Baseline studies
 - A Series of documents that provide Baseline's for comparison
 - http://www.netl.doe.gov/research/energy-analysis/energy-baseline-studies
- Quality Guidelines for Energy System Studies (QGESS) Documents
 - A series of documents that provide the details to performing TEAs
 - http://www.netl.doe.gov/research/energy-analysis/quality-guidelines-ggess
 - Also includes a manuscript titled "A proposed methodology for CO₂ capture and storage cost estimates" that outlines a methodology for costing



NETL Baseline



Volume	Title	Description
1	Bituminous Coal and Natural Gas to Electricity, aka Bituminous Baseline	Establishes performance and cost data for SOA fossil energy power systems for integrated gasification combined cycle (IGCC), pulverized coal (PC), and natural gas combined cycle (NGCC) plants with and without capture
3	Low-Rank Coal and Natural Gas to Electricity, aka Low Rank Baseline	Establishes performance and cost data for SOA fossil energy power systems for IGCC, PC, and NGCC plants using low rank coals

These documents provide:


- 1. A starting point for model design basis
- 2. An outline for TEA reporting format (stream tables, auxiliary load tables, etc.)

NETL Quality Guidelines for Energy System Studies (QGESS)



Title	Description						
Detailed Coal Specifications	Provides detailed specifications for seven coals commonly used with detailed production information						
Specifications for Selected Feedstocks	Provides recommended specifications for natural gas and coal that are commonly found in NETL energy system studies.						
Process Modeling Design Parameters	Documents the process modeling assumptions most commonly used in systems analysis studies and the basis for those assumptions. The large number of assumptions required for a systems analysis makes it impractical to document the entire set in each report. This document serves as a comprehensive reference for these assumptions as well as their justification.						
CO ₂ Impurity Design Parameters	Summarizes the impurity limits for CO_2 stream components for use in carbon steel pipelines, enhanced oil recovery (EOR), saline formation sequestration, and co-sequestration of CO_2 and H_2S in saline formations.						
Capital Cost Scaling Methodology	Provides a standard basis for scaling capital costs, with specific emphasis on scaling exponents. This document contains a listing of frequently used pieces of equipment and their corresponding scaling exponent for various plant types, along with their ranges of applicability.						
Cost Estimation Methodology	Summarizes the cost estimation methodology employed by NETL in its assessment of power plant performance.						
Estimating Carbon Dioxide Transport and Storage Costs	Addresses the cost of CO_2 transport and storage (T&S) in a deep saline formation with respect to plant location and region-specific aquifers.						
Fuel Prices for Selected Feedstocks	Provides an estimate of the market price delivered to specific end-use areas of four coals that are commonly used as feedstocks in the energy system studies sponsored by NETL. Also includes the estimated market price for natural gas delivered to three different regions.						





Steps to performing a TEA:

- 1. Form a Technology Analysis Plan
- 2. Create a Performance Model
- 3. Cost Estimating COE
- 4. Reporting Requirements



Technology Analysis Plan (TAP)

TAP



What is a TAP?

- A TAP discusses the approach and methodology required to conduct the TEA.
- Presented to stakeholders <u>prior</u> to starting the TEA
 - Document assumptions
 - Ensure valuable product

 Updated as the TEA is performed changes should be noted in a final document

Case	Baseline						
Case	(Reference)	Case 1	Case 2	Case 2A			
Technology Combinations							
CO ₂ Removal	Selexol	Selexol Novel Capture Tech.					
Enabling Tech.	Std. Te	ech.	Enabled Tech.				
CO ₂ Purification	No			Yes			

Objective: Aspirational Goals OR Current State of Technology

Reference Plant (Baseline studies)

Plant Wide Assumptions

Reason for reference case and planned deviations

Novel Technology
Cases

Novel Technology

Design Basis

High Level BFD's

Case Evaluation Table

Performance Assumptions and Basis

Cost Assumptions and Basis

Proposed Sensitivity Analysis

Technology Integration Plan

Expected Deliverable and Time Frame





Steps to performing a TEA:

- 1. Form a Technology Analysis Plan
- 2. Create a Performance Model
- 3. Cost Estimating COE
- 4. Reporting Requirements



Performance Model Results for Reporting



- Build a performance model
 - Frequently completed in ASPEN, ChemCAD, Thermoflow, etc.
 - When applying novel technology:
 - Hold constant:
 - PC: net power output constant
 - IGCC: hold combustion turbine power output constant
 - Balance of plant equipment NOT affected by research area will be scaled
 - Changes in operating parameters that are different than those in the Baseline Studies must be justified in the TEA document
- Detailed Process Flow Diagram

Performance Modeling Inconsistencies



- Items that are often varied between the reference and novel cases without justification:
 - Condenser pressure
 - Steam cycle conditions (e.g. reheat temperature)
 - Combustion turbine conditions (e.g. turbine inlet temperature)
 - Cooling water temperature
 - ASU performance and oxygen quality
 - Emissions levels
 - Equipment selection
- These variations without justification may require further communication or resubmission of report
- Performance variations <u>NOT</u> related to the Novel technology between the reference and novel cases should thoroughly explained

Performance Model

QGESS documents frequently referenced



QGESS on Process Modeling Design

http://www.netl.doe.gov/File%20Library/Research/Energy%20Analysis/Publications/QGESS ProcessModDesignParameters Public Rev2 20140513.pdf

- Site Conditions
- Steam cycle conditions
- Coal Combustion parameters
- Gasifier Performance

- Syngas processing
- Sulfur processing
- Equations of State
- Cooling water parameters

Feedstock: QGESS on Feedstock Specifications

http://www.netl.doe.gov/File%20Library/research/energy%20analysis/publications/QGESSSec1.pdf

- Natural Gas Composition
- Various Coal Compositions
- Limestone analysis

- Lime analysis
- LHV and HHV

CO₂ Specifications: QGESS on CO₂ Impurities

http://www.netl.doe.gov/File%20Library/Research/Energy%20Analysis/Publications/QGESS CO2Purity Rev3 20130927 1.pdf

- CO₂ delivery pressure
- Individual contaminate concentration limits
- CO₂ minimum concentration

- Specifications for intended use (Saline, EOR, etc.)
- Venting concerns

Performance Model Results for Reporting



Material and Energy Balances

- Consistent with the level of detail found in the Baseline reports Material balance should including
 - All inputs feedstock, catalyst, limestone, etc.
 - All outputs such as stack gas, waste water, solid waste disposal
 - Stream compositions
- Energy Balance should include
 - Thermal energy input from fuel
 - Major auxiliary loads
 - Detailed loads for new technology

Model Results

- Total power from turbines
- New auxiliary loads
- Net Power
- Heat rate, efficiencies, etc.
 - HHV Commonly used for NETL reporting purposes
- Water withdraw, consumption, and discharge
 - If new technology creates impurities in water discharge, this must be documented
- CO₂ impurities
- Air emissions
- Equipment and auxiliary loads NOT affected by novel technology will be scaled appropriately



POWER SUMMARY (Gross Power at Generator Terminals, kWe)						
Gas Turbine Power	464,000					
Sweet Gas Expander Power	7,500					
Steam Turbine Power	276,300					
TOTAL POWER, kWe	747,800					
AUXILIARY LOAD SUMMARY, kWe						
Coal Handling	460					
Coal Milling	2,180					
Sour Water Recycle Slurry Pump	180					
Slag Handling	1,120					
Air Separation Unit Auxiliaries	1,000					
Air Separation Unit Main Air Compressor	53,820					
Oxygen Compressor	10,260					
Nitrogen Compressors	33,340					
Boiler Feedwater Pumps	3,980					
Condensate Pump	230					
Quench Water Pump	520					
Circulating Water Pump	4,200					
Ground Water Pumps	430					
Cooling Tower Fans	2,170					
Scrubber Pumps	220					
Acid Gas Removal	2,590					
Gas Turbine Auxiliaries	1,000					
Steam Turbine Auxiliaries	100					
Claus Plant/TGTU Auxiliaries	250					
Claus Plant TG Recycle Compressor	2,090					
Miscellaneous Balance of Plant ²	3,000					
Transformer Losses	2,610					
TOTAL AUXILIARIES, kWe	125,750					
NET POWER, kWe	622,050					
Net Plant Efficiency, % (HHV)	39.0					
Net Plant Heat Rate, kJ/kWh (Btu/kWh)	9,238 (8,756)					
CONDENSER COOLING DUTY 106 kJ/hr (106 Btu/hr)	1,540 (1,460)					
CONSUMABLES						
As-Received Coal Feed, kg/hr (lb/hr)	211,783 (466,901)					
Thermal Input ¹ , kWt	1,596,320					
Raw Water Withdrawal, m³/min (gpm)	17.9 (4,735)					
Raw Water Consumption, m³/min (gpm)	14.2 (3,755)					

Reporting Novel Equipment



- Novel equipment should be reported at a greater level of detail than found in the Baseline study
- Items to include:
 - Design equations (if developed)
 - Scaling methodology and equations
 - Design basis (kinetics, volumetric throughput, etc.)
 - How was the data for the above collected (TGA, lab scale bubbling bed, etc.)




Steps to performing a TEA:

- 1. Form a Technology Analysis Plan
- 2. Create a Performance Model
- 3. Cost Estimating COE
- 4. Reporting Requirements



Classes of NETL Cost Estimates





Process flow diagrams (PFDs) and piping and instrument diagrams (P&IDs) are the primary documents that define project scope. Association for the Advancement of Cost Engineering International (AACE) Recommended Practice No. 18R-97 describes the AACE cost estimate classification system.

QGESS: Cost Estimation Methodology



Capital Cost Breakdown

- Estimate Class
- Contingency Guidelines
- Owner's Cost Recommendations
- Estimate Scope
- Project Scope

Economic Analysis

- Global Economic Assumptions
- Recommended Financing Structures
- Estimation of COE

the ENERGY lab

QUALITY GUIDELINES

FOR ENERGY SYSTEM STUDIES

Cost Estimation Methodology for NETL Assessments of Power Plant

Performance



NATIONAL ENERGY TECHNOLOGY LABORATORY





Economic Analysis – COE



- Cost of electricity (COE) is the minimum revenue a power plant must receive for the electricity generated to cover cost and stated IRROE
 - Determining the COE involves a complex set of financial assumptions
 - To simplify the COE calculation, a Capital Charge Factor (CCF) has been developed.
 - Simplifies and unifies common financial terms and assumptions
 - Annualizes the capital cost over the life of the plant
- A simplified equation can be utilized to determine the COE to unify assumptions

$$COE = \frac{First\ year}{capital\ charge} + \frac{first\ year}{tixed\ operating} + variable\ operating}{costs} \\ costs \\ annual\ net\ megawatt\ hours} \\ of\ power\ generation$$

$$COE = \frac{CCF \cdot TOC + OC_{FIX} + CF \cdot OC_{VAR}}{CF \cdot MWh}$$

Economic Analysis – COE



$$COE = \frac{CCF \cdot TOC + OC_{FIX} + CF \cdot OC_{VAR}}{CF \cdot MWh}$$

Plant Type	CCF w/ CC	CF
PC	0.124	0.85
IGCC	0.124	0.80
NGCC	0.111	0.85

- The **CCF** takes into account the financial aspects of the plant and represents them in a single factor that can then be used to annualize the capital over the life of the plant. Greater detail can be found in the QGESS documents.
- The MWh parameter is the net power generated (at 100% CF) by the plant.
- The **CF** parameter Capacity Factor, which is assumed to be equal to the availability

Economic Analysis – Operating Costs (RR)




$$COE = \frac{CCF \cdot TOC + \mathbf{OC_{FIX}} + CF \cdot \mathbf{OC_{VAR}}}{CF \cdot MWh}$$

Fixed Operating Costs (OC _{FIX})	Variable Operating Costs (OC _{VAR})				
Annual Operating Labor Cost	Maintenance Material Cost				
Maintenance Labor Cost	**Fuel**				
Administrative & Support Labor	Other Consumables				
Property Taxes and Insurance	Waste Disposal				
Additional OC _{Fix} for new technology	Emission Costs				
	Byproduct Revenues				
	Additional OC _{Var} for new technology				

Operating Costs reported should be similar to those found in the Baseline Reports

Economic Analysis – Capital Costs (RR)



Capital Costs Basis of Novel Equipment



- Capital costs (projected commercial costs) for unique equipment may be calculated by several methods: (RR)
 - Scaled: The equipment can be scaled if analogous equipment is available either in an NETL baseline study or otherwise
 - Bottom-up: Build cost from metal and manufacturing cost estimates
 - If neither a scaled approach or a bottom-up estimate can be produced research goals or bearable costs can be estimated
 - This approach is occasionally used at laboratory scale projects
 - Report what the basis is for cost (experimental scale)
- The methodology, reference equipment, and sources of data should be documented in detail within the TEA
- Balance of plant will be directly used or scaled from the Baseline reports

Contingency Estimation



- Contingency is to cover the known-unknowns or costs that will likely occur based on past experience due to incomplete engineering design
 - Example: early in the design phase, the plant will have high contingencies, future plants should have lower contingencies, but more known costs
- Two types of contingencies are used:
 - Project Contingency: AACE 16R-90 states that project contingency for a "budget-type" estimate (AACE Class 4 or 5) should be 15 percent to 30 percent of the sum of BEC, EPC fees and process contingency.
 - Process Contingency: intended to compensate for uncertainty in cost estimates caused by performance uncertainties associated with the development status of a technology.
- Each "process" in the TEA is assigned a contingency

	Process				
Technology Status	Contingency				
New Concept – limited data	40+%				
Concept with bench scale data	30-70%				
Small Pilot scale data	20-35%				
Full sized modules tested	5-20%				
Commercial process	0-10%				

Contingency Estimation



- Generally, novel technology should have a <u>higher contingency</u> than those in the Baseline studies
- Level of Contingency used should be relative to the development level and engineering completeness of the cost estimate for the novel technology.
- If R&D cost targets, if applicable, contingency might be inclusive
 - When assessing progress towards R&D targets, appropriate contingencies should be included

(From NETL's Baseline)

Process Contingency	
Slurry prep and Feed pump	5%
Gasifier and syngas cooler	15%
Two stage Selexol	20%
Mercury Removal	5%
CO ₂ removal (PC & NGCC)	20%
Combustion Turbine	5%
AHT in IGCC	10%
Instrumentation and controls	5%

Contingency is not:

- To cover poor engineering or poor estimates
- Accuracy
- Cover a scope change
- Account for delays
- Unexpected cost escalation
- Plant performance after startup

Process contingencies range between 2-5% of overall TPC




Economic Analysis – COE



Once COE has been calculated:

- Compared to reference to novel cases(RR)
- Sensitivity analysis can be conducted to guide research or suggest future goals (RR)
 - Examples include:
 - Capital cost,
 - changes in kinetics
 - reduced pressure drop,
 - reduced heat of reaction to reduce regeneration duties
- This information can be utilized to determine if a parameter is critical.





Steps to performing a TEA:

- 1. Form a Technology Analysis Plan
- 2. Create a Performance Model
- 3. Cost Estimating COE
- 4. Reporting Requirements

Reporting Requirements



- TAP share with stakeholders
 - State which Baseline case will be used as a reference case
 - State Design and Cost Assumptions and Basis

Stakeholders

- Updated TAP
- Performance Modeling
 - Block Flow diagram
 - Detailed Simulation Model
 - Material and Energy Balance
- Cost Estimating COE and Cost of Carbon Captured
 - Detailed COE calculations
 - Detailed TOC cost estimates
 - Sensitivity Studies
 - Cost of CO₂ Captured

Reporting Requirements



• The TEA report should:

- Provide reasoning for new equipment design basis experimental data is preferred
- Have a level a detail equal or greater than that outlined in the Bituminous Baseline (particularly for novel equipment)
- Provide a basis for both design and costing of novel equipment

Remember to:

- Choose a Baseline study that can easily use the new technology
- Justify any variations from the Baseline outside of the new technology
- Provide enough detail to reproduce stated number
- Once complete, use the information to guide research





For More Information, Contact NETL the ENERGY lab Delivering Yesterday and Preparing for Tomorrow













Contact Information



James C. Fisher II

James.Fisher@netl.doe.gov

National Energy Technology Laboratory
Office of Program Performance and Benefits
3610 Collins Ferry Rd. Morgantown WV 26507

ADDITIONAL INFORMATION

Economic Analysis – COE



$$COE = \frac{CCF \cdot TOC + OC_{FIX} + CF \cdot OC_{VAR}}{CF \cdot MWh}$$

Where (all items below are to reported (RR)):

- COE = Revenue received by the generator during the power plant's first year of operation
- CCF = Capital charge factor
- TOC = Total overnight capital
- OC_{FIX} = Sum of all fixed annual operating costs
- OC_{VAR} = Sum of all variable annual operating costs at 100 percent capacity
- CF = Plant capacity factor
- MWh = Annual <u>net</u> megawatt-hours

Contingency Estimation





	Case:	B4B-	- E-Gas IGCC	w/ CO ₂				Es	timate Type: (Conceptual	
	Plant Size (MW,net):	514						Cost Ba	se (\$x1,000):		Jun 2011
Item	Description	Equipment	Material	Labo	r	Bare Erected	Eng'g CM	Conting	gencies	Total Plan	t Cost
No.		Cost	Cost	Direct	Indirect	Cost	H.O.& Fee	Process	Project	\$	\$/kW
	1					Coal & Sorbent	Handling				
1.1	Coal Receive & Unload	\$4,536	\$0	\$2,186	\$0	\$6,722	\$672	\$0	\$1,479	\$8,873	\$17
1.2	Coal Stackout & Reclaim	\$5,862	\$0	\$1,402	\$0	\$7,263	\$726	\$0	\$1,598	\$9,587	\$19
1.3	Coal Conveyors & Yd Crush	\$5,450	\$0	\$1,387	\$0	\$6,836	\$684	\$0	\$1,504	\$9,024	\$18
1.4	Other Coal Handling	\$1,426	\$0	\$321	\$0	\$1,747	\$175	\$0	\$384	\$2,306	\$4 \$28
1.9	Coal & Sorbent Hnd. Foundations	\$0	\$3,029	\$7,916	\$0	\$10,945	\$1,095	\$0	\$2,408	\$14,447	\$28
	Subtotal	\$17,273	\$3,029	\$13,211	\$0	\$33,513	\$3,351	\$0	\$7,373	\$44,238	\$86
	4					Gasifier & Acc	essories				
4.1	Syngas Cooler Gasifier System	\$137,262	\$0	\$76,506	\$0	\$213,769	\$21,377	\$29,564	\$40,623	\$305,333	\$594
4.2	Syngas Cooler	w/4.1	\$0	w/ 4.1	\$0	\$0	\$0	\$0	\$0	\$0	\$0
4.3	ASU & Oxidant Compression	\$222,841	\$0	w/equip.	\$0	\$222,841	\$22,284	\$0	\$24,513	\$269,638	\$525
4.4	LT Heat Recovery & FG Saturation	\$28,817	\$0	\$10,949	\$0	\$39,766	\$3,977	\$0	\$8,749	\$52,492	\$102
4.5	Misc. Gasification Equipment	w/4.1&4.2	\$0	w/4.1&4.2	\$0	\$0	\$0	\$0	\$0	\$0	\$0
4.6	Flare Stack System	\$0	\$1,981	\$801	\$0	\$2,782	\$278	\$0	\$612	\$3,672	\$7
4.8	Major Component Rigging	w/4.1&4.2	\$0	w/4.1&4.2	\$0	\$0	\$0	\$0	\$0	\$0	\$0
4.9	Gasification Foundations	\$0	\$9,765	\$5,824	\$0	\$15,589	\$1,559	\$0	\$4,287	\$21,434	\$42
	Subtotal	\$388,921	\$11,746	\$94,080	\$0	\$494,747	\$49,475	\$29,564	\$78,784	\$652,569	\$1,271
	5A					Gas Cleanup &					
5A.1	Double Stage Selexol	\$162,818	\$0	w/equip.	\$0	\$162,818	\$16,282	\$32,564	\$42,333	\$253,996	\$495
5A.2	Elemental Sulfur Plant	\$12,406	\$2,418	\$15,897	\$0	\$30,721	\$3,072	\$0	\$6,759	\$40,552	\$79
5A.3	Mercury Removal	\$1,867	\$0	\$1,411	\$0	\$3,278	\$328	\$164	\$ 754	\$4,524	\$9
5A.4	Shift Reactors	\$8,605	\$0	\$3,440	\$0	\$12,044	\$1,204	\$0	\$2,650	\$15,898	\$31
5A.5	Particulate Removal	w/4.1	\$0	w/4.1	\$0	\$0	\$0		\$0	\$0	\$0 \$3
5A.6	Blowback Gas Systems	\$657	\$369	\$206	\$0	\$1,232	\$123	\$0	\$27 <u>1</u>	\$1,626	\$3
5A.7	Fuel Gas Piping	\$0	\$926	\$606	\$0	\$1,532	\$153	\$0	\$337	\$2,022	\$4
5A.9	HGCU Foundations	\$0	\$838	\$565	\$0	\$1,403	\$140	\$0	\$463	\$2,007	\$4
	Subtotal	\$186,353	\$4,551	\$22,125	\$0	\$213,029	\$21,303	\$32,727	\$53,566	\$320,626	\$624

Economic Analysis – Cost of CO₂ Captured



$$Cost \ of \ CO_2 \ Captured = \frac{(COE_{With \ CC} - \ COE_{Without \ CC})}{CO_2 \ Captured}$$

Where:

- COE_{with CC}: The plant modeled with novel technology
- COE_{Without CC}: Reference non-capture plant
 - Generally Case 11 in the Bituminous Baseline Rev. 2
- CO₂ captured equals the rate of CO₂ captured, tonne/MWh
- it does <u>NOT</u> include the cost to transport and store (T&S) CO₂

Cost of CO₂ Transport and Storage (T&S)




Reported separately from plant capital and O&M costs

- TS&M capital and O&M costs levelized using same methodology as inside-the-gate costs
- Added on as O&M-type costs maintaining the perspective of the plant
- Pipeline transport of 50 miles
- Storage costs
 - Site screening and evaluation
 - Injection wells and equipment
 - O&M costs
 - Pore volume acquisition costs
- Monitoring costs
 - Liability fund
 - Monitoring costs



Estimating Carbon Dioxide Transport and Storage Costs



NATIONAL ENERGY TECHNOLOGY LABORATORY



Capital Costs – Research Goals and Bearable Costs



- Research goals Intended targets for the costs of technology under development
 - Detailed descriptions as to the reason for the selection of the targets should be provided
 - Available data that supports the goal selection should be provided
- Bearable costs The costs at which the technology meets a specific goal
 - If a goal has been provided (e.g. < 30 percent increase in COE), the bearable cost to meet the goal can be calculated