





World Bank Pre-Feasibility Study for Establishing a Carbon Capture Pilot Plant in Mexico Contract 7175527

**2016 NETL CO<sub>2</sub> Capture Technology Project Review Meeting** 

Haoren Lu, Robert Chu and Gerald Choi - Nexant

**Bill Elliott - Bechtel** 

## **Acknowledgements**

The project was conducted under funding from The World Bank and in collaboration with several Mexican government organizations, of which we would like to acknowledge the support and contributions of the following –

The World Bank – Dr. Natalia Kulichenko, Dr. Frank Mourits, Dr. Moises Davila and Mr. Guillermo Hernandez Gonzalez; Professor Jon Gibbins of UKCCS as a Technical Advisor to the World Bank team

SENER (Department of Energy of Mexico) – Ms. Jazmin Mota Nieto

CFE (Comision Federal de Electricidad) – Mr. Agustin Herrera

IIE (Electrical Research Institute) – Mr. Jose Miguel Gonzalez

## Disclaimer

This study report was prepared by Nexant under a contract with the World Bank. Neither Nexant nor any of its employees or team members make any warranty, express or implied, or assume any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represent that its use would not infringe upon privately own rights. Reference herein to any specific commercial process, product or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by any entity identified herein.

The Technology Evaluation Study, was performed, in part, based on information that was provided to Nexant under the terms of Non-Disclosure Agreements with several technology licensors. No third-party proprietary information and/or data are directly revealed in the report. In performing the study, Nexant had to adjust some of the data and fill in any missing information, thus rendering the study results and conclusions as only Nexant's interpretation of the technologies.

While it is believed that the information contained in this report will be reliable under the conditions and subject to the limitations set forth herein, Nexant cannot guarantee the accuracy thereof. The views and opinions expressed herein and, in particular, in the documentation that constitute this study are specifically those of the authors of this study. The use of this report or any information contained therein shall be at the user's own risk.

## **Project Background**

As part of the overall World Bank funded effort to develop capacity for carbon capture, utilization and storage technology (CCUS) in Mexico, the Nexant Team was tasked to perform a feasibility study to:

- Task 1: Evaluate and recommend the <u>most appropriate commercially- available post-</u> <u>combustion</u> CO<sub>2</sub> capture technology for NGCC power plants in Mexico, and
- Task 2: Develop a conceptual design for a CO<sub>2</sub> capture pilot plant to be located at the 250 MW Poza Rica generation station in the state of Veracruz

The conceptual design would lead to a next phase (Phase II) of the project to develop a Front End Engineering Design (FEED) package for the capture pilot plant.

Current presentation will only cover the Task 1 work scope and results. A copy of the entire report can be found on the SENER website at -

http://www.gob.mx/sener/en/documentos/pre-feasibility-study-for-establishing-a-carboncapture-pilot-plant-in-mexico?idiom=en



## **Technology Roadmap for CCUS in Power Plants**



2016 NETL CO<sub>2</sub> Capture Technology Project Review



## Task 1 – Approach and Activities Performed

## **Site Selection:**

- **250MW Poza Rica NGCC Generating Station, located in State of Veracruz**
- **Preliminary site and plant data provided by CFE**
- **Obtain data from CO<sub>2</sub> Capture Technology Providers:**
- **Study will only focus on post-combustion CO<sub>2</sub> capture (PCC)** 
  - **o** World Bank/SENER's interest in near-term technology deployment
  - Advanced amine-based absorption process for PCC nearest to commercialization
- Prepared and issued "Request for Information" (RFI) to ten (10) technology developers/vendors; Six (6) agreed to participate in the study.



## Task 1 – Approach and Activities Performed

## **Site Selection:**

- **250MW Poza Rica NGCC Generating Station, located in State of Veracruz**
- **Preliminary site and plant data provided by CFE**

**Obtain data from CO<sub>2</sub> Capture Technology Providers:** 

Participating PCC Technologies

- Alstom Advanced Amine Process
- BASF/Linde
- Fluor
- HTC
- MHI
- Shell Cansolv

#### **() Nexant**

## Task 1 – Approach and Activities Performed (Cont'd)

## **Design Basis:**

- **Established based on Poza Rica NGCC battery limit data**
- Consistent interface information is provided to participating PCC technology vendors
- **35% CO<sub>2</sub> capture rate**

#### **Pre-PCC Power Plant Simulation:**

Developed Thermoflex model of existing Poza Rica NGCC

#### **Reference PCC Design:**

- Established a *full-size* generic amine (30 wt% MEA) PCC plant design for Poza Rica NGCC
  - **o** Estimated cost and overall power plant performance
  - Serve as the reference CO<sub>2</sub> capture case for comparison with proprietary PCC technologies

#### **()** Nexant

## Task 1 – Approach and Activities Performed (Cont'd)

Integrated NGCC/Full-Scale Advanced Amine PCC Technology

Cases:

- Used PCC technology providers' RFI questionnaire responses as inputs into model
  - Recovered CO<sub>2</sub> conditions
  - **o** Steam conditions and consumption rates
  - PCC power consumption
  - Capital costs
- Evaluated cost and performance for the six cases among one another and with the Reference PCC design
- Performed Cost of Electricity (COE) calculation consistent with DOE-NETL methodology



## **Poza Rica NGCC/PCC Division of Responsibilities**



2016 NETL CO<sub>2</sub> Capture Technology Project Review

#### NGCC Plant with Full-Scale PCC – Pre- & Post-PCC Retrofit HRSG/Steam Turbine Configuration



#### **() Nexant**

#### NGCC Plant with Full-Scale PCC – Pre- & Post-PCC Retrofit HRSG/Steam Turbine Configuration



#### NGCC Plant with Full-Scale PCC -

#### **()** Nexant

#### **Pre- & Post-PCC Cooling Tower Arrangement**



# Poza Rica NGCC Reference (30 wt% MEA) CO<sub>2</sub> Capture Plant Flow Diagram



#### **ONEXANT**

## CO<sub>2</sub> Compression & Dehydration Plant Flow Diagram

![](_page_14_Figure_2.jpeg)

## Aerial View of Conceptual Poza Rica NGCC w/ Generic 30 wt Mexant MEA PCC

![](_page_15_Picture_1.jpeg)

## Aerial View of Conceptual Poza Rica NGCC w/ Generic 30 wt Mexant MEA PCC

Available Plot Space

![](_page_16_Picture_2.jpeg)

## Aerial View of Conceptual Poza Rica NGCC w/ Generic 30 wt Nexant

![](_page_17_Picture_1.jpeg)

## Task 1 Findings: Full-Scale Poza Rica NGCC PCC Retrofit Performance Evaluation (All Licensors @ 85% CO<sub>2</sub> Capture)

See Note 1	No PCC	Generic 30% MEA PCC	Alstom	BASE	Fluor [See Note 2]	HTC Purenergy	MH	<u>Shell</u> CanSolv
NGCC CO2 Emissions, STPD	2,532	380	362	379	379	381	381	377
Recovered CO2 Product, STPD	0	2152	2170	2153	2153	2151	2151	2155
% CO2 Capture	0	85%	86%	85%	85%	85%	85%	85%
Power Balance, MW Generation			All sho	w perfor	mance ir	nproverr	nent over	MEA
Gas Turbine Gross Output	166.6	166.6	166.6	166.6	166.6	166.6	166.6	166.6
Steam Turbine Gross Output	82.5	39.6	49.6	49.4	48.0	46.7	49.2	49.4
Back Pressure Turbine	0	21.6	16.6	16.7	17.4	18.1	16.8	16.7
Total Gross Output	249.1	227.8	232.8	232.7	232.0	231.3	232.6	232.7
Auxiliary Consumption Existing NGCC Plant Parasitic Loads Flue Gas Blower PCC + CO2 Compression + Plant Mods Total New PCC Parasitic Load	7.2 0 <u>0</u> 7.2	7.2 8.8 <u>16.1</u> 32.0	7.2 8.8 <u>17.3</u> 33.3	7.2 8.8 <u>14.1</u> 30.1	7.2 8.8 <u>16.0</u> 32.0	7.2 8.8 <u>14.0</u> 29.9	7.2 8.8 <u>15.7</u> 31.7	7.2 8.8 <u>14.2</u> 30.1
Net Power Plant Export, MW	241.9	195.8	199.5	202.6	200.0	201.4	200.9	202.5
△ Plant Export, MW		-46.1	-42.4	-39.3	-41.9	-40.5	-41.0	-39.3
% Plant Export Reduction		-19.1%	-17.5%	-16.2%	-17.3%	-16.7%	-16.9%	-16.3%
Net Plant Heat Rate, Btu/kWh Net Plant Efficiency, % LHV	6,584 51.8	8,134 42.0	7,984 42.7	7,860 43.4	7,962 42.9	7,907 43.2	7,926 43.1	7,862 43.4
Incremental Water Import, gpm	0	406	808	454	455	351	676	417

Note 1 - Values presented here are Nexant's interpretation of the data provided by the PCC licensors.

Note 2 - Fluor provided information for CO<sub>2</sub> capture rate of 90%. Nexant adjusted Fluor's performance to 85% to be consistent with the design basis

#### **() Nexant**

## Task 1 Findings: Full-Scale Poza Rica NGCC PCC Retrofit Economic Evaluation (All Licensors @ 85% CO<sub>2</sub> Capture)

	Estimated Post-Combustion CO2 Capture Costs										
Incremental Costs to Poza Rica NGCC without CO2 Capture [Note 1]	Generic 30% MEA PCC Design	Alstom	BASF / Linde	Fluor	HTC Purenergy	МНІ	Shell CanSolv				
CAPEX Estimate, \$MM US USGC											
PCC Plant + CO2 Compression											
[Note 2]	181.4	234.7	187.7	174.0	194.5	178.8	194.9				
Flue Gas Blower	14.2	14.2	14.2	14.2	14.2	14.2	14.2				
Poza Rica Plant Modifications	32.8	32.4	30.4	31.4	29.1	30.9	30.4				
TOTAL	228.4	281.4	232.3	219.7	237.8	223.9	239.5				
O&M Estimate, \$MM US											
Variable Costs [Note 3]	7.6	7.6	7.6	7.5	7.3	7.5	7.5				
Fixed Costs	11.0	13.3	11.1	10.9	11.4	10.8	11.6				
TOTAL	18.5	21.0	18.7	18.4	18.7	18.3	19.1				
Estimated Cost of Electricity (COE),											
\$/MWh [Note 4]	37.6	41.4	35.3	35.0	36.2	35.1	36.0				

Note 1 - Values presented here are Nexant's interpretation of the data provided by the PCC licensors.

Note 2 - All except Nexant 'Generic 30% MEA Design' are based on vendor-provided data, which are considered proprietary.

Note 3 - Major component is the amine replacement costs, which are considered proprietary.

Note 4 - Incremental to estimated existing Poza Rica NGCC COE of \$40.69/MWhr

## Task 1 Findings: Full-Scale Poza Rica NGCC PCC Retrofit COEs for 85% CO<sub>2</sub> Capture

![](_page_20_Figure_1.jpeg)

2016 NETL CO<sub>2</sub> Capture Technology Project Review **()** Nexant

## Task 1 – Conclusions

- Retrofitting Poza Rica with PCC can incur significant thermal penalty to the plant
  - ~19% reduction in the net MW plant output based on current state-of-the-art 30% MEA amine capture technology
- □ All six proprietary PCC technologies evaluated show slight improvement in performance, 16%-18% reduction in power export vs 19% for MEA
- Estimated incremental capital cost for retrofitting Poza Rica for CO<sub>2</sub> capture is between \$224 to \$282MM US -
  - Estimated CAPEX based on the study design of a 30% MEA amine capture is about \$228MM of which breakdown as follows:
    - Amine CO<sub>2</sub> capture plant 62%
    - CO<sub>2</sub> compression plant 18%
    - Flue gas blower 6%
    - NGCC plant modification 14%
- Estimated incremental O&M cost is between \$18.3 to \$21.0MM per year.

## Task 1 – Conclusions (Cont')

- Within the accuracy of the data provided, the performance of all six technologies are reasonable and comparable; no one technology is 'head and shoulders' above the rest
- Pilot plant testing would be needed to independently validate the claimed performances, in order to make sound choice of technology for large-scale commercial deployment
- Decided on an MEA-based pilot plant with design flexibility
  - **O** Discussed in Task 2 of the World Bank report

#### **ONEXANT**

## **Full Report**

#### http://www.gob.mx/sener/en/documentos/pre-feasibility-study-for-establishing-acarbon-capture-pilot-plant-in-mexico?idiom=en

Report No: AUS8579 - 2

United Mexican States

MX TF Carbon Capture, Utilization and Storage Development in Mexico

Pre-Feasibility Study for Establishing a Carbon Capture Pilot Plant in Mexico

May 18, 2016

GEE04 LATIN AMERICA AND CARIBBEAN

![](_page_23_Picture_9.jpeg)

![](_page_24_Picture_0.jpeg)

## Thank you! Questions?