



2018 NETL CO<sub>2</sub> Capture Technology Project Review Meeting

## Engineering-scale Demonstration of Mixed-Salt Process (MSP) for CO<sub>2</sub> Capture (FE0031588)



Indira S. Jayaweera

Sr. Staff Scientist and Sr. Program Manager  
Advanced Technology and Systems Division

SRI International



August 13-17, 2018 • Omni William Penn Hotel • Pittsburgh, Pennsylvania



# Technology Background

# Mixed-salt Process (MSP)

## How it works:

Selected composition of potassium carbonate and ammonium salts

- Overall heat of reaction 35 to 60 kJ/mol (tunable)

Absorber operation at 20° - 40°C at 1 atm with 30-40 wt.% mixture of salts

Regenerator operation at 120° - 160°C at 10-20 atm

- Produces high-pressure CO<sub>2</sub> stream


K<sub>2</sub>CO<sub>3</sub>-NH<sub>3</sub>-CO<sub>2</sub>-H<sub>2</sub>O system

**High CO<sub>2</sub> cycling capacity**

## Process Highlights:

- Reduced ammonia emissions
- Enhanced efficiency
- Reduced reboiler duty
- Reduced CO<sub>2</sub> compression energy

**A SIGNIFICANT PARASITIC POWER REDUCTION COMPARED TO MEA !**



# MSP Summary and Benefits

## Process Summary

- Uses inexpensive, industrially available material (potassium and ammonium salts)
- No chemical degradation
- Has the potential for easy permitting in many localities
- Uses known process engineering
- Accelerated development possible



## Demonstrated Benefits (by testing and/or modeling)

- Enhanced CO<sub>2</sub> capture efficiency
- High CO<sub>2</sub>-loading capacity
- High-pressure release of CO<sub>2</sub> (10-20 bar)
- Reduced reboiler energy consumption ( ~ 2 MJ/kg-CO<sub>2</sub>)
- Reduced auxiliary electricity loads



# **Recently Completed Project (FE0012959)**


# Large Bench-scale Mixed-salt System at SRI

0.25 t-CO<sub>2</sub>/ day capacity - operational since January 2016



20-ft

Absorbers



A : Rich solution inlet locations.

B : Discharge location for high NH<sub>3</sub>/K ratio solution

C : Discharge location for low NH<sub>3</sub>/K ratio solution

D : Heat exchangers (Cold rich ↔ Hot lean)


Regenerator pictures from different angles

System built under FE0012959


Continuous smooth operation of the integrated system over 1.5 years of operation

# Data from Integrated System Testing in 2016


## Excellent Performance



Observed 90% capture efficiency and regeneration with cyclic loading of ~0.7 mole of CO<sub>2</sub>/mole of ammonia at 10 bar.



Alkalinity of rich and lean solutions circulating in the integrated system



Data showing relationship of the measured pH of rich and lean solutions from Absorber 1

Absorber: 20-35°C

Regenerator stage 1: 140°C

Regenerator stage 2: 160°C

L/G = 2 to 6 (kg/kg)

Solvent composition: 5 to 8 m

Results from FE0012959

# Techno-Economic Data

## Comparison Between Mixed-salt Technology and DOE Baseline Case

| Case name  | Case B12A w/o capture<br>(report NETL 2015) | Case B12B Cansolv<br>(report NETL 2015) | Case Mixed-Salt       |
|--|---|---|-----------------------|
| Coal feed rate [kg/hr]   | 179193                                      | 224791                                  | 220576                |
| CO2 removal  | n/a   | Cansolv                                 | Mixed-Salt Technology |
| CO2 purification   | n/a   | no                                      | no                    |
| Sulfur removal   | FGD   | FGD                                     | FGD                   |
| <b>Performance and Economic Summary</b>                                |   |   |                       |
| CO2 capture  | n/a   | 90.0%                                   | 90.0%                 |
| CO2 purity   | n/a   | >99%                                    | >99%                  |
| H2 recovery  | n/a   | n/a                                     | n/a                   |
| HHV plant efficiency   | 40.7%                                       | 32.5%                                   | 32.7%                 |
| COE w/o T&S [\$/MWh]   | 82.3  | 133.2                                   | 117.5                 |
| COE w/ T&S [\$/MWh]  | 82.3  | 142.8                                   | 127.0                 |
| Increase in COE comparing the case w/o capture with the case w/ CC&T&S | 0%  | 88%                                     | 67%                   |
| Reference money value  | Costs in \$ June 2011                       | Costs in \$ June 2011                   | Costs in \$ June 2011 |

Reference :NETL, «Cost and Performance Baseline for Fossil Energy Plants Volume 1a: Bituminous Coal (PC) and Natural Gas to Electricity Revision 3,» pp. 137-166, 2015

### Process Modeling: OLI, IHI, and POLIMI

Cyclic loading: 0.18 to 0.58; Reboiler duty: 2.0 (OLI); 2.3 MJ/kg-CO<sub>2</sub> (POLIMI); 2.1 to 2.3 MJ/kg-CO<sub>2</sub> (IHI-measured)

Ammonia emission < 10 ppm

Cost of CO<sub>2</sub> Capture at <\$40/t CO<sub>2</sub>; Cost Of CO<sub>2</sub> avoided (excluding T&S) ~ \$51/t CO<sub>2</sub>

Cost analysis was performed by POLIMI





# **Current Project (FE0031588)**

# Project Budget, Team, and Work Organization

DE-FE0031588

Two Budget Period s (BP1 and BP2)

BP1: 7/12/2018 to 10/31/2018


BP1 DOE Funding: \$566,135

TCM: In-kind cost-share

**Project Manager:** Mr. Andrew Jones, NETL

**Prime Contractor:** SRI International


**Project Team:** US and International Partners



## Work Organization

- SRI International
  - Technology provider
- Technology Center Mongstad (TCM), Norway
  - Host site and cost-share partner
- OLI Systems, USA
  - Process modeling (energy and mass balance)
- Aqueous Systems Aps, Denmark
  - Thermodynamic modeling
- POLIMI, Italy
  - Techno-economic analysis

# BP1 Work Update



- Workshop at TCM on June 28, 29: Discussions on the program details, TCM requirements, TCM-CAP system P&IDs and modification requirements, and current status of the TCM-CAP system.
- TCM-CAP system inspection meeting at TCM (August 28, 29): Project progress evaluation and information exchange.

FE0031588

# BP2 Tasks

Task 1. Project Management

Task 2. CAP System Re-commissioning and Modification

Task 3. Dynamic Testing of MSP

Task 4. Steady-state Testing of MSP

Task 5. Process Economics, Technology Gap Analysis, and Technology Maturation Plan

Task 6. Environmental, Health & Safety Assessment

Task 7. Pilot Shutdown and Project Closure

The planned system inspection and modification period is about 12 - 18 months and the planned technology testing period is about 9 -12 months. BP2 Tasks will be finalized after completing the BP1 work.


FE0031588

# Technology Maturation: MSP Developments

*Small bench to mini pilot to large pilot*

## Ammonia technology development started at SRI in 2004

Chilled Ammonia Process (CAP)



CAP Validation at TCM

Step change

Mixed-salt Process (MSP)



MSP Testing in TCM-CAP System (DOE-FE0031588)


Step change

Transformational Technology Development

Next Generation MSP

(DOE-FE0012959)

# Technology Maturation: Testing MSP at TCM and Beyond



*SRI has the patent coverage for MSP in US, Japan and Europe*

# Acknowledgements

## NETL (DOE)

- Andrew Jones, Ted McMahon, Steven Mascaro, Jose Figueroa, Lynn Bricket, John Litynski and other NETL staff members

## SRI Team

- Indira Jayaweera, Palitha Jayaweera, Elisabeth Perea, Regina Elmore, William Olsen, Marcy Berding, Chris Lantman, and Barbara Haydon

## Host Site

- TCM (Bjørn-Erik Haugan, Jorunn Brigsten, Thilak Narayanadoss, Gerard Lombardo, and Kjetil Hantveit)

## Other Collaborators and Contributors

- OLI Systems (Prodip Kondu and Andre Anderko)
- POLIMI (Gianluca Valenti and others)
- Stanford University (Adam Brant and Charles Kang)
- Aqueous (Kaj Thomsen)
- BHGE (Gianluca Difederico, and Olaf Stallmann)
- IHI Corporation (Mr. Shiko Nakamura, Mr. Okuno Shinya, Mr. Yasuro Yamanaka, Dr. Kubota Nabuhiko, and others)

# Thank You

Contact:

Dr. Indira Jayaweera

[indira.jayaweera@sri.com](mailto:indira.jayaweera@sri.com)

1-650-859-4042

**Headquarters**

333 Ravenswood Avenue  
Menlo Park, CA 94025  
+1.650.859.2000

Additional U.S. and  
international locations

**[www.sri.com](http://www.sri.com)**

## Disclaimer

This presentation includes an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.