

Characterizing Impacts of Dry Coal Feeding in High Pressure Oxy-Coal Combustion Systems

Department of Energy under Cooperative Agreement No. DE-FE0029162



2018 NETL CO₂ Capture Technology Project Review Meeting

Omni William Penn Hotel; Pittsburgh, PA

August 14, 2018

Motivation

Relevance

- Fuel feeding and firing system flexibility are challenges for high pressure coal and biomass fed combustion and gasification equipment
 - Slurry-fed systems often have atomization and burnout problems exacerbated at high pressure
 - Slurry atomization processes may be difficult to scale up
- Dry feeding has the potential to yield efficiency gains, provide better control over flame aerodynamics, improve flexibility and facilitate scale up

Objective

Develop data and validate mechanisms describing heat transfer, ash deposition and corrosion in a high temperature, high pressure oxy-coal combustion system with dry coal feeding



Technical Approach

1. Design, construction and installation of a pressurized feeding system for dry pulverized coal in an entrained flow pressurized combustor
2. CFD-based guidance of burner design and pilot-scale operation of pressurized oxy-coal combustion with a dry feed system
3. Detailed measurements of heat flux and flame and material temperatures at high temperatures while firing at 300 kW and 17 bar
4. Ash aerosol measurements at 17 bar pressure experimental conditions to determine slagging and fouling propensity of the ash, and its deposition rates as a function of high pressure
5. Characterize corrosion propensity under high temperature and high pressure conditions using real time corrosion sensors
6. Refinement of CFD modeling tools to ensure accurate prediction of the impacts of high temperature and high pressure oxy-coal combustion on heat flux, ash deposition and corrosion in a commercial boiler implementation



Program Overview


Enabling Technologies for Advanced Oxy-Coal Combustion Systems

Characterizing Impacts of Dry Coal Feeding in
High Pressure Oxy-Coal Combustion Systems
(DFHP)

October 2016 – September 2019



Program Elements








Design, construct and install pressurized dry feed system

Design, construct and install pressurized burner system

Conduct experiments at University of Utah's Entrained Flow Pressurized Reactor (EFPR)

Validate simulations of high pressure oxy-coal combustion






Economic analysis and full scale boiler scoping




Program Organization



- Program management
- Pressurized oxy-coal burner design
- CFD modeling of pilot-scale tests
- Development/refinement and validation of key mechanisms in CFD sub-models
- Conceptual design and simulation of multi-burner furnace at pressurized conditions
- Full scale boiler scoping and economic analysis

				
<ul style="list-style-type: none"> • Responsible for installation and certification of the dry feeding system. • Operation of 300 kW Entrained Flow Pressurized Reactor (EFPR) • Gathering experimental data 	<ul style="list-style-type: none"> • Design of dry feeding system, and construction of critical (internal) components • Consultation and advisory during startup and operation of EFPR 	<ul style="list-style-type: none"> • Direction in construction of high pressure corrosion monitor design • Guidance of corrosion assessment of pressurized oxy-fuel combustion 	<ul style="list-style-type: none"> • Supply power industry perspective and technical support • Design review and feedback on economic analysis and full scale boiler scoping 	<ul style="list-style-type: none"> • Provide O₂ and CO₂ for multi-scale testing • Provide guidance on oxy-combustion testing • Serve as informal advisor



Timeline and Budget



Total Budget
\$1,537,220

Total Federal
\$1,229,720

DFHP Budget




REI Federal Share
SEU Federal Share
EPRI Cost Share

U of U Federal Share
SEU Cost Share
CM Federal Share

U of U Cost Share
EPRI Federal Share
CM Cost Share



Schedule of Tasks: Q3 2018-Q2 2019




■ Task In Progress
 ■ Task Complete
 ■ Task Overdue
 ◆ Milestone




300 kW Entrained Flow Pressurized Reactor (EFPR)

- Converted from entrained flow gasifier
- 300 kW (rated) pilot scale
- Max pressure 450 psi
- Coal-water slurry or dry feeding with pure O₂
- Down-fired, self-sustained and no external heating





CFD Tools: GLACIER

- REI's in-house CFD software
- Developed specifically for application to solid fuel fired furnaces and boilers
- 3D, steady-state, turbulent flows
- Coupling between turbulent fluid mechanics, radiative and convective heat transfer, homogeneous and heterogeneous reactions
- Statistical description of particles including particle dispersion
- Pollutant formation kinetics for NO_x , SO_x , CO, Hg and fine particles
- Continually evolving including recent developments for atmospheric pressure and pressurized oxy-coal applications







Pulverized Coal Feeder Design

Integration with EFPR




Pulverized Coal Feeder Design


Final design of fluidized feeder body




Pulverized Coal Feeder Design

Distributor cup assembly







Pulverized Coal Feeder Design & Construction




**Entrained flow
pressurized reactor**




**Dry feed system
pressure vessel**



EFPR Dry Pulverized Coal Burner Design Concepts




Design 1



Design 2

CFD Model Predictions


Gas Temperature Profiles




CFD Model Predictions

Gas Temperature Profiles

Gas Temperature (°F)





Peak = 5088 °F Peak = 4605 °F



Controlling the Rate of Heat Release


Tracking CO_2 Formation in the Furnace

CO_2 Concentration (%)






Design 1

Design 2




CFD Model Predictions


Radiant Flux Distribution



High Pressure Aerosol Sampling System





System Schematic



BLPI: 0.0324 μm – 15.7 μm
 SMPS: 0.0143 μm – 0.6732 μm
 APS: 0.532 μm – 20 μm



Effect of Pressure on Ash Aerosol Particle Size Distributions



Summary

- Design of dry feeding system for integration with EFPR completed and in fabrication
- CFD-guided design of burner for the EFPR with dry feeding has been completed and drawings are being finalized
- Testing of equipment for advanced aerosol characterization in EFPR completed
- Design of corrosion monitoring equipment for use in the EFPR underway
- Integration of dry feeder with high pressure entrained flow reactor and subsequent shakedown testing scheduled for October



Acknowledgment

This material is based upon work supported by the Department of Energy under Cooperative Agreement No. DE-FE0029162.

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.



Disclaimer

Disclaimer: This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

