

# Development and Demonstration of Waste Heat Integration with Solvent Process for More Efficient CO<sub>2</sub> Removal from Coal-Fired Flue Gas

DE-FE0007525

**2017 NETL CO<sub>2</sub> Capture Technology  
Project Review Meeting**

**August 22<sup>nd</sup>, 2017**



1. Project Overview
2. Background Technologies
  - MHI CO<sub>2</sub> Capture Technology “KM-CDR Process<sup>®</sup>”
  - MHPS High Efficiency System “HES”
3. 25-MW Pilot Demonstration at Plant Barry
4. Test Results
5. Techno-Economic Analysis Results
6. Summary

# 1. Project Overview



Southern  
Company

---

**Project Management**  
**Funding**  
**Host Site**

**AECOM**

---

**Reporting**  
**Detailed Design**  
**Flue Gas Measurement**



**Technology Provider**  
**Reporting**



**Project Management**  
**Funding**



Southern  
Company

---

**Nick Irvin (P.I.)**  
**Joe Kowalczyk**  
**Jerrad Thomas**

**AECOM**

---

**Katherine Dombrowski**  
**Max Bernau**  
**Jack Cline**




**Tim Thomas**  
**Shintaro Honjo**



**Bruce Lani**

# Total Project Budget (\$MM)



- **The heat integration was chosen for its ability to provide:**
  - ✓ Increased plant efficiency,
  - ✓ Mitigation of parasitic losses from a CO<sub>2</sub> capture system (CCS),
  - ✓ Reduced water consumption and cooling water use, and
  - ✓ Improvement in air quality system performance
- **The heat integration included heat recovery for use in the coal EGU Rankine cycle. The heat was sourced from:**
  - ✓ A pilot CO<sub>2</sub> capture facility and
  - ✓ The coal EGU flue gas.

# Objectives – to quantify the benefit of heat integration

Quantify energy efficiency improvements

Unit heat rate improvement

Flue gas pressure drop

Identify and/or resolve integration problems

Effect on water quality

Corrosion, erosion, or plugging

Issues with high-sulfur flue gas

Quantify ancillary benefits

Better ESP performance

Increased SO<sub>3</sub>, Hg, Se capture

Reduced water consumption and use

# Overall Project Schedule

Nov 2011 – Mar 2013

**BP1**

- FEED and Target Cost Estimate
- Permitting



Apr 2013 – Apr 2015

**BP2**

- Engineering, Procurement, Construction



May 2015 – May 2017



**BP3**

- Operations
- Field Testing Analysis



## 2. Background Technologies

## Coal-fired Power Station




Clean Flue Gas



CO<sub>2</sub> Capture Plant



CO<sub>2</sub> Compressor





# Petra Nova Project Overview

- “NRG Energy, JX Nippon complete world’s largest post-combustion carbon capture facility on-budget and on-schedule”



NRG press release: <http://investors.nrg.com/phoenix.zhtml?c=121544&p=irol-newsArticle&ID=2236424>

## Hirono P/S Japan - 600MW



→ Water Loop  
→ Flue Gas


Plume Abatement

# High Efficiency System (HES)



- Commercially proven technology
  - Installed & operated at ten coal-fired units in Japan since 1997
  - MHP's proprietary heat exchanger

## ● Benefits of HES

- Removal improvement of hazardous air toxics (PM, SO<sub>3</sub>, Hg, Se, etc.) across the ESP
- Reduction of makeup & cooling water
- AQCS (ESP, FGD & CCS) cost reduction
- Reduction of total energy penalty of CCS plant
- Potential to simplify boiler/steam turbine cycles






Tomato P/S Japan - 700MW




Commercial application of HES

## Heat Integration System with HES

- HES recovers waste heat from the flue gas by incorporating a heat extractor downstream of the air heater
- Recovered heat can be applied to the boiler feed water, thereby reducing the energy penalty of CCS plant



Eliminate LP heaters and steam extraction



Application to boiler/steam turbine cycles

Operates downstream of the APH


Mechanism for removal of SO<sub>3</sub> from flue gas

- $\text{SO}_3 (\text{g}) + \text{H}_2\text{O} (\text{g}) \rightarrow \text{H}_2\text{SO}_4 (\text{g})$
- $\text{H}_2\text{SO}_4 (\text{g}) \rightarrow \text{H}_2\text{SO}_4 (\text{l})$
- $\text{H}_2\text{SO}_4 (\text{l})$  condenses on fly ash in flue gas and a protective layer of ash on tube bundles

Flue Gas Cooler tube skin temperature < SO<sub>3</sub> dewpoint

- Alkaline species in fly ash (Ca, Na) neutralize  $\text{H}_2\text{SO}_4$
- Silicates, etc. physically adsorb  $\text{H}_2\text{SO}_4$

Carbon steel tubes in good condition after 2 years of operation in Japan.




Higher fly ash or dust loading in the flue gas can mitigate corrosion rate.

# **3. 25-MW Pilot Demonstration at Plant Barry**


- **Funded by industry consortium**
- **Fully integrated CO<sub>2</sub> capture/compression**
- **Storage in Citronelle Dome**
- **Capacity: 500 metric tons CO<sub>2</sub>/day**




# Process Flow of 25-MW Pilot Demonstration Plant



# Aerial View of Plant Barry Demonstration Plant



# 3D Model of Plant Barry Demonstration Plant





CO<sub>2</sub> Cooler



Flue Gas Cooler



Flue Gas Blower



Pilot ESP (0.25 MW)

# 4. Test Results

## Confirmed heat integration performance


- 240-300 MMBTU/hr heat recovery for 550 MW base plant (Case 9)

Source	Data collected	Units	w/o HES heat integration	w/ HES heat integration	w/ HES heat integration
			12/16/2015	9/9/2015	9/1/2015
FGC	Flue gas flow rate	scfm	49,998	60,640	60,631
	Flue gas temp FGC inlet	degF	288	323	314
	Flue gas temp FGC outlet	degF	NA	200	186
	Recovered heat	MMBtu/h	NA**	8.66	9.09
CO <sub>2</sub>	Flue gas flow rate*	scfm	73,800	73,800	73,800
	CO <sub>2</sub> removal performance*	%	> 90	> 90	> 90
	BC flow rate	stph	0	38	50
	BC temp CO <sub>2</sub> cooler inlet	degF	NA	128	123
	BC temp CO <sub>2</sub> cooler outlet	degF	NA	167	167
	Recovered heat	MMBtu/h	NA	2.9	4.4
Plant	Boiler Load net	MW	721	783	680
	BC flow rate	stph	0	38	50
	BC feed temp	degF	NA	128	123
	BC return temp	degF	NA	280	264
	Recovered heat	MMBtu/h	NA	11.1	13.6
	Recovered heat for 550 MW base plant	MMBtu/h	NA	244	300

- Calculated heat integration benefit by Aspen model
  - 18.3 MW was gained from the DOE Case 10 plant (subcritical PC EGU with CCS)
  - 0.9% of plant efficiency was increased

	Original Case 10 Value	Gain or Loss (-) Due to HES
<b>Total LP feedwater heater and deaerator steam extraction</b>	421,000 lb/hr	-366,000 lb/hr
<b>Turbine generation</b>	673 MW	18.7 MW
<b>Cooling fan and water pumps power consumption increase</b>	-	1.6 MW
<b>Induced draft fan power consumption</b>	12.1 MW	-1.3 MW
<b>Total Power Gain</b>	-	18.3 MW
<b>Plant Thermal Efficiency</b>	26.2%	0.9% points

- By cooling the flue gas, FGD makeup water can be reduced
- Percentage of water saved was calculated, not measured
- Up to 65% of the FGD makeup water can be saved
  - 502 gpm for a 550-MW plant
- 50-60% reduction of cooling water use in the CCS system
  - 45,000 gpm for a 550 MW plant




## ● Test Conditions

- No FGC 300F: No water flowed through the FGC, the flue gas was not cooled
- FGC 203F + SO<sub>3</sub>: The flue gas was cooled to 203F and SO<sub>3</sub> was injected
- FGC 203F: The flue gas at the FGC outlet was cooled to 203F
- FGC 185F: The flue gas was further cooled down to 185F


## ● Test Methods and Locations

Location	Analyte(s)
FGC Inlet	Particulate Matter, Metals (total and gas-phase), SO <sub>2</sub> , SO <sub>3</sub>
FGC Outlet	Flowrate only
ESP Inlet	Particulate Matter only
ESP Outlet	Particulate Matter, Metals (total and gas-phase), SO <sub>2</sub> , SO <sub>3</sub>

- Impurities removal is enhanced by the Flue Gas Cooler operation due to operation of the FGC:
  - Native mercury removal by fly ash increased significantly from 28 to >86% due to the Flue Gas Cooler
  - Selenium removal increased from 96 to 98%
  - No discernable effect due to temperature decrease from 203 to 185°F on either metal or particulate matter
  - SO<sub>3</sub> removal not calculated due to low concentrations



- SO<sub>3</sub> injection inhibits Mercury capture, no effect on Selenium or Particulate Matter due to SO<sub>3</sub> injection:
  - Mercury removal decreased from >92 to 40%
  - Mercury removal still higher during SO<sub>3</sub> injection than without FGC operation
  - Selenium removal unchanged
  - Particulate matter removal unchanged
  - SO<sub>3</sub> removal not calculated due to low concentrations



## ● Confirmed Impurities Removal performance

- PM removal: > 99.5%
- SO<sub>3</sub> removal: less than 0.05 ppm at ESP outlet
- Hg removal: > 86% w/o SO<sub>3</sub> injection, ~40% w/ SO<sub>3</sub> injection
- Se removal: > 98%

Condition, Day	Run Number, Day	SO <sub>3</sub> con. at ESP outlet	Percent Removal Across FGC/ESP		
		ppmd at 3% O <sub>2</sub>	PM	Hg	Se
<b>NO FGC 300F</b>	R3-0 (12/15-16, 2015)	0.03	99.3%	28%	96%
<b>FGC 203F+ SO<sub>3</sub></b>	R3-2 (12/18-19, 2015)	0.04	99.7%*	40%	98%
<b>FGC 203F</b>	R3-1-1 (09/23-24, 2015)	0.04	99.7%*	>92%	98%
<b>FGC 185F</b>	R3-1-2 (09/25-26, 2015)	0.02	99.6%	86%	98%

\* Calculated from the estimated inlet concentrations

- Flue Gas Cooler internal surfaces were visually inspected before, during and after operation
- No mechanical damage to tubes found via visual inspection (see pictures below)
- No damage to soot blowers found via visual inspection
- No ash deposition or accumulation on tube walls



(a) Before operation



(b) October, 2015



(c) January, 2016\*

\*The remaining fly ash can be easily removed by soot-blowers.

- The sample with the most uniform corrosion provided a rate of 40 mils/year which has never been seen in commercial plants
- Flue gas was not purged from the duct after operation like would be done in a full-scale plant



Tested Tube Samples

# 5. Techno-Economic Analysis Results

- **Case 9**
  - DOE/NETL case for a 550-MW subcritical coal EGU without CCS, burning bituminous coal;
- **Case 10**
  - DOE/NETL case for a 550-MW subcritical bituminous coal EGU using the [monoethanolamine \(MEA\) solvent, Econamine](#), CCS system
- **Case 10b**
  - 550-MW subcritical bituminous coal EGU using the [KM CDR Process](#) for the CCS system, also has SO<sub>3</sub> control
- **Case 10c**
  - 550-MW subcritical bituminous coal EGU using the [KM CDR Process](#) for the CCS system, also has SO<sub>3</sub> control and [High Efficiency System](#)

# Summary of TEA Results

Case		9	10	10b	10c
Plant Configuration		Subcritical PC w/out CCS	Subcritical PC w MEA CCS	Subcritical PC w KM CDR <sup>®</sup> CCS	Subcritical PC w KM CDR <sup>®</sup> CCS w heat integration
Avoided Cost	\$/ton		70.6	58.5	51.4
Total Overnight Cost	MM\$	1,098	1,985	1,800	1,741
Cost of Electricity	mils/kWh	59.4	109.6	101.5	96.5
Percent Increase in COE from Case 9		-	98%	71%	62%
Percent Decrease in COE from Case 10		-	-	13.7%	18.0%

## 6. Summary

Quantify energy  
efficiency  
improvements

Unit heat rate  
improvement

Flue gas pressure  
drop

- Use of the HES can increase the generation of a 550-MW plant with CCS by 18.3 MW.
- Thermal efficiency can be increased by 0.9 percentage points (i.e. from 26.2 to 27.1%), alternately heat rate could decrease from 13,050 to 12,630 Btu/kWh.
- Pressure drop across the Flue Gas Cooler was measured to be 2-4 inWc.


Identify and/or  
resolve integration  
problems

Effect on water  
quality

Corrosion, erosion,  
or plugging

Issues with high-  
sulfur flue gas

- Boiler condensate water quality was found to be unaffected by the HES.
- Corrosion was found on the Flue Gas Cooler tubes. Corrosion may have been increased due to the lack of a flue gas purge.
- No plugging was found in the Flue Gas Cooler.
- Little to no  $\text{SO}_3$  was measured in the flue gas, even during injection of  $\text{SO}_3$ .



Via the reduced flue gas temperature:

- ESP outlet flue gas particulate matter concentration decreased by 36%,
- ESP outlet flue gas mercury concentration decreased by 80%,
- ESP outlet flue gas selenium concentration decreased by 33-56%,
- Up to 65% of FGD makeup water can be saved, and
- 50-60% of CCS cooling water can be saved.

**MOVE THE WORLD FORWARD**

**MITSUBISHI  
HEAVY  
INDUSTRIES  
GROUP**